

Final Report R19-04B

***Stability Studies of the Proposed Cielo
Caprock-East Wind Farm Project***

Prepared for

Xcel Energy Services, Inc.

Submitted by:
James Feltes
Assistant Vice President

Yachi Lin
Consultant

Consulting Services

April 28, 2004

Shaw PTI Project Number: 1000034



Shaw® Shaw Power Technologies, Inc.™

1482 Erie Boulevard • P.O. Box 1058
Schenectady, New York 12301-1058
518.395.5000 • www.pti-us.com

Contents

Legal Notice.....	iii
Executive Summary	v
Section 1 Introduction.....	1-1
Section 2 Data Preparation.....	2-1
2.1 Load Flow Data.....	2-2
2.1.1 Generator data.....	2-2
2.1.2 Analysis of reactive power support.....	2-4
2.1.3 Light Load.....	2-9
2.1.4 PSS/E Setup	2-9
2.2 Dynamics Data.....	2-10
Section 3 Stability Analysis	3-1
3.1 Disturbances	3-1
3.2 Results and Discussions.....	3-3
3.2.1 Peak load conditions with Cielo Wind Farm on-line at 100% rated output .	3-5
3.2.2 Light load conditions with Cielo Wind Farm on-line at 100% rated output .	3-6
3.2.3 Light load conditions with Cielo Wind Farm on-line at 75% rated output....	3-9
3.2.4 Peak load conditions with Cielo Wind Farm off-line	3-9
Appendix A Load Flow Data of the Cielo Wind Farm	A-1
Appendix B PSAS File.....	B-1
Appendix C Plots of Dynamic Simulation with Cielo Wind Farm on-line during Peak Load Conditions	C-1
Appendix D Plots of Dynamic Simulation with Cielo Wind Farm on-line during Light Load Conditions	D-1
Appendix E Plots of Dynamic Simulation with Cielo Wind Farm off-line during Peak Load Conditions	E-1

Legal Notice

This document was prepared by Shaw Power Technologies, Inc.™ (“Shaw PTI”), solely for the benefit of Xcel Energy Services, Inc (XES). Neither Shaw PTI, nor parent corporation or its or their affiliates, nor Xcel Energy, Inc, nor any person acting in their behalf (a) makes any warranty, expressed or implied, with respect to the use of any information or methods disclosed in this document; or (b) assumes any liability with respect to the use of any information or methods disclosed in this document.

Any recipient of this document, by their acceptance or use of this document, releases Shaw PTI, its parent corporation and its and their affiliates, and XES from any liability for direct, indirect, consequential or special loss or damage whether arising in contract, warranty, express or implied, tort or otherwise, and irrespective of fault, negligence, and strict liability.

Executive Summary

PTI was contracted by XES to perform a stability study in order to evaluate the impact of a proposed Cielo Caprock-East Wind Farm Project near Tucumcari, New Mexico on the Southwestern Public Service Company (SPS) transmission system.

The proposed point of interconnection (POI) of Cielo Wind farm is about 16% down the 115 kV line V47 between F.E.C. Interchange and Curry County. The wind farm is located 9 miles from the interconnection point into SPS system, and is comprised of 80 units of Mitsubishi 1000A 1000 kW turbines. The rated output is 80 MW.

The reactive power support of the wind farm is comprised of the three items as following:

1. At the 34.5 kV collector bus, two D-VAR modules, 8 MVAR each, will be installed.
2. At the 34.5 kV collector bus, 9 capacitor banks, 3.6 MVAR each will be installed for steady-state reactive power support.
3. At the 34.5 kV collector bus, 2 capacitor banks, 16 MVAR each, will be installed.

A set of stability studies comprising fourteen disturbances was performed to evaluate the wind farm using PTI's power system simulation program PSS/E, revision 29. The proposed reactive compensation system provided adequate support for the wind farm to ride through most of the disturbances.

Two disturbances resulted in islanding the wind farm and the Tucumcari loads. It should be noted that these disturbances would result in loss of load even without the presence of the wind farm.

One simulated disturbance caused 25 units out of the total 80 units to be tripped during peak load conditions. During light load conditions with the wind farm generating 100% rated output, all or most of the 80 units of the Cielo Wind Farm were tripped off-line in two simulated disturbances. With the output reduced to 75% (60 MW), the wind farm was able to ride through all disturbances. The details are given in Section 3.2.

The reactive compensation system has an important role in supporting the voltage of the wind farm during and after disturbances. For disturbances that do not result in an isolation of the generation and nearby loads from the SPS network, whether the reactive power support is sufficient and activated in a timely manner has a direct impact on the generator terminal voltages, and hence whether the generators remained connected to the grid.

From the simulation results, it appears that the proposed reactive power compensation scheme has to be adjusted to cope with the few disturbances resulting in generator tripping. In the absence of the control block diagram of the DVAR model, it is difficult to advance comments on the behavior and possible limitations of the reactive compensation system.

Introduction

PTI was contracted by XES to perform a specified set of stability studies in order to evaluate the impact of a proposed Cielo Caprock-East Wind Farm Project near Tucumcari, New Mexico. This report summarizes results of the study.

In August 2002, PTI has performed stability studies of the Proposed York wind farm (PTI report number R25-02). The project was sold to Cielo Wind and the new developers have changed the wind turbines from the original Vestas V80 to Mitsubishi 1000A 1000kW turbines, in addition to changing the location. The wind farm will be located 9 miles from the interconnection point into SPS system, and is comprised of 80 units of Mitsubishi 1000A 1000 kW turbines.

The setup for load flow and dynamic simulation was based on the previously completed York Wind Farm study. DC lines PNM and EPE are both modeled. All the 80 wind turbine units were modeled in detail according to the wind farm layout submitted by the developer. The dynamic model for Mitsubishi wind turbines was developed based on manufacturer's data and PTI's experience in wind farm modeling.

A set of stability studies was performed to evaluate the wind farm using PTI's power system simulation program PSS/E, revision 29.

Section
2

Data Preparation

The proposed point of interconnection (POI) of Cielo Wind farm is about 16% down the 115 kV line V47 between F.E.C. Interchange and Curry County. The geographical location of the plant is indicated in Figure 2-1.




Figure 2-1: Geographical location of the Cielo Wind Farm

A customer-owned 9.1 miles line will connect the plant to the POI. At the end of the customer-owned line, a 48/64/80 MVA transformer serves to connect the 34.5 kV side of the plant. Figure 2-2 shows the details of the point of interconnection.




Figure 2-2: Point of Interconnection of the Cielo Wind Farm

2.1 Load Flow Data

The detailed plant layout was submitted by the developer. Accordingly, three major collector branches were established. The number of units along each feeder is listed in Table 2-1.

Table 2-1: number of wind turbines along each collection cable

	Feeder 1	Feeder 2	Feeder 3
# of units	28	25	27

The parameters of the cables were calculated based on the cable size and length.

2.1.1 Generator data

Table 2-2 lists the original equivalent induction generator parameters that were retrieved from Attachment J (page 13) in the scope of work for the Cielo project.

Table 2-2: original generator parameters

	Ohm	Per unit
R1	0.0066	0.0202
X1	0.1082	0.3306
X2	0.0679	0.2075
R2	0.0127	0.0379
Xm	3.72	11.3668

Figure 2-3 is the induction motor curve using the parameters above. The maximum torque is only 0.9 pu, much too low compared with typical induction motors. There is no operating point for the value of torque needed to represent full load and no range above it for dynamic responses. Additionally, the equivalent starting current is only 2 pu. In PSS/E, the induction generator is not started as an induction machine, but the equivalent starting current is still a useful quantifying number. The induction generator can not be initialized with these parameters at the specified loading.




Figure 2-3: induction motor curves with original values

To investigate, we tried the following approach. We assumed the original values retrieved are not in ohms (as specified in the document), but in per unit. Figure 2-4 is the resulting induction motor curve. The maximum torque is 2 pu while the starting current is about 5.8 pu. These numbers are closer to typical induction generator parameters. In addition, the resulting curves are similar to those given in the manufacturer's data sheets.

It was agreed between Cielo Wind, XES and PTI to use the original values as per unit values. Communications had been established between Cielo Wind and the manufacturer Mitsubishi in the hope to solve the problem. At the moment of issuing the report, no response about this issue is yet received from Mitsubishi. All the simulations following in this report are based on the assumption of treating the original values as per unit values.




Figure 2-4: induction motor curves with alternative values

2.1.2 Analysis of reactive power support

Mitsubishi wind turbines have a nominal output of 1000 kW per turbine, and their base voltage is 600 V. The nominal power factor is 0.97 leading (absorbing VARs) at rated output with reactive power compensation. Each induction generator has a power factor of 0.891 before power factor correction, and 260 kVAR of capacitance is installed in order to correct the power factor to 0.97. For a real power output of 80 MW, 20 MVAR reactive power support will be needed just to maintain the power factor to 1.0 pu. In addition, to account for the loss on the 115/34.5 kV transformers and the 34.5 kV collector cables, more reactive power has to be planned to support the power factor to be 1.0 pu at the 115 kV point of interconnection.

The power factors before and after the reactive power compensation were calculated from manufacturer’s data sheets. Table 2-3 summarizes the power factors of different output level.

Table 2-3: power factors of the Mitsubishi wind turbine with and without capacitors

% of rated output	Unit P generation	PF w/o cap (leading)	KVAR generation	Cap KVAR	PF w/i cap (leading)
100	1100 kW	0.89	-563.5	260	0.964
90.9	1000 kW	0.89	-510.6	260	0.970
50	550 kW	0.86	-326.4	260	0.993

Figure 2-5 is the one-line diagram in the immediate neighborhood of Cielo - Caprock East Wind Farm with the wind farm off-line. Color coding is used to distinguish different voltage

levels: green for 100 kV and below, red for between 100 and 200 kV, and black for above 200 kV. The load flow results were obtained when the plant is off-line. The voltages in the vicinity are within criteria.




Figure 2-5: one-line diagram with Cielo wind farm off-line

With the Cielo Wind Farm on-line at 100% rated output (80MW) without additional reactive power support, the wind farm has to absorb reactive power from the SPS network to maintain the voltage and power factor. More analysis on the size and form of appropriate reactive power support was therefore performed.

2.1.2.1 P-V Curve analysis

To investigate problems encountered when trying to solve the load flow case, a quick power-voltage sensitivity analysis was conducted to test the strength of the network. The plant will use Mitsubishi MWT-1000A units. The wind generators have a power factor of 0.97 leading when fully loaded. To have more insights on how the reactive consumption might impact the neighboring system, three power factors of the plant at the 34.5 kV collector bus were tested: 1.0, 0.99 (leading), and 0.97 (leading).

Figure 2.6 shows the resulting P-V curve at the interconnection point (bus 99991).




Figure 2-6: P-V curve at 115 kV bus 99991

Figure 2-7 shows the resulting P-V curve at the 34.5 kV collector bus 99993.




Figure 2-7: P-V curve at the 34.5 kV collector bus

Table 2-4 summarizes the P and Q output of the plant and the corresponding voltage at the 115kV interconnection bus (99991) and the 34.5 kV collector bus (99993) at three different power factors:

Table 2-4: P-V curve analysis of the wind farm

P	Plant PF = 1.0			Plant PF = 0.99			Plant PF = 0.97		
	Q	V(99991)	V(99993)	Q	V(99991)	V(99993)	Q	V(99991)	V(99993)
80	0	0.99981	0.99573	-11.4	0.91086	0.87023	-20	N/A ⁽¹⁾	N/A ⁽¹⁾
60	0	1.02738	1.02819	-8.55	0.98121	0.96014	-15	0.93312	0.89165
40	0	1.03571	1.03833	-5.7	1.00698	0.99613	-10	0.98319	0.96127
20	0	1.02317	1.02553	-2.85	1.00973	1.00555	-5	0.99919	0.98987
0	0	0.99381	0.99398	0	0.99381	0.99398	0	0.99381	0.99398

⁽¹⁾ Load flow solution did not converge.

Note that the voltage at the interconnection point is very sensitive to the power factor of the plant. At 100% rated output, voltage at the interconnection point drops from 0.9998 to 0.9109 when the plant power factor was lowered from 1.0 pu to 0.99 pu. When the plant power factor is 0.99, the power factor at the 115 kV interconnection point is only 0.931. If the plant power factor is to be lower than 0.99, the reactive power support in the neighboring network becomes so weak that the load flow has trouble converging. This indicates that the network is not capable of transmitting 80MW at the power factor of 0.97.

To operate the plant at 100% rated output, a proper source of reactive power has to be installed to maintain the voltage should the power factor of the plant output be less than unity. Moreover, during dynamic simulations, the voltage fluctuations will be even greater than the differences we see in steady state.

2.1.2.2 Capacitor Sizing Analysis

As a result of the P-V curve analysis, the capacitor sizing analysis was performed to evaluate the amount of reactive power needed for the steady-state plant operation. Two objectives are observed in this capacitor sizing analysis:

1. To insure the major load at 115 kV bus 51070 Tucumcari being supplied adequately, with the requirement that the voltage at bus 51070 has to above 0.98 pu
2. The power factor of the output of the wind farm at the interconnection point (bus 99991) must be above 0.98 pu

Table 2-5 lists the results of a multi-variable capacitor sizing analysis. To assess the necessary reactive power support, the two objectives have to be both fulfilled: the power factor at POI has to be above 0.98 pu while the voltage at bus 51070 to be above 0.98 pu as well.

Table 2-5: multi-variable capacitor sizing analysis

Plant output	80 MW	44 MW
% of rated output	100 %	55.0 %
% of max output	90.9 %	50 %
unit PF with cap	0.970	0.993
Unit P gen. (MW)	1.0000	0.550
Unit Q gen. (MVAR)	-0.5095	-0.3264
SVC cap (MVAR)	24.5	1.7
Volt at 51070	0.980	0.995
Flow at POI	78.2 – j15.5	43.5 – j 8.6
PF at POI	0.9809	0.981

As the output level decreases, the power factor of each unit increases, and thus the reactive power support demanded from the system decreases as well.

If the plant is to operate at 100% rated output, 24.5 MVAR of reactive power is needed at the 34.5 kV collector bus in order to maintain both the voltage of the major load at bus 51070 and the power factor at the interconnection point. On the other hand, if the plant is to operate at 55% of rated output, only 1.7 MVAR of reactive power support is needed at the same location.

The analysis study indicates that an SVC or STATCOM might be necessary for the wind farm in order to stabilize the voltage. In this case, three locations can be considered: the interconnection point (bus 99991), 9 miles from the POI (bus 99992), and the 34.5 kV collector bus of the wind farm (bus 99993).

2.1.2.3 DVAR

As a result of the P-V curve and capacitor sizing analysis, Cielo Wind Power contracted American Super Conductor (AMSC) to propose a design of the reactive power support required in order to comply with the voltage and power factor design criteria proposed by XES. A reactive compensation system containing three items is proposed by AMSC to provide proper reactive power support during both steady-state operation and under disturbances. The three items are the following:

1. At the 34.5 kV collector bus, install two D-VAR modules, 8 MVAR each. The D-VARs provide the main dynamic voltage boost for all faults, and control for all of the capacitor banks.
2. At the 34.5 kV collector bus, install 9 capacitor banks, 3.6 MVAR each for steady-state reactive power support. This helps to maintain unity power factor and regulate voltage at the Cielo 115 kV bus. These capacitor banks can be switched by the D-VARs as the wind farm's generation varies.
3. At the 34.5 kV collector bus, install 2 capacitor banks, 16 MVAR each. These two capacitor banks provide additional voltage boost for the worst faults. These capacitor banks are also switched by the D-VARs for voltage support.

2.1.3 Light Load

A light load case was created by XES. The load and generation in the control area of SPS was scaled to reflect the light load conditions. The load was scaled down to 57% while the generation is scaled down approximately 58%. The power output of the Cielo wind farm remains 100% rated output.

During light load conditions, the SPS network requires less reactive power support. Therefore, the reactive power output from the SVC at Eddy County was reduced to approximately 10 MVAR from 60 MVAR by raising the scheduled voltage from 1.0 pu to 1.025 pu. The fictitious capacitive bus shunt was reduced to 21.2 MVAR.


The network near the Cielo wind farm is very sensitive to the amount of reactive power support provided by the DVAR and capacitors banks. Table 2-6 lists the voltage at the collector bus with three different amount of capacitive bus shunt. Note that the voltage increases 3% when the reactive shunt increased from 21.0 to 21.6 MVAR. This also confirms the need of installing the DVAR or a SVC to provide the reactive power support to achieve the fast and precise control required by the Cielo wind farm.

Table 2-6: comparison of the voltage and shunt at the collector bus

Capacitive bus shunt at 99993	Voltage at 99993
21.6 MVAR	1.04738 pu
21.2 MVAR	1.02767 pu
21.0 MVAR	1.01604 pu

2.1.4 PSS/E Setup

All 80 units have identical equipments. A 34.5kV/600V transformer with 5.65% impedance connects the wind turbine unit to the collector bus. The complete load flow data of the wind farm is included in Appendix A. WTG 21 is shown on the diagram below as an example for the layout of a single wind turbine generator (WTG). The bus number for the 34.5 kV side (collector side) is 1021, and the 600 V side (generator side) is 91021.



2.2 Dynamics Data

80 units of Mitsubishi MWT-1000A wind turbines are used in the Cielo Caprock-East wind farm. The dynamic model of the wind turbine generators was developed by PTI. Note that this is an approximate model that incorporates only those components that are known to influence system performance in the timeframe of interest.

Wound-rotor induction generators are used by the Mitsubishi units, and the PSS/E induction generator model CIMTR3 is used to represent the generator. In addition, these turbines have a voltage protection that trips the unit when the voltage drops too low. The protection scheme helps to prevent the induction generators from stalling and absorbing too much current from the neighboring system. Two levels of under-voltage protections are simulated:

- Instantaneous trip for WTG 600-V bus voltage less than 0.6 p.u
- Trip when WTG 600-V bus voltage between 0.6 p.u and 0.95 p.u. for more than 0.2 seconds

The following is the model data for the wind turbine generator at bus 91001 from PSS/E. Buses 91002 to 91080 all have the same model representation and parameters.

```

** CIMTR3 ** BUS X-- NAME --X BASEKV MC      C O N S      S T A T E S      V A R S      ICON
91001      CIEL_G1  0.6000 1  115331-115343  43117-43122  5702-5704      932

      MBASE      Z S O R C E      X T R A N      GENTAP
      1.1  0.00000+J 0.17490  0.00000+J 0.00000  1.00000

      T'      T''      H      X      X'      X''      XL
      0.810  0.000  1.20  3.8282  0.1749  0.0000  0.1082

      E1      S(E1)      E2      S(E2)      D      SYN-POW
      1.0000  0.0600  1.2000  0.5250  0.00  0.0000

      *** CALL VBDCN( 1012,116373,      0, 5942) ***

      BUS  NAME  BSKV      GENR BUS  NAME  BSKV
      91001 CIEL_G1 .600      0 CIEL_G1 .600

      I C O N S      C O N S      V A R
      1012-1015  116373-116376  5942

      VLO      VUP      PICKUP      TB
      0.600  5.000  0.016  0.030

      *** CALL VBDCN( 1332,116693,      0, 6022) ***

      BUS  NAME  BSKV      GENR BUS  NAME  BSKV
      91001 CIEL_G1 .600      0 CIEL_G1 .600

      I C O N S      C O N S      V A R
      1332-1335  116693-116696  6022

      VLO      VUP      PICKUP      TB
      0.950  5.000  0.200  0.030

```

The setup of the reactive compensation system for PSS/E simulation was provided by AMSC.

Each 8 MVAR DVAR module has a three per unit over-current capability under system disturbances. Combining two modules, the transient reactive power support provided by the DVAR modules is equal to $8 \text{ MVAR} * 2 * 3 = 48 \text{ MVAR}$.

During severe disturbances, it is essential that the two 16 MVAR capacitor banks are switched in, along with the DVAR, to prevent the voltage from dropping too low and thus tripping the wind farm turbines. The present setting for the switched shunts is that if the voltage drops below 0.925 pu for longer than 0.1 seconds, the capacitors will be switched in. In the case of over-voltage, if the voltage rises above 1.05 pu for longer than 0.35 seconds, the capacitors will be switched out.

In addition, a second logic is implemented to decide when the capacitor banks should be switched in. The reactive power compensation system will be armed any time the voltage at the 34.5 kV collector bus 99993 goes below 95%. The control system will wait 6 cycles (0.1 seconds) before it operates. This will allow the 2 D-VAR units 1 cycle to boost the voltage at the 34.5 kV collector bus back up to at least 90%. If the voltage is not above 90% within 0.1 second, the caps will be switched in 28 ms. If the voltage is above 90%, they will not be switched in yet, and the decision will be delayed. If at any point in time, the voltage goes below the "Fast Cap Turn On Line", the fast caps will be

turned on in 28 ms. On a voltage-time plot, the "Fast Cap Turn On Line" is a straight line defined by two points: the first point has time equal to 6 cycles and voltage equal to 0.9 pu, and the second point has time equal to 10 cycles and voltage equal to 0.95 pu. This straight line functions as a blind. If the voltage of the collector bus remains on the left side of the line, which indicates rapid voltage recovery, the caps remains off-service. However, if the voltage enters the right side of the line, which indicates the voltage is not recovering fast enough, then the fast caps will be turned on.

26 MVAR of reactive power is needed to maintain the voltage and power factor criteria during steady-state operation. It is simulated as a capacitive bus-shunt in the load flow case. This equivalent bus shunt represents the amount of reactive power support needed to maintain steady-state operation from the nine 3.6 MVAR capacitor banks and two 8 MVAR DVAR. The following is the model data for the 16 MVAR capacitor bank at bus 801 and the 8 MVAR DVAR at bus 51000. The other DVAR is located at bus 61000 while the second 16 MVAR capacitor bank is at bus 802, with the same parameters as below.

```

*** CALL SWSHN1( 1686,117073, 6148) ***

** SWSHN1 **  BUS X-- NAME --X BASEKV  I C O N S      C O N S      V A R S
                801 C-CAP1      34.500  1686-1692    117073-117078  6148-6151

REMOTE BUS  SWITCHES  VIN1      PT1      ST1      VIN2      PT2      ST2
 99993      99      0.0000    0.3500   0.0280   0.0000    0.1000   0.0280

* CDSMES *  BUS NAME      BSKV MACH  C O N S      S T A T E S      V A R S
          51000 D-VAR A   .480 A   117013-117042  43599-43601     6102-6124

                I C O N S      MBASE
                VLTG SRC CNV    1652-1668      8.0

          SRATED  VDC      IINIT      IMIN      TDIS      TON      TOFF
          8.0000  3.0000   1.0500    0.4000   0.6000   0.0010   0.0010

          V1      V2      V3      V4      KAVR      T1      T2      T3      T4      AVRDR00P
          1.0500  0.9300   0.9000   0.5000  300.0000   1.0000   1.0000   1.0000   1.0000   0.0000

          PAUX_THRESH  TOVLD  TBACK  KOL  TBOOST_BEG  BOOST_DUR  STEP_VREF  KOV
          0.1000  1.0000  1.0000  300.0000  9999.0000  1.0000  0.0100  110.0000

                VQMAX  VQMIN  IACMAX  PMAX  PMIN
                999.0000-999.0000  3.0000  999.0000  0.0000

```

The PSS/E model CDSMES used here is not the same as the standard PSS/E model CDSMES. AMSC has modified the model to simulate the transient response of the DVAR through customized setup. The parameters listed in the DOCU output are not used in the dynamic simulation. Table 2-7 lists the actual parameters for the 8 MVAR DVAR at bus 51000.

Table 2-7: parameters of the 8 MVAR DVAR

Value	Name	Value	Name
0.95	Low Reg Level (pu)	0	Util2: FastT2 (s)
1.05	High Reg Level (pu)	0.3	Util2: FastT3 (s)
0.5	Near Fault Level (pu)	0	Util2: FastT4 (s)
1.08	Over Voltage Limit (pu)	0.01	Util2: FastT5 (s)
35	Inverter Current Ref Minimum (A)	0.95	Util2: Fast Boost Trip Level (pu)
300	Inverter I Rated (A)	1	Util2: SlowDelay (CTicks)
60	Overload Cycles	1	Alt A2d is Ac input
3	OverLoad Multiplier	1	Dc Bus is Disconnected
60	Ramp Down (Line Cycles)	60	Undervoltage Inhibit T1 (cycles)
300	Thermal Recovery Time (s)	300	Undervoltage Inhibit T2 (cycles)
480	Inverter Terminal Voltage (V)	240	Max UnderVolt Inhibit delay (cycles)
60	Operating Frequency (Hz)	1	Alt Protection Level (pu)
0.1	No Reaction Level (pu)	0	Alt Protection Slope (pu A/pu V)
8	Stacks	1.06	Util2: Upper Buck Trip Level (pu)
0.92	Voltage Comp Level (pu)	4	Util2: Upper Buck Trip Time (CTicks)
0	Trailer Has Magnet Subsystem (1=true)	0.03	Upper Nominal Neg Seq Limit (pu)
1.35	High AC Peak Fault Limit (pu)	4	Min Throttled Inv Count
4	Trailer Configuration Type	60	Pos Seq Avg Block cycles
0	External Cap Control Type	60	Neg Seq Avg Block cycles
16	Onset Ring Blanking (Cticks)	1.1	PLL cutoff freq (Hz)
100	LeadLag: Gain 1	0.1	PLL Damping Const
1	LeadLag: Gain 2	120	Seq Notch Filter Freq (Hz)
1	LeadLag: T1 (s)	0.707	Seq Notch Damping Const
0	LeadLag: T2 (s)	90	Seq Low Pass Cutoff Freq (Hz)
3	LeadLag: T3 (s)	1	Enable Stack Throttling
0	LeadLag: T4 (s)	0.005	Slow Threshold Err (pu)
0.04	LeadLag: T5 (s)	0.025	Fast Threshold Err (pu)
1.03	LeadLag: Target V (pu)	0.005	Alt Slow Threshold Err (pu)
0.02	LeadLag: Droop	0.025	Alt Fast Threshold Err (pu)
20	LeadLag: Upper Limit	10	Slow Filt Cutoff Freq (Hz)
-20	LeadLag: Lower Limit	400	Fast Filt Cutoff Freq (Hz)
1.03	LeadLag: Boost Off (pu)	0.02	Boost On Err (pu)
1.03	LeadLag: Buck Off (pu)	0.03	Buck On Err (pu)
11.26	V Comp Slope (pu A/pu V)	0.25	Pos Droop Filt K
5	V Comp Type	1.08	Max Drooped Upper Lvl (pu)
0.125	V Comp Scale	0.92	Max Drooped Lower Lvl (pu)
1.03	Util2: Rapid Boost SlewOff (pu)	20	Slow Avg Cutoff Freq (Hz)
1.03	Util2: Rapid Buck SlewOff (pu)	20	Bandlimited Cutoff Freq (Hz)
4	Util2: Lower Boost Trip Time (CTicks)	0	Bumpless Turn On Time (cycles)
100	Util2: Upper Boost Trip Time (CTicks)	0	Require Alt Input above NoReact
0.85	Util2: Lower Boost Trip Level (pu)	1	Phase Lock to Primary PT

Value	Name	Value	Name
1.01	Util2: Upper Boost Trip Level (pu)	0.99	Pos Seq Longterm Limit (pu)
0.2	Max 3-Phs Imbalance (Neg Seq) (pu)	1.15	Fixed Upper Limitor (pu)
4	Util2: Low 3Phs Trip Time (CTicks)	0.8	Fixed Lower Limitor (pu)
1.045	Util2: Lower Buck Trip Level (pu)	0.03	Limitor Hysterisis (pu)
20	Util2: Lower Buck Trip Time (CTicks)	5	Max Neg Seq Run time (s)
200	Util2: FastGainK1	20	Max Pos Seq Run time (s)
0.1	Util2: FastT1 (s)	0.2	PSS-E: V-compliance speed factor

Stability Analysis

3.1 Disturbances

The following faults were simulated in the study (3 phase and single phase):

1. Faults on the Tolk (51435) – Cloviss (51205) 230kV Line (mid-line). A new bus (*Mid-Line bus*) was established in the electrical middle of the line.

FLT13PH - 3 Phase Fault

- a. Apply the fault at the *Mid-Line bus*.
- b. Clear Fault after 5 cycles, by remove lines from 51435 to *Mid-Line bus* and *Mid-Line bus* to 51205.
- c. Wait 20 cycles and then re-close both lines in (b) back into the fault.
- d. Leave fault on for 5 cycles, then trip both lines in (b) to remove fault.

FLT11PH - 1 phase Fault

- a. Same as FLT13PH above.

2. Fault on the Tucumcari 115kV Bus (51070), removing the load bus.

FLT23PH - 3 Phase Fault

- a. Apply the fault on the Tucumcari 115kV Bus (51070).
- b. Clear Fault after 3 cycles¹, by removing the lines from 99991 to 51076 and from 51076 to 51070
- c. DO NOT RE-CLOSE

This simulates a high side transformer fault at Tucumcari.

FLT21PH - 1 phase Fault

- a. Same as FLT23PH above.

3. Fault on the Roosevelt (51202) – Cloviss(51206) 115kV Line, near Roosevelt.

FLT33PH - 3 Phase Fault

- a. Apply fault at the Roosevelt bus (51202).
- b. Clear Fault after 5 cycles by remove the 115kV line from 51202 to 51206.
- c. Wait 20 cycles, then re-close line in (b) into the fault.
- d. Leave fault on for 5 cycles, then trip the line in (b) and remove the fault.

FLT31PH - 1 phase Fault

- a. Same as FLT33PH above.

¹ Faster relays with three cycle pick-up timers were assumed to replace the existing relays with five cycle pick-up timers

4. Fault on the Tolk (51440) – Eddy County (52186) 345kV Line, near Eddy County.

FLT43PH - 3 Phase Fault

- b. Apply fault at bus 52186.
- c. Clear Fault after 5 cycles by remove the line from 51440 to 52186.
- d. Wait 30 cycles, then re-close line in (b) into the fault.
- e. Leave fault on for 5 cycles, then trip the line in (b) and remove the fault.

FLT41PH - 1 phase Fault

- a. Same as FLT43PH above.

5. Fault on Curry County (51176) – Caprock East Tap (99991) 115kV Line, near Curry

FLT53PH - 3 Phase Fault

- a. Apply fault at the Curry County bus (51176).
- b. Clear Fault after 5 cycles by remove the line from 51176 to 99991.
- c. DO NOT RE-CLOSE

This fault has no re-closing. XES is concerned with “Voltage Holdup” at Tucumcari (51070) and at FEC-Tucumcari (51076) (i.e. what does having the wind farm and the DVAR device connected to these two buses do to the voltage at these locations immediately following the fault).

FLT51PH - 1 phase Fault

- a. Same as FLT53PH above.

6. Fault on Tolk (51435) – Tuco (51533) 230kV Line

FLT63PH - 3 Phase Fault

- a. Apply fault at the Tuco bus (51533).
- b. Clear Fault after 5 cycles by remove the 230 kV line from 51533 to 51435.
- c. Wait 20 cycles, then re-close line in (b) into the fault.
- d. Leave fault on fro 5 cycles, then trip the line in (b) and remove the fault.

FLT61PH - 1 phase Fault

- a. Same as FLT63PH above.

7. Fault on Cloviss (51206) – Curry County (51176) 115kV Line, near Cloviss

FLT73PH - 3 Phase Fault

- e. Apply fault at the Cloviss bus (51206).
- f. Clear Fault after 5 cycles by remove the line from 51206 to 51176.
- g. Wait 20 cycles, then re-close line in (b) into the fault.
- h. Leave fault on fro 5 cycles, then trip the line in (b) and remove the fault.

FLT71PH - 1 phase Fault

- a. Same as FLT73PH above.


The actual single-line-to-ground fault impedance’s at the substations were given by XES. Table 3-1 summarizes the single-line-to-ground fault impedances in per unit for each fault. The exact SLG equivalent fault impedance of the 115 kV substation Cloviss was not available. To simulate fault FLT71PH, the equivalent fault impedance of the nearby 115 kV substation Roosevelt was used. The resulting bus voltage of Cloviss 115 kV substation with a SLG fault is approximately 0.6 pu, which concludes the estimate to be reasonable.

Table 3-1: SLG equivalent fault impedance

bus name	kV	R-	X-	R0	X0
mid Tuco-Roosevelt	230	0.00353	0.03035	0.01193	0.05257
Tucumcari	115	0.14634	0.51204	0.06648	0.60102
Roosevelt	115	0.00593	0.05616	0.00311	0.03964
Eddy County	345	0.00451	0.05243	0.00142	0.03167
Curry County	115	0.01133	0.06678	0.01354	0.07276
Tuco	230	0.00268	0.0236	0.00319	0.02532

The PSAS files for simulating the disturbances in peak load conditions are included in Appendix B.

The locations of the faults are illustrated in Figure 3-1.

**Figure 3-1: fault locations**

3.2 Results and Discussions

Simulations were performed with a 0.1-second steady-state run followed by the appropriate disturbance described in Section 3.1. Simulations were run to at least 10 seconds to confirm proper machine damping.

The “dynamic” reactive power support from the two 8 MVAR DVAR units and two 16 MVAR capacitor banks has an important role in supporting the voltage of the wind farm during and

after disturbances. For disturbances that do not result in an isolation of the generation and nearby loads from the SPS network, whether the reactive power support is sufficient and activated in the timely manner has a direct impact on the generator terminal voltages, and hence the ability of the generators to remain connected to the grid.

Two levels of under-voltage protections are simulated:

- Instantaneous trip for WTG 600-V bus voltage less than 0.6 p.u
- Trip when WTG 600-V bus voltage is between 0.6 p.u and 0.95 p.u. for greater than 0.2-seconds

For all the disturbances simulated in this study, the terminal voltages of the generators remained above 0.6 pu, and the first level of protection was not triggered. All the fault durations are 5 cycles, and therefore it is essential for the voltage to recover above 95% within 15 cycles. Otherwise, the second level of voltage protection scheme would be activated to trip the wind turbine units off-line.

During peak load with the Cielo wind farm on-line, the wind farm was able to ride through all disturbances simulated except FLT5 (both single- and three-phase-to-ground fault near Curry County on the 115 kV line between Curry County and Caprock East Tap)) and FLT73PH (three-phase-to-ground fault on the 115 kV line between Clovis and Curry County). During light load, the wind turbine generators were tripped in one additional disturbance: FLT13PH (three-phase-to-ground fault on the mid point of the 230 kV line between Tolk and Clovis).

FLT53PH and FLT51PH are the most severe faults among all those simulated. Both disturbances caused the 115 kV line to be tripped from Cielo Wind farm to Curry County, leaving the wind farm and the loads isolated at Tucumcari (bus 51070) and FEC-Tucumcari (bus 51076). During peak load, the combined load at both substations is 22 MW, while during light load conditions, the combined load is 10 MW. When the load is isolated with the wind farm output at 80 MW, the severe power unbalance causes the network to collapse, at both peak and light load.

The DVAR is simulated as a generator with no real power output. Their user-written model requires that the steady-state output of the DVAR has to be zero in order for the model to be initialized correctly in dynamic simulations. To accommodate this requirement, an equivalent bus shunt was established at the collector bus for the combined output of the capacitor banks and the DVAR in steady-state, so the Q output of the DVAR generator can stay zero. In reality, the field engineer would adjust the so steady-state capacitor banks so the DVAR output is minimized, though it doesn't have to be zero. For peak load conditions, the equivalent bus shunt is 26 MVAR. It is 21.2 MVAR during light load conditions.

The logic to automatically adjust the amount of the bus shunt at the collector bus (representing the nine 3.6 MVAR and two 16 MVAR banks) has not been provided. If the wind farm is operating at less than the rated output, the reactive power support required must be adjusted accordingly both in steady-state and dynamic simulations. The logic to adjust the compensation following, for example, tripping of wind turbine generators, has not been supplied.

The response of the wind farm to disturbances during peak load conditions is described in Section 3.2.1. The response under light load conditions is given in Section 3.2.2.

Simulations were also performed on the peak load case with the Cielo wind farm off-line. More details are included in Section 3.2.3.

3.2.1 Peak load conditions with Cielo Wind Farm on-line at 100% rated output

The wind farm was able to ride through all disturbances except FLT53PH, FLT51PH and FLT73PH. The plots of the dynamic simulations are included in Appendix C.

For the most severe disturbance, FLT5 (both three- and single-phase-to-ground fault near Curry County on the 115 kV line between Curry County and Caprock East Tap), the severe imbalance between the load and generation caused the speed of the wind turbine generators to increase dramatically. The generator terminal voltages exceed 110% at approximately 0.3 seconds after the fault. The over-speed and over-voltage protection schemes were not given in the manufacturer's data sheet, and thus not modeled in the simulation; otherwise, the wind farm would have been tripped and the load at Tucumcari would have been lost.

Figure 3-2 shows the voltages at the collector bus 99993 and generator terminal bus 91001, and the reactive power output from the DVAR during the simulation of FLT73PH (three-phase-to-ground fault on the 115 kV line between Clovis and Curry County). Note that the generator terminal voltage reached 95% at 0.19 seconds after the fault, just in time to reset the under-voltage protection relay and prevent the wind farm generators from being tripped off-line.

The 80 wind turbine units of the Cielo Wind Farm spread across a large area with cables connecting the units to the collector feeders. The voltages at the generator terminal buses thus vary along the cables. During the fault FLT73PH, 25 units did not have their voltage recover above 95% within 0.2 seconds and were tripped by the under-voltage protection relay. In other words, the wind farm lost approximately 30% of its rated output under the disturbance FLT73PH.

The current user-written model of the DVAR, supplied by AMSC, does not automatically adjust the amount of the equivalent bus shunt at the collector bus to account for changes in the number of generators on-line. It is not clear how the nine 3.6 MVAR capacitor banks would be adjusted following a 30% drop in the wind farm output. In the present simulation, without adjusting the shunt compensation, the voltages at the 115 kV load buses FEC Tucumcari (51076) and Tucumcari (51070) recovered to 103% approximately 1 second after the fault.




Figure 3-2: voltage and DVAR output of FLT73PH

During FLT33PH (three-phase-to-ground fault on the 115 kV line between Clovis and Roosevelt), the reactive power support from the combination of two 8 MVAR DVAR and two 16 MVAR capacitor banks was sufficient to sustain the bus voltages of the wind turbines during and after the fault so the under-voltage protection scheme was not triggered to protect the turbines.

During other less severe three-phase-to-ground and single-line-to-ground faults, the reactive power support from the two 8 MVAR DVAR units was sufficient for the wind farm to ride through the simulated disturbances.

3.2.2 Light load conditions with Cielo Wind Farm on-line at 100% rated output

During light load conditions, the disturbance FLT5, which results in the isolation of the wind farm with the small amount of load results in the complete shutdown of that part of the system. Response to disturbance FLT73PH was similar to that described above for the peak load condition except that all wind farm generators tripped.

In addition, the wind farm was not able to ride through the disturbance FLT13PH. All or most of the 80 units were tripped off-line by the under-voltage protection scheme under these disturbances.

During the simulation of fault FLT13PH, the two 16 MVAR capacitor banks were not switched in because the voltage at the collector bus remained above 95% after the fault was cleared. However, the generator terminal voltage reached approximately 93%. Consequently, the under-voltage protection relay tripped the units when the voltage was below 95% for over 0.2

seconds. 72 units, out of the 80 units, were tripped. Figure 3-3 shows the voltages at the 34.5 kV collector bus 99993 and the generator terminal voltage at bus 91001.




Figure 3-3: voltage comparison of the collector and generator bus

Figure 3-4 shows the voltage at the collector bus 99993 and the DVAR output during the first 0.5 second of FLT13PH. Note that the reactive power output reached maximum at 0.1 seconds after the fault first took place, and the output level remained around 20 MVAR until the wind turbine generators were tripped at approximately 0.23 seconds after the fault was applied. The two DVAR units thus responded, including use of their over-current capabilities, but not enough to avoid the wind turbine generators tripping in this simulation. Severe over-voltages resulted from the presence of the two 16 MVAR capacitor banks on-line after the wind farm generators tripped off, indicating the need for coordination between generator tripping and capacitor tripping.





Figure 3-4: DVAR output of FLT13PH

During the simulation of FLT73PH, the voltage at the collector bus did not recover to 90% within 6 cycles, so the two 16 MVAR capacitors were turned on at 0.13 seconds after the fault was first applied. Even with the reactive power support from both the DVAR and switched capacitors, the generator terminal voltage did not recover to above 95% within 0.2 seconds. Therefore, all 80 wind turbine units were tripped off by the under-voltage protection.

With the 21.2 MVAR fixed bus shunt in-service, the voltages at the 115 kV load buses nearby were well above 110% after the fault was cleared and the wind farm tripped off-line. It is essential to further investigate how the DVAR controls the nine 3.6 MVAR and the two 16 MVAR capacitor banks under disturbances.



For the most severe disturbance, FLT53PH, the severe imbalance between the load and generation caused the wind farm to be tripped at approximately 4.5 seconds after the fault.

The plots of all the dynamic simulations for light load are included in Appendix D.

3.2.3 Light load conditions with Cielo Wind Farm on-line at 75% rated output

With the wind farm output reduced from 80 MW to 60 MW, the wind farm was able to ride through all disturbances but FLT53PH and FLT51PH during light load conditions.

3.2.4 Peak load conditions with Cielo Wind Farm off-line

The SPS network was able to ride through all the disturbances simulated. During the simulation of FLT53PH and FLT51PH, when the branch is tripped between 115 kV substations Curry and FEC Tucumcari, the load at Tucumcari is tripped as well due to isolation; there is no power source within the island. The plots of the dynamic simulations are included in Appendix E.



Load Flow Data of the Cielo Wind Farm

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E WED, APR 21 2004 16:37
 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW BRANCH DATA
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION

X-----FROM-----X		X-----TO-----X					Z S									
BUS#	NAME	BSKV	BUS#	NAME	BSKV	CKT	LINE	R	LINE	X	CHRGING	I	T	RATEA	RATEB	RATEC
801	C-CAP1	34.5*	99993	CIEL	34.5	1	0.00000	0.00011	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0
802	C-CAP2	34.5*	99993	CIEL	34.5	1	0.00000	0.00011	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0
1001	CIEL_T1	34.5*	1002	CIEL_T2	34.5	1	0.00672	0.00298	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0
1001	CIEL_T1	34.5	1010	CIEL_T1034.5*	1	0.05393	0.02391	0.00002	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1002	CIEL_T2	34.5*	1003	CIEL_T3	34.5	1	0.00672	0.00298	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0
1003	CIEL_T3	34.5*	1004	CIEL_T4	34.5	1	0.00672	0.00298	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0
1004	CIEL_T4	34.5*	1005	CIEL_T5	34.5	1	0.00672	0.00298	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0
1005	CIEL_T5	34.5*	1006	CIEL_T6	34.5	1	0.00672	0.00298	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0
1007	CIEL_T7	34.5*	1008	CIEL_T8	34.5	1	0.00940	0.00417	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0
1007	CIEL_T7	34.5	1081	CIEL_D1	34.5*	1	0.00940	0.00417	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0
1008	CIEL_T8	34.5*	1009	CIEL_T9	34.5	1	0.00940	0.00417	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0
1009	CIEL_T9	34.5*	1010	CIEL_T1034.5	1	0.00940	0.00417	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1011	CIEL_T1134.5*	1012	CIEL_T1234.5	1	0.00501	0.00222	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1011	CIEL_T1134.5	1081	CIEL_D1	34.5*	1	0.00501	0.00222	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1012	CIEL_T1234.5*	1013	CIEL_T1334.5	1	0.00501	0.00222	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1013	CIEL_T1334.5*	1014	CIEL_T1434.5	1	0.00501	0.00222	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1015	CIEL_T1534.5*	1016	CIEL_T1634.5	1	0.00334	0.00148	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1015	CIEL_T1534.5	1031	CIEL_T3134.5*	1	0.05343	0.02369	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1017	CIEL_T1734.5	1018	CIEL_T1834.5*	1	0.00668	0.00296	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1018	CIEL_T1834.5	1024	CIEL_T2434.5*	1	0.01336	0.00592	0.00001	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1019	CIEL_T1934.5	1020	CIEL_T2034.5*	1	0.00334	0.00148	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1020	CIEL_T2034.5	1021	CIEL_T2134.5*	1	0.00334	0.00148	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1021	CIEL_T2134.5*	1022	CIEL_T2234.5	1	0.00334	0.00148	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1021	CIEL_T2134.5*	1024	CIEL_T2434.5	1	0.00529	0.00699	0.00001	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1021	CIEL_T2134.5	99993	CIEL	34.5*	1	0.00706	0.00933	0.00002	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1022	CIEL_T2234.5*	1023	CIEL_T2334.5	1	0.00334	0.00148	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1024	CIEL_T2434.5*	1025	CIEL_T2534.5	1	0.02672	0.01185	0.00001	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1024	CIEL_T2434.5*	1081	CIEL_D1	34.5	1	0.00529	0.00699	0.00001	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1025	CIEL_T2534.5*	1026	CIEL_T2634.5	1	0.00672	0.00298	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1026	CIEL_T2634.5*	1027	CIEL_T2734.5	1	0.00672	0.00298	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1027	CIEL_T2734.5*	1028	CIEL_T2834.5	1	0.00672	0.00298	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1028	CIEL_T2834.5*	1029	CIEL_T2934.5	1	0.00672	0.00298	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1029	CIEL_T2934.5*	1030	CIEL_T3034.5	1	0.00672	0.00298	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1031	CIEL_T3134.5	1048	CIEL_T4834.5*	1	0.03362	0.01491	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1032	CIEL_T3234.5	1033	CIEL_T3334.5*	1	0.00334	0.00148	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1033	CIEL_T3334.5	1034	CIEL_T3434.5*	1	0.00334	0.00148	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
1034	CIEL_T3434.5	1035	CIEL_T3534.5*	1	0.00334	0.00148	0.00000	1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Load Flow Data of the Cielo Wind Farm

1035	CIEL_T3534.5	1083	CIEL_D3 34.5*	1	0.00334	0.00148	0.00000	1	0.0	0.0	0.0
1036	CIEL_T3634.5*	1037	CIEL_T3734.5	1	0.00334	0.00148	0.00000	1	0.0	0.0	0.0
1036	CIEL_T3634.5	1083	CIEL_D3 34.5*	1	0.01336	0.00592	0.00000	1	0.0	0.0	0.0
1038	CIEL_T3834.5	1039	CIEL_T3934.5*	1	0.00668	0.00296	0.00000	1	0.0	0.0	0.0
1038	CIEL_T3834.5*	1083	CIEL_D3 34.5	1	0.00668	0.00296	0.00000	1	0.0	0.0	0.0
1039	CIEL_T3934.5	1040	CIEL_T4034.5*	1	0.00668	0.00296	0.00000	1	0.0	0.0	0.0
1040	CIEL_T4034.5	1082	CIEL_D2 34.5*	1	0.00668	0.00296	0.00000	1	0.0	0.0	0.0
1041	CIEL_T4134.5*	1082	CIEL_D2 34.5	1	0.00353	0.00466	0.00001	1	0.0	0.0	0.0
1041	CIEL_T4134.5	99993	CIEL 34.5*	1	0.00706	0.00933	0.00002	1	0.0	0.0	0.0
1042	CIEL_T4234.5*	1043	CIEL_T4334.5	1	0.00151	0.00200	0.00000	1	0.0	0.0	0.0
1042	CIEL_T4234.5	1082	CIEL_D2 34.5*	1	0.00151	0.00200	0.00000	1	0.0	0.0	0.0
1043	CIEL_T4334.5*	1044	CIEL_T4434.5	1	0.00151	0.00200	0.00000	1	0.0	0.0	0.0
1044	CIEL_T4434.5*	1045	CIEL_T4534.5	1	0.00151	0.00200	0.00000	1	0.0	0.0	0.0
1045	CIEL_T4534.5*	1046	CIEL_T4634.5	1	0.00151	0.00200	0.00000	1	0.0	0.0	0.0
1046	CIEL_T4634.5*	1047	CIEL_T4734.5	1	0.00151	0.00200	0.00000	1	0.0	0.0	0.0
1047	CIEL_T4734.5*	1048	CIEL_T4834.5	1	0.00151	0.00200	0.00000	1	0.0	0.0	0.0
1048	CIEL_T4834.5*	1049	CIEL_T4934.5	1	0.00334	0.00148	0.00000	1	0.0	0.0	0.0
1049	CIEL_T4934.5*	1050	CIEL_T5034.5	1	0.00334	0.00148	0.00000	1	0.0	0.0	0.0
1050	CIEL_T5034.5*	1051	CIEL_T5134.5	1	0.00334	0.00148	0.00000	1	0.0	0.0	0.0
1051	CIEL_T5134.5*	1052	CIEL_T5234.5	1	0.00334	0.00148	0.00000	1	0.0	0.0	0.0
1052	CIEL_T5234.5*	1053	CIEL_T5334.5	1	0.03473	0.01540	0.00001	1	0.0	0.0	0.0
1054	CIEL_T5434.5*	1055	CIEL_T5534.5	1	0.00132	0.00175	0.00000	1	0.0	0.0	0.0
1054	CIEL_T5434.5	99993	CIEL 34.5*	1	0.02484	0.03283	0.00007	1	0.0	0.0	0.0
1055	CIEL_T5534.5*	1056	CIEL_T5634.5	1	0.00132	0.00175	0.00000	1	0.0	0.0	0.0
1056	CIEL_T5634.5*	1057	CIEL_T5734.5	1	0.00132	0.00175	0.00000	1	0.0	0.0	0.0
1057	CIEL_T5734.5*	1058	CIEL_T5834.5	1	0.00132	0.00175	0.00000	1	0.0	0.0	0.0
1058	CIEL_T5834.5*	1059	CIEL_T5934.5	1	0.00706	0.00933	0.00002	1	0.0	0.0	0.0
1059	CIEL_T5934.5*	1060	CIEL_T6034.5	1	0.00706	0.00933	0.00002	1	0.0	0.0	0.0
1060	CIEL_T6034.5*	1061	CIEL_T6134.5	1	0.00247	0.00326	0.00001	1	0.0	0.0	0.0
1061	CIEL_T6134.5*	1062	CIEL_T6234.5	1	0.00247	0.00326	0.00001	1	0.0	0.0	0.0
1062	CIEL_T6234.5*	1063	CIEL_T6334.5	1	0.00247	0.00326	0.00001	1	0.0	0.0	0.0
1063	CIEL_T6334.5*	1064	CIEL_T6434.5	1	0.00247	0.00326	0.00001	1	0.0	0.0	0.0
1064	CIEL_T6434.5*	1065	CIEL_T6534.5	1	0.01026	0.00672	0.00001	1	0.0	0.0	0.0
1065	CIEL_T6534.5*	1066	CIEL_T6634.5	1	0.00779	0.00346	0.00000	1	0.0	0.0	0.0
1066	CIEL_T6634.5*	1067	CIEL_T6734.5	1	0.00779	0.00346	0.00000	1	0.0	0.0	0.0
1067	CIEL_T6734.5*	1068	CIEL_T6834.5	1	0.00779	0.00346	0.00000	1	0.0	0.0	0.0
1068	CIEL_T6834.5*	1069	CIEL_T6934.5	1	0.00779	0.00346	0.00000	1	0.0	0.0	0.0
1069	CIEL_T6934.5*	1070	CIEL_T7034.5	1	0.00779	0.00346	0.00000	1	0.0	0.0	0.0
1070	CIEL_T7034.5*	1071	CIEL_T7134.5	1	0.00779	0.00346	0.00000	1	0.0	0.0	0.0
1071	CIEL_T7134.5*	1072	CIEL_T7234.5	1	0.00779	0.00346	0.00000	1	0.0	0.0	0.0
1072	CIEL_T7234.5*	1073	CIEL_T7334.5	1	0.00779	0.00346	0.00000	1	0.0	0.0	0.0
1073	CIEL_T7334.5*	1074	CIEL_T7434.5	1	0.00779	0.00346	0.00000	1	0.0	0.0	0.0
1074	CIEL_T7434.5*	1075	CIEL_T7534.5	1	0.00779	0.00346	0.00000	1	0.0	0.0	0.0
1075	CIEL_T7534.5*	1076	CIEL_T7634.5	1	0.01714	0.00760	0.00001	1	0.0	0.0	0.0
1076	CIEL_T7634.5*	1077	CIEL_T7734.5	1	0.00935	0.00415	0.00000	1	0.0	0.0	0.0
1077	CIEL_T7734.5*	1078	CIEL_T7834.5	1	0.00935	0.00415	0.00000	1	0.0	0.0	0.0
1078	CIEL_T7834.5*	1079	CIEL_T7934.5	1	0.00935	0.00415	0.00000	1	0.0	0.0	0.0
1079	CIEL_T7934.5*	1080	CIEL_T8034.5	1	0.00935	0.00415	0.00000	1	0.0	0.0	0.0
51076	FE-TUCU3 115*	99991	CIEL_TAP 115	1	0.02167	0.07150	0.00861	1	112.0	146.0	0.0
51176	CURRY3 115	99991	CIEL_TAP 115*	1	0.11331	0.37386	0.04504	1	112.0	146.0	0.0
99991	CIEL_TAP 115	99992	CIEL_WG 115*	1	0.01625	0.05362	0.00651	1	112.0	146.0	0.0
99993	CIEL 34.5	99995	CIEL_BP234.5*	1	0.00000	0.00010	0.00000	Z 1	0.0	0.0	0.0
99993	CIEL 34.5	99995	CIEL_BP234.5*	2	0.00000	0.00010	0.00000	Z 0	0.0	0.0	0.0

Load Flow Data of the Cielo Wind Farm

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E WED, APR 21 2004 16:38
SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW 2 WINDING XFRMER
80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION IMPEDANCE DATA

X	FROM	X	X	TO	X	C	C											
BUS#	NAME	BSKV	BUS#	NAME	BSKV	CKT	Z	M	R	1-2	X	1-2	WIBASE	MAG1	MAG2	RATA	RATB	RATC
1001	CIEL_T1	34.5	91001	CIEL_G1	.600	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1002	CIEL_T2	34.5	91002	CIEL_G2	.600	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1003	CIEL_T3	34.5	91003	CIEL_G3	.600	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1004	CIEL_T4	34.5	91004	CIEL_G4	.600	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1005	CIEL_T5	34.5	91005	CIEL_G5	.600	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1006	CIEL_T6	34.5	91006	CIEL_G6	.600	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1007	CIEL_T7	34.5	91007	CIEL_G7	.600	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1008	CIEL_T8	34.5	91008	CIEL_G8	.600	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1009	CIEL_T9	34.5	91009	CIEL_G9	.600	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1010	CIEL_T1034.5	91010	CIEL_G10	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1011	CIEL_T1134.5	91011	CIEL_G11	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1012	CIEL_T1234.5	91012	CIEL_G12	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1013	CIEL_T1334.5	91013	CIEL_G13	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1014	CIEL_T1434.5	91014	CIEL_G14	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1015	CIEL_T1534.5	91015	CIEL_G15	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1016	CIEL_T1634.5	91016	CIEL_G16	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1017	CIEL_T1734.5	91017	CIEL_G17	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1018	CIEL_T1834.5	91018	CIEL_G18	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1019	CIEL_T1934.5	91019	CIEL_G19	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1020	CIEL_T2034.5	91020	CIEL_G20	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1021	CIEL_T2134.5	91021	CIEL_G21	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1022	CIEL_T2234.5	91022	CIEL_G22	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1023	CIEL_T2334.5	91023	CIEL_G23	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1024	CIEL_T2434.5	91024	CIEL_G24	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1025	CIEL_T2534.5	91025	CIEL_G25	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1026	CIEL_T2634.5	91026	CIEL_G26	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1027	CIEL_T2734.5	91027	CIEL_G27	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1028	CIEL_T2834.5	91028	CIEL_G28	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1029	CIEL_T2934.5	91029	CIEL_G29	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1030	CIEL_T3034.5	91030	CIEL_G30	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1031	CIEL_T3134.5	91031	CIEL_G31	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1032	CIEL_T3234.5	91032	CIEL_G32	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1033	CIEL_T3334.5	91033	CIEL_G33	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1034	CIEL_T3434.5	91034	CIEL_G34	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1035	CIEL_T3534.5	91035	CIEL_G35	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1036	CIEL_T3634.5	91036	CIEL_G36	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1037	CIEL_T3734.5	91037	CIEL_G37	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1038	CIEL_T3834.5	91038	CIEL_G38	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1039	CIEL_T3934.5	91039	CIEL_G39	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1040	CIEL_T4034.5	91040	CIEL_G40	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1041	CIEL_T4134.5	91041	CIEL_G41	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1042	CIEL_T4234.5	91042	CIEL_G42	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1043	CIEL_T4334.5	91043	CIEL_G43	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1044	CIEL_T4434.5	91044	CIEL_G44	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1045	CIEL_T4534.5	91045	CIEL_G45	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1046	CIEL_T4634.5	91046	CIEL_G46	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1047	CIEL_T4734.5	91047	CIEL_G47	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0
1048	CIEL_T4834.5	91048	CIEL_G48	.600	1	1	1	1	0.00000		5.65000	100.0	0.0000	0.0000	0.0000	1	0	0

Load Flow Data of the Cielo Wind Farm

1049	CIEL_T4934.5	91049	CIEL_G49.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1050	CIEL_T5034.5	91050	CIEL_G50.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1051	CIEL_T5134.5	91051	CIEL_G51.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1052	CIEL_T5234.5	91052	CIEL_G52.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1053	CIEL_T5334.5	91053	CIEL_G53.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1054	CIEL_T5434.5	91054	CIEL_G54.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1055	CIEL_T5534.5	91055	CIEL_G55.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1056	CIEL_T5634.5	91056	CIEL_G56.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1057	CIEL_T5734.5	91057	CIEL_G57.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1058	CIEL_T5834.5	91058	CIEL_G58.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1059	CIEL_T5934.5	91059	CIEL_G59.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1060	CIEL_T6034.5	91060	CIEL_G60.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1061	CIEL_T6134.5	91061	CIEL_G61.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1062	CIEL_T6234.5	91062	CIEL_G62.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1063	CIEL_T6334.5	91063	CIEL_G63.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1064	CIEL_T6434.5	91064	CIEL_G64.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1065	CIEL_T6534.5	91065	CIEL_G65.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1066	CIEL_T6634.5	91066	CIEL_G66.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1067	CIEL_T6734.5	91067	CIEL_G67.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1068	CIEL_T6834.5	91068	CIEL_G68.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1069	CIEL_T6934.5	91069	CIEL_G69.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1070	CIEL_T7034.5	91070	CIEL_G70.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1071	CIEL_T7134.5	91071	CIEL_G71.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1072	CIEL_T7234.5	91072	CIEL_G72.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1073	CIEL_T7334.5	91073	CIEL_G73.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1074	CIEL_T7434.5	91074	CIEL_G74.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1075	CIEL_T7534.5	91075	CIEL_G75.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1076	CIEL_T7634.5	91076	CIEL_G76.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1077	CIEL_T7734.5	91077	CIEL_G77.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1078	CIEL_T7834.5	91078	CIEL_G78.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1079	CIEL_T7934.5	91079	CIEL_G79.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
1080	CIEL_T8034.5	91080	CIEL_G80.600	1	1	1	0.00000	5.65000	100.0	0.0000	0.0000	1	0	0
51000	D-VAR A .480	99993	CIEL 34.5	1	1	1	0.05520	0.50000	100.0	0.0000	0.0000	8	8	8
61000	D-VAR B .480	99993	CIEL 34.5	1	1	1	0.05520	0.50000	100.0	0.0000	0.0000	8	8	8
99992	CIEL_WG 115	99994	CIEL BP134.5	1	1	1	0.00000	0.15625	100.0	0.0000	0.0000	48	64	80

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E WED, APR 21 2004 16:38
SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW GENERATOR
80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION UNIT DATA

BUS#	NAME	BSKV	CD	ID	ST	PGEN	QGEN	QMAX	QMIN	PMAX	PMIN	OWN	FRACT	OWN	FRACT	MBASE	Z	S	O	R	C	E
91001	CIEL_G1	.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000			1.1	0.0000	0.1749				
91002	CIEL_G2	.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000			1.1	0.0000	0.1749				
91003	CIEL_G3	.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000			1.1	0.0000	0.1749				
91004	CIEL_G4	.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000			1.1	0.0000	0.1749				
91005	CIEL_G5	.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000			1.1	0.0000	0.1749				
91006	CIEL_G6	.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000			1.1	0.0000	0.1749				
91007	CIEL_G7	.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000			1.1	0.0000	0.1749				
91008	CIEL_G8	.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000			1.1	0.0000	0.1749				
91009	CIEL_G9	.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000			1.1	0.0000	0.1749				
91010	CIEL_G10	.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000			1.1	0.0000	0.1749				
91011	CIEL_G11	.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000			1.1	0.0000	0.1749				
91012	CIEL_G12	.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000			1.1	0.0000	0.1749				
91013	CIEL_G13	.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000			1.1	0.0000	0.1749				

Load Flow Data of the Cielo Wind Farm

91068	CIEL_G68.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000	1.1	0.0000	0.1749	
91069	CIEL_G69.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000	1.1	0.0000	0.1749	
91070	CIEL_G70.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000	1.1	0.0000	0.1749	
91071	CIEL_G71.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000	1.1	0.0000	0.1749	
91072	CIEL_G72.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000	1.1	0.0000	0.1749	
91073	CIEL_G73.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000	1.1	0.0000	0.1749	
91074	CIEL_G74.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000	1.1	0.0000	0.1749	
91075	CIEL_G75.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000	1.1	0.0000	0.1749	
91076	CIEL_G76.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000	1.1	0.0000	0.1749	
91077	CIEL_G77.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000	1.1	0.0000	0.1749	
91078	CIEL_G78.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000	1.1	0.0000	0.1749	
91079	CIEL_G79.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000	1.1	0.0000	0.1749	
91080	CIEL_G80.600	-2	1	1	1.0	-0.5	-0.5	-0.5	1.0	0.0	1	1.000	1.1	0.0000	0.1749	
99993	CIEL	34.5	-2	1	0	0.0	0.0	999.0	-999.0	0.0	0.0	1	1.000	100.0	0.0000	1.0000

PSAS File

```
PSS
PDEV
2 1 1
PDEV_WI_FLT13PH.TXT
ODEV
2 1 1
PDEV_WI_FLT13PH.TXT
FIN
RECOVER FROM WI_CIELO_CHAN.SNP AND WI_CIELO_CNV.SAV
INITIALIZE OUTPUT WI_FLT13PH.OUT
RUN TO 0.1 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 99997 ADMITTANCE 0 -2E+10 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
DISCONNECT BUS 99997
CLEAR FAULT
RUN FOR 20 CYCLES PRINT 0 PLOT 1
CHANGE BUS 99997 CODE TO 1
RECLOSE LINE FROM BUS 99997 TO BUS 51435 CKT 2
RECLOSE LINE FROM BUS 99997 TO BUS 51205 CKT 2
APPLY FAULT AT BUS 99997 ADMITTANCE 0 -2E+10 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
DISCONNECT BUS 99997
RUN TO 5 SECONDS PRINT 0 PLOT 1
RUN TO 10 SECONDS PRINT 0 PLOT 7
PSS
PDEV
1
ODEV
7
FIN
```

```
PSS
PDEV
2 1 1
PDEV_WI_FLT11PH.TXT
ODEV
2 1 1
PDEV_WI_FLT11PH.TXT
FIN
RECOVER FROM WI_CIELO_CHAN.SNP AND WI_CIELO_CNV.SAV
INITIALIZE OUTPUT WI_FLT11PH.OUT
RUN TO 0.1 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 99997 ADMITTANCE 217.3 -1165.47 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
DISCONNECT BUS 99997
CLEAR FAULT
RUN FOR 20 CYCLES PRINT 0 PLOT 1
CHANGE BUS 99997 CODE TO 1
RECLOSE LINE FROM BUS 99997 TO BUS 51435 CKT 2
RECLOSE LINE FROM BUS 99997 TO BUS 51205 CKT 2
APPLY FAULT AT BUS 99997 ADMITTANCE 217.3 -1165.47 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
DISCONNECT BUS 99997 / REMOVES TOLK-CLOVS 230 KV LINE FROM SERVICE
RUN TO 5 SECONDS PRINT 0 PLOT 1
RUN TO 10 SECONDS PRINT 0 PLOT 7
```

```
PSS
PDEV
1
ODEV
7
FIN
```

```
PSS
PDEV
2 1 1
PDEV_WI_FLT23PH.TXT
ODEV
2 1 1
PDEV_WI_FLT23PH.TXT
FIN
RECOVER FROM WI_CIELO_CHAN.SNP AND WI_CIELO_CNV.SAV
INITIALIZE OUTPUT WI_FLT23PH.OUT
RUN TO 0.1 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 51070 ADMITTANCE 0 -2E+10 MVA
RUN FOR 3 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51076 TO BUS 99991 CKT 1
TRIP LINE FROM BUS 51070 TO BUS 51076 CKT 1
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 1
RUN TO 10 SECONDS PRINT 0 PLOT 7
PSS
PDEV
```

```
1
ODEV
7
FIN

PSS
PDEV
2 1 1
PDEV_WI_FLT21PH.TXT
ODEV
2 1 1
PDEV_WI_FLT21PH.TXT
FIN
RECOVER FROM WI_CIELO_CHAN.SNP AND WI_CIELO_CNV.SAV
INITIALIZE OUTPUT WI_FLT21PH.OUT
RUN TO 0.1 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 51070 ADMITTANCE 16.57 -866.74 MVA
RUN FOR 3 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51076 TO BUS 99991 CKT 1
TRIP LINE FROM BUS 51070 TO BUS 51076 CKT 1
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 1
RUN TO 10 SECONDS PRINT 0 PLOT 7
PSS
PDEV
1
ODEV
7
FIN

PSS
PDEV
2 1 1
PDEV_WI_FLT33PH.TXT
ODEV
2 1 1
PDEV_WI_FLT33PH.TXT
FIN
RECOVER FROM WI_CIELO_CHAN.SNP AND WI_CIELO_CNV.SAV
INITIALIZE OUTPUT WI_FLT33PH.OUT
RUN TO 0.1 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 51202 ADMITTANCE 0 -2E+10 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51202 TO BUS 51206 CKT 2
CLEAR FAULT
RUN FOR 20 CYCLES PRINT 0 PLOT 1
RECLOSE LINE FROM BUS 51202 TO BUS 51206 CKT 2
APPLY FAULT AT BUS 51202 ADMITTANCE 0 -2E+10 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51202 TO BUS 51206 CKT 2
CLEAR FAULT
```

RUN TO 5 SECONDS PRINT 0 PLOT 1
RUN TO 10 SECONDS PRINT 0 PLOT 7
PSS
PDEV
1
ODEV
7
FIN

PSS
PDEV
2 1 1
PDEV_WI_FLT31PH.TXT
ODEV
2 1 1
PDEV_WI_FLT31PH.TXT
FIN
RECOVER FROM WI_CIELO_CHAN.SNP AND WI_CIELO_CNV.SAV
INITIALIZE OUTPUT WI_FLT31PH.OUT
RUN TO 0.1 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 51202 ADMITTANCE 97.63 -1034.63 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51202 TO BUS 51206 CKT 2
CLEAR FAULT
RUN FOR 20 CYCLES PRINT 0 PLOT 1
RECLOSE LINE FROM BUS 51202 TO BUS 51206 CKT 2
APPLY FAULT AT BUS 51202 ADMITTANCE 97.63 -1034.63 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51202 TO BUS 51206 CKT 2
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 1
RUN TO 10 SECONDS PRINT 0 PLOT 7
PSS
PDEV
1
ODEV
7
FIN

PSS
PDEV
2 1 1
PDEV_WI_FLT43PH.TXT
ODEV
2 1 1
PDEV_WI_FLT43PH.TXT
FIN
RECOVER FROM WI_CIELO_CHAN.SNP AND WI_CIELO_CNV.SAV
INITIALIZE OUTPUT WI_FLT43PH.OUT
RUN TO 0.1 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 52186 ADMITTANCE 0 -2E+10 MVA

```
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51440 TO BUS 52186 CKT 1
CLEAR FAULT
RUN FOR 30 CYCLES PRINT 0 PLOT 1
RECLOSE LINE FROM BUS 51440 TO BUS 52186 CKT 1
APPLY FAULT AT BUS 52186 ADMITTANCE 0 -2E+10 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51440 TO BUS 52186 CKT 1
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 1
RUN TO 10 SECONDS PRINT 0 PLOT 7
PSS
PDEV
1
ODEV
7
FIN

PSS
PDEV
2 1 1
PDEV_WI_FLT41PH.TXT
ODEV
2 1 1
PDEV_WI_FLT41PH.TXT
FIN
RECOVER FROM WI_CIELO_CHAN.SNP AND WI_CIELO_CNV.SAV
INITIALIZE OUTPUT WI_FLT41PH.OUT
RUN TO 0.1 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 52186 ADMITTANCE 83.43 -1183.18 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51440 TO BUS 52186 CKT 1
CLEAR FAULT
RUN FOR 30 CYCLES PRINT 0 PLOT 1
RECLOSE LINE FROM BUS 51440 TO BUS 52186 CKT 1
APPLY FAULT AT BUS 52186 ADMITTANCE 83.43 -1183.18 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51440 TO BUS 52186 CKT 1
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 1
RUN TO 10 SECONDS PRINT 0 PLOT 7
PSS
PDEV
1
ODEV
7
FIN

PSS
PDEV
2 1 1
```

```
PDEV_WI_FLT53PH.TXT
ODEV
2 1 1
PDEV_WI_FLT53PH.TXT
FIN
RECOVER FROM WI_CIELO_CHAN.SNP AND WI_CIELO_CNV.SAV
INITIALIZE OUTPUT WI_FLT53PH.OUT
RUN TO 0.1 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 51176 ADMITTANCE 0 -30000 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51176 TO BUS 99991 CKT 1
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 1
RUN TO 10 SECONDS PRINT 0 PLOT 7
PSS
PDEV
1
ODEV
7
FIN
```

```
PSS
PDEV
2 1 1
PDEV_WI_FLT51PH.TXT
ODEV
2 1 1
PDEV_WI_FLT51PH.TXT
FIN
RECOVER FROM WI_CIELO_CHAN.SNP AND WI_CIELO_CNV.SAV
INITIALIZE OUTPUT WI_FLT51PH.OUT
RUN TO 0.1 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 51176 ADMITTANCE 123.79 -694.58 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51176 TO BUS 99991 CKT 1
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 1
RUN TO 10 SECONDS PRINT 0 PLOT 7
PSS
PDEV
1
ODEV
7
FIN
```



```
PSS
PDEV
2 1 1
PDEV_WI_FLT63PH.TXT
ODEV
2 1 1
PDEV_WI_FLT63PH.TXT
FIN
RECOVER FROM WI_CIELO_CHAN.SNP AND WI_CIELO_CNV.SAV
INITIALIZE OUTPUT WI_FLT63PH.OUT
RUN TO 0.1 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 51533 ADMITTANCE 0 -30000 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51533 TO BUS 51435 CKT 1
CLEAR FAULT
RUN FOR 20 CYCLES PRINT 0 PLOT 1
RECLOSE LINE FROM BUS 51533 TO BUS 51435 CKT 1
APPLY FAULT AT BUS 51533 ADMITTANCE 0 -30000 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51533 TO BUS 51435 CKT 1
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 1
RUN TO 10 SECONDS PRINT 0 PLOT 7
PSS
PDEV
1
ODEV
7
FIN

PSS
PDEV
2 1 1
PDEV_WI_FLT61PH.TXT
ODEV
2 1 1
PDEV_WI_FLT61PH.TXT
FIN
RECOVER FROM WI_CIELO_CHAN.SNP AND WI_CIELO_CNV.SAV
INITIALIZE OUTPUT WI_FLT61PH.OUT
RUN TO 0.1 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 51533 ADMITTANCE 241.8 -2015.14 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51533 TO BUS 51435 CKT 1
CLEAR FAULT
RUN FOR 20 CYCLES PRINT 0 PLOT 1
RECLOSE LINE FROM BUS 51533 TO BUS 51435 CKT 1
APPLY FAULT AT BUS 51533 ADMITTANCE 241.8 -2015.14 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51533 TO BUS 51435 CKT 1
CLEAR FAULT
```

```
RUN TO 5 SECONDS PRINT 0 PLOT 1
RUN TO 10 SECONDS PRINT 0 PLOT 7
PSS
PDEV
1
ODEV
7
FIN


PSS
PDEV
2 1 1
PDEV_WI_FLT73PH.TXT
ODEV
2 1 1
PDEV_WI_FLT73PH.TXT
FIN
RECOVER FROM WI_CIELO_CHAN.SNP AND WI_CIELO_CNV.SAV
INITIALIZE OUTPUT WI_FLT73PH.OUT
RUN TO 0.1 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 51206 ADMITTANCE 0 -2E+10 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51206 TO BUS 51176 CKT 2
CLEAR FAULT
RUN FOR 20 CYCLES PRINT 0 PLOT 1
RECLOSE LINE FROM BUS 51206 TO BUS 51176 CKT 2
APPLY FAULT AT BUS 51206 ADMITTANCE 0 -2E+10 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51206 TO BUS 51176 CKT 2
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 1
RUN TO 10 SECONDS PRINT 0 PLOT 7
PSS
PDEV
1
ODEV
7
FIN
```

```
PSS
PDEV
2 1 1
PDEV_WI_FLT71PH.TXT
ODEV
2 1 1
PDEV_WI_FLT71PH.TXT
FIN
RECOVER FROM WI_CIELO_CHAN.SNP AND WI_CIELO_CNV.SAV
INITIALIZE OUTPUT WI_FLT71PH.OUT
RUN TO 0.1 SECONDS PRINT 0 PLOT 1
APPLY FAULT AT BUS 51206 ADMITTANCE 17.38 -76.63 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51206 TO BUS 51176 CKT 2
CLEAR FAULT
RUN FOR 20 CYCLES PRINT 0 PLOT 1
RECLOSE LINE FROM BUS 51206 TO BUS 51176 CKT 2
APPLY FAULT AT BUS 51206 ADMITTANCE 17.38 -76.63 MVA
RUN FOR 5 CYCLES PRINT 0 PLOT 1
TRIP LINE FROM BUS 51206 TO BUS 51176 CKT 2
CLEAR FAULT
RUN TO 5 SECONDS PRINT 0 PLOT 1
RUN TO 10 SECONDS PRINT 0 PLOT 7
PSS
PDEV
1
ODEV
7
FIN


END
```

Plots of Dynamic Simulation with Cielo Wind Farm on-line during Peak Load Conditions


CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISC LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH.OUT




CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISC LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH.OUT




CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISC LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH.OUT



CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISC LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH.OUT




CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISC LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH.OUT




FRI, MAY 21 2004 10:31
 CIELO CABLE3 GEN80 6

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISC LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH.OUT




FRI, MAY 21 2004 10:31
 DVAR OUTPUT 8

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISC LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH.OUT











FRI, MAY 21 2004 10:31
 CIELO CABLE3 GEN54 5





CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISC LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH.OUT



FRI, MAY 21 2004 10:31
 CIELO VOLTAGE 7










CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPRR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR

FILE: WI_FLT13PH.OUT




22



CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPRR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WI_FLT13PH.OUT



21




CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPRR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH.OUT




23

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION WI LARGER XPMR
 FILTER, SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT11PH.OUT




FRI, MAY 21 2004 10:31
 CIELO CABLE1 GEN6 2

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION WI LARGER XPMR
 FILTER, SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT11PH.OUT




FRI, MAY 21 2004 10:31
 CIELO CABLE2 GEN5 4

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION WI LARGER XPMR
 FILTER, SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT11PH.OUT




FRI, MAY 21 2004 10:31
 CIELO CABLE1 GEN1 1

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION WI LARGER XPMR
 FILTER, SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT11PH.OUT




FRI, MAY 21 2004 10:31
 CIELO CABLE2 GEN4 3


CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLTLPH: SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLTL1PH.OUT




CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLTLPH: SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLTL1PH.OUT











CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLTLPH: SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLTL1PH.OUT







CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLTLPH: SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLTL1PH.OUT










CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 100KW UNITS, D-VAR SOLUTION W/ LARGER XPRM
 FILTER, SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR


FILE: WI_FLT11PH.OUT



22

CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 100KW UNITS, D-VAR SOLUTION W/ LARGER XPRM
 FILTER, SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR


FILE: WI_FLT11PH.OUT




21


CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 100KW UNITS, D-VAR SOLUTION W/ LARGER XPRM
 FILTER, SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR

FILE: WI_FLT11PH.OUT





23


 CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT23PH.OUT





FRI, MAY 21 2004 10:32
CIELO CABLE1 GEN6 2


 CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT23PH.OUT





FRI, MAY 21 2004 10:32
CIELO CABLE2 GEN5 4


 CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT23PH.OUT




FRI, MAY 21 2004 10:32
CIELO CABLE1 GEN1 1


 CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT23PH.OUT




FRI, MAY 21 2004 10:32
CIELO CABLE2 GEN4 3

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT23PH.OUT




FRI, MAY 21 2004 10:32
 CIELO CABLE3 GEN80 6

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT23PH.OUT




FRI, MAY 21 2004 10:32
 DVAR OUTPUT 8

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT23PH.OUT











FRI, MAY 21 2004 10:32
 CIELO CABLE3 GEN54 5





CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT23PH.OUT



FRI, MAY 21 2004 10:32
 CIELO VOLTAGE 7








CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT23PH - THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE


FILE: WI_FLT23PH.OUT



22

CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT23PH - THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE


FILE: WI_FLT23PH.OUT



21


CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT23PH - THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE

FILE: WI_FLT23PH.OUT




23

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT21PH: SLG FAULT ON ON TUCUMARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT21PH.OUT




FRI, MAY 21 2004 10:31
 CIELO CABLE1 GEN6 2

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT21PH: SLG FAULT ON ON TUCUMARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT21PH.OUT




FRI, MAY 21 2004 10:31
 CIELO CABLE2 GEN53 4

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT21PH: SLG FAULT ON ON TUCUMARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT21PH.OUT




FRI, MAY 21 2004 10:31
 CIELO CABLE1 GEN1 1

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT21PH: SLG FAULT ON ON TUCUMARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT21PH.OUT




FRI, MAY 21 2004 10:31
 CIELO CABLE2 GEN41 3


CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT21PH.OUT




CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT21PH.OUT











CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT21PH.OUT








CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT21PH.OUT












 CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CT AT TUCUMARI, DISC LINE, NO RECLOSE

FILE: WI_FLT21PH.OUT




FRI, MAY 21 2004 10:31
POTTER-FINNEY

22



 CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CT AT TUCUMARI, DISC LINE, NO RECLOSE

FILE: WI_FLT21PH.OUT




FRI, MAY 21 2004 10:31
FINNEY-HOLCOMB

21


 CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CT AT TUCUMARI, DISC LINE, NO RECLOSE


FILE: WI_FLT21PH.OUT



FRI, MAY 21 2004 10:31
SVC OUTPUT


23

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION W/ LARGER XPR
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT33PH.OUT




FRI, MAY 21 2004 10:32
 CIELO CABLE1 GEN6 2

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION W/ LARGER XPR
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT33PH.OUT




FRI, MAY 21 2004 10:32
 CIELO CABLE2 GEN53 4

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION W/ LARGER XPR
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT33PH.OUT




FRI, MAY 21 2004 10:32
 CIELO CABLE1 GEN1 1

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION W/ LARGER XPR
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT33PH.OUT




FRI, MAY 21 2004 10:32
 CIELO CABLE2 GEN41 3

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPRR
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT33PH.OUT




FRI, MAY 21 2004 10:32
 CIELO CABLE3 GEN80 6

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPRR
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT33PH.OUT




FRI, MAY 21 2004 10:32
 DVAR OUTPUT 8

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPRR
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT33PH.OUT











FRI, MAY 21 2004 10:32
 CIELO CABLE3 GEN54 5





CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPRR
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT33PH.OUT



FRI, MAY 21 2004 10:32
 CIELO VOLTAGE 7








CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPRR
 FLT33PH - THREE PHASE FAULT ON ROOSEVELT-GLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WI_FLT33PH.OUT



22

CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPRR
 FLT33PH - THREE PHASE FAULT ON ROOSEVELT-GLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WI_FLT33PH.OUT



21


CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPRR
 FLT33PH - THREE PHASE FAULT ON ROOSEVELT-GLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR

FILE: WI_FLT33PH.OUT




23

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT31PH.OUT




FRI, MAY 21 2004 10:32
 CIELO CABLE1 GEN6 2

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT31PH.OUT




FRI, MAY 21 2004 10:32
 CIELO CABLE2 GEN5 4

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT31PH.OUT




FRI, MAY 21 2004 10:32
 CIELO CABLE1 GEN1 1

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT31PH.OUT




FRI, MAY 21 2004 10:32
 CIELO CABLE2 GEN4 3

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION W/ LARGER XPMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT31PH.OUT




FRI, MAY 21 2004 10:32
 CIELO CABLE3 GEN80 6

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION W/ LARGER XPMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT31PH.OUT




FRI, MAY 21 2004 10:32
 DVAR OUTPUT 8

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION W/ LARGER XPMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT31PH.OUT











FRI, MAY 21 2004 10:32
 CIELO CABLE3 GEN54 5





CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION W/ LARGER XPMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT31PH.OUT



FRI, MAY 21 2004 10:32
 CIELO VOLTAGE 7








CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WI_FLT31PH.OUT



22


CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR

FILE: WI_FLT31PH.OUT




21

CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR




23

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPMR
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT43PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE1 GEN6 2

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPMR
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT43PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE2 GEN53 4

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPMR
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT43PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE1 GEN1 1

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPMR
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT43PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE2 GEN41 3

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPMR
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT43PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE3 GEN80 6

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPMR
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT43PH.OUT




FRI, MAY 21 2004 10:33
 DVAR OUTPUT 8

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPMR
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT43PH.OUT











FRI, MAY 21 2004 10:33
 CIELO CABLE3 GEN54 5





CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPMR
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT43PH.OUT




FRI, MAY 21 2004 10:33
 CIELO VOLTAGE 7








CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPRM
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDT CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR




22

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPRM
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDT CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR




21

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPRM
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDT CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR




23

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT41PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE1 GEN6 2

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT41PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE2 GEN53 4

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT41PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE1 GEN1 1

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT41PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE2 GEN41 3

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT41PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE3 GEN80 6

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT41PH.OUT




FRI, MAY 21 2004 10:33
 DVAR OUTPUT 8

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT41PH.OUT











FRI, MAY 21 2004 10:33
 CIELO CABLE3 GEN54 5





CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT41PH.OUT



FRI, MAY 21 2004 10:33
 CIELO VOLTAGE 7








CIRLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 100KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT41PH - SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR


FILE: WI_FLT41PH.OUT



22

CIRLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 100KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT41PH - SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR


FILE: WI_FLT41PH.OUT



21


CIRLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 100KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT41PH - SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR

FILE: WI_FLT41PH.OUT




23

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT53PH: THREE PHASE FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT53PH.OUT




FRI, MAY 21 2004 10:34
 CIELO CABLE1 GEN6 2

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT53PH: THREE PHASE FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT53PH.OUT




FRI, MAY 21 2004 10:34
 CIELO CABLE2 GEN53 4

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT53PH: THREE PHASE FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT53PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE1 GEN1 1

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT53PH: THREE PHASE FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT53PH.OUT




FRI, MAY 21 2004 10:34
 CIELO CABLE2 GEN41 3

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT53PH: THREE PHASE FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT53PH.OUT




FRI, MAY 21 2004 10:34
 CIELO CABLE3 GEN80 6

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT53PH: THREE PHASE FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT53PH.OUT




FRI, MAY 21 2004 10:34
 DVAR OUTPUT 8

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT53PH: THREE PHASE FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT53PH.OUT











FRI, MAY 21 2004 10:34
 CIELO CABLE3 GEN54 5





CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT53PH: THREE PHASE FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT53PH.OUT



FRI, MAY 21 2004 10:34
 CIELO VOLTAGE 7








CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPR
 FLT53PH - THREE PHASE FAULT ON CURREY-CABROCK 115 KV LINE
 5 CY AT CURREY, DISCT LINE, NO RECLOSE


FILE: WI_FLT53PH.OUT



22

CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPR
 FLT53PH - THREE PHASE FAULT ON CURREY-CABROCK 115 KV LINE
 5 CY AT CURREY, DISCT LINE, NO RECLOSE


FILE: WI_FLT53PH.OUT



21


CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPR
 FLT53PH - THREE PHASE FAULT ON CURREY-CABROCK 115 KV LINE
 5 CY AT CURREY, DISCT LINE, NO RECLOSE

FILE: WI_FLT53PH.OUT




23

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000W UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE1 GEN6 2

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000W UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE2 GEN53 4

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000W UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE1 GEN1 1

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000W UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE2 GEN41 3

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 100KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE3 GEN80 6

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 100KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH.OUT




FRI, MAY 21 2004 10:33
 CIELO CABLE3 GEN54 5

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 100KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH.OUT











FRI, MAY 21 2004 10:33
 DVAR OUTPUT 8





CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 100KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH.OUT



FRI, MAY 21 2004 10:33
 CIELO VOLTAGE 7








CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE


FILE: WI_FLT51PH.OUT



22

CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE


FILE: WI_FLT51PH.OUT



21


CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CABROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE

FILE: WI_FLT51PH.OUT




23

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUO 230 KV LINE
 5 CY AT TUO, DISC LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH.OUT




FRI, MAY 21 2004 10:34
 CIELO CABLE1 GEN6 2

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUO 230 KV LINE
 5 CY AT TUO, DISC LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH.OUT




FRI, MAY 21 2004 10:34
 CIELO CABLE2 GEN53 4

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUO 230 KV LINE
 5 CY AT TUO, DISC LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH.OUT




FRI, MAY 21 2004 10:34
 CIELO CABLE1 GEN1 1

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUO 230 KV LINE
 5 CY AT TUO, DISC LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH.OUT




FRI, MAY 21 2004 10:34
 CIELO CABLE2 GEN41 3


CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUO 230 KV LINE
 5 CY AT TUO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH.OUT




CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUO 230 KV LINE
 5 CY AT TUO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH.OUT











CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUO 230 KV LINE
 5 CY AT TUO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH.OUT








CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUO 230 KV LINE
 5 CY AT TUO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH.OUT












 CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WI_FLT63PH.OUT




22


 CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WI_FLT63PH.OUT



21



 CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR

FILE: WI_FLT63PH.OUT




23

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH.OUT




FRI, MAY 21 2004 10:34
 CIELO CABLE1 GEN6 2

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH.OUT




FRI, MAY 21 2004 10:34
 CIELO CABLE2 GEN5 4

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH.OUT




FRI, MAY 21 2004 10:34
 CIELO CABLE1 GEN1 1

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH.OUT




FRI, MAY 21 2004 10:34
 CIELO CABLE2 GEN4 3

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT61PH: SLG FAULT ON TOLK-TUCC 230 KV LINE
 5 CY AT TUCC, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH.OUT




FRI, MAY 21 2004 10:34
 CIELO CABLE3 GEN80 6

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT61PH: SLG FAULT ON TOLK-TUCC 230 KV LINE
 5 CY AT TUCC, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH.OUT




FRI, MAY 21 2004 10:34
 DVAR OUTPUT 8

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT61PH: SLG FAULT ON TOLK-TUCC 230 KV LINE
 5 CY AT TUCC, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH.OUT




FRI, MAY 21 2004 10:34
 CIELO CABLE3 GEN54 5

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XPMR
 FLT61PH: SLG FAULT ON TOLK-TUCC 230 KV LINE
 5 CY AT TUCC, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH.OUT




FRI, MAY 21 2004 10:34
 CIELO VOLTAGE 7

CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH.OUT




FRI, MAY 21 2004 10:34
 SPP:230 KV BUS VOLTAGE 10

CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH.OUT




FRI, MAY 21 2004 10:34
 SPP: ROTOR ANGLE 12

CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH.OUT











FRI, MAY 21 2004 10:34
 SPP:345 KV BUS VOLTAGE 9

CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH.OUT




FRI, MAY 21 2004 10:34
 SPP:115 KV BUS VOLTAGE 11





CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TTCC 230 KV LINE
 5 CY AT TTCC, DISCI LINE, RECTOR 20 CY, 5 CY FLT, CLR

FILE: WI_FLT61PH.OUT




FRI, MAY 21 2004 10:34
 POTTER-FINNEY

22

CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TTCC 230 KV LINE
 5 CY AT TTCC, DISCI LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WI_FLT61PH.OUT



FRI, MAY 21 2004 10:34
 FINNEY-HOLCOMB

21


CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TTCC 230 KV LINE
 5 CY AT TTCC, DISCI LINE, RECTOR 20 CY, 5 CY FLT, CLR



FRI, MAY 21 2004 10:34


23

CIELO WIND FARM - EAST CABROCK = 80 MW
80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPMR
FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
FILE: WI_FLT73PH.OUT




FRI, MAY 21 2004 10:35
CIELO CABLE1 GEN6 2

CIELO WIND FARM - EAST CABROCK = 80 MW
80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPMR
FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
FILE: WI_FLT73PH.OUT




FRI, MAY 21 2004 10:35
CIELO CABLE2 GEN53 4

CIELO WIND FARM - EAST CABROCK = 80 MW
80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPMR
FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
FILE: WI_FLT73PH.OUT




FRI, MAY 21 2004 10:35
CIELO CABLE1 GEN1 1

CIELO WIND FARM - EAST CABROCK = 80 MW
80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPMR
FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
FILE: WI_FLT73PH.OUT




FRI, MAY 21 2004 10:35
CIELO CABLE2 GEN41 3

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPMR
 FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT73PH.OUT




FRI, MAY 21 2004 10:35
 CIELO CABLE3 GEN80 6

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPMR
 FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT73PH.OUT




FRI, MAY 21 2004 10:35
 DVAR OUTPUT 8

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPMR
 FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT73PH.OUT











FRI, MAY 21 2004 10:35
 CIELO CABLE3 GEN54 5





CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPMR
 FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT73PH.OUT



FRI, MAY 21 2004 10:35
 CIELO VOLTAGE 7








CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPRM
 FLT/3PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WI_FLT73PH.OUT



22

CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPRM
 FLT/3PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WI_FLT73PH.OUT



21


CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XPRM
 FLT/3PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR

FILE: WI_FLT73PH.OUT




23

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT/1PH: SLG FAULT ON CLOVIS-CORR 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT71PH.OUT




FRI, MAY 21 2004 10:34
 CIELO CABLE1 GEN6 2

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT/1PH: SLG FAULT ON CLOVIS-CORR 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT71PH.OUT




FRI, MAY 21 2004 10:35
 CIELO CABLE2 GEN53 4

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT/1PH: SLG FAULT ON CLOVIS-CORR 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT71PH.OUT




FRI, MAY 21 2004 10:34
 CIELO CABLE1 GEN1 1

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION WI LARGER XFMR
 FLT/1PH: SLG FAULT ON CLOVIS-CORR 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT71PH.OUT




FRI, MAY 21 2004 10:35
 CIELO CABLE2 GEN41 3

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT/1PH: SLG FAULT ON CLOVIS-CORRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT71PH.OUT




FRI, MAY 21 2004 10:35
 CIELO CABLE3 GEN80 6

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT/1PH: SLG FAULT ON CLOVIS-CORRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT71PH.OUT




FRI, MAY 21 2004 10:35
 DVAR OUTPUT 8

CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT/1PH: SLG FAULT ON CLOVIS-CORRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT71PH.OUT











FRI, MAY 21 2004 10:35
 CIELO CABLE3 GEN54 5





CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
 FLT/1PH: SLG FAULT ON CLOVIS-CORRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT71PH.OUT



FRI, MAY 21 2004 10:35
 CIELO VOLTAGE 7









CIELLO WIND FARM - EAST CABROCK = 80 MW
80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
FLT/1PH- SLG FAULT ON CLOVIS-CORR 115 KV LINE
5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR

FILE: WI_FLT71PH.OUT




CIELLO WIND FARM - EAST CABROCK = 80 MW
80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
FLT/1PH- SLG FAULT ON CLOVIS-CORR 115 KV LINE
5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR

FILE: WI_FLT71PH.OUT



CIELLO WIND FARM - EAST CABROCK = 80 MW
80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION W/ LARGER XFMR
FLT/1PH- SLG FAULT ON CLOVIS-CORR 115 KV LINE
5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WI_FLT71PH.OUT





Appendix


D


Plots of Dynamic Simulation with Cielo Wind Farm on-line during Light Load Conditions



 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISC LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH_LITE.OUT






 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISC LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH_LITE.OUT





 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISC LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH_LITE.OUT




 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISC LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH_LITE.OUT




SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISC LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH_LITE.OUT




FRI, MAY 21 2004 10:01
 CIELO CABLE3 GEN80 6

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISC LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH_LITE.OUT




FRI, MAY 21 2004 10:01
 DVAR OUTPUT 8

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISC LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH_LITE.OUT











FRI, MAY 21 2004 10:01
 CIELO CABLE3 GEN54 5





SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISC LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT13PH_LITE.OUT




FRI, MAY 21 2004 10:01
 CIELO VOLTAGE 7










 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FL113PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 20 CT, 5 CY FLT, CLR

FILE: WI_FL113PH_LITE.OUT




22

FRI, MAY 21 2004 10:01
POTTER-FINNEY



 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FL113PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 20 CT, 5 CY FLT, CLR


FILE: WI_FL113PH_LITE.OUT



21

FRI, MAY 21 2004 10:01
FINNEY-HOLCOMB



 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FL113PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 20 CT, 5 CY FLT, CLR



23


FRI, MAY 21 2004 10:01
SVC OUTPUT

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLTLPH: SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLTLPH_LITE.OUT




FRI, MAY 21 2004 10:00
 CIELO CABLE1 GEN6 2

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLTLPH: SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLTLPH_LITE.OUT




FRI, MAY 21 2004 10:01
 CIELO CABLE2 GEN53 4

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLTLPH: SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLTLPH_LITE.OUT




FRI, MAY 21 2004 10:00
 CIELO CABLE1 GEN1 1

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLTLPH: SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLTLPH_LITE.OUT




FRI, MAY 21 2004 10:00
 CIELO CABLE2 GEN41 3


SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLTLPH: SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISC LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLTLPH_LITE.OUT




SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLTLPH: SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISC LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLTLPH_LITE.OUT











SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLTLPH: SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISC LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLTLPH_LITE.OUT







SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLTLPH: SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE DISC LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLTLPH_LITE.OUT










SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLTLPH - SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 30 CT, 5 CY FLT, CLR


FILE: WI_FLTLPH_LITE.OUT



22


SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLTLPH - SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 30 CT, 5 CY FLT, CLR

FILE: WI_FLTLPH_LITE.OUT





21

SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLTLPH - SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 30 CT, 5 CY FLT, CLR





23


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT23PH_LITE.OUT





FRI, MAY 21 2004 10:01
CIELO CABLE1 GEN6 2


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT23PH_LITE.OUT





FRI, MAY 21 2004 10:02
CIELO CABLE2 GEN53 4


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT23PH_LITE.OUT





FRI, MAY 21 2004 10:01
CIELO CABLE1 GEN1 1


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT23PH_LITE.OUT





FRI, MAY 21 2004 10:01
CIELO CABLE2 GEN41 3


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT23PH_LITE.OUT





FRI, MAY 21 2004 10:02
CIELO CABLE3 GEN80 6


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT23PH_LITE.OUT





FRI, MAY 21 2004 10:02
DVAR OUTPUT 8


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT23PH_LITE.OUT











FRI, MAY 21 2004 10:02
CIELO CABLE3 GEN54 5






 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT23PH_LITE.OUT




FRI, MAY 21 2004 10:02
CIELO VOLTAGE 7










 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAIROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE

FILE: WI_FLT23PH_LITE.OUT




22

POTTER-FINNEY



 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAIROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE

FILE: WI_FLT23PH_LITE.OUT




21

FINNEY-HOLCOMB



 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAIROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE


FILE: WI_FLT23PH_LITE.OUT




23


FRI, MAY 21 2004 10:02


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT21PH_LITE.OUT





FRI, MAY 21 2004 10:01
CIELO CABLE1 GEN6 2


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT21PH_LITE.OUT





FRI, MAY 21 2004 10:01
CIELO CABLE2 GEN53 4


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT21PH_LITE.OUT




FRI, MAY 21 2004 10:01
CIELO CABLE1 GEN1 1


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT21PH_LITE.OUT




FRI, MAY 21 2004 10:01
CIELO CABLE2 GEN41 3

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT21PH_LITE.OUT




FRI, MAY 21 2004 10:01
 CIELO CABLE3 GEN80 6

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT21PH_LITE.OUT




FRI, MAY 21 2004 10:01
 DVAR OUTPUT 8

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT21PH_LITE.OUT











FRI, MAY 21 2004 10:01
 CIELO CABLE3 GEN54 5





SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE
 FILE: WI_FLT21PH_LITE.OUT




FRI, MAY 21 2004 10:01
 CIELO VOLTAGE 7










 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE


FILE: WI_FLT21PH_LITE.OUT




FRI, MAY 21 2004 10:01
 CHNL# 115: [APPR 50858 TO 50888 CKT 1] POTTER-FINNEY 22


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE


FILE: WI_FLT21PH_LITE.OUT




FRI, MAY 21 2004 10:01
 CHNL# 113: [APPR 56449 TO 50858 CKT 1] FINNEY-HOLCOMB 21



 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE


FILE: WI_FLT21PH_LITE.OUT





FRI, MAY 21 2004 10:01
 SVC OUTPUT 23



 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT33PH_LITE.OUT






 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT33PH_LITE.OUT





 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT33PH_LITE.OUT




 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT33PH_LITE.OUT




SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT33PH_LITE.OUT




FRI, MAY 21 2004 10:02
 CIELO CABLE3 GEN80 6

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT33PH_LITE.OUT




FRI, MAY 21 2004 10:02
 DVAR OUTPUT 8

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT33PH_LITE.OUT











FRI, MAY 21 2004 10:02
 CIELO CABLE3 GEN54 5





SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT33PH_LITE.OUT



FRI, MAY 21 2004 10:02
 CIELO VOLTAGE 7








SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT33PH - THREE PHASE FAULT ON ROOSEVELT-GLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WI_FLT33PH_LITE.OUT



FRI, MAY 21 2004 10:02
 CHNL# 115: [APPR 50858 TO 50888 CKT 1] POTTER-FINNEY 22


SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT33PH - THREE PHASE FAULT ON ROOSEVELT-GLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR

FILE: WI_FLT33PH_LITE.OUT




FRI, MAY 21 2004 10:02
 CHNL# 113: [APPR 56449 TO 50858 CKT 1] FINNEY-HOLCOMB 21

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT33PH - THREE PHASE FAULT ON ROOSEVELT-GLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR




FRI, MAY 21 2004 10:02
 SVC OUTPUT 23

SPR LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT31PH_LITE.OUT




FRI, MAY 21 2004 10:02
 CIELO CABLE1 GEN6 2

SPR LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT31PH_LITE.OUT




FRI, MAY 21 2004 10:02
 CIELO CABLE2 GEN53 4

SPR LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT31PH_LITE.OUT




FRI, MAY 21 2004 10:02
 CIELO CABLE1 GEN1 1

SPR LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT31PH_LITE.OUT




FRI, MAY 21 2004 10:02
 CIELO CABLE2 GEN41 3

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT31PH_LITE.OUT




FRI, MAY 21 2004 10:02
 CIELO CABLE3 GEN80 6

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT31PH_LITE.OUT




FRI, MAY 21 2004 10:02
 CIELO CABLE3 GEN54 5

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT31PH_LITE.OUT











FRI, MAY 21 2004 10:02
 DVAR OUTPUT 8





SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT31PH_LITE.OUT



FRI, MAY 21 2004 10:02
 CIELO VOLTAGE 7








SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT31PH- SLS FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CT, 5 CY FLT, CLR


FILE: WI_FLT31PH_LITE.OUT



22

SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT31PH- SLS FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CT, 5 CY FLT, CLR


FILE: WI_FLT31PH_LITE.OUT




21


SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000K UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT31PH- SLS FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CT, 5 CY FLT, CLR


FILE: WI_FLT31PH_LITE.OUT





23



 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT43PH_LITE.OUT






 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT43PH_LITE.OUT





 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT43PH_LITE.OUT




 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT43PH_LITE.OUT




SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT43PH_LITE.OUT




FRI, MAY 21 2004 10:03
 CIELO CABLE3 GEN80 6

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT43PH_LITE.OUT




FRI, MAY 21 2004 10:03
 DVAR OUTPUT 8

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT43PH_LITE.OUT











FRI, MAY 21 2004 10:03
 CIELO CABLE3 GEN54 5





SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT43PH: THREE PHASE FAULT ON TOLK-BDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT43PH_LITE.OUT



FRI, MAY 21 2004 10:03
 CIELO VOLTAGE 7








SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER AFMR
 FLT43PH: THREE PHASE FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR


FILE: WI_FLT43PH_LITE.OUT



22

SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER AFMR
 FLT43PH: THREE PHASE FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR


FILE: WI_FLT43PH_LITE.OUT




21


SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER AFMR
 FLT43PH: THREE PHASE FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR

FILE: WI_FLT43PH_LITE.OUT





23


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT41PH_LITE.OUT





FRI, MAY 21 2004 10:02
 CIELO CABLE1 GEN6 2


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT41PH_LITE.OUT





FRI, MAY 21 2004 10:02
 CIELO CABLE1 GEN1 1


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT41PH_LITE.OUT




FRI, MAY 21 2004 10:03
 CIELO CABLE2 GEN53 4


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT41PH_LITE.OUT




FRI, MAY 21 2004 10:03
 CIELO CABLE2 GEN41 3


SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT41PH_LITE.OUT




SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT41PH_LITE.OUT











SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT41PH_LITE.OUT







SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR
 FILE: WI_FLT41PH_LITE.OUT










SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT41PH - SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR


FILE: WI_FLT41PH_LITE.OUT



22

SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT41PH - SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR


FILE: WI_FLT41PH_LITE.OUT



21


SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT41PH - SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR

FILE: WI_FLT41PH_LITE.OUT




23

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT53PH: THREE PHASE FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT53PH_LITE.OUT




FRI, MAY 21 2004 10:03
 CIELO CABLE1 GEN6 2

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT53PH: THREE PHASE FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT53PH_LITE.OUT




FRI, MAY 21 2004 10:03
 CIELO CABLE2 GEN53 4

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT53PH: THREE PHASE FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT53PH_LITE.OUT




FRI, MAY 21 2004 10:03
 CIELO CABLE1 GEN1 1

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT53PH: THREE PHASE FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT53PH_LITE.OUT




FRI, MAY 21 2004 10:03
 CIELO CABLE2 GEN41 3

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT53PH: THREE PHASE FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT53PH_LITE.OUT




FRI, MAY 21 2004 10:04
 CIELO CABLE3 GEN80 6

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT53PH: THREE PHASE FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT53PH_LITE.OUT




FRI, MAY 21 2004 10:04
 DVAR OUTPUT 8

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT53PH: THREE PHASE FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT53PH_LITE.OUT











FRI, MAY 21 2004 10:03
 CIELO CABLE3 GEN54 5





SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT53PH: THREE PHASE FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT53PH_LITE.OUT



FRI, MAY 21 2004 10:04
 CIELO VOLTAGE 7








SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT53PH - THREE PHASE FAULT ON CURRY-CARROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE


FILE: WI_FLT53PH_LITE.OUT



22

SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT53PH - THREE PHASE FAULT ON CURRY-CARROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE


FILE: WI_FLT53PH_LITE.OUT




21


SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT53PH - THREE PHASE FAULT ON CURRY-CARROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE

FILE: WI_FLT53PH_LITE.OUT





23


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH_LITE.OUT





FRI, MAY 21 2004 10:03
CIELO CABLE1 GEN6 2


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH_LITE.OUT





FRI, MAY 21 2004 10:03
CIELO CABLE2 GEN53 4


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH_LITE.OUT




FRI, MAY 21 2004 10:03
CIELO CABLE1 GEN1 1


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH_LITE.OUT




FRI, MAY 21 2004 10:03
CIELO CABLE2 GEN41 3

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH_LITE.OUT




FRI, MAY 21 2004 10:03
 CIELO CABLE3 GEN80 6

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH_LITE.OUT




FRI, MAY 21 2004 10:03
 DVAR OUTPUT 8

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH_LITE.OUT











FRI, MAY 21 2004 10:03
 CIELO CABLE3 GEN54 5





SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH_LITE.OUT



FRI, MAY 21 2004 10:03
 CIELO VOLTAGE 7










SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE

FILE: WI_FLT51PH_LITE.OUT




FRI, MAY 21 2004 10:03
 CHNL# 115: [APPR 50858 TO 50888 CKT 1] POTTER-FINNEY 22



SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE


FILE: WI_FLT51PH_LITE.OUT



FRI, MAY 21 2004 10:03
 CHNL# 113: [APPR 56449 TO 50858 CKT 1] FINNEY-HOLCOMB 21




SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT51PH: SLG FAULT ON CURRY-CAPROCK 115 KV LINE
 5 CY AT CURRY, DISCT LINE, NO RECLOSE
 FILE: WI_FLT51PH_LITE.OUT




FRI, MAY 21 2004 10:03
 SVC OUTPUT 23

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUO 230 KV LINE
 5 CY AT TUO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH_LITE.OUT




FRI, MAY 21 2004 10:04
 CIELO CABLE1 GEN6 2

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUO 230 KV LINE
 5 CY AT TUO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH_LITE.OUT




FRI, MAY 21 2004 10:04
 CIELO CABLE2 GEN53 4

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUO 230 KV LINE
 5 CY AT TUO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH_LITE.OUT




FRI, MAY 21 2004 10:04
 CIELO CABLE1 GEN1 1

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUO 230 KV LINE
 5 CY AT TUO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH_LITE.OUT




FRI, MAY 21 2004 10:04
 CIELO CABLE2 GEN41 3


SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUO 230 KV LINE
 5 CY AT TUO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH_LITE.OUT




SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUO 230 KV LINE
 5 CY AT TUO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH_LITE.OUT











SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUO 230 KV LINE
 5 CY AT TUO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH_LITE.OUT








SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUO 230 KV LINE
 5 CY AT TUO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH_LITE.OUT











 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR

FILE: WI_FLT63PH_LITE.OUT


TSTART: 0.0 TSTOP: 10.0 TIC INCREMENT: 0.25
 CHNL# 116: [APPX 50858 TO 50888 CKT 1]



CHNL# 115: [APPR 50858 TO 50888 CKT 1]


FRI, MAY 21 2004 10:04
POTTER-FINNEY

22


 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH_LITE.OUT

FILE: WI_FLT63PH_LITE.OUT


TSTART: 0.0 TSTOP: 10.0 TIC INCREMENT: 0.25
 CHNL# 114: [APPX 56449 TO 50858 CKT 1]




CHNL# 113: [APPR 56449 TO 50858 CKT 1]

FRI, MAY 21 2004 10:04
FINNEY-HOLCOMB

21



 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT63PH: THREE PHASE FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT63PH_LITE.OUT



FRI, MAY 21 2004 10:04
SVC OUTPUT


23

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH_LITE.OUT




FRI, MAY 21 2004 10:04
 CIELO CABLE1 GEN6 2

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH_LITE.OUT




FRI, MAY 21 2004 10:04
 CIELO CABLE2 GEN53 4

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH_LITE.OUT




FRI, MAY 21 2004 10:04
 CIELO CABLE1 GEN1 1

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH_LITE.OUT




FRI, MAY 21 2004 10:04
 CIELO CABLE2 GEN41 3

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TUCC 230 KV LINE
 5 CY AT TUCC, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH_LITE.OUT




CIELO CABLE3 GEN80 6

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TUCC 230 KV LINE
 5 CY AT TUCC, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH_LITE.OUT




DVAR OUTPUT 8

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TUCC 230 KV LINE
 5 CY AT TUCC, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH_LITE.OUT











CIELO CABLE3 GEN54 5





SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT61PH: SLG FAULT ON TOLK-TUCC 230 KV LINE
 5 CY AT TUCC, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT61PH_LITE.OUT



CIELO VOLTAGE 7








SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT61PH - SLG FAULT ON TOLK-TOCO 230 KV LINE
 5 CY AT TOCO, DISCI LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WI_FLT61PH_LITE.OUT



FRI, MAY 21 2004 10:04
 CHNL# 115: [APPR 50858 TO 50888 CKT 1]
 POTTER-FINNEY 22


SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT61PH - SLG FAULT ON TOLK-TOCO 230 KV LINE
 5 CY AT TOCO, DISCI LINE, RECTOR 20 CY, 5 CY FLT, CLR

FILE: WI_FLT61PH_LITE.OUT





FRI, MAY 21 2004 10:04
 CHNL# 113: [APPR 56449 TO 50858 CKT 1]
 FINNEY-HOLCOMB 21


SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT61PH - SLG FAULT ON TOLK-TOCO 230 KV LINE
 5 CY AT TOCO, DISCI LINE, RECTOR 20 CY, 5 CY FLT, CLR





FRI, MAY 21 2004 10:04
 SVC OUTPUT 23



 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT73PH_LITE.OUT






 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT73PH_LITE.OUT






 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT73PH_LITE.OUT






 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT73PH_LITE.OUT






 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT73PH_LITE.OUT






 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT73PH_LITE.OUT












 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT73PH_LITE.OUT




 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT73PH_LITE.OUT











SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT/3PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT73PH_LITE.OUT

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT/3PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT73PH_LITE.OUT


SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT/3PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT73PH_LITE.OUT

SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT/3PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT73PH_LITE.OUT



SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER AFMR
 FLT/3PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WI_FLT73PH_LITE.OUT



22


SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER AFMR
 FLT/3PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR

FILE: WI_FLT73PH_LITE.OUT





21


SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CARROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER AFMR
 FLT/3PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR





23



 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT/1PH: SLG FAULT ON CLOVIS-CORRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT1PH_LITE.OUT






 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT/1PH: SLG FAULT ON CLOVIS-CORRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT1PH_LITE.OUT






 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT/1PH: SLG FAULT ON CLOVIS-CORRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT1PH_LITE.OUT






 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, WI LARGER XFMR
 FLT/1PH: SLG FAULT ON CLOVIS-CORRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT1PH_LITE.OUT






 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT/1PH: SLG FAULT ON CLOVIS-CORRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT1PH_LITE.OUT






 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT/1PH: SLG FAULT ON CLOVIS-CORRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT1PH_LITE.OUT












 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT/1PH: SLG FAULT ON CLOVIS-CORRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT1PH_LITE.OUT








 SPP LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT/1PH: SLG FAULT ON CLOVIS-CORRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WI_FLT1PH_LITE.OUT










SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT/1PH- SLG PROBL ON CLOVIS-CORR 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: MI_FLT71PH_LITE.OUT



22


SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT/1PH- SLG PROBL ON CLOVIS-CORR 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR

FILE: MI_FLT71PH_LITE.OUT



21

SPF LIGHT LOAD WITH CIELO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS, D-VAR SOLUTION, MI LARGER XFMR
 FLT/1PH- SLG PROBL ON CLOVIS-CORR 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR











23





Appendix

E


Plots of Dynamic Simulation with Cielo Wind Farm off-line during Peak Load Conditions








CIRLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR




15

CIRLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR











14





CIRLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLT13PH: THREE PHASE FAULT ON ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR



16








CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLTLPH: SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR


FILE: WO_FLTLPH.OUT



FRI, MAY 21 2004 9:47
 CHNL# 115: [APPR 50858 TO 50888 CKT 1] POTTER-FINNEY 15


CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLTLPH: SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR

FILE: WO_FLTLPH.OUT











FRI, MAY 21 2004 9:47
 CHNL# 113: [APPR 56449 TO 50858 CKT 1] FINNEY-HOLCOMB 14





CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLTLPH: SLG FAULT ON TOLK-CLOVIS 230 KV LINE
 5 CY IN THE MIDDLE, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR
 FILE: WO_FLTLPH.OUT



FRI, MAY 21 2004 9:47
 SVC OUTPUT 16










CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE

FILE: WO_FLT23PH.OUT




FRI, MAY 21 2004 9:48
 CHNL# 115: [APPR 50858 TO 50888 CKT 1] POTTER-FINNEY

15



CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE

FILE: WO_FLT23PH.OUT




FRI, MAY 21 2004 9:48
 CHNL# 113: [APPR 56449 TO 50858 CKT 1] FINNEY-HOLCOMB

14











CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLT23PH: THREE PHASE FAULT ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMCARI, DISC LINE, NO RECLOSE
 FILE: WO_FLT23PH.OUT







FRI, MAY 21 2004 9:48
 SVC OUTPUT


16








CIRLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE




15

CIRLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE











14





CIRLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS
 FLT21PH: SLG FAULT ON ON TUCUMCARI 115 KV BUS
 5 CY AT TUCUMARI, DISC LINE, NO RECLOSE



16








CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOYVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR


FILE: WO_FLT33PH.OUT



FRI, MAY 21 2004 9:48
 CHNL# 115: [APPR 50858 TO 50888 CKT 1] POTTER-FINNEY 15


CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOYVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR

FILE: WO_FLT33PH.OUT











FRI, MAY 21 2004 9:48
 CHNL# 113: [APPR 56449 TO 50858 CKT 1] FINNEY-HOLCOMB 14





CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLT33PH: THREE PHASE FAULT ON ROOSEVELT-CLOYVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR




FRI, MAY 21 2004 9:48
 SVC OUTPUT 16








CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR




15

CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR











14





CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLT31PH: SLG FAULT ON ROOSEVELT-CLOVIS 115 KV LINE
 5 CY AT ROOSEVELT, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR



16








CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS
 FLT43PH: THREE PHASE FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR


FILE: WO_FLT43PH.OUT



15

CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS
 FLT43PH: THREE PHASE FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR


FILE: WO_FLT43PH.OUT







14





CIELLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS
 FLT43PH: THREE PHASE FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECTOR 30 CY, 5 CY FLT, CLR





FILE: WO_FLT43PH.OUT



16








CIRLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR


FILE: WO_FLT41PH.OUT



FRI, MAY 21 2004 9:48
 CHNL# 115: [APPR 50858 TO 50888 CKT 1] POTTER-FINNEY 15


CIRLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR

FILE: WO_FLT41PH.OUT











FRI, MAY 21 2004 9:48
 CHNL# 113: [APPR 56449 TO 50858 CKT 1] FINNEY-HOLCOMB 14





CIRLO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS
 FLT41PH: SLG FAULT ON TOLK-EDDY CO 345 KV LINE
 5 CY AT EDDY CO, DISCT LINE, RECLOR 30 CY, 5 CY FLT, CLR



FRI, MAY 21 2004 9:48
 SVC OUTPUT 16








CIELLO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS
 FLT53PH: THREE PHASE FAULT ON CERRY-CAPROCK 115 KV LINE
 5 CY AT CERRY, DISCT LINE, NO RECLOSE


FILE: WO_FLT53PH.OUT



FRI, MAY 21 2004 9:49
 CHNL# 115: [APPR 50858 TO 50888 CKT 1] POTTER-FINNEY 15

CIELLO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS
 FLT53PH: THREE PHASE FAULT ON CERRY-CAPROCK 115 KV LINE
 5 CY AT CERRY, DISCT LINE, NO RECLOSE


FILE: WO_FLT53PH.OUT







FRI, MAY 21 2004 9:49
 CHNL# 113: [APPR 56449 TO 50858 CKT 1] FINNEY-HOLCOMB 14





CIELLO WIND FARM - EAST CAPROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS
 FLT53PH: THREE PHASE FAULT ON CERRY-CAPROCK 115 KV LINE
 5 CY AT CERRY, DISCT LINE, NO RECLOSE





FILE: WO_FLT53PH.OUT




FRI, MAY 21 2004 9:49
 SVC OUTPUT 16








CIRLO WIND FARM - EAST CABROCK = 80 MW
80 MITSUBISHI 1000KW UNITS
FLT51PH: SLG FAULT ON CURRY-CABROCK 115 KV LINE
5 CY AT CURRY, DISCT LINE, NO RECLOSE




15

CIRLO WIND FARM - EAST CABROCK = 80 MW
80 MITSUBISHI 1000KW UNITS
FLT51PH: SLG FAULT ON CURRY-CABROCK 115 KV LINE
5 CY AT CURRY, DISCT LINE, NO RECLOSE




14

CIRLO WIND FARM - EAST CABROCK = 80 MW
80 MITSUBISHI 1000KW UNITS
FLT51PH: SLG FAULT ON CURRY-CABROCK 115 KV LINE
5 CY AT CURRY, DISCT LINE, NO RECLOSE




16

CIRILO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS
 FLT63PH: THREE PHASE FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WO_FLT63PH.OUT




FRI, MAY 21 2004 9:49
 SPP: 230 KV BUS VOLTAGE 2

CIRILO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS
 FLT63PH: THREE PHASE FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WO_FLT63PH.OUT




FRI, MAY 21 2004 9:49
 SPP: ROTOR ANGLE 4

CIRILO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS
 FLT63PH: THREE PHASE FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WO_FLT63PH.OUT











FRI, MAY 21 2004 9:49
 SPP: 345 KV BUS VOLTAGE 1

CIRILO WIND FARM - EAST CABROCK = 80 MW
 80 MITSUBISHI 1000KW UNITS
 FLT63PH: THREE PHASE FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR
 FILE: WO_FLT63PH.OUT




FRI, MAY 21 2004 9:49
 SPP: 115 KV BUS VOLTAGE 3






CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLT63PH: THREE PHASE FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR



15

POTTER-FINNEY


CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLT63PH: THREE PHASE FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR



14





FINNEY-HOLCOMB





CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000KW UNITS
 FLT63PH: THREE PHASE FAULT ON TOLK-TUCO 230 KV LINE
 5 CY AT TUCO, DISCT LINE, RECLOR 20 CY, 5 CY FLT, CLR







16

FRI, MAY 21 2004 9:49








CIELLO WIND FARM - EAST CABROCK = 80 MW
80 MITSUBISHI 1000KW UNITS
FLT61PH: SLG FAULT ON TOLK-TTCCO 230 KV LINE
5 CY AT TTCCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WO_FLT61PH.OUT



15


CIELLO WIND FARM - EAST CABROCK = 80 MW
80 MITSUBISHI 1000KW UNITS
FLT61PH: SLG FAULT ON TOLK-TTCCO 230 KV LINE
5 CY AT TTCCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR

FILE: WO_FLT61PH.OUT




14

CIELLO WIND FARM - EAST CABROCK = 80 MW
80 MITSUBISHI 1000KW UNITS
FLT61PH: SLG FAULT ON TOLK-TTCCO 230 KV LINE
5 CY AT TTCCO, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR




16


CIRLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000K UNITS
 FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WO_FLT73PH.OUT




CIRLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000K UNITS
 FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WO_FLT73PH.OUT











CIRLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000K UNITS
 FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WO_FLT73PH.OUT



CIRLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000K UNITS
 FLT73PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR
 FILE: WO_FLT73PH.OUT








CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000K UNITS
 FLT/3PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WO_FLT73PH.OUT



FRI, MAY 21 2004 9:49
 CHNL# 115: [APPR 50858 TO 50888 CKT 1] POTTER-FINNEY 15

CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000K UNITS
 FLT/3PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WO_FLT73PH.OUT







FRI, MAY 21 2004 9:49
 CHNL# 113: [APPR 56449 TO 50858 CKT 1] FINNEY-HOLCOMB 14





CIELLO WIND FARM - EAST CABROCK = 80 MM
 80 MITSUBISHI 1000K UNITS
 FLT/3PH: THREE PHASE FAULT ON CLOVIS-CURRY 115 KV LINE
 5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR





FILE: WO_FLT73PH.OUT



FRI, MAY 21 2004 9:49
 SVC OUTPUT 16








CIRLO WIND FARM - EAST CABROCK = 80 MM
80 MITSUBISHI 1000K UNITS
FLT/1PH: SLG FAULT ON CLOVIS-CURRY 115 KV LINE
5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR


FILE: WO_FLT71PH.OUT



FRI, MAY 21 2004 9:49
CHNL# 115: [APPR 50858 TO 50888 CKT 1]
POTTER-FINNEY 15


CIRLO WIND FARM - EAST CABROCK = 80 MM
80 MITSUBISHI 1000K UNITS
FLT/1PH: SLG FAULT ON CLOVIS-CURRY 115 KV LINE
5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR

FILE: WO_FLT71PH.OUT



FRI, MAY 21 2004 9:49
CHNL# 113: [APPR 56449 TO 50858 CKT 1]
FINNEY-HOLCOMB 14

CIRLO WIND FARM - EAST CABROCK = 80 MM
80 MITSUBISHI 1000K UNITS
FLT/1PH: SLG FAULT ON CLOVIS-CURRY 115 KV LINE
5 CY AT CLOVIS, DISCT LINE, RECTOR 20 CY, 5 CY FLT, CLR



FRI, MAY 21 2004 9:49
SVC OUTPUT 16