



***System Impact Study for Generation
Interconnection Request***

GEN-2002-022

***SPP Tariff Studies
(#GEN-2002-022-4)***

September, 2005

1 Summary

ABB performed the following re-Study at the request of the Southwest Power Pool (SPP) for Generation Interconnection request GEN-2002-022. The request for interconnection was placed with SPP in accordance with SPP's Open Access Transmission Tariff, which covers new generation interconnections on SPP's transmission system.

Pursuant to the tariff, ABB was asked to perform a detailed stability analysis of the generation interconnection request to satisfy the Impact Study Agreement executed by the requesting customer and SPP. This re-study was conducted due to request by the Customer to change the manufacturer of the wind turbines at the wind farm.

The Federal Energy Regulatory Commission finalized the grid-interconnection rule for large wind power facilities May 25, 2005. The final rule provides that wind generators must meet the following conditions, if the transmission service provider demonstrates they are needed. First, if needed, a large wind generating facility must remain operational during voltage disturbances on the grid. Second, large wind plants must, if needed, meet the same technical criteria for providing reactive power to the grid as required of conventional large generating facilities. Third, the final rule provides for supervisory control and data acquisition (SCADA), if needed, to ensure appropriate real-time communication and data exchanges between the wind power producer and the grid operator.

On September 19, 2005, the American Wind Energy Association (AWEA) and NERC jointly made a filing at FERC recommending that all wind generators be able to ride through all faults with voltage drops up to zero volts for up to 9 cycles.

To this end SPP recommends that the Customer strongly consider these reliability requirements of the wind farm based on the FERC final rule.



IMPACT STUDIES FOR GENERATION INTERCONNECTION REQUEST GEN-2002-022

Prepared for: SOUTHWEST POWER POOL

Final Report

REPORT NO.: Consulting 2005-11118-1

September 29, 2005

Submitted by:

**ABB Inc., Electric Systems Consulting
940 Main Campus Drive, Suite 300
Raleigh, NC 27606**

Southwest Power Pool	No. 2005-11118-1		
Title: Interconnection Impact Studies for Generation Interconnection Request (GEN-2002-022)	Dept. ESC	Date September 29, 2005	Pages 33

Authors: Ravi kanth Varanasi

Reviewer: William Quaintance

Summary

Southwest Power Pool (SPP) has requested ABB to perform an interconnection impact study of a new 240 MW wind farm in Oldham County, Texas. The proposed plant will be connected to the Xcel Energy (SPS) transmission system at the Bushland Interchange. The wind farm developer requested that the studies be performed using two different types of wind turbine technologies: Gamesa G87 and the Bonus 2.3 Mk II. The proposed wind farm has previously been studied assuming wind turbines from Mitsubishi, GE, and Vestas.

Based on the results of the stability analysis, it is concluded that the interconnection of the 240 MW Gen-2002-022 wind farm at Bushland 230 kV station, with either Gamesa G87 or Bonus 2.3 Mk II wind turbines, does not adversely impact the stability of the SPP system. The wind turbines remain stable for all faults simulated. Some turbines may trip for close-in, low-impedance, multi-phase faults, but this will not affect system stability.

The results of this analysis are based on available data and assumptions made at the time of conducting this study. If any of the data and/or assumptions made in developing the study model change, the results provided in this report may not apply.

Rev. #	Revision	Date	Author	Reviewed	Approved
2	New Bonus Model (Beta)	09-22-2005	RV	WQ	
DISTRIBUTION: John E. Mills and Charles Hendrix of Southwest Power Pool					

LEGAL NOTICE

This document, prepared by ABB Inc., is an account of work sponsored by Southwest Power Pool. Neither Southwest Power Pool nor ABB Inc., nor any person or persons acting on behalf of either party: (i) makes any warranty or representation, expressed or implied, with respect to the use of any information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights, or (ii) assumes any liabilities with respect to the use of or for damages resulting from the use of any information, apparatus, method, or process disclosed in this document.

Table of Contents

1	INTRODUCTION.....	5
2	STABILITY ANALYSIS.....	6
2.1	STABILITY ANALYSIS METHODOLOGY	6
2.2	STUDY MODEL DEVELOPMENT	6
2.3	STABILITY RESULTS	17
3	STUDY CONCLUSIONS.....	21
	APPENDIX A – COLLECTOR SYSTEM.....	22
	APPENDIX A.1. COLLECTOR SYSTEM FOR THE GAMESA MACHINES	23
	APPENDIX A.2. COLLECTOR SYSTEM FOR THE BONUS MACHINES.....	24
	APPENDIX A.3. LOAD FLOW CASE CHANGES:	25
	APPENDIX B – STABILITY MODEL PARAMETERS.....	27
	APPENDIX C – STABILITY PLOTS	35

1 INTRODUCTION

SPP has requested an interconnection impact study for interconnecting a 240 MW wind farm in Oldham County, Texas. The wind farm will be connected to the Xcel Energy (SPS) transmission system at the existing Bushland Interchange. The generation developer requested that the impact study be conducted using two types of wind turbine generators: Gamesa G87 and Bonus Mk II machines. The feasibility (power flow) study was not performed as a part of this study.

The objective of the impact study is to evaluate the impact on system stability after connecting the 240 MW wind farm to the interconnection point and its effect on the nearby transmission system and generating stations. The study is performed on two system scenarios: 2006 Winter Case and the 2009 Summer Case provided by SPP. The new wind farm is modeled accurately to represent the collector system (Figure 1.1) and the study is performed by using 2 equivalent machines of 160 MW and 80 MW on the two 34.5 kV feeders. Figure 1.1 shows the topology of the new generator interconnection.




Figure 1.1: Proposed Interconnection of Wind Farm at Bushland 230 kV

2 STABILITY ANALYSIS

In this stability study, ABB investigated the stability of the system for faults in the vicinity of the proposed plant as defined by SPP. The faults involve three-phase and single-phase faults cleared by primary protection, reclosing with the fault still on, and then permanently clearing the fault with primary protection.

2.1 Stability Analysis Methodology

Using Planning Standards approved by NERC, the following stability definition was applied in the Transient Stability Analysis:

“Power system stability is defined as that condition in which the differences of the angular positions of synchronous machine rotors become constant following an aperiodic system disturbance.”

Stability analysis was performed using PTI’s PSS/E dynamics program V29. All the stability simulations were performed by modeling the new wind machines using the Gamesa G87 and the Bonus Mk II models.

Disturbances such as three-phase and single-phase line faults were simulated for the specified durations, including reclosing, and the synchronous machine rotor angles were monitored to make sure they maintained synchronism following the fault removal.

Single-phase line faults were simulated with the standard method of applying fault impedance to the positive sequence network to represent the effect of the negative and zero sequence networks on the positive sequence network. The fault impedance was computed to give a positive sequence voltage at the fault location of approximately 60% of pre-fault voltage, which is a typical value.

The ability of the wind generators to stay connected to the grid during the disturbances and during the fault recovery was also monitored. This is primarily determined by their low-voltage ride-through capabilities, or lack thereof, as represented in the models by low-voltage trip settings. Both the models of Gamesa G87 and Bonus Mk II units were equipped with over/under voltage relays and over/under frequency relays. All the faults that resulted in the tripping of the proposed wind farm were rerun with the tripping disabled to verify the stability of the farm.

2.2 Study Model Development

The study model consists of power flow cases and dynamics databases, developed as follows.

Collector System Development:

The developer provided a detailed layout of the wind farm collector system and wind turbine generators. While it is not practical to model 160, 1.5 MW generators in the case of Gamesa G87 and 105, 2.3 MW generators in the case of Bonus Mk II for the power systems stability analysis, the detailed data was used to calculate two equivalent machines of 160 MW and 80 MW on the two main feeders for the 240 MW plant (Figure 1.1). The detailed plant layout was modeled in PSS/E power flow, and short-circuit analysis was used to determine the Thevenin equivalent impedance of the wind farm at the low side of the substation transformers. This impedance was separated into three parts: an equivalent generator step-up transformer, equivalent source impedance, and the remainder representing equivalent 34.5 kV collector

system impedance¹. An equivalent line charging capacitance is added to the equivalent collector impedance to give the same Mvar injection at the substation in the equivalent model as in the detailed model. This equivalent charging is 0.00813 and 0.01626 per unit at the 80 and 160 MW substations, respectively, for the Gamesa model, and 0.00753 and 0.01546 per unit for the Bonus model.

Appendix A shows the wind farm equivalent model data used for the load flow case development.

The load flow data for the equivalent machines is obtained from the iplan program for modeling the Gamesa G87 machines, and the data to model the Bonus Mk II equivalent machines were obtained from the package provided by SPP.

Power Flow Cases Development:

SPP provided two PSS/E power flow cases called “SPP_2006_Winter_stability.sav” representing the winter conditions of the SPP system for the year 2006 and the “SPP_2009_Summer_stability.sav” representing the summer conditions of the SPP system for the year 2009. The cases provided were updated to make them compatible with the dynamics database provided. The changes made to the cases are captured in idev files and are listed in Appendix A.3. These changes are necessary to prevent initial condition suspects and initialization errors during dynamic simulations.

The GEN 2002-019 wind farm comprising 162 MW of GE DFIG wind turbines was added to the base cases provided by SPP to build the pre-project cases. The resulting cases were used as the base cases for the GEN-2002-022 study.

Wind farm modeling:

The proposed wind farm is modeled in the load flow cases as two equivalent wind turbine generators having capacities of 80 MW and 160 MW. Each of the equivalent machines has a generator step-up transformer (GSU) modeled as a lumped equivalent as shown in Figure 1.1. Two substation transformers of required capacity are modeled as per the data provided by SPP. Transformer taps are adjusted as necessary to obtain a good voltage profile across the wind farm. Additional substation capacitors are placed on the 34.5 kV substation buses to maintain a near-unity power factor at the point of interconnection in the case of Gamesa design. For the Gamesa units, 22 Mvar of capacitors were placed at the 80 MW substation and 35 Mvar at the 160 MW substation. For the Bonus Design, the reactive power output of the equivalent machines is adjusted such that a unity power factor is obtained at the point of interconnection (Bushland 230 kV).

Stability Case Development

SPP provided the stability database in the form of a PSS/E dynamic raw data file “SPP_2006_Winter_stability.dyr” to model the winter stability dynamics database for 2006 and “SPP_2009_Summer_stability.dyr” to model the summer stability dynamics database for the year 2009.

¹ This separation of the Thevenin equivalent is purely aesthetic. For example, if the impedance of all the *individual* GSU transformers were to change, it would not be sufficient to simply change the impedance of the *equivalent* GSU transformer. One would need to change the individual GSU impedances in the detailed model and recalculate the Thevenin impedance. Subtracting out the new equivalent GSU impedance would leave a new and different equivalent collector system impedance. The only instance where one can expect the equivalent collector impedance to stay the same when changing the GSUs is if all wind generators were identically distant in impedance from the substation, which is rarely the case.

Along with the above-mentioned files, idev and batch files were also provided to compile and link user-written models. The provided files required the use of PSS/E version 29.

The latest PSS/E DFIG dynamic model was used to model the 2002-019 wind farm which is a 162 MW plant at a tap on the Grapevine to Nichols 230 kV line. The PSS/E DFIG model requires execution of an IPLAN program to create the GSU and to create the generator on the low side (0.575 kV). This IPLAN program also generates a dynamic data file (*.dyr) for the DFIG machines. The direct dispatch (100.0%) for MW generation and voltage control mode for Mvar generation were used. The under-voltage and frequency trip settings have been retained. The cases developed after the addition of the 2002-019 plant were used as the base cases for the study of the proposed wind farm (2002-022). The proposed wind farm was added to the base cases to develop the cases used for the study.

The dynamics database for the year 2006 and the 2006 winter load flow case were adjusted to overcome network non-convergence during the simulation of some of the faults (FLT-3_3PH, FLT-9_1PH, FLT-10_3PH, and FLT-12_3PH). The Miles City and Lamar DC lines were equivalenced, in the 2006 Winter case only, because they were causing problems for the simulations. This case was used as a base for the year 2006 for the addition of the new plant.

The Gamesa G87 type of wind turbine was added to the case by running the IPLAN program from the package provided by SPP. The dynamic data file (*.dyr) is appended to the pre-project dynamic database to develop the stability database with the new wind generation. The Bonus Mk II model data was also added to the pre-project database to create the databases with the new generation. Dynamic data for the equivalent 160 MW and 80 MW Gamesa and Bonus generator models are listed in Appendix B.

The original dynamic model provided for the Bonus machines was a preliminary (alpha) version, and showed some problems. After numerous iterations of testing updated models from the turbine manufacturer, the "SMK 202 V1.1" version provided good simulation results. Future development of the Bonus 2.3 Mk II model is recommended to add the finishing touches of a final PSS/E dynamic model. Additional items to improve include the DOCU and DYDA output.

The Bonus machine has two control modes in the dynamic model: voltage control mode and a constant reactive current control mode. For this stability analysis, the Bonus machines are modeled with constant reactive current control mode to provide a more conservative stability analysis.

Four cases were developed by adding each type of generator model (Bonus Mk II and Gamesa G87) to the two pre-project cases established:

SPP_2006_Winter_stability-Gamesa-022.sav
SPP_2006_Winter_stability-Bonus-022.sav
SPP_2009_Summer_stability-Gamesa-022.sav
SPP_2009_Summer_stability-Bonusa-022.sav

Figures 2.1-2.4 illustrate the power flows for the region near the proposed wind farm for all the GEN-2002-022 cases developed.




Figure 2.1: 2006 Winter case with Gen-2002-022 (Bonus Mk II Model)




Figure 2.3: 2009 Summer case with Gen-2002-022 (Bonus Mk II Model)




Figure 2.4: 2009 Summer case with Gen-2002-022 (Gamesa G87 Model)

Low voltage ride through capability:

It is important to note that the PSS/E Gamesa model and the Bonus model include under / over-voltage and frequency trip relays in their models. The under voltage settings are the most critical. The following voltage settings were obtained from the model packages supplied by SPP.

Table 1. Gamesa G87 Voltage Trip Settings

Under / Over voltage settings (per unit)	Time Delay (seconds)
0.15	0.040
0.30	0.625
0.45	1.100
0.60	1.575
0.75	2.050
0.90	2.550
1.10	0.060

Table 2. Bonus Mk II Voltage Trip Settings

Under / Over voltage settings (per unit)	Time Delay (seconds)
0.15	0.150
0.70	1.00
0.90	5.00
1.10	1.00
1.20	0.20
Under / Over frequency settings (per unit)	Time Delay (seconds)
0.98	10.00
0.97	0.10
1.08	0.10

Note that wind turbine voltage and frequency protection relays are designed to protect the wind turbines, but they are not designed for ensuring system stability. These protective devices should not be relied upon for system stability. Thus, in cases where these relays tripped the wind turbines, the cases were rerun to see what would happen if the relays failed to trip the turbines as indicated by the model. If these no-tripping cases are stable, then this shows that the system will be stable regardless of the actions of these relays.

Contingencies Tested

Ten three-phase and seven single-phase line faults were simulated on branches connected to Bushland Interchange and surrounding stations. An additional fault at Bushland on the line to Deaf Smith is also simulated along with the faults supplied by SPP. All transmission lines were assumed to have reclosing enabled. The complete fault descriptions are included in Table 3.

Table 3: Description of Faults with Wind Farm at 240MW

FAULT	FAULT DESCRIPTION
FLT1-3PH 3-phase Fault	FAULT ON THE POTTER COUNTY (50887) – BUSHLAND (50993), 230KV LINE, NEAR POTTER.
	a. Apply Fault at the Potter Bus (50887).
	b. Clear Fault after 5 cycles by removing the line from 50887 - 50993.
	c. Wait 20 cycles, and then re-close the line in (b) into the fault.
	d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
FLT2-1PH 1-phase Fault	FAULT ON THE POTTER COUNTY (50887) – BUSHLAND (50993), 230KV LINE, NEAR POTTER.
	a. Apply Fault at the Potter Bus (50887).
	b. Clear Fault after 5 cycles by removing the line from 50887 - 50993.
	c. Wait 20 cycles, and then re-close the line in (b) into the fault.
	d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
FLT3-3PH 3-phase Fault	FAULT ON THE POTTER COUNTY (50888) – FINNEY SWITCH STATION (50858) 345KV LINE, NEAR FINNEY.
	a. Apply fault at the Finney bus (50858).
	b. Clear fault after 5 cycles by removing the line from 50888 – 50858.
	c. Wait 30 cycles, and then re-close line in (b) into the fault.
	d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
FLT4-3PH 3-phase Fault	FAULT ON THE BUSHLAND (50992) – COULTER (51002) 115KV LINE, NEAR COULTER.
	a. Apply fault at the Coulter bus (51002).
	b. Clear fault after 5 cycles by removing line from 50992 – 51002.
	c. Wait 20 cycles, and then re-close line in (b) into the fault.
	d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
FLT5-1PH 1-phase Fault	FAULT ON THE BUSHLAND (50992) – COULTER (51002) 115KV LINE, NEAR COULTER.
	a. Apply fault at the Coulter bus (51002).
	b. Clear fault after 5 cycles by removing line from 50992 – 51002.
	c. Wait 20 cycles, and then re-close line in (b) into the fault.
	d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
FLT6-3PH 3-phase Fault	FAULT ON THE HARRINGTON (50907) – RANDALL INTERCHANGE (51021) 230KV LINE, NEAR RANDALL.
	a. Apply fault at the Randall bus (51021).
	b. Clear fault after 5 cycles by removing the line from 50907 – 51021.
	c. Wait 20 cycles, and then re-close line in (b) into the fault.
	d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
FLT7-1PH 1-phase Fault	FAULT ON THE HARRINGTON (50907) – RANDALL INTERCHANGE (51021) 230KV LINE, NEAR RANDALL.
	a. Apply fault at the Randall bus (51021).
	b. Clear fault after 5 cycles by removing the line from 50907 – 51021.
	c. Wait 20 cycles, and then re-close line in (b) into the fault.
	d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.

FAULT	FAULT DESCRIPTION
FLT8-3PH 3-phase Fault	FAULT ON THE BUSHLAND (50993) – DEAF SMITH (51111) 230KV LINE, NEAR DEAF SMITH.
	a. Apply fault at the Deaf Smith bus (51111).
	b. Clear fault after 5 cycles by removing the line from 50993 - 51111.
	c. Wait 20 cycles, and then re-close the line in (b) into the fault.
FLT9-1PH 1-phase Fault	FAULT ON THE BUSHLAND (50993) – DEAF SMITH (51111) 230KV LINE, NEAR DEAF SMITH.
	a. Apply fault at the Deaf Smith bus (51111).
	b. Clear fault after 5 cycles by removing the line from 50993 - 51111.
	c. Wait 20 cycles, and then re-close the line in (b) into the fault.
FLT10-3PH 3-phase Fault	FAULT ON THE GRAPEVINE (50827) – ELK CITY (54153) 230KV LINE, NEAR ELK CITY.
	a. Apply fault at the Elk City bus (54153).
	b. Clear fault after 5 cycles by removing line from 54153 - 50827.
	c. Wait 20 cycles, and then re-close line in (b) into the fault.
FLT11-1PH 1-phase Fault	FAULT ON THE GRAPEVINE (50827) – ELK CITY (54153) 230KV LINE, NEAR ELK CITY.
	a. Apply fault at the Elk City bus (54153).
	b. Clear fault after 5 cycles by removing line from 54153 - 50827.
	c. Wait 20 cycles, and then re-close line in (b) into the fault.
FLT12-3PH 3-phase Fault	FAULT ON THE WOLFFORTH INTERCHANGE (51762) – TERRY COUNTY (51830) 115KV LINE, NEAR TERRY COUNTY.
	a. Apply fault at the Terry County bus (51830).
	b. Clear fault after 5 cycles by removing line from 51762 -51830.
	c. Wait 20 cycles, and then re-close line in (b) into the fault.
FLT13-1PH 1-phase Fault	FAULT ON THE WOLFFORTH INTERCHANGE (51762) – TERRY COUNTY (51830) 115KV LINE, NEAR TERRY COUNTY.
	a. Apply fault at the Terry County bus (51830).
	b. Clear fault after 5 cycles by removing line from 51762 -51830.
	c. Wait 20 cycles, and then re-close line in (b) into the fault.
FLT14-3PH 3-phase Fault	FAULT ON THE POTTER COUNTY (50887) – BUSHLAND (50993) 230KV LINE, NEAR BUSHLAND.
	a. Apply fault at the Bushland bus (50993).
	b. Clear fault after 5 cycles by removing the line from 50887 - 50993.
	c. Wait 20 cycles, and then re-close the line in (b) into the fault.
FLT15-1PH 1-phase Fault	FAULT ON THE POTTER COUNTY (50887) – BUSHLAND (50993) 230KV LINE, NEAR BUSHLAND.
	a. Apply fault at the Bushland bus (50993).
	b. Clear fault after 5 cycles by removing the line from 50887 - 50993.
	c. Wait 20 cycles, and then re-close the line in (b) into the fault.
	d. Leave fault on for 5 cycles, then trip the line in (b) and remove the fault.

FAULT	FAULT DESCRIPTION
FLT16-3PH 3-phase Fault	FAULT ON THE BUSHLAND (50993) 230/115KV TRANSFORMER
	a. Apply fault at the Bushland (50993) 230/115 transformer.
	b. Clear fault after 5 cycles by removing the 230/115 kV transformer.
	c. Wait 20 cycles, and then re-close the 230/115 kV transformer (b) into the fault.
FLT17-3PH 3-phase Fault	FAULT ON THE BUSHLAND (50993) – DEAF SMITH (51111) 230KV LINE, NEAR BUSHLAND.
	a. Apply fault at the Bushland bus (50993).
	b. Clear fault after 5 cycles by removing the line from 50993 - 51111.
	c. Wait 20 cycles, and then re-close the line in (b) into the fault.
	d. Leave fault on for 5 cycles, then trip the line in (b) and remove the fault.

2.3 Stability Results

Results for all the disturbances simulated are summarized in Tables 4 and 5. The results indicate that the system and all generators are stable following all the faults.

The frequency tripping of the Gen-2002-022 wind generators during a 3-phase fault at Bushland (fault 14) was observed when the machines were modeled using Gamesa G87 on the 2009 summer case. PSS/E is not capable of calculating accurate frequencies during three-phase bolted fault conditions and the wind farm in reality would probably not trip on under-frequency. Fault 14 was repeated with the frequency tripping disabled to verify wind farm stability, and the system remained stable following the fault.

The voltage / frequency tripping of the Gen-2002-022 wind generators during a 3-phase fault at Bushland 230 kV (faults 14 and 16) was observed when the machine was modeled as a Bonus MK-II machine in the 2006 Winter case. The tripping was disabled and the faults were rerun, which resulted in a stable system following the fault. Similar tripping of the Gen-2002-022 was also observed for the fault 17 when the wind generator was modeled as a Bonus Mk-II machine on the 2009 summer case. The fault was rerun with the tripping of the machine disabled and the result indicated a stable system after the fault.

Currently the PSS/E model does not consider cumulative low-voltage time caused by one or more reclosings. However, cumulative fault time in a short time span may indeed be important in determining true low-voltage ride-through capability. To study this phenomenon in detail, a three-phase electromagnetic transient study would be needed, along with more information from the wind turbine manufacturer. This issue is relevant to all wind turbines close to transmission lines with reclosing.

Simulation plots for all fault cases are shown in Appendix E.

All the faults simulated on the 2006 and 2009 cases with the Gamesa models and also with Bonus models were stable.

Table 4: Summary of Fault Results with Gamesa G87 Turbines

FAULT	FAULT DEFINITION	2006 Winter	2009 Summer
FLT1-3PH	FAULT ON THE POTTER COUNTY (50887) - BUSHLAND (50993), 230KV LINE, NEAR POTTER.	STABLE	STABLE
FLT2-1PH	FAULT ON THE POTTER COUNTY (50887) - BUSHLAND (50993), 230KV LINE, NEAR POTTER.	STABLE	STABLE
FLT3-3PH	FAULT ON THE POTTER COUNTY (50888) - FINNEY SWITCH STATION (50858) 345KV LINE, NEAR FINNEY.	STABLE	STABLE
FLT4-3PH	FAULT ON THE BUSHLAND (50992) - COULTER (51002) 115KV LINE, NEAR COULTER.	STABLE	STABLE
FLT5-1PH	FAULT ON THE BUSHLAND (50992) - COULTER (51002) 115KV LINE, NEAR COULTER.	STABLE	STABLE
FLT6-3PH	FAULT ON THE HARRINGTON (50907) - RANDALL INTERCHANGE (51021) 230KV LINE, NEAR RANDALL.	STABLE	STABLE
FLT7-1PH	FAULT ON THE HARRINGTON (50907) - RANDALL INTERCHANGE (51021) 230KV LINE, NEAR RANDALL.	STABLE	STABLE
FLT8-3PH	FAULT ON THE BUSHLAND (50993) - DEAF SMITH (51111) 230KV LINE, NEAR DEAF SMITH.	STABLE	STABLE
FLT9-1PH	FAULT ON THE BUSHLAND (50993) - DEAF SMITH (51111) 230KV LINE, NEAR DEAF SMITH.	STABLE	STABLE
FLT10-3PH	FAULT ON THE GRAPEVINE (50827) - ELK CITY (54153) 230KV LINE, NEAR ELK CITY.	STABLE	STABLE
FLT11-1PH	FAULT ON THE GRAPEVINE (50827) - ELK CITY (54153) 230KV LINE, NEAR ELK CITY.	STABLE	STABLE
FLT12-3PH	FAULT ON THE WOLFFORTH INTERCHANGE (51762) - TERRY COUNTY (51830) 115KV LINE, NEAR TERRY COUNTY.	STABLE	STABLE
FLT13-1PH	FAULT ON THE WOLFFORTH INTERCHANGE (51762) - TERRY COUNTY (51830) 115KV LINE, NEAR TERRY COUNTY.	STABLE	STABLE
FLT14-3PH	FAULT ON THE POTTER COUNTY (50887) - BUSHLAND (50993) 230KV LINE, NEAR BUSHLAND.	STABLE	STABLE, GEN-2002-022 Tripped
FLT14-3PH-NT	FAULT ON THE POTTER COUNTY (50887) - BUSHLAND (50993) 230KV LINE, NEAR BUSHLAND., TRIPPING DISABLED.	STABLE	STABLE
FLT15-1PH	FAULT ON THE POTTER COUNTY (50887) - BUSHLAND (50993) 230KV LINE, NEAR BUSHLAND.	STABLE	STABLE
FLT16-3PH	FAULT ON THE BUSHLAND (50993) 230/115KV TRANSFORMER	STABLE	STABLE
FLT17-3PH	FAULT ON THE BUSHLAND (50993) - DEAF SMITH (51111) 230KV LINE, NEAR BUSHLAND.	STABLE	STABLE


Table 5: Summary of Fault Results with Bonus Mk II Wind Turbines

FAULT	FAULT DEFINITION	2006 Winter	2009 Summer
FLT1-3PH	FAULT ON THE POTTER COUNTY (50887) - BUSHLAND (50993), 230KV LINE, NEAR POTTER.	STABLE	STABLE
FLT2-1PH	FAULT ON THE POTTER COUNTY (50887) - BUSHLAND (50993), 230KV LINE, NEAR POTTER.	STABLE	STABLE
FLT3-3PH	FAULT ON THE POTTER COUNTY (50888) - FINNEY SWITCH STATION (50858) 345KV LINE, NEAR FINNEY.	STABLE	STABLE
FLT4-3PH	FAULT ON THE BUSHLAND (50992) - COULTER (51002) 115KV LINE, NEAR COULTER.	STABLE	STABLE
FLT5-1PH	FAULT ON THE BUSHLAND (50992) - COULTER (51002) 115KV LINE, NEAR COULTER.	STABLE	STABLE
FLT6-3PH	FAULT ON THE HARRINGTON (50907) - RANDALL INTERCHANGE (51021) 230KV LINE, NEAR RANDALL.	STABLE	STABLE
FLT7-1PH	FAULT ON THE HARRINGTON (50907) - RANDALL INTERCHANGE (51021) 230KV LINE, NEAR RANDALL.	STABLE	STABLE
FLT8-3PH	FAULT ON THE BUSHLAND (50993) - DEAF SMITH (51111) 230KV LINE, NEAR DEAF SMITH.	STABLE	STABLE
FLT9-1PH	FAULT ON THE BUSHLAND (50993) - DEAF SMITH (51111) 230KV LINE, NEAR DEAF SMITH.	STABLE	STABLE
FLT10-3PH	FAULT ON THE GRAPEVINE (50827) - ELK CITY (54153) 230KV LINE, NEAR ELK CITY.	STABLE	STABLE
FLT11-1PH	FAULT ON THE GRAPEVINE (50827) - ELK CITY (54153) 230KV LINE, NEAR ELK CITY.	STABLE	STABLE
FLT12-3PH	FAULT ON THE WOLFFORTH INTERCHANGE (51762) - TERRY COUNTY (51830) 115KV LINE, NEAR TERRY COUNTY.	STABLE	STABLE
FLT13-1PH	FAULT ON THE WOLFFORTH INTERCHANGE (51762) - TERRY COUNTY (51830) 115KV LINE, NEAR TERRY COUNTY.	STABLE	STABLE
FLT14-3PH	FAULT ON THE POTTER COUNTY (50887) - BUSHLAND (50993) 230KV LINE, NEAR BUSHLAND.	STABLE GEN-2002-022 Tripped	STABLE
FLT14-3PH-NT	FAULT ON THE POTTER COUNTY (50887) - BUSHLAND (50993) 230KV LINE, NEAR BUSHLAND.	STABLE	- -
FLT15-1PH	FAULT ON THE POTTER COUNTY (50887) - BUSHLAND (50993) 230KV LINE, NEAR BUSHLAND.	STABLE	STABLE
FLT16-3PH	FAULT ON THE BUSHLAND (50993) 230/115KV TRANSFORMER	STABLE GEN-2002-022 Tripped	STABLE
FLT16-3PH-NT	FAULT ON THE BUSHLAND (50993) 230/115KV TRANSFORMER	STABLE	- -
FLT17-3PH	FAULT ON THE BUSHLAND (50993) - DEAF SMITH (51111) 230KV LINE, NEAR BUSHLAND.	STABLE	STABLE GEN-2002-022 Tripped
FLT17-3PH-NT	FAULT ON THE BUSHLAND (50993) - DEAF SMITH (51111) 230KV LINE, NEAR BUSHLAND.	- -	STABLE

Comparison of Bonus and Gamesa Parameters:

Figure 2.5 shows the plots for electrical output, var output and the terminal voltage of the 160 MW equivalent machine modeled using Bonus and Gamesa on the 2009 summer stability case during the simulation of FLT01-3PH.

Figure 2.5: Comparison of Bonus Mk II and Gamesa G87 Response



3 STUDY CONCLUSIONS

Based on the results of the stability analysis, it is concluded that the interconnection of the 240 MW Gen-2002-022 wind farm at Bushland 230 kV station, with either Gamesa G87 or Bonus 2.3 Mk II wind turbines, does not adversely impact the stability of the SPP system. The wind turbines remain stable for all faults simulated. Some turbines may trip for close-in, low-impedance, multi-phase faults, but this will not affect system stability.

The results of this analysis are based on available data and assumptions made at the time of conducting this study. If any of the data and/or assumptions made in developing the study model change, the results provided in this report may not apply.

APPENDIX A – COLLECTOR SYSTEM

Appendix A.1. Collector System for the Gamesa Machines

Substation Main Transformers data:

Unit 1

100,000/133,300/166,600 kVA

230/34.5/13.8 kV

825/200/110 kV BIL

9.0% @ 100 MVA base

Unit 2

50,000/666,667/83,333

230/34.5/13.8 kV

825/200/110 kV BIL

9.0% @ 50 MVA

Collector system Equivalent 1:

$R = 0.00982$

$X = 0.01730$

$B = 0.01626$

Collector system Equivalent 2:

$R = 0.02160$

$X = 0.03660$

$B = 0.00813$

GSU Equivalent 1:

2000 kVA times 80 turbines equals 160 MVA

34.5/0.690 kV

150/30 kV BIL

7.5 % @ 160 MVA

GSU Equivalent 2:

2000 kVA times 40 turbines equals 80 MVA

34.5/0.690 kV

150/30 kV BIL

7.5 % @ 80 MVA

Appendix A.2. Collector System for the Bonus Machines

Substation Main Transformers data:

Unit 1

100,000/133,300/166,600 kVA

230/34.5/13.8 kV

825/200/110 kV BIL

9.0% @ 100 MVA base

Unit 2

50,000/666,667/83,333

230/34.5/13.8 kV

825/200/110 kV BIL

9.0% @ 50 MVA

Collector system Equivalent 1:

$R = 0.00926$

$X = 0.00945$

$B = 0.01546$

Collector system Equivalent 2:

$R = 0.01566$

$X = 0.01281$

$B = 0.00753$

GSU Equivalent 1:

2600 kVA times 70 turbines equals 182 MVA

34.5/0.690

150/30 kV BIL

6.0% @ 182 MVA

GSU Equivalent 2:

2600 kVA times 35 turbines equals 91 MVA

34.5/0.690

150/30 kV BIL

6.0% @ 91 MVA

Appendix A.3. Load Flow Case Changes:

1. 2006 Winter stability case:

```

DSCN
16745
15621
15622
52500

RDCH
1
66569,,1
59995,,1
59996,,1
59998,,1
56758,,2

0
37607,'W ',,,,,,,,,,0.2300,,
23618,1,124.0,
32287,4,98.0,
34899,6,100.0,
42630,1,168.0,
63007,2,177.0,
73574,'1 ',,,,,,,,,,0,

Q

Fdns,opt
1,1,1
0

@END

```

2. 2009 Summer stability case:

```

DSCN
67621

RDCH
1
16745,,1
66569,,1
59995,,1
59996,,1
59998,,1

0
34899,6,100,
52632,1,234,
54910,1,49,
54911,1,49,

```

59800,8,18,
59802,6,19,
63806,4,865,
64496,3,15,
64499,1,18,
72869,1,1310,
54206,1,78.0,
54204,1,455.0,

60173,-67564,'1', 0.00176, 0.03004, 2.75280, 2251.7,3691.9, , 0.00000, 0.00000, 0.00000, -
2.25000,1, 0.00, 667,1.0000

Q

FDNS,OPT
1,1,1,,
0

rdch
1
0
0
72869,1,1310,

q

fdns,opt
1,1,1
0

APPENDIX B – STABILITY MODEL PARAMETERS

PSS/E Dynamic Data for Equivalent Gamesa 160 MW Generator

PLANT MODELS

REPORT FOR ALL MODELS BUS 95995 [CLR1_0220.6900] MODELS

```

** G8XDFG ** BUS X-- NAME --X BASEKV MC C O N S S T A T E S VAR ICON
95995 CLR1_022 0.6900 1 235057-235063 89108-89112 16289-16316 8107

Ra La Lm_D Lm_Y R1 L1
0.0102 0.1428 7.2114 6.9453 0.0101 0.1750

cosfi
1.0000
    
```

```

** G8XCNT for G8XDFG ** BUS X-- NAME --X BASEKV MC C O N S S T A T E S VAR ICON
95995 CLR1_022 0.6900 1 0-0 89118-89123 16345-16355 8109-8111
    
```

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E TUE, JUL 12 2005 12:00
 2004 SERIES, NERC/MMWG BASE CASE LIBRARY
 2009 SUMMER, FINAL; FOR DYN

CONEC MODELS

REPORT FOR ALL MODELS BUS 95995 [CLR1_0220.6900] MODELS

*** CALL GTWIND(8117,235078, 0, 16370) ***

```

** GTWIND ** BUS X-- NAME --X BASEKV MC C O N S V A R S ICONS
95995 CLR1_022.690 1 235078-235084 16370-16372 8117-8118

VWB T1G TG MAXG T1R T2R MAXR
17.00099999.000 5.000 30.00099999.00099999.000 30.000
    
```

Wind generator Bus # 95995
 Wind Generator ID 1

```

** G8XAER for DFIG ** BUS X-- NAME --X BASEKV MC C O N S STATE VAR ICON
95995 CLR1_022 0.6900 1 235091-235096 89131-89131 16377-16380 8122-8124

VWinit Lambda_Max Lambda_Min PITCH_MAX PITCH_MIN Ta
17.0000 19.5000 0.0000 50.0000 0.0000 0.5000
    
```

Wind Generator Bus # 95995
 Wind Generator ID 1

```

** G8XPTC for G8XDFG ** BUS X-- NAME --X BASEKV MC C O N S STATE VAR ICON
95995 CLR1_022 0.6900 1 0-0 89137-89141 16392-16402 8128-8130

Wind Generator Bus # 95995
Wind Generator ID 1
    
```

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E TUE, JUL 12 2005 12:00
 2004 SERIES, NERC/MMWG BASE CASE LIBRARY
 2009 SUMMER, FINAL; FOR DYN

CONET MODELS

REPORT FOR ALL MODELS BUS 95995 [CLR1_0220.6900] MODELS

*** CALL G_VTRP(8166,235125, 0, 16410) ***

```

BUS NAME BSKV GENR BUS NAME BSKV
95995 CLR1_022.690 95995 CLR1_022.690

I C O N S C O N S V A R
8166-8170 235125-235128 16410
    
```

VLO	VUP	PICKUP	TB
0.150	5.000	0.040	0.050

*** CALL G_VTRP(8171,235129, 0, 16411) ***

BUS	NAME	BSKV	GENR	BUS	NAME	BSKV
95995	CLR1_022.690		95995	CLR1_022.690		

I C O N S	C O N S	V A R
8171-8175	235129-235132	16411

VLO	VUP	PICKUP	TB
0.300	5.000	0.625	0.050

*** CALL G_VTRP(8176,235133, 0, 16412) ***

BUS	NAME	BSKV	GENR	BUS	NAME	BSKV
95995	CLR1_022.690		95995	CLR1_022.690		

I C O N S	C O N S	V A R
8176-8180	235133-235136	16412

VLO	VUP	PICKUP	TB
0.450	5.000	1.100	0.050

*** CALL G_VTRP(8181,235137, 0, 16413) ***

BUS	NAME	BSKV	GENR	BUS	NAME	BSKV
95995	CLR1_022.690		95995	CLR1_022.690		

I C O N S	C O N S	V A R
8181-8185	235137-235140	16413

VLO	VUP	PICKUP	TB
0.600	5.000	1.575	0.050

*** CALL G_VTRP(8186,235141, 0, 16414) ***

BUS	NAME	BSKV	GENR	BUS	NAME	BSKV
95995	CLR1_022.690		95995	CLR1_022.690		

I C O N S	C O N S	V A R
8186-8190	235141-235144	16414

VLO	VUP	PICKUP	TB
0.750	5.000	2.050	0.050

*** CALL G_VTRP(8191,235145, 0, 16415) ***

BUS	NAME	BSKV	GENR	BUS	NAME	BSKV
95995	CLR1_022.690		95995	CLR1_022.690		

I C O N S	C O N S	V A R
8191-8195	235145-235148	16415

VLO	VUP	PICKUP	TB
0.900	5.000	2.550	0.050

*** CALL G_VTRP(8196,235149, 0, 16416) ***

BUS	NAME	BSKV	GENR	BUS	NAME	BSKV
95995	CLR1_022.690		95995	CLR1_022.690		

I C O N S	C O N S	V A R
8196-8200	235149-235152	16416

VLO	VUP	PICKUP	TB
0.000	1.100	0.060	0.050

*** CALL G_FRTP(8207,235157, 0, 16418) ***

BUS	NAME	BSKV	GEN	BUS	NAME	BSKV	ID
95995	CLR1_022	.690	95995	CLR1_022	.690		1

```

I C O N S      C O N S      V A R
8207-8212     235157-235160  16418

      FLO      FUP      PICKUP      TB
      57.000   62.000   0.000      0.050

```

PSS/E Dynamic Data for Equivalent Gamesa 80 MW Generator

PLANT MODELS

REPORT FOR ALL MODELS BUS 95996 [CLR2_0220.6900] MODELS

```

** G8XDFG ** BUS X-- NAME --X BASEKV MC      C O N S      S T A T E S      VAR      ICON
      95996      CLR2_022 0.6900 1  235064-235070  89113-89117  16317-16344  8108

      Ra      La      Lm_D      Lm_Y      Rl      Ll
      0.0102   0.1428   7.2114   6.9453   0.0101   0.1750

      cosfi
      1.0000

** G8XCNT for G8XDFG ** BUS X-- NAME --X BASEKV MC      C O N S      S T A T E S      VAR      ICON
      95996      CLR2_022 0.6900 1  0-0      89124-89129  16356-16366  8112-8114

```

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E TUE, JUL 12 2005 12:01
 2004 SERIES, NERC/MMWG BASE CASE LIBRARY
 2009 SUMMER, FINAL; FOR DYN

CONEC MODELS

REPORT FOR ALL MODELS BUS 95996 [CLR2_0220.6900] MODELS

*** CALL GTWIND(8115,235071, 0, 16367) ***

```

** GTWIND ** BUS X-- NAME --X BASEKV MC      C O N S      V A R S      ICONS
      95996 CLR2_022.690      1  235071-235077  16367-16369  8115-8116

      VWB      TlG      TG      MAXG      TlR      T2R      MAXR
      17.0009999.000  5.000  30.0009999.0009999.000  30.000

      Wind generator Bus # 95996
      Wind Generator ID 1

```

```

** G8XAER for DFIG ** BUS X-- NAME --X BASEKV MC      C O N S      STATE      VAR      ICON
      95996      CLR2_022 0.6900 1  235085-235090  89130-89130  16373-16376  8119-8121

      Vwinit      Lambda_Max      Lambda_Min      PITCH_MAX      PITCH_MIN      Ta
      17.0000      19.5000      0.0000      50.0000      0.0000      0.5000

      Wind Generator Bus # 95996
      Wind Generator ID 1

```

```

** G8XPTC for G8XDFG ** BUS X-- NAME --X BASEKV MC      C O N S      STATE      VAR      ICON
      95996      CLR2_022 0.6900 1  0-0      89132-89136  16381-16391  8125-8127

      Wind Generator Bus # 95996
      Wind Generator ID 1

```

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E TUE, JUL 12 2005 12:01
 2004 SERIES, NERC/MMWG BASE CASE LIBRARY
 2009 SUMMER, FINAL; FOR DYN

CONET MODELS

REPORT FOR ALL MODELS BUS 95996 [CLR2_0220.6900] MODELS

*** CALL G_VTRP(8131,235097, 0, 16403) ***


```

BUS  NAME  BSKV      GENR BUS  NAME  BSKV
95996 CLR2_022.690      95996 CLR2_022.690

      I C O N S      C O N S      V A R
      8131-8135      235097-235100      16403

      VLO      VUP      PICKUP      TB
      0.150      5.000      0.040      0.050

*** CALL G_VTRP( 8136,235101,      0, 16404) ***

BUS  NAME  BSKV      GENR BUS  NAME  BSKV
95996 CLR2_022.690      95996 CLR2_022.690

      I C O N S      C O N S      V A R
      8136-8140      235101-235104      16404

      VLO      VUP      PICKUP      TB
      0.300      5.000      0.625      0.050

*** CALL G_VTRP( 8141,235105,      0, 16405) ***

BUS  NAME  BSKV      GENR BUS  NAME  BSKV
95996 CLR2_022.690      95996 CLR2_022.690

      I C O N S      C O N S      V A R
      8141-8145      235105-235108      16405

      VLO      VUP      PICKUP      TB
      0.450      5.000      1.100      0.050

*** CALL G_VTRP( 8146,235109,      0, 16406) ***

BUS  NAME  BSKV      GENR BUS  NAME  BSKV
95996 CLR2_022.690      95996 CLR2_022.690

      I C O N S      C O N S      V A R
      8146-8150      235109-235112      16406

      VLO      VUP      PICKUP      TB
      0.600      5.000      1.575      0.050

*** CALL G_VTRP( 8151,235113,      0, 16407) ***

BUS  NAME  BSKV      GENR BUS  NAME  BSKV
95996 CLR2_022.690      95996 CLR2_022.690

      I C O N S      C O N S      V A R
      8151-8155      235113-235116      16407

      VLO      VUP      PICKUP      TB
      0.750      5.000      2.050      0.050

*** CALL G_VTRP( 8156,235117,      0, 16408) ***

BUS  NAME  BSKV      GENR BUS  NAME  BSKV
95996 CLR2_022.690      95996 CLR2_022.690

      I C O N S      C O N S      V A R
      8156-8160      235117-235120      16408

      VLO      VUP      PICKUP      TB
      0.900      5.000      2.550      0.050

*** CALL G_VTRP( 8161,235121,      0, 16409) ***

BUS  NAME  BSKV      GENR BUS  NAME  BSKV
95996 CLR2_022.690      95996 CLR2_022.690

      I C O N S      C O N S      V A R
      8161-8165      235121-235124      16409

      VLO      VUP      PICKUP      TB
      0.000      1.100      0.060      0.050

```

```

*** CALL G_FRTP( 8201,235153,    0, 16417) ***

  BUS   NAME   BSKV   GEN BUS   NAME   BSKV   ID
95996  CLR2_022 .690    95996  CLR2_022 .690    1

      I C O N S       C O N S       V A R
      8201-8206     235153-235156  16417

      FLO      FUP      PICKUP      TB
      57.000   62.000   0.000      0.050

```

PSS/E Dynamic Data for Equivalent Bonus 160 MW Generator

PLANT MODELS

REPORT FOR ALL MODELS BUS 95995 [CLR1_0220.6900] MODELS

```

** S2M301 ** BUS MACH   C O N S   S T A T E S   V A R S   I C O N S
          95995  1   *****
          Mbase  Rsource  Xsource  |Vterm|  P_lf    Q_lf
          161.000 0.000000 0.200000 1.038521 0.999995 0.196274

```

PSS/E Dynamic Data for Equivalent Bonus 80 MW Generator

PLANT MODELS

REPORT FOR ALL MODELS BUS 95996 [CLR2_0220.6900] MODELS

```

** S2M301 ** BUS MACH   C O N S   S T A T E S   V A R S   I C O N S
          95996  1   *****
          Mbase  Rsource  Xsource  |Vterm|  P_lf    Q_lf
          80.500 0.000000 0.200000 1.038502 0.999995 0.224348

```

PSS/E Dynamic Data for For Both Bonus Generators

TNEI Services Ltd

SMK202 V1.1

GNB 01/09/05

Jdn 12/09/ Integral gain for voltage controller reduced by factor 7/50

Linked spreadsheet usage: Only enter values in the yellow highlighted boxes

Base and Loadflow Information			
Prated	2.30	Machine Active Power Rating (MW)	MBASE
Vrated	0.69	Stator Voltage Rating (kV)	
Busbar	90200	Connection busbar number	
Gen ID	1	Generator Identifier	
Rg	0	Generator Resistance in Loadflow (pu)	RSORCE
Xg	0.2000	Generator Reactance in Loadflow (pu)	XSORCE
Srated	2.6	Unit Transformer Rating (MVA)	Note 1
Rt	0.0082	Unit Transformer Resistance (pu)	Note 1
Xt	0.0580	Unit Transformer Reactance (pu)	Note 1

ICONS	Value	Description	Ref:
M	1	Model Version Number	
M+1	1	Reactive control mode (0=fixed, 1=voltage, 2 & 3 not in use)	
M+2	1	Enable Under-voltage relay 1	
M+3	1	Enable Under-voltage relay 2	
M+4	1	Enable Under-voltage relay 3	
M+5	1	Enable Over-voltage relay 1	
M+6	1	Enable Over-voltage relay 2	
M+7	1	Enable Under-frequency relay 1	
M+8	1	Enable Under-frequency relay 2	
M+9	1	Enable Over-frequency relay 1	

CONs	Value	Description	Ref:
J	18.0251		
J+1	1.0927	Generator Inertia Constant (MW.s/MVA)	
J+2	14.3349	Rotor Inertia Constant (MW.s/MVA)	
J+3	0.1458	Shaft Damping	
J+4	138.49	Shaft Stiffness	
J+5	1.3169		
J+6	1.1109		
J+7	22		
J+8	100000		
J+9	1078		
J+10	100000		
J+11	2.00		
J+12	0.10	Voltage dip threshold for FRT activation (pu)	
J+13	0.050	FRT reset time delay (s)	
J+14	1.0455		
J+15	1.00		
J+16	3.9782		
J+17	99.4544		
J+18	0.487		dKpVcon
J+19	136.5		dKiVcon
J+20	0.060		
J+21	1.60		
J+22	0.70		
J+23	1.20		
J+24	0.70		
J+25	1.89		
J+26	2.00		
J+27	0.82		

J+28	0.50	
J+29	0.40	
J+30	4.00	
J+31	1.23	Air density
J+32	15.00	User defined wind speed for rated power operation (m/s)
J+33	1.00	
J+34	0.1768	
J+35	0.6464	
J+36	1.0069	
J+37	13.05	
J+38	-94.25	
J+39	-52.36	
J+40	0.15	
J+41	7.0	
J+42	-8.0	
J+43	45.0	Maximum pitch angle
J+44	-1.0	Minimum pitch angle
J+45	2.0	
J+46	0.9655	
J+47	-4.73	
J+48	-0.68	
J+49	0.22	
J+50	-0.22	
J+51	1.00	
J+52	1.17	
J+53	0.90	Under Voltage Relay 1 - Voltage Setting (pu)
J+54	5.000	Under Voltage Relay 1 - Time Setting (s)
J+55	0.100	Under Voltage Relay 1 - Relay activation time (s)
J+56	0.70	Under Voltage Relay 2 - Voltage Setting (pu)
J+57	1.000	Under Voltage Relay 2 - Time Setting (s)
J+58	0.100	Under Voltage Relay 2 - Relay activation time (s)
J+59	0.15	Under Voltage Relay 3 - Voltage Setting (pu)
J+60	0.150	Under Voltage Relay 3 - Time Setting (s)
J+61	0.100	Under Voltage Relay 3 - Relay activation time (s)
J+62	1.10	Over Voltage Relay 1 - Voltage Setting (pu)
J+63	1.000	Over Voltage Relay 1 - Time Setting (s)
J+64	0.000	Over Voltage Relay 1 - Relay activation time (s)
J+65	1.20	Over Voltage Relay 2 - Voltage Setting (pu)
J+66	0.200	Over Voltage Relay 2 - Time Setting (s)
J+67	0.000	Over Voltage Relay 2 - Relay activation time (s)
J+68	0.98	Under Frequency Relay 1 - Frequency Setting (pu)
J+69	10.000	Under Frequency Relay 1 - Time Setting (s)
J+70	0.000	Under Frequency Relay 1 - Relay activation time (s)
J+71	0.97	Under Frequency Relay 2 - Frequency Setting (pu)
J+72	0.100	Under Frequency Relay 2 - Time Setting (s)
J+73	0.000	Under Frequency Relay 2 - Relay activation time (s)
J+74	1.08	Over Frequency Relay 1 - Frequency Setting (pu)
J+75	0.100	Over Frequency Relay 1 - Time Setting (s)
J+76	0.000	Over Frequency Relay 1 - Relay activation time (s)
J+77	0.15	Retained voltage threshold for Island Detection (pu)

DYRE Data (auto-generated from datasheet information. Copy/paste into DYRE file.)

```

/ SMK202 V1.1, 2.3 MW Turbine Data
90200 'USRMDL' 1 'SMK202' 1 1 10 78 18 53
1 1 1 1 1 1 1 1 1 18.0251 1.0927 14.3349 0.1458 138.49 1.3169 1.1109 22 100000 1078 100000
2.00 0.10 0.050 1.0455 1.00 3.9782 99.4544 0.487 136.5 0.060 1.60 0.70 1.20 0.70 1.89 2.00 0.82 0.50
0.40 4.00 1.23 15.00 1.00 0.1768 0.6464 1.0069 13.05 -94.25 -52.36 0.15 7.0 -8.0 45.0 -1.0 2.0 0.9655 -4.73 -0.68
0.22 -0.22 1.00 1.17 0.90 5.000 0.100 0.70 1.000 0.100 0.15 0.150 0.100 1.10 1.000 0.000 1.20 0.200 0.000
0.98 10.000 0.000 0.97 0.100 0.000 1.08 0.100 0.000 0.15 /

```

APPENDIX C – STABILITY PLOTS

AVAILABLE ON REQUEST