



***Impact Study for Generation
Interconnection Request
GEN-2003-020***

Restudy

SPP Tariff Studies

(#GEN-2003-020)

January 2009

Summary

ABB Inc. Electric Systems consulting (ABB) performed the attached Study at the request of the Southwest Power Pool (SPP) for Generation Interconnection request GEN-2003-020. The request for interconnection was placed with SPP in accordance with SPP's Open Access Transmission Tariff which covers new generation interconnections on SPP's transmission system.

GEN-2003-020 is a 160 MW wind farm that is proposed to be interconnected to a new 115kV ring bus substation to be built near the existing Carson County substation. Originally this request consisted of using GE 1.5 MW turbines, and an impact study has been completed using GE 1.5 turbines. Phase I of the GEN-2003-020 wind farm is currently under construction using GE turbines. However, the Customer has requested that Phase II consist of wind turbines other than GE. This request, and the subject of this report, is the system impact study in which Mitsubishi 2.4 MW turbines are used to generate 80MW of the 160 MW requested in GEN-2003-020.

The results of the stability analysis indicated that interconnecting the proposed wind farm, GEN-2003-020, utilizing 80 MW generated by Mitsubishi 2.4 MW turbines and 80 MW generated by GE 1.5 MW turbines will not adversely affect the stability of the system.

If the Customer wishes to construct Phase II of the wind farm with Mitsubishi WTG, a revised IA will need to be executed. The revised IA will include changes identified in this Study:

- Use Mitsubishi WTG MHI95 (2.4 MW) to produce 80 MW out of the 160 MW total (the other 80 MW to be produced by GE 1.5 MW WTG).
- Due to the reactive capabilities of the Mitsubishi WTG, no additional reactive power support is required at the windfarm.

Using Mitsubishi MHI95 2.4 MW turbines the Customer wind farm will comply with FERC Order #661A, Low Voltage Ride Through (LVRT) Requirements.

Frequency Trip Settings – The documentation submitted by the Customer indicated that the Mitsubishi wind turbines will trip at 59 Hz. This trip setting will not meet SPP underfrequency load shed plan requirements. SPP requires that all generators on the transmission system be able to withstand frequency excursions down to 58.5 Hz. Discussions with the Customer, who contacted Mitsubishi, indicated that the Mitsubishi wind turbines frequency trip settings can be modified to meet SPP underfrequency load shed plan requirements. This requirement will be denoted in the modified LGIA.



**POWER SYSTEMS DIVISION
GRID SYSTEMS - CONSULTING**

**Southwest Power Pool
System Impact Study of GEN-2003-020 Generation
Interconnection (Mitsubishi WTG MHI95)**

FINAL REPORT

REPORT NO.: 2008-E750-0050-1-R0
Issued On: November 4, 2008
Revised on: November 7, 2008
Revised On: November 24, 2008

**ABB Inc.
Power Systems Division
Grid Systems - Consulting
940 Main Campus Drive, Suite 300
Raleigh, NC 27606**

Legal Notice

This document, prepared by ABB Inc., is an account of work sponsored by Southwest Power Pool. Neither Southwest Power Pool nor ABB Inc, nor any person or persons acting on behalf of either party: (i) makes any warranty or representation, expressed or implied, with respect to the use of any information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights, or (ii) assumes any liabilities with respect to the use of or for damages resulting from the use of any information, apparatus, method, or process disclosed in this document.

Southwest Power Pool	No. 2008-E750-0050-1-R0	
System Impact Study of GEN-2003-020 Generation Interconnection (Mitsubishi WTG MHI95)	Date : November 4, 2008	# Pages 22

Author(s):
Chong Han

Reviewed by:
Amit Kekare

Approved by:
Willie Wong

Executive Summary

The main objective of this study is to assess the impact on local stability of interconnecting the proposed GEN-2003-020 wind farm located in Carson County, Texas. This proposed wind farm (GEN-2003-020) would be interconnected to the existing Carson county substation (Xcel Energy). System impact study for this wind farm was previously performed by ABB by using GE 1.5 MW and Mitsubishi 1.0MW wind turbines (Report: ‘2004-10963-R1’, ‘2006-11209-2R1.0’, and ‘2006-11266-R1’). While the phase-I of this wind farm (80 MW) has been installed with GE 1.5 MW wind turbines, the developer requested Phase-II (80 MW) in the wind farm to be studied with the Mitsubishi 2.4 MW wind turbines. Hence, the system impact study of 80 MW of GEN-2003-020 (Phase-II) wind farm with Mitsubishi 2.4 MW wind turbine is the subject of this report.

A comprehensive range of faults defined by SPP has been run in the study. Overall, the post-fault recoveries show stable system performance for GEN-2003-020 with Mitsubishi 2.4 MW wind turbine generators in 80 MW size. The voltage and power factor at the POI were acceptable in both pre-contingency and post-fault transient period. Hence, there was no need of additional reactive power support for the proposed windfarm.

The results of stability analysis indicated that interconnecting the proposed wind farm, GEN-2003-020, at a level of additional 80 MW with Mitsubishi 2.4 MW WTGs will not adversely affect the stability of the system.

FERC Order 661A Compliance – The Low Voltage Ride through (LVRT) capability was verified for compliance with Federal Energy Regulatory Commission’s (FERC) standard for Interconnection of Wind generating plants: ‘Low Voltage Ride-Through (LVRT) requirement. The proposed project (GEN-2003-020, 80 MW with Mitsubishi 2.4 MW WTGs) complies with the latest FERC order on low voltage ride through for wind farms. With this arrangement, the proposed wind farm would not trip off line by voltage relay actuation for local faults near the POI.

A full description of the study, and results, are given in this report.

The results of this study are based on available data and assumptions made at the time this study was conducted. The results included in this report may not apply if any of the data and/or assumptions made in developing the study models change.

Rev No.	Revision Description	Date	Authored by	Reviewed by	Approved by
0	Draft Report	11/4/08	Chong Han	A. Kekare	W. Wong
1	Updated per SPP’s comments	11/7/2008	Chong Han	A. Kekare	W. Wong
2	Final Report	11/24/08	Chong Han	A. Kekare	W. Wong

DISTRIBUTION:

Charles Hendrix, Southwest Power Pool (SPP)

THIS PAGE WAS INTENTIONALLY LEFT BLANK

Table of Contents

TABLE OF CONTENTS	3
1 INTRODUCTION	4
2 BASE CASE DEVELOPMENT	5
3 FAULT CASES	11
4 STUDY RESULTS	12
5 CONCLUSIONS	14
APPENDIX A – LOAD FLOW DATA FOR GEN-2003-020.....	15
APPENDIX B – STABILITY DATA FOR GEN-2003-020.....	16
APPENDIX C – PLOTS FOR STABILITY SIMULATIONS WITH GEN-2003-20.....	20

1 Introduction

Southwest Power Pool (SPP) commissioned ABB Inc., to perform the Impact Study for a Generation Interconnection request – wind farm GEN-2003-020 (80MW) besides the original 80 MW (Phase-I) with GE 1.5 MW wind turbines. The main objective of this study was to assess the impact of interconnecting the proposed 80 MW Phase-II of GEN-2003-020 with Mitsubishi 2.4 MW wind turbines on the stability of the system. The proposed wind farm would be interconnected at the Carson county substation (SPS d/b/a/ Xcel Energy). The System Impact Study for this wind farm was previously performed by ABB by using 1.5 MW GE-DFIG and 1.0 MW Mitsubishi wind turbine generators (See Report: ‘2004-10963-R1’, ‘2006-11209-2R1.0’, and ‘2006-11266-R1’). While the phase-I of this wind farm (80 MW) has been installed with GE 1.5 MW wind turbines, the developer requested Phase-II (80 MW) in the wind farm to be studied with the Mitsubishi 2.4 MW wind turbines. Hence, the system impact study of 80 MW of GEN-2003-020 (Phase-II) wind farm with Mitsubishi 2.4 MW wind turbine is the subject of this report.

The faults simulated for the stability analysis were those defined in the SPP document "*Scope of Interconnection Impact Study for GEN-2003-020*".

Section 2 describes the efforts of base case development.

Section 3 describes the faults simulated.

Section 4 describes the simulation of all fault cases.

Section 5 describes the conclusions of the study.

2 Base Case Development

SPP provided two (Summer Peak 2008 and Winter Peak 2008) load flow cases (file names: 'gen-2003-020_sp.sav' and 'gen-2003-020_wp.sav'). The proposed wind farm (GEN-2003-020) was added to the base cases. The plant was re-dispatched against the generation as per the information provided by SPP. Figure 2-2 to Figure 2-5 show one line diagram for the local area with and without proposed GEN-2003-020 project.

GEN-2003-020 Windfarm modeling

The proposed 80 MW windfarm was modeled as a single equivalent generator representing thirty-three (33) wind turbine generators. The single equivalent wind turbine generator was connected to the 34.5 kV collector bus via a 0.69/34.5 kV equivalent generator step-up transformer (GSU). The collector bus system was modeled representing equivalent collector bus system impedance. The 34.5 kV collector bus was connected to the 115 kV Point of Interconnection (POI) through a 34.5/115 kV step-up transformer. Figure 2-1 shows the one-line diagram for the GEN-2003-020 windfarm. As per the modeling guidelines for Mitsubishi 2.4 MW¹ the reactive power capacity of the wind turbine generator was set to -0.90/+0.95 p.f. Also, a permanently connected shunt capacitor of 3.63 Mvar (=0.11 Mvar for each WTG X 33 WTGs) was modeled. The voltage and power factor at the POI were acceptable and there was no need for additional reactive power compensation. The power flow model representation is included in Appendix A.




Figure 2-1: One-line diagram for GEN-2003-020 windfarm (Mitsubishi 2.4 MW WTGs)

¹ 'Rpt102-07_MWT9295_PSSEmodelUpgrade_rev3', October 15, 2007

Dynamic Data

Snapshot files corresponding to the Summer Peak 2008 and Winter Peak 2009 load flow cases were provided by SPP for the study.

The Mitsubishi dynamic data for the proposed GEN-2003-020 plant is added to create the snapshot for GEN-2003-020 case. The stability model parameters were based on default data provided with the Mitsubishi Wind model. The wind model included several sub-models representing doubly-fed induction generator, electrical control, turbine control, aerodynamic conversion, pitch control, wind disturbance etc. The under/over voltage and frequency protection was modeled per the manufacturer's default settings. The stability model representation is included in Appendix B.




Figure 2-2: One-line diagram without Mitsubishi 2.4 MW WTGs (80 MW) - 2008
 Summer Peak




Figure 2-3: One-line diagram with Mitsubishi 2.4 MW WTGs (80 MW) - 2008
 Summer Peak




Figure 2-4: One-line diagram without Mitsubishi 2.4 MW WTGs (80 MW) - 2008 Winter Peak




Figure 2-5: One-line diagram with Mitsubishi 2.4 MW WTGs (80 MW) - 2008 Winter Peak

3 Fault Cases

The fault scenarios considered for the local stability assessment are listed in Table 3-1. The sequence impedance used to model the SLG faults were estimated by ABB.

Table 3-1: List of Disturbances simulated for Local Stability Analysis

FAULT	FAULT DESCRIPTION
FLT_1_3PH	3 Phase Fault on the Nichols (524044) to Grapevine (523771), 230kV line near Grapevine After 5cy, Trip the Nichols (52404)-Grapevine (523771) 230kV line After 20cy, and then re-close the Nichols-Grapevine 230kV line into the fault After 5cy, trip the Nichols-Grapevine 230kV line and remove fault
FLT_2_1PH	SLG fault same as FLT_1_3PH
FLT_3_3PH	3 Phase Fault at Elk City 230kV bus (511490) After 5cy, trip Grapevine (523771) -Elk City (511490) 230kV line After 20cy, and then re-close the Elk City-Grapevine 230kV line into the fault After 5cy, trip the Elk City-Grapevine 230kV line and remove fault
FLT_4_1PH	SLG fault same as FLT_3_3PH
FLT_5_3PH	3 Phase Fault at Kirby bus 115kV (524088) After 5cy, trip the following lines Kirby (524088)-Conway (524079) Conway (524079)-Yarnell (524072) Yarnell (524072)-Nichols (524043) After 20cy, reclose the Kirby-Conway-Yarnell-Nichols lines into the fault After 5cy, trip Kirby-Conway-Yarnell-Nichols lines and clear the fault
FLT_6_1PH	SLG fault same as FLT_5_3PH
FLT_7_3PH	3Phase Fault at Hutchinson Co. Interchange (523546) After 5cy, trip Hutchinson Co. Interchange (523546)-Riverview Interchange (523377) 115kV After 20cy, reclose Hutchinson Co. Interchange-Riverview Interchange 115kV into the fault After 5cy, trip Hutchinson Co. Interchange-Riverview Interchange 115kV and clear the fault
FLT_8_1PH	SLG fault same as FLT_7_3PH
FLT_9_3PH	3 Phase fault at Carson Bus (523924) After 5cy, trip Hutchinson Co. Interchange (523546)-Carson (523924) 115kV line After 20cy, reclose the Hutchinson Co. Interchange-Carson 115kV line After 5cy, trip the Hutchinson Co. Interchange-Carson 115kV line and clear the fault
FLT_10_1PH	SLG fault same as FLT_9_3PH
FLT_11_3PH	3 Phase fault at Carson Bus (523924) After 5cy, trip Carson (523924)- Pantex N (523938) 115kV line After 20cy, reclose the Carson-Pantex N 115kV line into the fault After 5cy, trip the Carson-Pantex N 115kV line and clear the fault
FLT_12_1PH	SLG fault same as FLT_11_3PH
FLT_13_3PH	3 Phase fault at HighLt3 (523931) After 5cy, Trip HighLt3 (523931)-Pantex S (523945) 115kV line After 20cy, reclose the HighLt3-Pantex S 115kV line into the fault After 5cy, trip the HighLt3-Pantex S 115kV line and clear the fault
FLT_14_1PH	SLG fault same as FLT_13_3PH
FLT_15_3PH	3 Phase fault at Nichols (524044) After 5 cy, trip Nichols (524044)-Harrington (523977) 230kV line After 20cy, reclose the Nichols-Harrington 230kV line into the fault After 5cy, trip the Nichols-Harrington 230kV line and clear the fault
FLT_16_1PH	SLG fault same as FLT_15_3PH

4 Study Results

The results for local stability simulations for Summer Peak 2008 and Winter Peak 2008 are summarized in Table 4-1 and Table 4-2.

All faults were run for 10 seconds.

The detailed simulation plots for all the faults are included in Appendix C.

No stability criteria violations were observed following all the simulated faults. The proposed wind farm remains on-line for all the simulated faults.

A local area wind farm (240 MW) connected to Conway 115 kV bus was tripped following two faults (FLT_5_3PH, and FLT_6_3PH). These two faults involve loss of Kirby – Conway – Yarnell – Nichols 115 kV line, islanding the windfarm. As the windfarm is an induction generator, it can not operate in the island mode. The prior-queued windfarm connected to Conway 115 kV was tripped following the two faults in both cases, with and without proposed wind farm.

Table 4-1: Results for Stability Analysis GEN-2003-020 (Summer Peak 2008)

FAULT	WITHOUT GEN-2003-020	WITH GEN-2003-020
FLT_1_3PH	Not Tested	Stable
FLT_2_1PH	Not Tested	Stable
FLT_3_3PH	Not Tested	Stable
FLT_4_1PH	Not Tested	Stable
FLT_5_3PH	Stable **	Stable **
FLT_6_1PH	Stable **	Stable **
FLT_7_3PH	Not Tested	Stable
FLT_8_1PH	Not Tested	Stable
FLT_9_3PH	Not Tested	Stable
FLT_10_1PH	Not Tested	Stable
FLT_11_3PH	Not Tested	Stable
FLT_12_1PH	Not Tested	Stable
FLT_13_3PH	Not Tested	Stable
FLT_14_1PH	Not Tested	Stable
FLT_15_3PH	Not Tested	Stable
FLT_16_1PH	Not Tested	Stable

Note: - **The 240 MW windfarm (#90090) connected to Conway 115 kV (524079) tripped. The fault involves loss of Kirby-Conway-Yarnell-Nichols 115 kV islanding the windfarm.

Table 4-2: Results for Stability Analysis GEN-2003-020 (Winter Peak 2008)

FAULT	WITHOUT GEN-2003-020	WITH GEN-2003-020
FLT_1_3PH	Not Tested	Stable
FLT_2_1PH	Not Tested	Stable
FLT_3_3PH	Not Tested	Stable
FLT_4_1PH	Not Tested	Stable
FLT_5_3PH	Not Tested	Stable **
FLT_6_1PH	Not Tested	Stable **
FLT_7_3PH	Not Tested	Stable
FLT_8_1PH	Not Tested	Stable
FLT_9_3PH	Not Tested	Stable
FLT_10_1PH	Not Tested	Stable
FLT_11_3PH	Not Tested	Stable
FLT_12_1PH	Not Tested	Stable
FLT_13_3PH	Not Tested	Stable
FLT_14_1PH	Not Tested	Stable
FLT_15_3PH	Not Tested	Stable
FLT_16_1PH	Not Tested	Stable

Note: - **The 250 MW windfarm (#90090) connected to Conway 115 kV (524079) tripped. The fault involves loss of Kirby-Conway-Yarnell-Nichols 115 kV islanding the windfarm.

5 Conclusions

A comprehensive range of fault cases has been simulated for stability analysis. Overall, the post-fault recoveries show stable system performance for GEN-2003-020 with Mitsubishi 2.4 MW wind turbine generators in 80 MW size. The voltage and power factor at the POI were acceptable in both pre-contingency and post-fault transient period. Hence, there was no need of additional reactive power support for the proposed windfarm.

The results of stability analysis indicated that interconnecting the proposed wind farm, GEN-2003-020, at a level of additional 80 MW with Mitsubishi 2.4 MW WTGs will not adversely affect the stability of the system.

FERC Order 661A Compliance – The Low Voltage Ride through (LVRT) capability was verified for compliance with Federal Energy Regulatory Commission's (FERC) standard for Interconnection of Wind generating plants: 'Low Voltage Ride-Through (LVRT) requirement. The proposed project (GEN-2003-020, 80 MW with Mitsubishi 2.4 MW WTGs) complies with the latest FERC order on low voltage ride through for wind farms. With this arrangement, the proposed wind farm would not trip off line by voltage relay actuation for local faults near the POI.

The results of this study are based on available data and assumptions made at the time this study was conducted. The results included in this report may not apply if any of the data and/or assumptions made in developing the study models change.

APPENDIX A – Load Flow Data for GEN-2003-020

```
0, 100.00 / PSS/E-30.2 FRI, OCT 31 2008 14:40
SPP MDWG 2007 STABILITY BASE CASE: STAB2-08W-30-RED 4-12-07
2008 SUMMER PEAK: GEN-2003-020 INTERCONNECTION STUDY
 9995,'GEN20_S3 ', 34.5000,1, 0.000, 0.000, 526,1403,1.05000, 15.4666, 1
99950,'GEN20_S1 ', 34.5000,1, 0.000, 0.000, 526,1403,1.03993, 14.9233, 1
99995,'G03-20-S ', 0.6900,2, 0.000, 0.000, 526,1403,1.05436, 19.1494, 1
0 / END OF BUS DATA, BEGIN LOAD DATA
0 / END OF LOAD DATA, BEGIN GENERATOR DATA
99995,'1 ', 79.200, 3.633, 26.070, -38.280,1.05000, 9995, 83.160,
0.00000,9999.00000, 0.00000, 0.00000,1.00000,1, 100.0, 79.200, 0.000, 1,1.0000
0 / END OF GENERATOR DATA, BEGIN BRANCH DATA
9995, 99950,'1 ', 0.01250, 0.01390, 0.04860, 0.00, 0.00, 0.00, 0.00000,
0.00000, 0.00000, 0.00000,1, 0.00, 1,1.0000
0 / END OF BRANCH DATA, BEGIN TRANSFORMER DATA
9995, 99995, 0,'1 ',1,2,1, 0.00000, 0.00000,2,' ',1, 1,1.0000
0.00000, 0.08000, 89.10
1.00000, 0.000, 0.000, 89.10, 89.10, 89.10, 0, 0, 1.05000, 0.95000, 1.05000,
0.95000, 5, 0, 0.00000, 0.00000
1.00000, 0.000
90008, 99950, 0,'1 ',1,2,1, 0.00000, 0.00000,2,' ',1, 1,1.0000
0.00000, 0.10000, 70.00
1.01560, 0.000, 0.000, 90.00, 90.00, 90.00, 0, 0, 1.05000, 0.95000, 1.05000,
0.95000, 5, 0, 0.00000, 0.00000
1.00000, 0.000
0 / END OF TRANSFORMER DATA, BEGIN AREA DATA
526,525561, -66.000, 1.000,'SPS '
0 / END OF AREA DATA, BEGIN TWO-TERMINAL DC DATA
0 / END OF TWO-TERMINAL DC DATA, BEGIN VSC DC LINE DATA
0 / END OF VSC DC LINE DATA, BEGIN SWITCHED SHUNT DATA
99995,0,1.00000,1.00000, 0, 100.0,' ', 3.63, 1, 3.63
0 / END OF SWITCHED SHUNT DATA, BEGIN IMPEDANCE CORRECTION DATA
0 / END OF IMPEDANCE CORRECTION DATA, BEGIN MULTI-TERMINAL DC DATA
0 / END OF MULTI-TERMINAL DC DATA, BEGIN MULTI-SECTION LINE DATA
0 / END OF MULTI-SECTION LINE DATA, BEGIN ZONE DATA
1403,'SPS-AMA '
0 / END OF ZONE DATA, BEGIN INTER-AREA TRANSFER DATA
0 / END OF INTER-AREA TRANSFER DATA, BEGIN OWNER DATA
1,'CENT HUD '
0 / END OF OWNER DATA, BEGIN FACTS DEVICE DATA
0 / END OF FACTS DEVICE DATA
```

APPENDIX B – Stability Data for GEN-2003-020

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E FRI, OCT 31 2008 14:47
 SPP MDWG 2007 STABILITY BASE CASE: STAB2-08W-30-RED 4-12-07
 2008 SUMMER PEAK: GEN-2003-020 INTERCONNECTION STUDY

PLANT MODELS

REPORT FOR ALL MODELS BUS 99995 [G03-20-S 0.6900] MODELS

** M9295G ** BUS X-- NAME --X BASEKV MC C O N S S T A T E S VAR ICON
 99995 G03-20-S 0.6900 1 111171-111174 41918-41921 12052-12055 8289-8291

Kp11 Kipl1 PLLMX Tconv
 30.0000 0.0000 0.1000 0.0750

Type of the wind turbine: MWT 95
 number of lumped original machines: 42

** M9295E ** BUS X-- NAME --X BASEKV MC C O N S S T A T E S VAR ICON
 99995 G03-20-S 0.6900 1 111175-111192 41922-41923 12056-12059 8292-8293

Wmin Wmax Kopt PRTLIM KPP KIP
 -0.3210 0.1333 0.3006 1.0416 5.8830 1.2265

PFDEM LIM_I PitchMin V_UP V_LOW
 0.0000 1.0000 21.0000 1.1000 0.9000

V_CROW T_VT K_Q SN TNDH_OFF
 0.1000 0.0050 2.0000 0.1300 3.0000

TNDH_CROW TCROW_OFF
 0.2000 0.2000

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E FRI, OCT 31 2008 14:47
 SPP MDWG 2007 STABILITY BASE CASE: STAB2-08W-30-RED 4-12-07
 2008 SUMMER PEAK: GEN-2003-020 INTERCONNECTION STUDY

CONEC MODELS

REPORT FOR ALL MODELS BUS 99995 [G03-20-S 0.6900] MODELS

** M9295W ** BUS X-- NAME --X BASEKV MC C O N S V A R S ICONS
 99995 G03-20-S 0.6900 1 111193-111199 12060-12063 8294-8295

VWMAX T1G TG MAXG T1R T2R MAXR
 25.000 9999.000 3.000 3.000 9999.000 3.000 3.000

Wind generator Bus # 99995

Wind Generator ID 1

** M9295T ** BUS X-- NAME --X BASEKV MC C O N S STATE VAR
 ICON 99995 G03-20-S 0.6900 1 111200-111204 41924-41927 12064-12067
 8296-8298

H DAMP Hfrac Freq1 DSHAFT
 7.7260 0.0000 0.8562 2.3000 3.0000

Southwest Power Pool
System Impact Study of GEN-2003-020 Generation
Interconnection (Mitsubishi WTG MHI95)

2008-E750-0050-1-R0

Wind Generator Bus # 99995
 Wind Generator ID 1

** M9295A ** BUS X-- NAME --X BASEKV MC C O N S STATE VAR ICON
 99995 G03-20-S 0.6900 1 111205-111213 41928-41928 12068-12071 8299-8301

Lambda_Max Lambda_Min PITCH_MAX PITCH_MIN Ta
 19.5000 0.0000 109.0000 21.0000 0.0000

RHO Radius GB_RATIO SYNCHR
 1.2250 47.5000 90.5880 1200.00

Wind Generator Bus # 99995
 Wind Generator ID 1

** M9295P ** BUS X-- NAME --X BASEKV MC C O N S STATE VAR ICON
 99995 G03-20-S 0.6900 1 111214-111228 41929-41931 0-0 8302-8304

Tp Kp1 Kil Kp2 Ki2
 0.1000 152.6400 62.2070 0.1750 0.0594

TetaMax TetaMin RTetaMax RTetaMin GSPit1
 109.0000 21.0000 7.5000 -6.0000 20.0000

GSPit2 GSDiv1 GSDiv2 Wmin Wmax
 50.0000 1.0000 4.0000 -0.3210 0.1333

Wind Generator Bus # 99995
 Wind Generator ID 1

** M925PT ** BUS X-- NAME --X BASEKV MC V A R S ICONS
 99995 G03-20-S 0.69001 12072-12080 8305-8306

Wind generator Bus # 99995
 Wind Generator ID 1

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E FRI, OCT 31 2008 14:47
 SPP MDWG 2007 STABILITY BASE CASE: STAB2-08W-30-RED 4-12-07
 2008 SUMMER PEAK: GEN-2003-020 INTERCONNECTION STUDY

CONET MODELS

REPORT FOR ALL MODELS BUS 99995 [G03-20-S 0.6900] MODELS

*** CALL VTGDCA(8307,111229, 0, 12081) ***

BUS NAME BSKV GENR BUS NAME BSKV ID
 99995 G03-20-S.690 99995 G03-20-S.690 1

I C O N S C O N S V A R
 8307-8312 111229-111232 12081

VLO VUP PICKUP TB
 0.025 5.000 0.150 0.080

*** CALL VTGDCA(8313,111233, 0, 12082) ***

BUS NAME BSKV GENR BUS NAME BSKV ID
 99995 G03-20-S.690 99995 G03-20-S.690 1

I C O N S C O N S V A R
 8313-8318 111233-111236 12082



Southwest Power Pool
System Impact Study of GEN-2003-020 Generation
Interconnection (Mitsubishi WTG MHI95)

2008-E750-0050-1-R0

VLO VUP PICKUP TB
0.200 5.000 0.783 0.080

*** CALL VTGDCA(8319,111237, 0, 12083) ***

BUS	NAME	BSKV	GENR	BUS	NAME	BSKV	ID
99995	G03-20-S.690		99995	G03-20-S.690			1

I C O N S C O N S V A R
8319-8324 111237-111240 12083

VLO VUP PICKUP TB
0.250 5.000 0.942 0.080

*** CALL VTGDCA(8325,111241, 0, 12084) ***

BUS	NAME	BSKV	GENR	BUS	NAME	BSKV	ID
99995	G03-20-S.690		99995	G03-20-S.690			1

I C O N S C O N S V A R
8325-8330 111241-111244 12084

VLO VUP PICKUP TB
0.350 5.000 1.258 0.080

*** CALL VTGDCA(8331,111245, 0, 12085) ***

BUS	NAME	BSKV	GENR	BUS	NAME	BSKV	ID
99995	G03-20-S.690		99995	G03-20-S.690			1

I C O N S C O N S V A R
8331-8336 111245-111248 12085

VLO VUP PICKUP TB
0.450 5.000 1.575 0.080

*** CALL VTGDCA(8337,111249, 0, 12086) ***

BUS	NAME	BSKV	GENR	BUS	NAME	BSKV	ID
99995	G03-20-S.690		99995	G03-20-S.690			1

I C O N S C O N S V A R
8337-8342 111249-111252 12086

VLO VUP PICKUP TB
0.550 5.000 1.892 0.080

*** CALL VTGDCA(8343,111253, 0, 12087) ***

BUS	NAME	BSKV	GENR	BUS	NAME	BSKV	ID
99995	G03-20-S.690		99995	G03-20-S.690			1

I C O N S C O N S V A R
8343-8348 111253-111256 12087

VLO VUP PICKUP TB
0.650 5.000 2.208 0.080

*** CALL VTGDCA(8349,111257, 0, 12088) ***

BUS	NAME	BSKV	GENR	BUS	NAME	BSKV	ID
99995	G03-20-S.690		99995	G03-20-S.690			1

I C O N S C O N S V A R
8349-8354 111257-111260 12088

```

VLO      VUP      PICKUP    TB
0.750    5.000    2.525    0.080

*** CALL VTGDCA( 8355,111261,      0, 12089) ***

BUS  NAME  BSKV      GENR BUS  NAME  BSKV  ID
99995 G03-20-S.690      99995 G03-20-S.690  1

I C O N S      C O N S      V A R
8355-8360    111261-111264    12089

VLO      VUP      PICKUP    TB
0.850    5.000    2.842    0.080

*** CALL VTGDCA( 8361,111265,      0, 12090) ***

BUS  NAME  BSKV      GENR BUS  NAME  BSKV  ID
99995 G03-20-S.690      99995 G03-20-S.690  1

I C O N S      C O N S      V A R
8361-8366    111265-111268    12090

VLO      VUP      PICKUP    TB
0.900    5.000    3.000    0.080

*** CALL VTGDCA( 8367,111269,      0, 12091) ***

BUS  NAME  BSKV      GENR BUS  NAME  BSKV  ID
99995 G03-20-S.690      99995 G03-20-S.690  1

I C O N S      C O N S      V A R
8367-8372    111269-111272    12091

VLO      VUP      PICKUP    TB
0.000    1.100    0.020    0.080

*** CALL VTGDCA( 8373,111273,      0, 12092) ***

BUS  NAME  BSKV      GENR BUS  NAME  BSKV  ID
99995 G03-20-S .690      99995 G03-20-S .690  1

I C O N S      C O N S      V A R
8373-8378    111273-111276    12092

FLO      FUP      PICKUP    TB
59.000    70.000    0.300    0.080

*** CALL FRQDCA( 8379,111277,      0, 12093) ***

BUS  NAME  BSKV      GENR BUS  NAME  BSKV  ID
99995 G03-20-S .690      99995 G03-20-S .690  1

I C O N S      C O N S      V A R
8379-8384    111277-111280    12093

FLO      FUP      PICKUP    TB
50.000    61.000    0.300    0.080

```

APPENDIX C – Plots for Stability Simulations with Gen-2003-20