



***Impact Study for Generation  
Interconnection Request  
GEN – 2004 – 003***

***SPP Coordinated Planning  
(#GEN-2004-003)***

**May 2005**

## **Summary**

Pterra Consulting performed the following Study at the request of the Southwest Power Pool (SPP) for Generation Interconnection request Gen-2004-003. The request for interconnection was placed with SPP in accordance SPP's Open Access Transmission Tariff, which covers new generation interconnections on SPP's transmission system.

Pursuant to the tariff, Pterra Consulting was asked to perform a detailed Impact Study of the generation interconnection request to satisfy the Impact Study Agreement executed by the requesting customer and SPP.

*Pterra Consulting*

Report No. R112-05

# **“Impact Study for Generation Interconnection Request GEN-2004-003”**

Submitted to

**The Southwest Power Pool**

May 2005



4 Automation Lane, Ste.125, Albany, NY 12205 Tel: 518-724-3832 Web: [www.pterra.us](http://www.pterra.us)

*Report No. R112-05*

# “Impact Study for Generation Interconnection Request GEN- 2004-003”

<b>1. Executive Summary .....</b>	<b>2</b>
<b>2. Introduction.....</b>	<b>3</b>
2.1 Project Overview .....	3
2.2 Objective.....	4
<b>3. Stability Analysis.....</b>	<b>6</b>
3.1 Modeling of the Wind Turbines.....	6
3.2 Assumptions .....	7
3.3 Contingencies Simulated.....	8
3.4 Simulation Results .....	11
<b>4. Conclusion .....</b>	<b>12</b>
<b>Appendix A.....</b>	<b>14</b>

## **1. Executive Summary**

This report presents the stability simulation findings of the impact study of a proposed interconnection (Gen-2004-003). The analysis was conducted through the Southwest Power Pool Tariff for a 115kV 240 MW wind farm in Carson County, Texas. This wind farm would be interconnected to the existing Conway district substation via a new 115 kV Main breaker. The Conway district substation is owned by Xcel Energy (d/b/a SWPS). The wind farm will use GE 1.5 MW wind turbines with the standard ride through package.

Two base cases each comprising of a power flow and corresponding dynamics database for 2009 summer and fall were provided by SPP. Transient stability simulations were conducted with the proposed wind farm in service with a full output of 240 MW. In order to integrate the proposed 240 MW wind farm in SPP system, the existing generation footprint was re-dispatched as provided by SPP.

Twenty (20) contingencies were considered for the transient stability simulations which included 3-phase faults, as well as, 1-phase to ground faults, at the locations defined by SPP. 1-phase faults were simulated by applying a fault impedance to the positive sequence network at the fault location, representing the effect of the negative and zero sequence networks on the positive sequence network. The fault impedance was computed to give a positive sequence voltage at the specified fault location of approximately 60% of pre-fault voltage. This method is in agreement with SPP current practice.

The proposed wind generators were modeled with under/over voltage/frequency ride through protection. The settings were in accordance with standard or default settings.

The simulations conducted in the study did not find any angular or voltage instability problems for the twenty contingencies. However, tripping of the wind farm was observed as follow:

- For peak summer loading condition, the wind farm tripped due to relay actuation in disturbances #1 and #2 (3-phase and 1-phase faults respectively, at Kirby 115kV bus). Tripping of the wind farm because of these specific contingencies is normal since the fault clearing procedures require tripping of Conway 115kV at which the proposed 240MW wind farm is connected.
- For fall loading condition, tripping of the wind farm occurred in disturbance # 17 (3-phase fault at Whitaker on Nichols to Whitaker 115kV line) in addition to the two disturbances #1 and #2 as in the summer case. Tripping of the wind farm for disturbance # 17 was mainly due to the actuation of the over frequency relay because of high frequency excursion. It was found that the amplitude of the frequency

excursion in the fall base case is higher than that in the summer base case because of the lesser system inertia.

All oscillations were well damped. The study finds that the proposed 240MW wind farm project shows stable performance of SPP system for the contingencies tested on the supplied base cases.

## 2. Introduction

### 2.1 Project Overview

The proposed 240MW wind farm would be interconnected to the existing Conway district substation via a new 115 kV Main breaker. It is anticipated the substation will be modified to add a breaker to accept the interconnection. A new 115 kV line from the Customer collector bus to the Conway district Substation will be built. Figure 1 shows the interconnection diagram of the proposed GEN 2004-003 project to the 115kV transmission system. The detailed connection diagram of the wind farm is provided by SPP.




Figure 1. Interconnection Plan for GEN 2004-003 to the 115kV System

In order to integrate the proposed 240MW wind farm in SPP system, dispatch for the existing generation in the following areas SWPA, AEPW, GRRP, OKGE, WFEC, SPS, MIDW, WERE, KACP, EMDE, and SPRM was scaled down by 240 MW.

In order to simplify the model of the wind farm while capturing the effect of the different impedances of cables (due to change of the conductor size and length), the wind turbines connected to the same 34.5kV feeder end points were aggregated into one equivalent unit. An equivalent impedance of that feeder is represented in the load flow database by taking the equivalent series impedances of the different feeders connecting the wind turbines. Using this approach, the proposed 240MW wind farm was modeled with 62 equivalent units as shown in Figure 2. The number in each circle in the diagram shows the number of individual wind turbine units that were aggregated at that bus. SPP provided the impedance values for the different feeders at 34.5kV level. SPP provided the data for the following equipment:

1. 34.5kV feeders
2. Generating unit step up transformers
3. 115kV/34.5kV transformers
4. Data for the new 115kV line

Pterra added two prior queued projects into the base case model before running the fault study. The two prior queued projects are as follow:

1. GEN-2002-019 (160 MW)
2. GEN-2002-022 (240 MW)

SPP provided the data needed to include these prior projects in the final model for GEN 2004-003. The provided data included interconnection points of these two prior queued projects to SPP system, dispatch for existing generation to integrate these projects in SPP system, and the dynamics Database.

## 2.2 Objective

The objective of the study is, to determine the impact on system stability of connecting the proposed 240MW wind farm to SPP's 115 kV transmission system.




Figure 2. Wind Farm Equivalent representation in Load Flow

### 3. Stability Analysis

#### 3.1 Modeling of the Wind Turbines

Equivalents for the wind turbine and generator step-up (GSU) transformer in the load flow case were modeled. For the stability simulations, the GE 1.5 MW wind turbine generators were modeled using the latest GE wind turbine model set.

Table 1. GE 1.5 MW Wind Generator Data

Parameter	Value
BASE KV	0.575
WTG MBASE	1.667
TRANSFORMER MBASE	1.75
TRANSFORMER R ON TRANSFORMER BASE	0.0077
TRANSFORMER X ON TRANSFORMER BASE	0.0579
GTAP	1.05
PMAX (MW)	1.5
PMIN	0.0
RA	0.00706
LA	0.1714
LM	2.904
R1	0.005
L1	0.1563
INERTIA	0.57
DAMPING	0.0
QMAX (MVAR)	0.49
QMIN (MVAR)	-0.73

The wind turbine generators have ride-through capability for voltage and frequency. Detailed relay settings are shown in the following tables.

Table 2: Over/Under Frequency Relay Settings for GE Wind Turbine

Frequency Settings in Hertz	Time Delay in Seconds	Breaker time in Seconds
$F \leq 56.5$	0.02	0.15
$56.5 < F \leq 57.5$	10.0	0.15
$61.5 < F \leq 62.5$	30.0	0.15
$F \geq 62.5$	0.02	0.15

Table 3. Over/Under Voltage Relay Settings for GE Wind Turbine

Voltage Settings Per Unit	Time Delay in Seconds	Breaker time in Seconds
$V \leq 0.30$	0.02	0.15
$0.30 < V \leq 0.70$	0.10	0.15
$0.70 < V \leq 0.75$	1.00	0.15
$0.75 < V \leq 0.85$	10.0	0.15
$V \geq 1.10$	1.00	0.15
$1.10 > V \geq 1.15$	0.10	0.15
$1.15 > V \geq 1.3$	0.02	0.15

### 3.2 Assumptions

The following assumptions were adopted for the study:

1. A constant maximum and uniform wind speed was considered during the entire period of study.

2. The wind turbine control models were used with their default values.
3. The settings for the under/over voltage/frequency were set according to the standard manufacturer data.

### 3.3 Contingencies Simulated

Twenty (20) contingencies were considered for the transient stability simulations which included three phase faults, as well as single phase line faults, at the locations defined by SPP. 1-phase line faults were simulated by applying a fault impedance to the positive sequence network at the fault location to represent the effect of the negative and zero sequence networks on the positive sequence network. The fault impedance was computed to give a positive sequence voltage at the specified fault location of approximately 60% of pre-fault voltage. This method is in agreement with SPP current practice. Table 4 shows the list of simulated contingencies. The table also shows the fault clearing time and the time delay before re-closing for all the study contingencies.

Table 1. List of Contingencies

Cont. No.	Cont. Name	Description
1	FLT13PH	Fault on the Nichols (50914) to Kirby (50932), 115 kV line, near Kirby. <ol style="list-style-type: none"> <li>a. Apply Fault at the Kirby bus (50932).</li> <li>b. Clear fault after 5 cycles by removing the lines</li> <li>c. Kirby (50932) to Conway (50928)</li> <li>d. Conway (50928) to Yarnell (50926) and</li> <li>e. Yarnell (50926) to Nichols (50914)</li> <li>f. Wait 20 cycles, and then re-close the line in (b) into the fault.</li> </ol>
2	FLT21PH	Single phase fault and sequence like Cont. No. 1
3	FLT33PH	Fault on the Kirby (50932) to Grapevine (50826), 115 kV line, near Grapevine <ol style="list-style-type: none"> <li>a. Apply fault at the Grapevine bus (50826)</li> <li>b. Clear fault after 5 cycles by removing the line from Kirby (50932) to Grapevine (50826).</li> <li>c. Wait 20 cycles, and then re-close the line in (b) into the fault.</li> <li>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</li> </ol>
4	FLT41PH	Single phase fault and sequence like Cont. No. 3

Cont. No.	Cont. Name	Description
5	FLT53PH	Fault on the Grapevine (50826) to Bowers (50820), 115 kV line, near Bowers a. Apply fault at the Bowers bus (50820) b. Clear fault after 5 cycles by removing the line from Grapevine (50826) to Bowers (50820). c. Wait 20 cycles, and then re-close the line in (b) into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
6	FLT61PH	Single phase fault and sequence like Cont. No. 5
7	FLT73PH	Fault on the Kirby to McLelln3, 115 kV line, near McLelln3 a. Apply fault at the Mclelln3 bus (50383) b. Clear fault after 5 cycles by removing the line from Kirby (50932) to McLelln3 (50383). c. Wait 20 cycles, and then re-close the line in (b) into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
8	FLT81PH	Single phase fault and sequence like Cont. No. 7
9	FLT93PH	Fault on the McLelln3 (50383) to McLean Rural (50840), 115 kV line, near McLean Rural a. Apply fault at the Mclean Rural bus (50840) b. Clear fault after 5 cycles by removing the line from McLelln3 (50383) to McLean Rural (50840). c. Wait 20 cycles, and then re-close the line in (b) into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
10	FLT101PH	Single phase fault and sequence like Cont. No. 9
11	FLT113PH	Fault on the Grapevine (50827) to Elk City (54153) 230 kV line, near Elk City. a. Apply fault at the Elk City bus (54153). b. Clear fault after 5 cycles by removing the line from Grapevine (50827) to Elk City (54153). c. Wait 20 cycles, and then re-close the line in (b) into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
12	FLT121PH	Single phase fault and sequence like Cont. No. 11

Cont. No.	Cont. Name	Description
13	FLT133PH	Fault on the Nichols (50915) to Grapevine (50827), 230 kV line, (at Mid Line). Establish a new bus (Mid-Line Bus) in the electrical middle of the 345 kV line. a. Apply Fault at the Mid-line bus (899). b. Clear Fault after 5 cycles by removing the line from Nichols (50915) to Mid-line bus (899) and from Mid-line bus (899) to Grapevine (50827). c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
14	FLT141PH	Single phase fault and sequence like Cont. No. 13
15	FLT153PH	Fault on the Nichols (50915) to Hutchison County Interchange (50751), 230 kV line, near Hutchison County Interchange. a. Apply Fault at the Hutchison County Interchange bus (50751). b. Clear fault after 5 cycles by removing the line from Nichols (50915) to Hutchison County Interchange (50751). c. Wait 20 cycles, and then re-close the line in (b) into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
16	FLT161PH	Single phase fault and sequence like Cont. No. 15
17	FLT173PH	Fault on the Nichols (50915) to Whitaker (50922), 115 kV line, near Whitaker a. Apply Fault at the Whitaker bus (50922). b. Clear fault after 5 cycles by removing the line from Nichols (50915) to Whitaker (50922). c. Wait 20 cycles, and then re-close the line in (b) into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
18	FLT181PH	Single phase fault and sequence like Cont. No. 17
19	FLT193PH	Fault on the Whitaker (50922) to East Plant Interchange (50956), 115 kV line, near East Plant Interchange a. Apply Fault at the East Plant Interchange bus (50956). b. Clear fault after 5 cycles by removing the line from Whitaker (50922) to East Plant Interchange (50956).

Cont. No.	Cont. Name	Description
		c. Wait 20 cycles, and then re-close the line in (b) into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
20		Single phase fault and sequence like Cont. No. 19

### 3.4 Simulation Results

Simulations were performed with a 0.1-second steady-state run followed by the appropriate disturbance as described in Table 4. Simulations were run for a minimum 10-second duration to confirm proper machine damping. Based on the obtained simulation results, the system remained stable for all the simulated faults with the proposed 240MW wind farm project in service. All oscillations were well damped. The study finds that the proposed 240MW wind farm project, on the basis of base cases, modeling assumptions described within this report, and for the tested contingencies (on the supplied base cases) show stable performance of SPP system.

A complete set of the transient stability plots for rotor angle, speed, and voltages for the monitored buses in SPP for all contingencies for the two base cases with the proposed 240MW wind farm in service, are in an electronic format on the accompanying CD.

Sample plots for rotor angle, speed, and voltages for disturbances #1 and #11 for summer peak load and for disturbance #17 for fall loading conditions are included in Appendix A.

From the simulation results obtained, the following conclusions can be made:

- For peak summer loading condition, the wind farm tripped due to relay actuation in disturbances #1 and #2 (3-phase and 1-phase faults respectively, at Kirby 115kV bus. See Table 4 for complete descriptions). Tripping of the wind farm because of these specific contingencies is normal since the fault clearing procedures require tripping of Conway115kV at which the proposed 240MW wind farm is connected. In fact, tripping of the wind farm should be considered as part of the fault clearing procedures.
- For fall loading condition, tripping of the wind farm occurred in disturbance # 17 (3-phase fault at Whitaker on Nichols to Whitaker 115kV line. See Table 4 for complete descriptions) in addition to the two disturbances #1 and #2 as in the summer case. Tripping of the wind farm for disturbance # 17 was mainly due to the actuation of the over frequency relay because of high frequency excursion. It was found out that the amplitude of the frequency excursion in

the fall base case is higher than that in the summer base case because of the lesser system inertia.

All oscillations were well damped. The study finds that the proposed 240MW wind farm project shows stable performance of SPP system for the contingencies tested on the supplied base cases.

#### 4. Conclusion

The stability simulation findings of the impact study of a proposed interconnection (Gen-2004-003) were presented in this report. The study was conducted through the Southwest Power Pool Tariff for a 115kV 240 MW wind farm in Carson County, Texas. This wind farm would be interconnected to the existing Conway district substation via a new 115 kV Main breaker. The Conway district substation is owned by Xcel Energy (d/b/a SWPS). The wind farm is using GE 1.5 MW wind turbines with the standard ride through package.

The 2009 summer and fall load flow cases together with the necessary data needed for the transient stability simulations were provided by SPP. Transient stability simulations were conducted with the proposed wind farm in service with a full output of 240 MW. In order to integrate the proposed 240MW wind farm in SPP system, re-dispatch for the existing SPP footprint generation was provided by SPP.

Twenty (20) contingencies were considered for the transient stability simulations which included three phase faults, as well as single line to ground faults, at the locations defined by SPP. 1-phase faults were simulated by applying a fault impedance to the positive sequence network at the fault location to represent the effect of the negative and zero sequence networks on the positive sequence network. The fault impedance was computed to give a positive sequence voltage at the specified fault location of approximately 60% of pre-fault voltage. This method is in agreement with SPP current practice.

The proposed wind generators were modeled with voltage/frequency ride through protection. The settings of both under/over voltage and frequency relays were in accordance with standard or default settings.

The simulations conducted in the study did not find any angular or voltage instability problems for the twenty contingencies. However, tripping of the wind farm was observed as follow:

- For peak summer loading condition, the wind farm tripped due to relay actuation in disturbances #1 and #2 (3-phase and 1-phase faults respectively, at Kirby 115kV bus). Tripping of the wind farm because of these specific contingencies is normal since the fault clearing procedures require tripping of Conway115kV at which the proposed 240MW wind farm is connected.


- For fall loading condition, tripping of the wind farm occurred in disturbance # 17 (3-phase fault at Whitaker on Nichols to Whitaker 115kV line) in addition to the two disturbances #1 and #2 as in the summer case. Tripping of the wind farm for disturbance # 17 was mainly due to the actuation of the over frequency relay because of high frequency excursion. It was found out that the amplitude of the frequency excursion in the fall base case is higher than that in the summer base case because of the lesser system inertia.

All oscillations were well damped. The study finds that the proposed 240MW wind farm project shows stable performance of SPP system for the contingencies tested on the supplied base cases.

## **Appendix A**


### A-1 Sample Plots for Rotor Angle, Voltage, and Speed for Summer Peak

1. Disturbance #1 (Fault on the Nichols to Kirby, 115 kV line, near Kirby)







2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN




2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN




2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN




2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN









2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN




2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN




2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN




2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN









2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN




2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN



2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN




2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN







2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN




2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN




2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN




2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN









2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN




2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN



2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN




2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN







2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN




2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN











2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN



2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN











2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\1\_FLT13PH.OUT



2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN



FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\1\_FLT13PH.OUT



2. Disturbance #11 (Fault on the Grapevine to Elk City 230 kV line, near Elk City)

**W** 2004 SERIES, NERC/MWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN  
FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

**W** 2004 SERIES, NERC/MWG BASE CASE LIBRARY  
2009 SUMMER, FINAL; FOR DYN  
FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT



**2004 SERIES, NERC/MWNG BASE CASE LIBRARY**

**2009 SUMMER, FINAL; FOR DYN**

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

360.00 CHNU# 7.7: (ANG GEN 2004-003 CLR 4)  $\times - - - - \times$  0.0

360.00 CHNU# 7.6: (ANG GEN 2004-003 CLR 2)  $\leftarrow - - - - +$  0.0


360.00 CHNU# 7.5: (ANG GEN 2004-003 CLR 1)  $\leftarrow - - - - \diamond$  0.0

360.00 CHNU# 7.4: (ANG GEN 2002-022)  $\leftarrow - - - - \diamond$  0.0

360.00 CHNU# 7.3: (ANG GEN 2002-019)  $\leftarrow - - - - \diamond$  0.0

360.00 CHNU# 85.1: (ANG GEN 2004-003 CLR 12)  $\leftarrow - - - - \diamond$  0.0

WED, MAY 04 2005 14:53  
ROTOR ANGLE



**2004 SERIES, NERC/MWNG BASE CASE LIBRARY**  
2009 SUMMER, FINAL; FOR DYN

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT


360.00 CHNU# 90: (ANG GEN 2004-003 CLR 16)  $\times - - - - \times$  0.0

360.00 CHNU# 89: (ANG GEN 2004-003 CLR 15)  $\times - - - - \times$  0.0

360.00 CHNU# 88: (ANG GEN 2004-003 CLR 14)  $\leftarrow - - - - +$  0.0

360.00 CHNU# 87: (ANG GEN 2004-003 CLR 13)  $\leftarrow - - - - \diamond$  0.0

WED, MAY 04 2005 14:53  
ROTOR ANGLE



**2004 SERIES, NERC/MWNG BASE CASE LIBRARY**  
2009 SUMMER, FINAL; FOR DYN

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

360.00 CHNU# 84: (ANG GEN 2004-003 CLR 10)  $\times - - - - \times$  0.0

360.00 CHNU# 83: (ANG GEN 2004-003 CLR 9)  $\times - - - - \times$  0.0



360.00 CHNU# 82: (ANG GEN 2004-003 CLR 8)  $\leftarrow - - - - +$  0.0

360.00 CHNU# 81: (ANG GEN 2004-003 CLR 7)  $\leftarrow - - - - \diamond$  0.0

360.00 CHNU# 80: (ANG GEN 2004-003 CLR 6)  $\leftarrow - - - - \diamond$  0.0

360.00 CHNU# 79: (ANG GEN 2004-003 CLR 5)  $\leftarrow - - - - \diamond$  0.0

WED, MAY 04 2005 14:53  
ROTOR ANGLE



WED, MAY 04 2005 14:53  
ROTOR ANGLE

**2004 SERIES, NERC/MWNG BASE CASE LIBRARY**

**2009 SUMMER, FINAL; FOR DYN**

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

360.00 CHNU# 101: (ANG GEN 2004-003 CUR 27) x - - - - x 0.0

360.00 CHNU# 100: (ANG GEN 2004-003 CUR 26) ← - - - - + 0.0


360.00 CHNU# 99: (ANG GEN 2004-003 CUR 25) ← - - - - + 0.0

360.00 CHNU# 98: (ANG GEN 2004-003 CUR 24) ← - - - - + 0.0

360.00 CHNU# 97: (ANG GEN 2004-003 CUR 23) ← - - - - + 0.0

360.00 CHNU# 109: (ANG GEN 2004-003 CUR 36) ← - - - - + 0.0

WED, MAY 04 2005 14:53  
ROTOR ANGLE



**2004 SERIES, NERC/MWNG BASE CASE LIBRARY**  
2009 SUMMER, FINAL; FOR DYN

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

360.00 CHNU# 98: (ANG GEN 2004-003 CUR 22) x - - - - x 0.0

360.00 CHNU# 97: (ANG GEN 2004-003 CUR 21) x - - - - x 0.0


360.00 CHNU# 94: (ANG GEN 2004-003 CUR 20) ← - - - - + 0.0

360.00 CHNU# 93: (ANG GEN 2004-003 CUR 19) ← - - - - + 0.0

360.00 CHNU# 92: (ANG GEN 2004-003 CUR 18) ← - - - - + 0.0

360.00 CHNU# 91: (ANG GEN 2004-003 CUR 17) ← - - - - + 0.0

WED, MAY 04 2005 14:53  
ROTOR ANGLE



**2004 SERIES, NERC/MWNG BASE CASE LIBRARY**  
2009 SUMMER, FINAL; FOR DYN

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

360.00 CHNU# 108: (ANG GEN 2004-003 CUR 34) x - - - - x 0.0

360.00 CHNU# 107: (ANG GEN 2004-003 CUR 33) x - - - - x 0.0



360.00 CHNU# 106: (ANG GEN 2004-003 CUR 32) ← - - - - + 0.0

360.00 CHNU# 105: (ANG GEN 2004-003 CUR 31) ← - - - - + 0.0

360.00 CHNU# 104: (ANG GEN 2004-003 CUR 30) ← - - - - + 0.0

360.00 CHNU# 103: (ANG GEN 2004-003 CUR 29) ← - - - - + 0.0

WED, MAY 04 2005 14:53  
ROTOR ANGLE



**2004 SERIES, NERC/MWNG BASE CASE LIBRARY**

**2009 SUMMER, FINAL; FOR DYN**


FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

CHNU#	LANG GEN	2004-003 CLR	51	0.0
125.	[ANG GEN 2004-003 CLR 51]	x	- - - - x	0.0
124.	[ANG GEN 2004-003 CLR 50]	x	- - - - +	0.0
123.	[ANG GEN 2004-003 CLR 49]	x	- - - - +	0.0
122.	[ANG GEN 2004-003 CLR 48]	x	- - - - +	0.0
121.	[ANG GEN 2004-003 CLR 47]	x	- - - - +	0.0
120.	[ANG GEN 2004-003 CLR 46]	x	- - - - +	0.0

CHNU#	LANG GEN	2004-003 CLR	621	0.0
136.	[ANG GEN 2004-003 CLR 621]	x	- - - - +	0.0
135.	[ANG GEN 2004-003 CLR 61]	x	- - - - +	0.0
134.	[ANG GEN 2004-003 CLR 601]	x	- - - - +	0.0
133.	[ANG GEN 2004-003 CLR 591]	x	- - - - +	0.0

WED, MAY 04 2005 14:53  
ROTOR ANGLE




**2004 SERIES, NERC/MWNG BASE CASE LIBRARY**  
2009 SUMMER, FINAL; FOR DYN

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

CHNU#	LANG GEN	2004-003 CLR	45	0.0
119.	[ANG GEN 2004-003 CLR 45]	x	- - - - x	0.0
118.	[ANG GEN 2004-003 CLR 44]	x	- - - - +	0.0
117.	[ANG GEN 2004-003 CLR 43]	x	- - - - +	0.0
116.	[ANG GEN 2004-003 CLR 42]	x	- - - - +	0.0
115.	[ANG GEN 2004-003 CLR 41]	x	- - - - +	0.0
114.	[ANG GEN 2004-003 CLR 40]	x	- - - - +	0.0

WED, MAY 04 2005 14:53  
ROTOR ANGLE




**2004 SERIES, NERC/MWNG BASE CASE LIBRARY**  
2009 SUMMER, FINAL; FOR DYN



FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT





CHNU#	LANG GEN	2004-003 CLR	59	0.0
132.	[ANG GEN 2004-003 CLR 59]	x	- - - - +	0.0
131.	[ANG GEN 2004-003 CLR 57]	x	- - - - x	0.0
130.	[ANG GEN 2004-003 CLR 56]	x	- - - - x	0.0
129.	[ANG GEN 2004-003 CLR 55]	x	- - - - +	0.0
128.	[ANG GEN 2004-003 CLR 54]	x	- - - - +	0.0
127.	[ANG GEN 2004-003 CLR 53]	x	- - - - +	0.0





WED, MAY 04 2005 14:53  
ROTOR ANGLE



WED, MAY 04 2005 14:53  
ROTOR ANGLE







**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**

2009

SUMMER

FINAL

FOR DYN


14:54

VOLTAGE

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT  
1.1.000 CHNU# 426: [VOLTAGE BLUE CRANCA WIND WEEF] - - - - - 0.50000  
1.1.000 CHNU# 425: [VOLTAGE GRAY CO WIND WEEF] - - - - - 0.50000  
1.1.000 CHNU# 424: [VOLTAGE WHITE DEER MIND WEEF] - - - - + 0.50000  
1.1.000 CHNU# 423: [VOLTAGE CAPROCK WIND SPS] - - - - + 0.50000  
1.1.000 CHNU# 422: [VOLTAGE SAN JUAN MESA WIND 2 SPS] - - - - + 0.50000  
1.1.000 CHNU# 421: [VOLTAGE SAN JUAN MESA WIND 1 SPS] - - - - + 0.50000  
1.1.000 CHNU# 420: [VOLTAGE SAN JUAN MESA WIND 0 SPS] - - - - + 0.50000

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT  
1.1.000 CHNU# 437: [VOLTAGE LANG 345KV] - - - - - 0.50000  
1.1.000 CHNU# 436: [VOLTAGE JFC N 345KV] - - - - + 0.50000  
1.1.000 CHNU# 435: [VOLTAGE HOYT 345KV] - - - - + 0.50000  
1.1.000 CHNU# 434: [VOLTAGE IAPAN 345KV] - - - - + 0.50000

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT  
1.1.000 CHNU# 438: [VOLTAGE MERIT 345KV] - - - - - 0.50000  
1.1.000 CHNU# 437: [VOLTAGE LANG 345KV] - - - - - 0.50000  
1.1.000 CHNU# 436: [VOLTAGE JFC N 345KV] - - - - + 0.50000  
1.1.000 CHNU# 435: [VOLTAGE HOYT 345KV] - - - - + 0.50000  
1.1.000 CHNU# 434: [VOLTAGE IAPAN 345KV] - - - - + 0.50000



**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
2009 SUMMER, FINAL, FOR DYN

14:54

VOLTAGE

TIME (SECONDS)

0.0

1.0000

2.0000

3.0000

4.0000

5.0000

6.0000

7.0000

8.0000

9.0000

10.000

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT  
1.1.000 CHNU# 418: [VOLTAGE EAST GYMON WIND SPS] - - - - - 0.50000  
1.1.000 CHNU# 417: [VOLTAGE MINERS CREEK WIND WEEF] - - - - + 0.50000  
1.1.000 CHNU# 416: [VOLTAGE SLEEPING BEAR WIND WEEF] - - - - + 0.50000  
1.1.000 CHNU# 415: [VOLTAGE FPL WOODWARD WIND OSE] - - - - + 0.50000

WED, MAY 04 2005 14:54  
VOLTAGE

TIME (SECONDS)

0.0

1.0000

2.0000

3.0000

4.0000

5.0000


6.0000

7.0000

8.0000

9.0000

10.000



**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
2009 SUMMER, FINAL, FOR DYN

14:54

VOLTAGE

TIME (SECONDS)

0.0

1.0000

2.0000

3.0000

4.0000

5.0000


6.0000

7.0000

8.0000

9.0000

10.000



**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
2009 SUMMER, FINAL, FOR DYN

14:54

VOLTAGE

TIME (SECONDS)

0.0

1.0000

2.0000

3.0000

4.0000

5.0000





6.0000

7.0000

8.0000

9.0000

10.000



**2004 SERIES, NERC/MWG BASE CASE LIBRARY**

**2009 SUMMER, FINAL; FOR DYN**


FILE: C:\Pterra\...\SPP\_2009\_Summer\SUMMER-003\output\11\_FLT13PH.OUT

FILE: C:\Pterra\...\SPP\_2009\_Summer\SUMMER-003\output\11\_FLT13PH.OUT

1.5000 CHNU# 46.9: (VOLTAGE GEN 2004-003 CLR 15)  $\downarrow$  - - - -  $\uparrow$  0.50000  
1.5000 CHNU# 46.8: (VOLTAGE GEN 2004-003 CLR 14)  $\downarrow$  - - - -  $\uparrow$  0.50000  
1.5000 CHNU# 46.7: (VOLTAGE GEN 2004-003 CLR 13)  $\downarrow$  - - - -  $\uparrow$  0.50000

1.5000 CHNU# 46.6: (VOLTAGE GEN 2004-003 CLR 12)  $\downarrow$  - - - -  $\uparrow$  0.50000  
1.5000 CHNU# 46.5: (VOLTAGE GEN 2004-003 CLR 11)  $\downarrow$  - - - -  $\uparrow$  0.50000

WED, MAY 04 2005 14:54 VOLTAGE




**2004 SERIES, NERC/MWG BASE CASE LIBRARY**  
**2009 SUMMER, FINAL; FOR DYN**

FILE: C:\Pterra\...\SPP\_2009\_Summer\SUMMER-003\output\11\_FLT13PH.OUT

FILE: C:\Pterra\...\SPP\_2009\_Summer\SUMMER-003\output\11\_FLT13PH.OUT

1.5000 CHNU# 46.9: (VOLTAGE GEN 2004-003 CLR 10)  $\downarrow$  - - - -  $\uparrow$  0.50000  
1.5000 CHNU# 46.8: (VOLTAGE GEN 2004-003 CLR 9)  $\downarrow$  - - - -  $\uparrow$  0.50000  
1.5000 CHNU# 46.2: (VOLTAGE GEN 2004-003 CLR 8)  $\downarrow$  - - - -  $\uparrow$  0.50000  
1.5000 CHNU# 46.1: (VOLTAGE GEN 2004-003 CLR 7)  $\downarrow$  - - - -  $\uparrow$  0.50000  
1.5000 CHNU# 46.0: (VOLTAGE GEN 2004-003 CLR 6)  $\downarrow$  - - - -  $\uparrow$  0.50000  
1.5000 CHNU# 45.9: (VOLTAGE GEN 2004-003 CLR 5)  $\downarrow$  - - - -  $\uparrow$  0.50000

WED, MAY 04 2005 14:54 VOLTAGE




**2004 SERIES, NERC/MWG BASE CASE LIBRARY**  
**2009 SUMMER, FINAL; FOR DYN**

FILE: C:\Pterra\...\SPP\_2009\_Summer\SUMMER-003\output\11\_FLT13PH.OUT

FILE: C:\Pterra\...\SPP\_2009\_Summer\SUMMER-003\output\11\_FLT13PH.OUT

1.5000 CHNU# 47.5: (VOLTAGE GEN 2004-003 CLR 21)  $\downarrow$  - - - -  $\uparrow$  0.50000  
1.5000 CHNU# 47.4: (VOLTAGE GEN 2004-003 CLR 20)  $\downarrow$  - - - -  $\uparrow$  0.50000  
1.5000 CHNU# 47.3: (VOLTAGE GEN 2004-003 CLR 19)  $\downarrow$  - - - -  $\uparrow$  0.50000  
1.5000 CHNU# 47.2: (VOLTAGE GEN 2004-003 CLR 18)  $\downarrow$  - - - -  $\uparrow$  0.50000  
1.5000 CHNU# 47.1: (VOLTAGE GEN 2004-003 CLR 17)  $\downarrow$  - - - -  $\uparrow$  0.50000

WED, MAY 04 2005 14:54 VOLTAGE



TIME (SECONDS)

TIME (SECONDS)

**2004 SERIES, NERC/MWG BASE CASE LIBRARY**

**2009 SUMMER, FINAL; FOR DYN**


FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

CHNL# 4931: VOLTAGE GEN 2004-003 CLR 40 ↗ - - - - - 0.50000  
CHNL# 4931: VOLTAGE GEN 2004-003 CLR 39 ↗ - - - - - 0.50000  
CHNL# 4932: VOLTAGE GEN 2004-003 CLR 381 ↗ - - - - + 0.50000  
CHNL# 4911: VOLTAGE GEN 2004-003 CLR 377 ↗ - - - - + 0.50000  
CHNL# 4901: VOLTAGE GEN 2004-003 CLR 361 ↗ - - - - + 0.50000  
CHNL# 4891: VOLTAGE GEN 2004-003 CLR 351 ↗ - - - - + 0.50000

CHNL# 505: VOLTAGE GEN 2004-003 CLR 52 ↗ - - - - - 0.50000  
CHNL# 504: VOLTAGE GEN 2004-003 CLR 50 ↗ - - - - + 0.50000  
CHNL# 503: VOLTAGE GEN 2004-003 CLR 49 ↗ - - - - + 0.50000  
CHNL# 502: VOLTAGE GEN 2004-003 CLR 481 ↗ - - - - + 0.50000  
CHNL# 501: VOLTAGE GEN 2004-003 CLR 471 ↗ - - - - + 0.50000

WED, MAY 04 2005 14:54 VOLTAGE



**2004 SERIES, NERC/MWG BASE CASE LIBRARY**  
**2009 SUMMER, FINAL; FOR DYN**


FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

CHNL# 4891: VOLTAGE GEN 2004-003 CLR 341 ↗ - - - - - 0.50000  
CHNL# 4871: VOLTAGE GEN 2004-003 CLR 33 ↗ - - - - - 0.50000  
CHNL# 4861: VOLTAGE GEN 2004-003 CLR 32 ↗ - - - - + 0.50000  
CHNL# 4851: VOLTAGE GEN 2004-003 CLR 31 ↗ - - - - + 0.50000  
CHNL# 4841: VOLTAGE GEN 2004-003 CLR 301 ↗ - - - - + 0.50000  
CHNL# 4831: VOLTAGE GEN 2004-003 CLR 291 ↗ - - - - + 0.50000

CHNL# 505: VOLTAGE GEN 2004-003 CLR 52 ↗ - - - - - 0.50000  
CHNL# 504: VOLTAGE GEN 2004-003 CLR 50 ↗ - - - - + 0.50000  
CHNL# 503: VOLTAGE GEN 2004-003 CLR 49 ↗ - - - - + 0.50000  
CHNL# 502: VOLTAGE GEN 2004-003 CLR 481 ↗ - - - - + 0.50000  
CHNL# 501: VOLTAGE GEN 2004-003 CLR 471 ↗ - - - - + 0.50000

WED, MAY 04 2005 14:54 VOLTAGE



**2004 SERIES, NERC/MWG BASE CASE LIBRARY**  
**2009 SUMMER, FINAL; FOR DYN**


FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

CHNL# 4931: VOLTAGE GEN 2004-003 CLR 40 ↗ - - - - - 0.50000  
CHNL# 4931: VOLTAGE GEN 2004-003 CLR 39 ↗ - - - - - 0.50000  
CHNL# 4932: VOLTAGE GEN 2004-003 CLR 381 ↗ - - - - + 0.50000  
CHNL# 4911: VOLTAGE GEN 2004-003 CLR 377 ↗ - - - - + 0.50000  
CHNL# 4901: VOLTAGE GEN 2004-003 CLR 361 ↗ - - - - + 0.50000  
CHNL# 4891: VOLTAGE GEN 2004-003 CLR 351 ↗ - - - - + 0.50000

CHNL# 505: VOLTAGE GEN 2004-003 CLR 52 ↗ - - - - - 0.50000  
CHNL# 504: VOLTAGE GEN 2004-003 CLR 50 ↗ - - - - + 0.50000  
CHNL# 503: VOLTAGE GEN 2004-003 CLR 49 ↗ - - - - + 0.50000  
CHNL# 502: VOLTAGE GEN 2004-003 CLR 481 ↗ - - - - + 0.50000  
CHNL# 501: VOLTAGE GEN 2004-003 CLR 471 ↗ - - - - + 0.50000

WED, MAY 04 2005 14:54 VOLTAGE



**2004 SERIES, NERC/MWG BASE CASE LIBRARY**  
**2009 SUMMER, FINAL; FOR DYN**

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

WED, MAY 04 2005 14:54 VOLTAGE

**2004 SERIES, NERC/MMNG BASE CASE LIBRARY**  
**2009 SUMMER, FINAL, FOR DYN**

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT


1.5000 CHNL# 516: [VOLTAGE GEN 2004-003 CLR 621] +---+ 0.50000

1.5000 CHNL# 515: [VOLTAGE GEN 2004-003 CLR 61] +---+ 0.50000

1.5000 CHNL# 514: [VOLTAGE GEN 2004-003 CLR 60] +---+ 0.50000

1.5000 CHNL# 513: [VOLTAGE GEN 2004-003 CLR 59] +---+ 0.50000

WED, MAY 04 2005 14:54  
**VOLTAGE**



**2004 SERIES, NERC/MMNG BASE CASE LIBRARY**  
**2009 SUMMER, FINAL, FOR DYN**

FILE: C:\Pterra\...\SPP 2009 Summer\SUMMER-003\output\11\_FLT13PH.OUT

1.5000 CHNL# 512: [VOLTAGE GEN 2004-003 CLR 59] +---+ 0.50000

1.5000 CHNL# 511: [VOLTAGE GEN 2004-003 CLR 57] x - - - - x 0.50000


1.5000 CHNL# 510: [VOLTAGE GEN 2004-003 CLR 56] - - - - + 0.50000

1.5000 CHNL# 509: [VOLTAGE GEN 2004-003 CLR 55] \* - - - - \* 0.50000

1.5000 CHNL# 508: [VOLTAGE GEN 2004-003 CLR 54] - - - - - 0.50000

1.5000 CHNL# 507: [VOLTAGE GEN 2004-003 CLR 53] @ - - - - @ 0.50000

WED, MAY 04 2005 14:54  
**VOLTAGE**



A-2 Sample Plots for Rotor Angle, Voltage, and Speed for Fall Loading Conditions

1. Disturbance #17 (Fault on the Nichols to Whitaker, 115 kV line, near Whitaker)

**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
**FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
**FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT  
 FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT  
 FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT

180.00 CHNL# 10: (ANG GRAY CO WIND WEPD) x - - - - x -180.0

180.00 CHNL# 22: (ANG WOLF CREEK ST WEPD) x - - - - x -180.0

180.00 CHNL# 9: (ANG WHITE DEER WIND SPS) - - - - + -180.0

180.00 CHNL# 21: (ANG GILL EN CTR WHEEL) - - - - + -180.0

180.00 CHNL# 8: (ANG CAPROCK WIND SPS) - - - - + -180.0


180.00 CHNL# 20: (ANG EVANS SVC WERE) - - - - + -180.0

180.00 CHNL# 7: (ANG SANJUANMESA WIND 2 SPS) - - - - + -180.0

180.00 CHNL# 19: (ANG MCPHERSON PLANT WERE) - - - - + -180.0

180.00 CHNL# 6: (ANG SANJUANMESA WIND 1 SPS) - - - - + -180.0

180.00 CHNL# 18: (ANG EVANS EN CTR WERE) - - - - + -180.0



**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
**FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
**FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT

180.00 CHNL# 10: (ANG GRAY CO WIND WEPD) x - - - - x -180.0

180.00 CHNL# 22: (ANG WOLF CREEK ST WEPD) x - - - - x -180.0

180.00 CHNL# 9: (ANG WHITE DEER WIND SPS) - - - - + -180.0

180.00 CHNL# 21: (ANG GILL EN CTR WHEEL) - - - - + -180.0

180.00 CHNL# 8: (ANG CAPROCK WIND SPS) - - - - + -180.0

180.00 CHNL# 20: (ANG EVANS SVC WERE) - - - - + -180.0

180.00 CHNL# 7: (ANG SANJUANMESA WIND 2 SPS) - - - - + -180.0

180.00 CHNL# 19: (ANG MCPHERSON PLANT WERE) - - - - + -180.0

180.00 CHNL# 6: (ANG SANJUANMESA WIND 1 SPS) - - - - + -180.0

180.00 CHNL# 18: (ANG EVANS EN CTR WERE) - - - - + -180.0



**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
**FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
**FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT  
 CHNL# 76: (ANG GEN 2004-003 CLR 5) X - - - - > 0.0

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT  
 CHNL# 82: (ANG GEN 2004-003 CLR 9) X - - - - > 0.0


360.00 CHNL# 77: (ANG GEN 2004-003 CLR 4) X - - - - > 0.0  
 360.00 CHNL# 76: (ANG GEN 2004-003 CLR 3) ← - - - - + 0.0

360.00 CHNL# 83: (ANG GEN 2004-003 CLR 10) X - - - - > 0.0  
 360.00 CHNL# 82: (ANG GEN 2004-003 CLR 9) ← - - - - + 0.0

360.00 CHNL# 75: (ANG GEN 2004-003 CLR 2) ← - - - - + 0.0  
 360.00 CHNL# 74: (ANG GEN 2004-003 CLR 11) ← - - - - + 0.0

360.00 CHNL# 85: (ANG GEN 2004-003 CLR 12) ← - - - - + 0.0  
 360.00 CHNL# 86: (ANG GEN 2004-003 CLR 13) ← - - - - + 0.0

TUE, MAY 03 2005 15:42  
 ROTOR ANGLE



**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
**FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
**FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**


FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT  
 CHNL# 81: (ANG GEN 2004-003 CLR 8) ← - - - - + 0.0

360.00 CHNL# 82: (ANG GEN 2004-003 CLR 9) X - - - - > 0.0  
 360.00 CHNL# 81: (ANG GEN 2004-003 CLR 8) ← - - - - + 0.0

360.00 CHNL# 80: (ANG GEN 2004-003 CLR 7) ← - - - - + 0.0  
 360.00 CHNL# 79: (ANG GEN 2004-003 CLR 6) X - - - - > 0.0

360.00 CHNL# 82: (ANG GEN 2004-003 CLR 9) X - - - - > 0.0  
 360.00 CHNL# 80: (ANG GEN 2004-003 CLR 7) ← - - - - + 0.0

TUE, MAY 03 2005 15:42  
 ROTOR ANGLE



**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
**FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
**FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT  
 CHNL# 78: (ANG GEN 2004-003 CLR 5) X - - - - > 0.0

360.00 CHNL# 77: (ANG GEN 2004-003 CLR 4) X - - - - > 0.0  
 360.00 CHNL# 76: (ANG GEN 2004-003 CLR 3) ← - - - - + 0.0

360.00 CHNL# 75: (ANG GEN 2004-003 CLR 2) ← - - - - + 0.0  
 360.00 CHNL# 74: (ANG GEN 2004-003 CLR 11) ← - - - - + 0.0

360.00 CHNL# 73: (ANG GEN 2002-022) ← - - - - + 0.0  
 360.00 CHNL# 72: (ANG GEN 2002-019) ← - - - - + 0.0


TUE, MAY 03 2005 15:42  
 ROTOR ANGLE

2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)


2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

FILE: C:\Pterra\...\SPP FUTURE\_Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT  
360.00 CHNU# 101: (ANG GEN 2004-003 CLR 29) x - - - - x 0.0  
360.00 CHNU# 100: (ANG GEN 2004-003 CLR 27) x - - - - + 0.0  
360.00 CHNU# 99: (ANG GEN 2004-003 CLR 26) x - - - - + 0.0  
360.00 CHNU# 98: (ANG GEN 2004-003 CLR 25) x - - - - + 0.0  
360.00 CHNU# 97: (ANG GEN 2004-003 CLR 24) x - - - - + 0.0

FILE: C:\Pterra\...\SPP FUTURE\_Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT  
360.00 CHNU# 113: (ANG GEN 2004-003 CLR 41) x - - - - x 0.0  
360.00 CHNU# 112: (ANG GEN 2004-003 CLR 39) x - - - - + 0.0  
360.00 CHNU# 111: (ANG GEN 2004-003 CLR 38) x - - - - + 0.0  
360.00 CHNU# 110: (ANG GEN 2004-003 CLR 37) x - - - - + 0.0  
360.00 CHNU# 109: (ANG GEN 2004-003 CLR 36) x - - - - + 0.0



FILE: C:\Pterra\...\SPP FUTURE\_Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT  
360.00 CHNU# 101: (ANG GEN 2004-003 CLR 29) x - - - - x 0.0  
360.00 CHNU# 100: (ANG GEN 2004-003 CLR 27) x - - - - + 0.0  
360.00 CHNU# 99: (ANG GEN 2004-003 CLR 26) x - - - - + 0.0  
360.00 CHNU# 98: (ANG GEN 2004-003 CLR 25) x - - - - + 0.0  
360.00 CHNU# 97: (ANG GEN 2004-003 CLR 24) x - - - - + 0.0




2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

FILE: C:\Pterra\...\SPP FUTURE\_Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT  
360.00 CHNU# 98: (ANG GEN 2004-003 CLR 23) x - - - - x 0.0  
360.00 CHNU# 99: (ANG GEN 2004-003 CLR 22) x - - - - x 0.0  
360.00 CHNU# 94: (ANG GEN 2004-003 CLR 21) x - - - - + 0.0  
360.00 CHNU# 93: (ANG GEN 2004-003 CLR 20) x - - - - + 0.0  
360.00 CHNU# 92: (ANG GEN 2004-003 CLR 19) x - - - - + 0.0  
360.00 CHNU# 91: (ANG GEN 2004-003 CLR 18) x - - - - + 0.0  
360.00 CHNU# 103: (ANG GEN 2004-003 CLR 30) x - - - - + 0.0

2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

FILE: C:\Pterra\...\SPP FUTURE\_Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT  
360.00 CHNU# 107: (ANG GEN 2004-003 CLR 35) x - - - - x 0.0  
360.00 CHNU# 106: (ANG GEN 2004-003 CLR 34) x - - - - x 0.0  
360.00 CHNU# 105: (ANG GEN 2004-003 CLR 32) x - - - - + 0.0  
360.00 CHNU# 104: (ANG GEN 2004-003 CLR 31) x - - - - + 0.0  
360.00 CHNU# 103: (ANG GEN 2004-003 CLR 30) x - - - - + 0.0



2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

FILE: C:\Pterra\...\SPP FUTURE\_Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT  
360.00 CHNU# 101: (ANG GEN 2004-003 CLR 29) x - - - - x 0.0  
360.00 CHNU# 100: (ANG GEN 2004-003 CLR 27) x - - - - + 0.0  
360.00 CHNU# 99: (ANG GEN 2004-003 CLR 26) x - - - - + 0.0  
360.00 CHNU# 98: (ANG GEN 2004-003 CLR 25) x - - - - + 0.0  
360.00 CHNU# 97: (ANG GEN 2004-003 CLR 24) x - - - - + 0.0

2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

FILE: C:\Pterra\...\SPP FUTURE\_Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT

FILE: C:\Pterra\...\SPP FUTURE\_Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT

360.00 CHNU# 12.5: (ANG GEN 2004-003 CLR 52) x - - - - x 0.0

360.00 CHNU# 12.4: (ANG GEN 2004-003 CLR 51) - - - + 0.0


360.00 CHNU# 12.3: (ANG GEN 2004-003 CLR 50) - - - - + 0.0

360.00 CHNU# 12.2: (ANG GEN 2004-003 CLR 49) - - - - + 0.0

360.00 CHNU# 12.1: (ANG GEN 2004-003 CLR 48) B - E 0.0

360.00 CHNU# 13.3: (ANG GEN 2004-003 CLR 60) B - E 0.0

TUE, MAY 03 2005 15:42 ROTOR ANGLE



2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

FILE: C:\Pterra\...\SPP FUTURE\_Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT

FILE: C:\Pterra\...\SPP FUTURE\_Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT

360.00 CHNU# 11.9: (ANG GEN 2004-003 CLR 47) x - - - - x 0.0

360.00 CHNU# 11.8: (ANG GEN 2004-003 CLR 46) x - - - - x 0.0


360.00 CHNU# 11.7: (ANG GEN 2004-003 CLR 45) - - - + 0.0

360.00 CHNU# 11.6: (ANG GEN 2004-003 CLR 44) - - - - + 0.0

360.00 CHNU# 11.5: (ANG GEN 2004-003 CLR 43) - - - - + 0.0

360.00 CHNU# 11.5: (ANG GEN 2004-003 CLR 42) B - E 0.0

TUE, MAY 03 2005 15:42 ROTOR ANGLE



2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

FILE: C:\Pterra\...\SPP FUTURE\_Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT

FILE: C:\Pterra\...\SPP FUTURE\_Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT

360.00 CHNU# 13.2: (ANG GEN 2004-003 CLR 59) x - - - - x 0.0



360.00 CHNU# 13.1: (ANG GEN 2004-003 CLR 58) x - - - - x 0.0

360.00 CHNU# 13.0: (ANG GEN 2004-003 CLR 57) - - - + 0.0

360.00 CHNU# 12.9: (ANG GEN 2004-003 CLR 56) - - - - + 0.0

360.00 CHNU# 12.8: (ANG GEN 2004-003 CLR 55) - - - - + 0.0

360.00 CHNU# 12.7: (ANG GEN 2004-003 CLR 54) B - E 0.0





**2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

**2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT







**2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**





**2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT








2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

FILE: C:\Pterra\...\SPP FUTURE\_Fall\FALL-003\OUTPUT\17\_FLT17PH.OUT  
2.5008 CHNL# 351: (SPEED GEN 2004-003 CLR 81) -1.500


TUE, MAY 03 2005 15:42 SPEED



2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

FILE: C:\Pterra\...\SPP FUTURE\_Fall\FALL-003\OUTPUT\17\_FLT17PH.OUT  
2.5008 CHNL# 361: (SPEED GEN 2004-003 CLR 13) -1.500



TUE, MAY 03 2005 15:42 SPEED



2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)





FILE: C:\Pterra\...\SPP FUTURE\_Fall\FALL-003\OUTPUT\17\_FLT17PH.OUT  
2.5008 CHNL# 369: (SPEED GEN 2004-003 CLR 20) -1.500

TUE, MAY 03 2005 15:42 SPEED



**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
**FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
**FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**



2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)


2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

FILE: C:\Pterra\...\SPP FUTURE\_Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT  
2.5.008 CIR# 404: [SPEED GEN 2004-003 CLR 55] x - - - - x -1.500

2.5.008 CIR# 403: [SPEED GEN 2004-003 CLR 54] ← - - - - + -1.500  
CIR# 402: [SPEED GEN 2004-003 CLR 53] ← - - - - ◆ -1.500

2.5.008 CIR# 401: [SPEED GEN 2004-003 CLR 52] ← - - - - ◇ -1.500  
CIR# 400: [SPEED GEN 2004-003 CLR 51] ← - - - - □ -1.500

2.5.008 CIR# 403: [SPEED GEN 2004-003 CLR 50] ← - - - - ◇ -1.500




2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

FILE: C:\Pterra\...\SPP FUTURE\_Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT  
2.5.008 CIR# 415: [VOLTAGE RED HILLS WIND\_WFEC] ← - - - - + -1.500

2.5.008 CIR# 414: [VOLTAGE EAST GUNNOM WIND\_SPS] ← - - - - ◇ -1.500  
CIR# 413: [VOLTAGE MUNKERS CREEK WIND\_WFEC] ← - - - - □ -1.500

2.5.008 CIR# 412: [VOLTAGE SLEEPING BEAR WIND\_WFEC] ← - - - - □ -1.500



2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT  
CIRCUIT PROCESS  
CIRCUIT NUMBER: 426: (NORTHERN SYSTEM 345KV)

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT  
CIRCUIT PROCESS  
CIRCUIT NUMBER: 426: (NORTHERN SYSTEM 345KV)

1.1.000 CIRCUIT 425: (VOLTAGE W GRDR 345KV) X - - - - X 0.50000

1.1.000 CIRCUIT 425: (VOLTAGE W GRDR 345KV) X - - - - X 0.50000

1.1.000 CIRCUIT 424: (VOLTAGE LATAN 345KV) ← - - - - + 0.50000

1.1.000 CIRCUIT 424: (VOLTAGE LATAN 345KV) ← - - - - + 0.50000

1.1.000 CIRCUIT 423: (VOLTAGE FPL WOODWARD WIND GSE) ← - - - - ♦ 0.50000

1.1.000 CIRCUIT 423: (VOLTAGE FPL WOODWARD WIND GSE) ← - - - - ♦ 0.50000

1.1.000 CIRCUIT 422: (VOLTAGE BLUE CANYON WIND WECI) ← - - - - → 0.50000

1.1.000 CIRCUIT 422: (VOLTAGE BLUE CANYON WIND WECI) ← - - - - → 0.50000

1.1.000 CIRCUIT 421: (VOLTAGE GRAY CO WIND WECI) ← - - - - → 0.50000

1.1.000 CIRCUIT 421: (VOLTAGE GRAY CO WIND WECI) ← - - - - → 0.50000

1.1.000 CIRCUIT 420: (VOLTAGE BULL RIVER WIND 1 WECI) ← - - - - → 0.50000

1.1.000 CIRCUIT 420: (VOLTAGE BULL RIVER WIND 1 WECI) ← - - - - → 0.50000

1.1.000 CIRCUIT 419: (VOLTAGE CAPROK WIND SPSI) ← - - - - → 0.50000

1.1.000 CIRCUIT 419: (VOLTAGE CAPROK WIND SPSI) ← - - - - → 0.50000

1.1.000 CIRCUIT 418: (VOLTAGE SANJUAN MESA WIND 2 SPSI) ← - - - - ♦ 0.50000


1.1.000 CIRCUIT 418: (VOLTAGE SANJUAN MESA WIND 2 SPSI) ← - - - - ♦ 0.50000

1.1.000 CIRCUIT 417: (VOLTAGE SANJUAN MESA WIND 1 SPSI) ← - - - - → 0.50000

1.1.000 CIRCUIT 417: (VOLTAGE SANJUAN MESA WIND 1 SPSI) ← - - - - → 0.50000

1.1.000 CIRCUIT 416: (VOLTAGE BULL RIVER WIND 1 WECI) ← - - - - → 0.50000

1.1.000 CIRCUIT 416: (VOLTAGE BULL RIVER WIND 1 WECI) ← - - - - → 0.50000



2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT

1.1.000 CIRCUIT 425: (VOLTAGE JEC N 345KV) X - - - - X 0.50000

1.1.000 CIRCUIT 425: (VOLTAGE JEC N 345KV) X - - - - X 0.50000

1.1.000 CIRCUIT 424: (VOLTAGE LATAN 345KV) ← - - - - + 0.50000

1.1.000 CIRCUIT 424: (VOLTAGE LATAN 345KV) ← - - - - + 0.50000

1.1.000 CIRCUIT 423: (VOLTAGE CRAGS 345KV) ← - - - - → 0.50000

1.1.000 CIRCUIT 423: (VOLTAGE CRAGS 345KV) ← - - - - → 0.50000

1.1.000 CIRCUIT 422: (VOLTAGE HANTH 345KV) ← - - - - → 0.50000

1.1.000 CIRCUIT 422: (VOLTAGE HANTH 345KV) ← - - - - → 0.50000

1.1.000 CIRCUIT 421: (VOLTAGE BULL RIVER WIND 1 WECI) ← - - - - → 0.50000

1.1.000 CIRCUIT 421: (VOLTAGE BULL RIVER WIND 1 WECI) ← - - - - → 0.50000

1.1.000 CIRCUIT 420: (VOLTAGE CAPROK WIND SPSI) ← - - - - → 0.50000

1.1.000 CIRCUIT 420: (VOLTAGE CAPROK WIND SPSI) ← - - - - → 0.50000

1.1.000 CIRCUIT 418: (VOLTAGE SANJUAN MESA WIND 2 SPSI) ← - - - - ♦ 0.50000


1.1.000 CIRCUIT 418: (VOLTAGE SANJUAN MESA WIND 2 SPSI) ← - - - - ♦ 0.50000

1.1.000 CIRCUIT 417: (VOLTAGE SANJUAN MESA WIND 1 SPSI) ← - - - - → 0.50000

1.1.000 CIRCUIT 417: (VOLTAGE SANJUAN MESA WIND 1 SPSI) ← - - - - → 0.50000

1.1.000 CIRCUIT 416: (VOLTAGE BULL RIVER WIND 1 WECI) ← - - - - → 0.50000

1.1.000 CIRCUIT 416: (VOLTAGE BULL RIVER WIND 1 WECI) ← - - - - → 0.50000



2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT

FILE: C:\Pterra\...\SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT

1.1.000 CIRCUIT 425: (VOLTAGE W GRDR 345KV) X - - - - X 0.50000

1.1.000 CIRCUIT 425: (VOLTAGE W GRDR 345KV) X - - - - X 0.50000

1.1.000 CIRCUIT 424: (VOLTAGE LATAN 345KV) ← - - - - + 0.50000

1.1.000 CIRCUIT 424: (VOLTAGE LATAN 345KV) ← - - - - + 0.50000

1.1.000 CIRCUIT 423: (VOLTAGE CRAGS 345KV) ← - - - - → 0.50000

1.1.000 CIRCUIT 423: (VOLTAGE CRAGS 345KV) ← - - - - → 0.50000

1.1.000 CIRCUIT 422: (VOLTAGE HANTH 345KV) ← - - - - → 0.50000

1.1.000 CIRCUIT 422: (VOLTAGE HANTH 345KV) ← - - - - → 0.50000

1.1.000 CIRCUIT 421: (VOLTAGE BULL RIVER WIND 1 WECI) ← - - - - → 0.50000

1.1.000 CIRCUIT 421: (VOLTAGE BULL RIVER WIND 1 WECI) ← - - - - → 0.50000

1.1.000 CIRCUIT 420: (VOLTAGE CAPROK WIND SPSI) ← - - - - → 0.50000

1.1.000 CIRCUIT 420: (VOLTAGE CAPROK WIND SPSI) ← - - - - → 0.50000

1.1.000 CIRCUIT 418: (VOLTAGE SANJUAN MESA WIND 2 SPSI) ← - - - - ♦ 0.50000

1.1.000 CIRCUIT 418: (VOLTAGE SANJUAN MESA WIND 2 SPSI) ← - - - - ♦ 0.50000

1.1.000 CIRCUIT 417: (VOLTAGE SANJUAN MESA WIND 1 SPSI) ← - - - - → 0.50000

1.1.000 CIRCUIT 417: (VOLTAGE SANJUAN MESA WIND 1 SPSI) ← - - - - → 0.50000

1.1.000 CIRCUIT 416: (VOLTAGE BULL RIVER WIND 1 WECI) ← - - - - → 0.50000

1.1.000 CIRCUIT 416: (VOLTAGE BULL RIVER WIND 1 WECI) ← - - - - → 0.50000

**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
**FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
**FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

FILE: C:\Pterra\...\SPP FUTURE\_Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT  
 CIRCUIT PROCESS  
 FILE: C:\Pterra\...\SPP FUTURE\_Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT  
 CIRCUIT PROCESS

FILE: C:\Pterra\...\SPP FUTURE\_Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT  
 CIRCUIT PROCESS

1.1.000 CIRCUIT 449: (VOLTAGE GEN 2002-019) X - - - - X 0.50000

1.1.000 CIRCUIT 452: (VOLTAGE GEN 2004-03 CLR 7) X - - - - X 0.50000

1.1.000 CIRCUIT 448: (VOLTAGE MCFERSON PLANT) - - - - + 0.50000

1.1.000 CIRCUIT 453: (VOLTAGE GEN 2004-03 CLR 6) - - - - + 0.50000

1.1.000 CIRCUIT 447: (VOLTAGE FAIRB 345KV) + - - - + 0.50000


1.1.000 CIRCUIT 454: (VOLTAGE MORGAN 345KV) + - - - + 0.50000

1.1.000 CIRCUIT 446: (VOLTAGE SIBLEY 345KV) + - - - + 0.50000



1.1.000 CIRCUIT 455: (VOLTAGE GEN 2004-03 CLR 5) + - - - + 0.50000

1.1.000 CIRCUIT 445: (VOLTAGE MORGAN 345KV) + - - - + 0.50000

1.1.000 CIRCUIT 456: (VOLTAGE GEN 2004-03 CLR 4) + - - - + 0.50000



TUE, MAY 03 2005 15:42 VOLTAGE



TUE, MAY 03 2005 15:42 VOLTAGE

**2004 SERIES, NERC/MMWG BASE CASE LIBRARY**  
**FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

FILE: C:\Pterra\...\SPP FUTURE\_Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT  
 CIRCUIT PROCESS

1.1.000 CIRCUIT 443: (VOLTAGE PLANT HBL 345KV) - - - - > 0.50000

1.1.000 CIRCUIT 442: (VOLTAGE WOLFTRK 345KV) X - - - - X 0.50000

1.1.000 CIRCUIT 441: (VOLTAGE WISHTA 345KV) + - - - + 0.50000

1.1.000 CIRCUIT 440: (VOLTAGE ROSEBL 345KV) + - - - + 0.50000

1.1.000 CIRCUIT 439: (VOLTAGE NEOSH 345KV) + - - - + 0.50000

1.1.000 CIRCUIT 438: (VOLTAGE NEOSH 345KV) + - - - + 0.50000

1.1.000 CIRCUIT 437: (VOLTAGE GEN 2002-019) X - - - - X 0.50000

1.1.000 CIRCUIT 436: (VOLTAGE GEN 2004-03 CLR 8) + - - - + 0.50000

1.1.000 CIRCUIT 435: (VOLTAGE GEN 2004-03 CLR 7) + - - - + 0.50000

1.1.000 CIRCUIT 434: (VOLTAGE GEN 2004-03 CLR 6) + - - - + 0.50000

1.1.000 CIRCUIT 433: (VOLTAGE GEN 2004-03 CLR 5) + - - - + 0.50000

1.1.000 CIRCUIT 432: (VOLTAGE GEN 2004-03 CLR 4) + - - - + 0.50000

1.1.000 CIRCUIT 431: (VOLTAGE GEN 2004-03 CLR 3) + - - - + 0.50000

1.1.000 CIRCUIT 430: (VOLTAGE GEN 2004-03 CLR 2) + - - - + 0.50000

1.1.000 CIRCUIT 429: (VOLTAGE GEN 2004-03 CLR 1) + - - - + 0.50000

1.1.000 CIRCUIT 428: (VOLTAGE GEN 2004-03 CLR 0) + - - - + 0.50000

1.1.000 CIRCUIT 427: (VOLTAGE GEN 2004-03 CLR 9) + - - - + 0.50000

1.1.000 CIRCUIT 426: (VOLTAGE GEN 2004-03 CLR 8) + - - - + 0.50000

1.1.000 CIRCUIT 425: (VOLTAGE GEN 2004-03 CLR 7) + - - - + 0.50000

1.1.000 CIRCUIT 424: (VOLTAGE GEN 2004-03 CLR 6) + - - - + 0.50000

1.1.000 CIRCUIT 423: (VOLTAGE GEN 2004-03 CLR 5) + - - - + 0.50000

1.1.000 CIRCUIT 422: (VOLTAGE GEN 2004-03 CLR 4) + - - - + 0.50000

1.1.000 CIRCUIT 421: (VOLTAGE GEN 2004-03 CLR 3) + - - - + 0.50000

1.1.000 CIRCUIT 420: (VOLTAGE GEN 2004-03 CLR 2) + - - - + 0.50000


1.1.000 CIRCUIT 419: (VOLTAGE GEN 2004-03 CLR 1) + - - - + 0.50000

1.1.000 CIRCUIT 418: (VOLTAGE GEN 2004-03 CLR 0) + - - - + 0.50000

1.1.000 CIRCUIT 417: (VOLTAGE GEN 2004-03 CLR 9) + - - - + 0.50000

1.1.000 CIRCUIT 416: (VOLTAGE GEN 2004-03 CLR 8) + - - - + 0.50000

1.1.000 CIRCUIT 415: (VOLTAGE GEN 2004-03 CLR 7) + - - - + 0.50000



TUE, MAY 03 2005 15:42 VOLTAGE

**M** 2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)


**M** 2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

FILE: C:\Pterra\.\^SPP FUTURE Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT  
1.5000 CHNL# 46.9: VOLTAGE GEN 2004-003 CLR 19 - - - - > 0.50000  
1.5000 CHNL# 46.8: VOLTAGE GEN 2004-003 CLR 18 - - - - + 0.50000  
1.5000 CHNL# 46.7: VOLTAGE GEN 2004-003 CLR 17 - - - - + 0.50000  
1.5000 CHNL# 46.6: VOLTAGE GEN 2004-003 CLR 16 - - - - + 0.50000  
1.5000 CHNL# 46.5: VOLTAGE GEN 2004-003 CLR 15 - - - - + 0.50000

TUE, MAY 03 2005 15:42  
VOLTAGE

FILE: C:\Pterra\.\^SPP FUTURE Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT  
1.5000 CINH# 48.1: VOLTAGE GEN 2004-003 CLR 31 - - - - > 0.50000  
1.5000 CINH# 48.0: VOLTAGE GEN 2004-003 CLR 30 - - - - + 0.50000  
1.5000 CINH# 47.9: VOLTAGE GEN 2004-003 CLR 29 - - - - + 0.50000  
1.5000 CINH# 47.8: VOLTAGE GEN 2004-003 CLR 28! - - - - + 0.50000

TUE, MAY 03 2005 15:42  
VOLTAGE




**M** 2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)

FILE: C:\Pterra\.\^SPP FUTURE Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT  
1.5000 CHNL# 46.9: VOLTAGE GEN 2004-003 CLR 14 - - - - > 0.50000  
1.5000 CHNL# 46.8: VOLTAGE GEN 2004-003 CLR 13 - - - - > 0.50000  
1.5000 CHNL# 46.2: VOLTAGE GEN 2004-003 CLR 12! - - - - + 0.50000  
1.5000 CHNL# 46.1: VOLTAGE GEN 2004-003 CLR 11! - - - - + 0.50000  
1.5000 CHNL# 46.0: VOLTAGE GEN 2004-003 CLR 10! - - - - + 0.50000  
1.5000 CHNL# 45.9: VOLTAGE GEN 2004-003 CLR 9! - - - - + 0.50000

TUE, MAY 03 2005 15:42  
VOLTAGE

FILE: C:\Pterra\.\^SPP FUTURE Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT  
1.5000 CHNL# 47.5: VOLTAGE GEN 2004-003 CLR 25! - - - - > 0.50000  
1.5000 CINH# 47.4: VOLTAGE GEN 2004-003 CLR 24! - - - - + 0.50000  
1.5000 CINH# 47.3: VOLTAGE GEN 2004-003 CLR 23! - - - - + 0.50000  
1.5000 CINH# 47.2: VOLTAGE GEN 2004-003 CLR 22! - - - - + 0.50000  
1.5000 CINH# 47.1: VOLTAGE GEN 2004-003 CLR 21! - - - - + 0.50000

TUE, MAY 03 2005 15:42  
VOLTAGE



FILE: C:\Pterra\.\^SPP FUTURE Fall\Fall-003\OUTPUT\17\_FLT173PH.OUT  
1.5000 CHNL# 46.9: VOLTAGE GEN 2004-003 CLR 14 - - - - > 0.50000  
1.5000 CHNL# 46.8: VOLTAGE GEN 2004-003 CLR 13 - - - - > 0.50000  
1.5000 CHNL# 46.2: VOLTAGE GEN 2004-003 CLR 12! - - - - + 0.50000  
1.5000 CHNL# 46.1: VOLTAGE GEN 2004-003 CLR 11! - - - - + 0.50000  
1.5000 CHNL# 46.0: VOLTAGE GEN 2004-003 CLR 10! - - - - + 0.50000  
1.5000 CHNL# 45.9: VOLTAGE GEN 2004-003 CLR 9! - - - - + 0.50000

TUE, MAY 03 2005 15:42  
VOLTAGE

**2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**


**2004 SERIES, NERC/MMWG BASE CASE LIBRARY  
FUTURE FALL, GI MODEL (LOADS FROM 2005 FALL-GENS FUTURE)**

FILE: C:\Pterra\.\^SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT  
1.5000 CHNL# 4931: VOLTAGE GEN 2004-003 CLR 44 ↘ - - - - - 0.50000  
1.5000 CHNL# 4932: VOLTAGE GEN 2004-003 CLR 421 ↗ - - - - + 0.50000  
1.5000 CHNL# 4911: VOLTAGE GEN 2004-003 CLR 411 ↗ - - - - + 0.50000  
1.5000 CHNL# 4901: VOLTAGE GEN 2004-003 CLR 401 ↗ - - - - + 0.50000  
1.5000 CHNL# 4891: VOLTAGE GEN 2004-003 CLR 391 ↗ - - - - + 0.50000


TUE, MAY 03 2005 15:42  
VOLTAGE

FILE: C:\Pterra\.\^SPP FUTURE Fall\FALL-003\OUTPUT\17\_FLT173PH.OUT  
1.5000 CHNL# 505: VOLTAGE GEN 2004-003 CLR 55 ↘ - - - - - 0.50000  
1.5000 CHNL# 504: VOLTAGE GEN 2004-003 CLR 541 ↗ - - - - + 0.50000  
1.5000 CHNL# 503: VOLTAGE GEN 2004-003 CLR 531 ↗ - - - - + 0.50000  
1.5000 CHNL# 502: VOLTAGE GEN 2004-003 CLR 521 ↗ - - - - + 0.50000  
1.5000 CHNL# 501: VOLTAGE GEN 2004-003 CLR 511 ↗ - - - - + 0.50000

TUE, MAY 03 2005 15:42  
VOLTAGE



TUE, MAY 03 2005 15:42  
VOLTAGE



TUE, MAY 03 2005 15:42  
VOLTAGE