



***System Impact Study for Generation
Interconnection Request***

GEN-2004-005

SPP Tariff Studies

(#GEN-2004-005)

December 2004

Executive Summary

<OMITTED TEXT>Customer has requested a System Impact Study to evaluate a proposal to add up to 275MW of coal-fired generation at an existing City Utilities Springfield, Missouri plant in Greene County, MO. The requested in-service date is March 1, 2009.

The Customer has proposed the addition of 275MW of coal-fired generation at the site. The unit will be interconnected to the existing Southwest Power Station (SWPS) 161kV substation.

The network upgrade requirements include expansion of the SWPS 161kV bus and installation of three (3) new 161kV circuit breakers. This expansion would provide terminals for the unit generator step up transformer and station service transformer necessary for the generation interconnection. The estimated cost of this network upgrade is \$2,500,000 with construction completed by the station in-service date of March 1, 2009.

During the single-contingency analysis performed as part of the System Impact Study, it was found that during the 2010 Winter Peak time period, the Southwest Power Administration 161kV line from Springfield to Clay overloads for the outage of the City Utilities Southwest Power Station to James River Power Station 161kV line. This overload can be mitigated by replacement of the Springfield disconnect switches. The cost of this upgrade is estimated at \$200,000 and would increase the emergency rating to 188MVA from 167MVA. The lead-time for this upgrade is estimated at 12 months.

The total estimated cost of the required network upgrades for interconnection is \$2,700,000.

Short circuit analysis will be performed as part of the Facility Study performed by the Transmission Owner if the customer wishes to proceed.

Transient stability analysis indicates that for more probable disturbances with normal fault clearing times, system stability is maintained. Three-phase to ground faults were applied at numerous locations on the surrounding transmission system including simulated loss of generation at SWPS unit #1 and the planned unit #2. No fault resulted in either angular or voltage instability. No upgrades are required at this time to maintain system stability.

Transmission Service is not analyzed during the interconnection impact study.

1. Introduction

1.1 Project Description

<OMITTED TEXT>Customer has requested an System Impact Study to evaluate a proposal to add up to 275MW of coal-fired generation at an existing City Utilities Springfield, Missouri plant in Greene County, MO. The requested in-service date is March 1, 2009.

1.2 Study Methodology

The Interconnection System Impact Study investigates the effect of new generation on system performance during normal and contingency conditions. Deliverability of power to final customers is not analyzed. Those facilities that are affected only by the interconnection of the generation are analyzed in the Interconnection System Impact Study. Separate studies evaluate the impact of deliverability of the plants output.

Comparison of the base case, which excludes any proposed facilities, to the study case, which includes the proposed Customer unit, reveals any system constraints that result from the proposed generation addition. The analysis cases are based on the SPP 2004 Series, Update 4 models representing the 2010 summer peak and 2010 winter peak. The proposed plant is modeled at maximum output of 275MW for all study cases.

The proposed plant is to be located in the City Utilities, Springfield Missouri (SPRM) transmission system.

Full AC contingency analysis (ACCC) is used to investigate the limiting constraints of the transmission system during contingency events. The analysis is performed using Shaw PTI's PSS/E v. 29.5. Comparisons are made between the cases with and without the Customer generation in service in order to identify the severity and cause of the overloading conditions. All branches in the SPRM system and surrounding control areas and all ties with SPRM are monitored for overloads exceeding 100% of emergency rating (Rate B). A TDF of 3% is required before a facility is flagged as impacted. Buses are monitored for voltage deviations exceeding +/- 5% of nominal.

2. Powerflow Analysis

2.1 2010 Summer Peak

Added generation at the Customer facility results in no base case overloads on the transmission system. During single contingency analysis, no overloading occurs as a result of outages of transmission facilities in the 2010 Summer Peak case.

2.2 2010 Winter Peak

Added generation at the Customer facility results in no base case overloads on the transmission system. During single contingency analysis, one facility is overloaded as a result of a separate outage of transmission facilities in the 2010 Winter Peak case. The table below shows the facility impacted by the addition of the proposed generation.

| Study Case | From Area | To Area | Monitored Branch Over 100% Rate B | Rate <MVA> | BC % Loading | TC % Loading | %TDF | Outaged Branch Causing Overload |
|------------|-----------|---------|-----------------------------------|------------|--------------|--------------|--------|---------------------------------|
| 10WP | SPRM | SWPA | CLAY - SPRINGFIELD 161KV | 167 | 41.039 | 103.79 | 38.109 | JAMES RIVER - SOUTHWEST 161KV |

SPRM has included a second 161kV circuit from SWPS – Battlefield in the SPP 2010 models. This line was considered a proposed facility and was removed from service for the contingency analysis. The line was closed to determine if the above contingency overload was mitigated by the line. Loading on the Clay – Springfield 161kV line increased slightly by including the proposed SWPS – Battlefield 161kV line in the case. However, the loading increase was minimal and would still be mitigated by the replacement of the disconnect switches at Springfield discussed later.

3. Interconnection Network Upgrades

3.1 Interconnection Substation

The Customer plant will be interconnected with the 161kV transmission system at the SWPS substation in Greene County, MO. The existing 161kV bus will be expanded to accommodate the new generating unit and a new station service transformer. Three (3) 161kV circuit breakers will be added to accommodate the new unit. The estimated cost of the interconnection substation work is \$2,500,000.

3.2 161kV Upgrades

After the installation of the proposed generation, the Southwest Power Administration (SWPA) Springfield to Clay 161kV line must be upgraded to alleviate the overload that occurs during the outage of the SWPS to James River Power Station 161kV line. Upgrade of this facility will include replacement of the disconnect switches at Springfield to increase the emergency rating to 188MVA. The estimated cost of this upgrade is \$200,000.

The preliminary cost estimates for the network upgrade facilities are listed in Table 1 below. An estimated project schedule will be included in the Facility Study.

| Table 1 – Summary of Network Upgrade Costs for Interconnection | |
|--|--------------------|
| Stand Alone Network Upgrades | |
| Description | Cost |
| SWPS 161kV substation facilities and equipment to facilitate interconnection | \$2,500,000 |
| Total Stand Alone Network Upgrades | \$2,500,000 |

| Other Required Network Upgrades | |
|---|--------------------|
| Description | Cost |
| Disconnect switches at Springfield on SWPA Springfield – Clay 161kV | \$200,000 |
| Total Other Required Network Upgrades | \$200,000 |
| Total Required Network Upgrades | \$2,700,000 |

The facilities mentioned above are required only for interconnection of the generation facility.

4. Short Circuit Analysis

A short circuit study will be conducted by SPRM as part of the Facility Study to determine if fault current levels exceed equipment ratings at SPRM facilities.

5. Transient Stability Analysis

Transient Stability analysis was performed to verify dynamic system response to disturbances on the system using the 2010 summer peak model. The customer provided the machine data for the proposed Customer plant. Typical values were provided for a 334MVA generator with an ESST1A exciter. This data was used to create a PTI dynamics model for the Customer plant. The machine data for the remaining system was obtained from the current SPP dynamics data files modified to include all previously queued plants proposed for the study period. Selected three-phase fault scenarios were simulated. Machines in the SPRM system and surrounding control areas were monitored for stability. A list of the faults applied is in Table 2 below.

Table 2 Selected Faults

| Fault # | Fault Description |
|----------------|---|
| FLT_1_3PH | Three Phase fault at Southwest Power Station (SWPS) on the SWPS-SWDisposal 161kV line |
| FLT_2_3PH | Three Phase fault at Brookline on the SWPS – Brookline 161kV line |
| FLT_3_3PH | Three Phase fault at the line midpoint on the SWPS – James River Power Station 161kV line |
| FLT_4_3PH | Three Phase fault at Battlefield on the SWDisposal – Battlefield 161kV line |
| FLT_5_3PH | Three Phase fault at Springfield on the Springfield – Clay 161kV line |
| FLT_6_3PH | Three Phase fault at Brookline on the Brookline – Flint Creek 345kV line |
| FLT_7_3PH | Three Phase fault at Main on the Battlefield – Main 161kV line |
| FLT_8_3PH | Three Phase fault at Brookline on the Brookline – Morgan 161kV line |
| FLT_9_3PH | Three Phase fault at Brookline on the Brookline – Junction 161kV line |
| FLT_10 | Trip SWPS unit #1 |
| FLT_11 | Trip Customer plant (SWPS unit #2) |
| FLT_12_3PH | Three Phase fault at SWPS on the SWPS – Battlefield 161kV line |

The faults above were applied in four scenarios:

1. A basecase without the Customer plant online, and the proposed SWPS – Battlefield 161kV line out-of-service
2. A basecase without the Customer plant online, and the proposed SWPS – Battlefield 161kV line in-service
3. A case with the Customer generation online at 275MW and the proposed SWPS – Battlefield 161kV line out-of-service.
4. A case with the Customer generation online at 275MW and the proposed SWPS – Battlefield 161kV line in-service.

The proposed SWPS – Battlefield line does not affect system stability whether the line is in-service or not. The line also has minimal effect on powerflow contingency results. Plots of machine angles and selected system voltages for all scenarios analyzed are attached in the Appendices to this report.

6. Conclusion

This System Impact Study was requested by Customer to assess the interconnection requirements for the addition of 275MW of new generation in Greene County, MO. The analysis evaluates the impact of introducing the new generation on the power system during normal operation and contingency conditions.

The addition of 275MW generating capacity at the proposed site results in the overloading of a transmission facility during an outage on the 161kV system. Replacement of the disconnect switches at the SWPA Springfield substation on the Springfield – Clay 161kV line are required for the plant interconnection. Estimated lead-time for this network upgrade is 12 months.

Network upgrades are also required at the SWPS substation to accommodate the proposed plant. Expansion of the 161kV bus and installation of three (3) 161kV circuit breakers is necessary for the new unit terminal and station service transformer. Land acquisition and environmental impact issues are not included in the cost of constructing interconnection facilities. The total estimated cost for the network upgrades, including those outside of the SWPS 161kV substation, is \$2,700,000. An estimated project schedule will be determined during the Facility Study.

The costs do not include any costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies when the Customer requests transmission service through Southwest Power Pool's OASIS.

Appendix A-1

Plots of Fault Simulations

Plots of selected machine angle response during faults

Scenario:

2010 Summer Peak


Basecase (SWPS-Battlefield 161kV out of service)

[No Customer Plant – No Network Upgrades]



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_1_3_PH.0UT




WED, NOV 03 2004 10:28

FLT_1_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_2_3_PH.0UT




WED, NOV 03 2004 10:28

FLT_2_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_3_3_PH.0UT




WED, NOV 03 2004 10:28

FLT_3_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_4_3_PH.0UT




WED, NOV 03 2004 10:28

FLT_4_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_5_3_PH.0UT




WED, NOV 03 2004 10:28

FLT_5_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_6_3_PH.0UT




WED, NOV 03 2004 10:28

FLT_6_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_7_3_PH.0UT




WED, NOV 03 2004 10:28

FLT_7_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_8_3_PH.0UT




WED, NOV 03 2004 10:28

FLT_8_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_9_3_PH.0UT




WED, NOV 03 2004 10:28
FLT_9_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK: MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: ... \stabilj11ty-results\FLT_10_drop_unit_1.0UT



WED, NOV 03 2004 10:28
FLT_10_MACHINE ANGLES

Appendix A-2

Plots of Fault Simulations

Plots of selected bus voltage response during faults

Scenario:

2010 Summer Peak

Basecase (SWPS-Battlefield 161kV out of service)


[No Customer Plant – No Network Upgrades]

A:\www
 SPH_Voltages
 11/3/04

SPH MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_1_3_P4.OUT

| CHNL # | CHNL NAME | VOLTAGE | PHASE |
|--------|------------------------------|---------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:19
 FLT_1_3PH_VOLTAGES

A:\www
 SPH_Voltages
 11/3/04

SPH MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_2_3_P4.OUT

| CHNL # | CHNL NAME | VOLTAGE (KV) | PHASE |
|--------|------------------------------|--------------|-------|
| 2.0000 | CHNL * 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL * 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL * 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL * 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL * 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:19
 FLT_2_3PH_VOLTAGES

A:\www
 SPN Project
 11/3/04

SPN MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_3_3_P1.OUT

| CHNL # | DESCRIPTION | VOLTAGE | PHASE |
|--------|------------------------------|---------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:19
 FLT_3_3PH_VOLTAGES

A:\www
 SPN Project
 11/3/04

SPN MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_4_3_P1.OUT

| CHNL # | CHNL NAME | VOLTAGE (KV) | PHASE |
|--------|------------------------------|--------------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:19
 FLT_4_3PH_VOLTAGES

A:\www
 SPW PAPER
 11/1/04 10:19 AM

SPW MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SUPPDED

FILE: C:\Interconnection Studies\... \stability-results\FLT_5_3_P4.OUT

| CHNL # | LOCATION | VOLTAGE | PHASE |
|--------|------------------------------|---------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:19
 FLT_5_3PH_VOLTAGES

A:\www
 SPH_PVTG.DAT
 11/03/04

SPH MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_6_SPH.OUT

| | | |
|--------|-------------------------------------|-----|
| 2.0000 | CHNL # 356: EVOLTAGE GOLDEN 161KV3 | 0.0 |
| 2.0000 | CHNL # 338: EVOLTAGE MAIN 161KV3 | 0.0 |
| 2.0000 | CHNL # 348: EVOLTAGE CLAY 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: EVOLTAGE BAKLINE 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: EVOLTAGE BAITFLD 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: EVOLTAGE SMPS 161KV3 | 0.0 |




WED, NOV 03 2004 10:19
 FLT_6_SPH_VOLTAGES

3477
 3478
 3479
 3480
 3481
 3482
 3483
 3484
 3485
 3486
 3487
 3488
 3489
 3490
 3491
 3492
 3493
 3494
 3495
 3496
 3497
 3498
 3499
 3500

SPB MDWG 04 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SUPPDED

FILE: C:\Interconnection Studies\... \stability-results\FLT_7_3_P1.OUT

| Channel # | Channel Name | Level (kV) | Phase |
|-----------|------------------------------|------------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161kV | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161kV | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161kV | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161kV | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMTS | 161kV | 0.0 |




WED, NOV 03 2004 10:19
 FLT_7_3PH_VOLTAGES

A:\www
 SPN Project
 11/3/04

SPN MDWG 04 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_8_3_P1.OUT

| CHNL # | LOCATION | VOLTAGE | PHASE |
|--------|------------------------------|---------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:19
 FLT_8_3PH_VOLTAGES

A:\www
 S:\M\Program
 11/3/04

SPR MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_9_3.PH.OUT

| CHNL # | CHNL NAME | VOLTAGE (KV) | PHASE |
|--------|------------------------------|--------------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:19
 FLT_9_VOLTAGES

3477
 3478
 3479
 3480

SPP MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCL UDINO PRIOR SCHEDULE

FILE: ... \stability-results\Flt_10_drog_unit_11.out

| | | |
|--------|-------------------------------------|-----|
| 2.0000 | CHNL # 358: CVOLTAGE GOLDEN 161KV3 | 0.0 |
| 2.0000 | CHNL # 338: CVOLTAGE MAIN 161KV3 | 0.0 |
| 2.0000 | CHNL # 348: CVOLTAGE CLAY 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BAITFLD 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS 161KV3 | 0.0 |



WED, NOV 03 2004 10:19
 FLT_10_VOLTAGES

Appendix B-1

Plots of Fault Simulations

Plots of selected machine angle response during faults

Scenario:

2010 Summer Peak


Basecase_2 (SWPS-Battlefield 161kV in service)

[No Customer Plant – No Network Upgrades]



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_1_3_PH.0UT




WED, NOV 03 2004 13:31

FLT_1_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_2_3_PH.0UT




WED, NOV 03 2004 13:31

FLT_2_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_3_3_PH.0UT




WED, NOV 03 2004 13:31

FLT_3_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_4_3_PH.0UT




WED, NOV 03 2004 13:31

FLT_4_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_5_3_PH.0UT




WED, NOV 03 2004 13:31

FLT_5_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK: MODIFIED
GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_6_3_PH.0UT




WED, NOV 03 2004 13:31

FLT_6_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_7_3_PH.0UT




WED, NOV 03 2004 13:31

FLT_7_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_8_3_PH.0UT




WED, NOV 03 2004 13:31

FLT_8_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_9_3_PH.0UT




WED, NOV 03 2004 13:31
FLT_9_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK: MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: ... \stabilj11ty-results\FLT_10_drop_unit_1.0UT




WED, NOV 03 2004 13:31
FLT_10_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK: MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-resu]ts\FLT_12_3_PH.OUT



WED, NOV 03 2004 13:31

FLT_12_3PH_MACHINE ANGLES

Appendix B-2

Plots of Fault Simulations

Plots of selected bus voltage response during faults

Scenario:

2010 Summer Peak

Basecase_2 (SWPS-Battlefield 161kV in service)


[No Customer Plant – No Network Upgrades]

3941 Page 8
11/3/04 10:25 AM

SPP MDMS Q4 STABILITY; 2010 SUM PEAK; MODIFIED
GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_1_3_P4.OUT

| CHNL # | LOCATION | VOLTAGE | PHASE |
|--------|------------------------------|---------|-------|
| 2.0000 | CHNL * 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 346: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:25
FLT_1_3PH_VOLTAGES

300000
 100000
 0
 100000
 200000

SPB MDWG 04 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_2_3_P1.OUT

| CHNL # | LOCATION | VOLTAGE | PHASE |
|--------|------------------------------|---------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 13:25
 FLT_2_3PH_VOLTAGES

3PH VOLTAGE
 10/27/04 10:25 AM

SPP MDWG 04 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SUPPDED

FILE: C:\Interconnection Studies\... \stability-results\FLT_3_3_PH.OUT

| Channel # | Channel Name | Level (kV) | Value |
|-----------|------------------------------|------------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161kV | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161kV | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161kV | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161kV | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161kV | 0.0 |




WED, NOV 03 2004 10:25
 FLT_3_3PH_VOLTAGES

3000
 1000
 0000
 0000
 0000

SPP MDWG 04 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_4_3_P1.OUT
 CHNL # 356: EVOLTAGE GOLDEN 161KV
 CHNL # 338: EVOLTAGE MAIN 161KV
 CHNL # 346: EVOLTAGE CLAY 161KV
 CHNL # 347: EVOLTAGE BAKLINE 161KV
 CHNL # 339: EVOLTAGE BAITFLD 161KV
 CHNL # 334: EVOLTAGE SMPS 161KV




WED, NOV 03 2004 13:25
 FLT_4_3PH_VOLTAGES

SPP MDMS Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

3941
 3942
 3943

FILE: C:\Interconnection Studies\... \stability-results\FLT_5_3_P4.OUT

| | | |
|--------|-----------------------------------|-----|
| 2.0000 | CHNL # 356: VOLTAGE GOLDEN 12KV | 0.0 |
| 2.0000 | CHNL # 338: VOLTAGE MAIN 161KV | 0.0 |
| 2.0000 | CHNL # 348: VOLTAGE CLAY 161KV | 0.0 |
| 2.0000 | CHNL # 347: VOLTAGE BAKLINE 161KV | 0.0 |
| 2.0000 | CHNL # 339: VOLTAGE BAITFLD 161KV | 0.0 |
| 2.0000 | CHNL # 344: VOLTAGE SOPS 161KV | 0.0 |




WED, NOV 03 2004 13:25
 FLT_5_3PH_VOLTAGES

3000000
 1000000
 500000
 0

SPB MDWG 04 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_6_3_P1.001

| | | |
|--------|-------------------------------------|-----|
| 2.0000 | CHNL # 356: EVOLTAGE GOLDEN 161KV3 | 0.0 |
| 2.0000 | CHNL # 338: EVOLTAGE MAIN 161KV3 | 0.0 |
| 2.0000 | CHNL # 346: EVOLTAGE CLAY 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: EVOLTAGE BAKLINE 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: EVOLTAGE BAITFLD 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: EVOLTAGE SMPS 161KV3 | 0.0 |




WED, NOV 03 2004 13:25
 FLT_6_3PH_VOLTAGES

3941.PRT
11/2/04 10:25

SPP MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_7_3_P4.OUT
CHNL # 356: EVOLTAGE GOLDEN 161KV
CHNL # 338: EVOLTAGE MAIN 161KV
CHNL # 346: EVOLTAGE CLAY 161KV
CHNL # 347: EVOLTAGE BAKLINE 161KV
CHNL # 339: EVOLTAGE BRIFLD 161KV
CHNL # 334: EVOLTAGE SPTS 161KV




WED, NOV 03 2004 10:25
FLT_7_3PH_VOLTAGES

300000
 100000
 0
 100000
 200000

SPB MDWG 04 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_8_3_P1.OUT

| | | |
|--------|-------------------------------------|-----|
| 2.0000 | CHNL # 356: EVOLTAGE GOLDEN 161KV3 | 0.0 |
| 2.0000 | CHNL # 338: EVOLTAGE MAIN 161KV3 | 0.0 |
| 2.0000 | CHNL # 346: EVOLTAGE CLAY 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: EVOLTAGE BAKLINE 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: EVOLTAGE BRIFLD 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: EVOLTAGE SMPS 161KV3 | 0.0 |




WED, NOV 03 2004 13:25
 FLT_8_3PH_VOLTAGES

3000
 1000
 0000
 0000
 0000

SPP MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_9_3_P1.OUT

| | | |
|--------|-------------------------------------|-----|
| 2.0000 | CHNL # 356: EVOLTAGE GOLDEN 161KV3 | 0.0 |
| 2.0000 | CHNL # 338: EVOLTAGE MAIN 161KV3 | 0.0 |
| 2.0000 | CHNL # 346: EVOLTAGE CLAY 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: EVOLTAGE BAKLINE 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: EVOLTAGE BRIFLD 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: EVOLTAGE SMPS 161KV3 | 0.0 |




WED, NOV 03 2004 13:25
 FLT_9_VOLTAGES

3381 Page 8
 11/3/04 10:25 AM

SPP MDMS Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCL UDINO PRIOR SCHEDULE

FILE: ... \stability-results\Flt_10_drog_unit1.001

| CHNL # | DESCRIPTION | VOLTAGE | UNIT |
|--------|------------------------------|---------|------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:25
 FLT_10_VOLTAGES

3PH VOLTAGE
 1000000
 1000000
 1000000

SPP MDWG 04 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCL UDINO PRIOR SUPPDED

FILE: C:\Interconnection Studies\... \stability-results\FLT_12_3_PH.OUT

| Channel # | Channel Name | Voltage (KV) | Phase |
|-----------|------------------------------|--------------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BRKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |



WED, NOV 03 2004 13:25
 FLT_12_3PH_VOLTAGES

Appendix C-1

Plots of Fault Simulations

Plots of selected machine angle response during faults

Scenario:

2010 Summer Peak


275MW (SWPS-Battlefield 161kV out of service)

[No Customer Plant – No Network Upgrades]



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\Working\stabil\ity-results\FLT_1_3.PH.OUT




TUE, NOV 02 2004 13:01

FLT_1_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\Working\stabil\ity-results\FLT_2_3_PH.OUT




TUE, NOV 02 2004 13:01

FLT_2_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\Working\stabil\ity-results\FLT_3_3_PH.OUT




TUE, NOV 02 2004 13:02

FLT_3_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\Working\stabil\ity-results\FLT_4_3PH.OUT




TUE, NOV 02 2004 13:02

FLT_4_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\Working\stabil\ity-results\FLT_5_3.PH.OUT




TUE, NOV 02 2004 13:02

FLT_5_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\Working\stabil\ity-results\FLT_6_3PH.OUT




TUE, NOV 02 2004 13:02

FLT_6_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\Working\stabil\ity-results\FLT_7_3_PH.OUT




TUE, NOV 02 2004 13:02

FLT_7_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\Working\stabil\ity-results\FLT_8_3PH.OUT




TUE, NOV 02 2004 13:02

FLT_8_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\Working\stabil\ity-results\FLT_9_3.PH.OUT




TUE, NOV 02 2004 13:02
FLT_9_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK: MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: ... \stabj11ty-results\FLT_10_drop_unit_1.0UT




TUE, NOV 02 2004 13:02
FLT_10_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: ... \stabj11ty-results\FLT_11_drop_unit_2.0UT



TUE, NOV 02 2004 13:02
FLT_11_MACHINE ANGLES

Appendix C-2

Plots of Fault Simulations

Plots of selected bus voltage response during faults

Scenario:

2010 Summer Peak

275MW (SWPS-Battlefield 161kV out of service)


[No Customer Plant – No Network Upgrades]

3477
 3478
 3479
 3480
 3481
 3482
 3483
 3484
 3485
 3486
 3487
 3488
 3489
 3490
 3491
 3492
 3493
 3494
 3495
 3496
 3497
 3498
 3499
 3500

SPP MDMS Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\Working\Stability-results\FLT_1_3_PH.DAT

| CHNL # | DESCRIPTION | VOLTAGE (KV) | PHASE |
|--------|------------------------------|--------------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 348: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BAITFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 344: CVOLTAGE SWPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:10
 FLT_1_3PH_VOLTAGES

2004-11-03 10:10
 2004-11-03 10:10
 2004-11-03 10:10

SPP MDMS Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\Working\Stability-results\FLT_2_3_PH.001

| CHNL # | DESCRIPTION | VOLTAGE (KV) | PHASE |
|--------|------------------------------|--------------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:10
 FLT_2_3PH_VOLTAGES

A:\www
 2004/11/03
 10:10:00

SPP MDMS Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\Working\Stability-results\FLT_3_3_PH.DAT

| CHNL # | VOLTAGE | MIN | MAX | PHASE |
|--------|------------------|--------|-----|-------|
| 2.0000 | CVOLTAGE MAIN | 161KV3 | | 0.0 |
| 2.0000 | CVOLTAGE CLAY | 161KV3 | | 0.0 |
| 2.0000 | CVOLTAGE BAKLINE | 161KV3 | | 0.0 |
| 2.0000 | CVOLTAGE BAITFLD | 161KV3 | | 0.0 |
| 2.0000 | CVOLTAGE SWPS | 161KV3 | | 0.0 |




WED, NOV 03 2004 10:10
 FLT_3_3PH_VOLTAGES

3477
 3478
 3479
 3480
 3481
 3482
 3483
 3484
 3485
 3486
 3487
 3488
 3489
 3490
 3491
 3492
 3493
 3494
 3495
 3496
 3497
 3498
 3499
 3500

SPP MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\Working\Stability-Results\FLT_4_3_PH.DAT

| CHNL # | DESCRIPTION | VOLTAGE (KV) | PHASE |
|--------|------------------------------|--------------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:10
 FLT_4_3PH_VOLTAGES

3477
 3478
 3479
 3480
 3481
 3482
 3483
 3484
 3485
 3486
 3487
 3488
 3489
 3490
 3491
 3492
 3493
 3494
 3495
 3496
 3497
 3498
 3499
 3500

SPP MDMS 04 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\Working\Stability-results\FLT_5_3_PH.DAT

| CHNL # | DESCRIPTION | VOLTAGE (KV) | PHASE |
|--------|------------------------------|--------------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:10
 FLT_5_3PH_VOLTAGES

A:\www
 SPN PAPER
 11/2/04

SPN MDMS Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\Norking's Stability-Results\FLT_6_3_PH.DAT

| CHNL # | VOLTAGE | MODEN | PHASE |
|--------|---------|-------|-------|
| 2.0000 | 161KV3 | | 0.0 |
| 2.0000 | 161KV3 | | 0.0 |
| 2.0000 | 161KV3 | | 0.0 |
| 2.0000 | 161KV3 | | 0.0 |
| 2.0000 | 161KV3 | | 0.0 |




WED, NOV 03 2004 10:10
 FLT_6_3PH_VOLTAGES

3477
 3478
 3479
 3480
 3481
 3482
 3483
 3484
 3485
 3486
 3487
 3488
 3489
 3490
 3491
 3492
 3493
 3494
 3495
 3496
 3497
 3498
 3499
 3500

SPP MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\Working\Stability-results\FLT_7_3_PH.DAT

| CHNL # | CHNL NAME | VOLTAGE | PHASE |
|--------|------------------------------|---------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:10
 FLT_7_3PH_VOLTAGES

A:\www
 SPN Project
 11/2/04

SPN MDMS 04 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

File: C:\Interconnection Studies\MD King's Stability-Results\F11_B_3_P11.DAT

| CHNL # | DESCRIPTION | VOLTAGE | PHASE |
|--------|------------------------------|---------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:10
 FLT_0_3PH_VOLTAGES

2004-11-03 10:10
 161KV3
 161KV3

SPP MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR CORRECTED

FILE: C:\Interconnection Studies\MDWG\Stability-results\FLT_9_3.PH.001

| CHNL # | DESCRIPTION | VOLTAGE | PHASE |
|--------|------------------------------|---------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 349: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:10
 FLT_9_VOLTAGES

SPP MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCL UDINO PRIOR SCHEDULED

FILE: ... \stability-results\FLT_10_drog_unit_11.001

| CHNL # | Material | Voltage (kV) | Time (s) |
|--------|------------------|--------------|----------|
| 338 | LYOLTAGE GOLDEN | 161kV | 0.0 |
| 338 | LYOLTAGE MAIN | 161kV | 0.0 |
| 348 | LYOLTAGE CLAY | 161kV | 0.0 |
| 347 | LYOLTAGE BAKLINE | 161kV | 0.0 |
| 339 | LYOLTAGE BAITFLD | 161kV | 0.0 |
| 339 | LYOLTAGE SMPS | 161kV | 0.0 |




WED, NOV 03 2004 10:10
 FLT_10_VOLTAGES

SPP MDMS Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCL UDINO PRIOR SCHEDULED

FILE: ... \stability-results\FLT_11_drog_unit_2.0UT

| CHNL # | DESCRIPTION | VOLTAGE | UNIT |
|--------|------------------------------|---------|------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRTFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |



WED, NOV 03 2004 10:10
 FLT_11_VOLTAGES

Appendix D-1

Plots of Fault Simulations

Plots of selected machine angle response during faults

Scenario:

2010 Summer Peak


275MW_2 (SWPS-Battlefield 161kV in service)

[No Customer Plant – No Network Upgrades]



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_1_3_PH.0UT




WED, NOV 03 2004 13:47

FLT_1_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
 GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_2_3_PH.0UT




WED, NOV 03 2004 13:47

FLT_2_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_3_3_PH.0UT




WED, NOV 03 2004 13:47

FLT_3_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK: MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_4_3_PH.0UT




WED, NOV 03 2004 13:47

FLT_4_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_5_3_PH.0UT




WED, NOV 03 2004 13:47

FLT_5_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_6_3_PH.OUT




WED, NOV 03 2004 13:47

FLT_6_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
 GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_7_3_PH.0UT




WED, NOV 03 2004 13:47

FLT_7_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK: MODIFIED
 GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_8_3_PH.OUT




WED, NOV 03 2004 13:47

FLT_8_3PH_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-results\FLT_9_3_PH.0UT




WED, NOV 03 2004 13:47
FLT_9_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK: MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: ... \stabj11ty-results\FLT_10_drop_unit_1.0UT




WED, NOV 03 2004 13:47
FLT_10_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECRSE INCLUDING PRIOR QUEUED

FILE: ... \stabj11ty-results\FLT_11_drop_unit_2.0UT




WED, NOV 03 2004 13:47
FLT_11_MACHINE ANGLES



SPP MDWG 04 STABILITY:2010 SUM PEAK; MODIFIED
GEN-2004-005 BASECASE INCLUDING PRIOR QUEUED

FILE: C:\Interconnection Studies\...\stability-resu]ts\FLT_12_3_PH.OUT



WED, NOV 03 2004 13:47

FLT_12_3PH_MACHINE ANGLES

Appendix D-2

Plots of Fault Simulations

Plots of selected bus voltage response during faults

Scenario:

2010 Summer Peak

275MW_2 (SWPS-Battlefield 161kV in service)


[No Customer Plant – No Network Upgrades]

344
 347
 339
 334

SPP MDMS Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCL UDINO PRIOR SUPPDED

FILE: C:\Interconnection Studies\... \stability-results\FLT_1_3_P4.OUT

| Channel # | Channel Name | Level (KV) | Scale |
|-----------|------------------------------|------------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 346: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SWPS | 161KV3 | 0.0 |




WED, NOV 03 2004 13:40
 FLT_1_3PH_VOLTAGES

3PH VOLTAGE
 1000000
 1000000
 1000000

SPP MDWG 04 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR CORRECTED

FILE: C:\Interconnection Studies\... \stability-results\FLT_2_3_PH.OUT

| | | |
|--------|-------------------------------------|-----|
| 2.0000 | CHNL # 356: EVOLTAGE GOLDEN 161KV3 | 0.0 |
| 2.0000 | CHNL # 338: EVOLTAGE MAIN 161KV3 | 0.0 |
| 2.0000 | CHNL # 346: EVOLTAGE CLAY 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: EVOLTAGE BAKLINE 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: EVOLTAGE BAITFLD 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: EVOLTAGE SMPS 161KV3 | 0.0 |




WED, NOV 03 2004 13:40
 FLT_2_3PH_VOLTAGES

SPP MDMS 04 STABILITY; 2010 SUM PEAK; MODIFIED
GEN-2004-005 BRSECHSE INCLUDING PRIOR SUPPLEMENT

3941 Page 8
11/2/04 10:40 AM

FILE: C:\Interconnection Studies\... \stability-results\FLT_3_3_P1.001

| CHNL # | LOCATION | VOLTAGE | PHASE |
|--------|------------------------------|---------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | 0.0 |




WED, NOV 03 2004 10:40
FLT_3_3PH_VOLTAGES

3000
 1000
 0000
 0000
 0000

SPP MDWG 04 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_4_3_P1.OUT

| | | |
|--------|-------------------------------------|-----|
| 2.0000 | CHNL # 356: EVOLTAGE GOLDEN 161KV3 | 0.0 |
| 2.0000 | CHNL # 338: EVOLTAGE MAIN 161KV3 | 0.0 |
| 2.0000 | CHNL # 346: EVOLTAGE CLAY 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: EVOLTAGE BAKLINE 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: EVOLTAGE BRIFLD 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: EVOLTAGE SMPS 161KV3 | 0.0 |




WED, NOV 03 2004 13:40
 FLT_4_3PH_VOLTAGES

3941 Page 8
 11/3/04 10:40 AM

SPR MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_5_3_P1.OUT

| CHNL # | VOLTAGE | MIN | MAX | AVG |
|--------|------------------|--------|--------|-----|
| 2.0000 | CVOLTAGE MAIN | 161KV3 | 161KV3 | 0.0 |
| 2.0000 | CVOLTAGE CLAY | 161KV3 | 161KV3 | 0.0 |
| 2.0000 | CVOLTAGE BRKLINE | 161KV3 | 161KV3 | 0.0 |
| 2.0000 | CVOLTAGE BRIFLD | 161KV3 | 161KV3 | 0.0 |
| 2.0000 | CVOLTAGE SWPS | 161KV3 | 161KV3 | 0.0 |




WED, NOV 03 2004 10:40
 FLT_5_3PH_VOLTAGES

3000000
 1000000
 500000
 0

SPB MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCL UDINO PRIOR SUPPDED

FILE: C:\Interconnection Studies\... \stability-results\FLT_6_3_P1.OUT

| | | |
|--------|-------------------------------------|-----|
| 2.0000 | CHNL # 356: EVOLTAGE GOLDEN 161KV3 | 0.0 |
| 2.0000 | CHNL # 338: EVOLTAGE MAIN 161KV3 | 0.0 |
| 2.0000 | CHNL # 346: EVOLTAGE CLAY 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: EVOLTAGE BAKLINE 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: EVOLTAGE BAITFLD 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: EVOLTAGE SMPS 161KV3 | 0.0 |




WED, NOV 03 2004 13:40
 FLT_6_3PH_VOLTAGES

3000
 1000
 0000
 0000
 0000

SPB MDWG 04 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCL UDINO PRIOR SUPPDED

FILE: C:\Interconnection Studies\... \stability-results\FLT_7_3_PH.OUT

| | | |
|--------|-------------------------------------|-----|
| 2.0000 | CHNL # 356: EVOLTAGE GOLDEN 161KV3 | 0.0 |
| 2.0000 | CHNL # 338: EVOLTAGE MAIN 161KV3 | 0.0 |
| 2.0000 | CHNL # 346: EVOLTAGE CLAY 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: EVOLTAGE BAKLINE 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: EVOLTAGE BRIFLD 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: EVOLTAGE SMTS 161KV3 | 0.0 |




WED, NOV 03 2004 13:40
 FLT_7_3PH_VOLTAGES

3000 Points
 100000 Bytes
 10/27/04

SPB MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

FILE: C:\Interconnection Studies\... \stability-results\FLT_8_3_P4.OUT

| Channel # | Channel Name | Level (KV) | Phase |
|-----------|------------------------------|------------|-------|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV | 0.0 |
| 2.0000 | CHNL # 349: CVOLTAGE CLAY | 161KV | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV | 0.0 |




WED, NOV 03 2004 13:40
 FLT_8_3PH_VOLTAGES

SPP MDMS Q4 STABILITY; 2010 SUM PEAK; MODIFIED
GEN-2004-005 BRSECHSE INCLUDING PRIOR SCHEDULE

3000 PAGES
10/27/04 10:55 AM

FILE: C:\Interconnection Studies\... \stability-results\FLT_9_3_P1.OUT
CHNL # 356: CVOLTAGE GOLDEN 161KV
CHNL # 338: CVOLTAGE MAIN 161KV
CHNL # 349: CVOLTAGE CLAY 161KV
CHNL # 347: CVOLTAGE BAKLINE 161KV
CHNL # 339: CVOLTAGE BAITFLD 161KV
CHNL # 334: CVOLTAGE SMPS 161KV




WED, NOV 03 2004 10:40
FLT_9_VOLTAGES

3381.P1000
 3381.P1000
 3381.P1000

SPP MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCL UDINO PRIOR SCHEDULE

FILE: ... \stability-results\Flt_10_dropp_unit1.1.out

| | | |
|--------|-------------------------------------|-----|
| 2.0000 | CHNL # 338: CVOLTAGE GOLDEN 161KV3 | 0.0 |
| 2.0000 | CHNL # 338: CVOLTAGE MAIN 161KV3 | 0.0 |
| 2.0000 | CHNL # 346: CVOLTAGE CLAY 161KV3 | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE 161KV3 | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BAITFLD 161KV3 | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS 161KV3 | 0.0 |




WED, NOV 03 2004 13:40
 FLT_10_VOLTAGES

3381.P1008
 3381.P1008
 3381.P1008

SPP MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCL UDINO PRIOR SCHEDULE

FILE: ... \stability-results\Flt_11_drop_unit_2.0UT

| | | | | | |
|--------|------------------------------|--------|---|---|-----|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | X | X | 0.0 |
| 2.0000 | CHNL # 340: CVOLTAGE CLAY | 161KV3 | + | + | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BAKLINE | 161KV3 | ◇ | ◇ | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | ◀ | ▶ | 0.0 |
| 2.0000 | CHNL # 334: CVOLTAGE SMPS | 161KV3 | ≡ | ≡ | 0.0 |




WED, NOV 03 2004 13:40
 FLT_11_VOLTAGES

344
 347
 339
 334

SPP MDWG Q4 STABILITY; 2010 SUM PEAK; MODIFIED
 GEN-2004-005 BRSECHSE INCL UDINO PRIOR SUPPDED

FILE: C:\Interconnection Studies\... \stability-results\FLT_12_3_P4.OUT

| | | | | | |
|--------|------------------------------|--------|---|---|-----|
| 2.0000 | CHNL # 338: CVOLTAGE MAIN | 161KV3 | X | X | 0.0 |
| 2.0000 | CHNL # 348: CVOLTAGE CLAY | 161KV3 | + | + | 0.0 |
| 2.0000 | CHNL # 347: CVOLTAGE BRKLINE | 161KV3 | ◇ | ◇ | 0.0 |
| 2.0000 | CHNL # 339: CVOLTAGE BRIFLD | 161KV3 | ◇ | ◇ | 0.0 |
| 2.0000 | CHNL # 344: CVOLTAGE SWPS | 161KV3 | + | + | 0.0 |



WED, NOV 03 2004 13:40
 FLT_12_3PH_VOLTAGES