



*System Impact Study
SPP-2004-006-3
For Network Service
Requested By
Xcel Energy Marketing*

From SPS To SPS

*For a Reserved Amount Of 320 MW
From 7/15/2005 To 7/1/2019*

SPP Engineering, Tariff Studies

Table of Contents

1. EXECUTIVE SUMMARY	3
2. INTRODUCTION	5
3. STUDY METHODOLOGY.....	6
A. DESCRIPTION	6
B. MODEL UPDATES	6
C. TRANSFER ANALYSIS.....	7
D. TRANSFER ANALYSIS BASED ON THE SPS TO LP&L AGGREGATE TIE-LINE POWER FACTOR	7
E. UPGRADE ANALYSIS.....	7
4. STUDY RESULTS	8
A. STUDY ANALYSIS RESULTS.....	8
5. CONCLUSION.....	11
FIGURE 1	12
FIGURE 2	13
FIGURE 3	14
FIGURE 3a	15
FIGURE 4	16
FIGURE 5	17
FIGURE 5a	18
APPENDIX A	19

ATTACHMENT: *SPP-2004-006-3 Tables*

1. Executive Summary

Xcel Energy Marketing has requested a system impact study for Network Integration Transmission Service from SPS to SPS for 320 MW. The period of the service requested is from 7/15/2005 to 7/1/2019. The OASIS reservation number is 705270.

The principal objective of this study is to identify system constraints and potential system modifications necessary to grant the requested Network Service while maintaining system reliability. The study includes transfer analyses from generation to generation and transfer analyses based on the aggregate power factor of the four SPS to Lubbock Power and Light (LP&L) 230 kV ties lines. The requested service was studied using two System Scenarios with SPS exporting and importing, respectively. To determine what limitations occur with all LP&L generation off, the service was modeled from SPS generation to the Network load and to LP&L generation, until LP&L generation was dispatched at zero MW.

The study was revised to account for status changes of two higher priority requests. A SECI to SPS 300 MW request and a SPS to EDDY 200 MW request have both withdrawn. The ATC and upgrades required may vary from these results due to the status of one remaining higher priority request. The higher priority request is a SECI to SPS 150 MW request. Additional analysis was performed with the higher priority request and assigned upgrades included in the models. The outcome of the higher priority request has a significant impact on the upgrades required for the Network Service.

Tables 1.1 and 1.2 list the SPP facility overloads caused or impacted by the transfers modeled, using Scenario 1 and 2, respectively. Tables 2.1 and 2.2 lists the SPP voltage violations caused or impacted by the transfers modeled, using Scenario 1 and 2, respectively. Tables 3.1 and 3.2 list the Non-SPP facility overloads caused or impacted by the transfers modeled, using Scenarios 1 and 2, respectively. Tables 4.1 and 4.2 list the Non-SPP voltage violations caused or impacted by the transfers modeled, using Scenarios 1 and 2, respectively. Selected solutions with known engineering and construction costs are provided for the SPP Facility Overloads and Voltage violations found in the Tables.

Limits were identified in the 2005, 2007, and 2010 Summer Peak models with all LP&L generation off. Due to the inability to mitigate the limiting constraints identified through transmission upgrades by the 7/15/2005 start date, critical contingencies were analyzed to determine maximum allowable SPS to LP&L aggregate tie line flow based on the aggregate tie line power factor. The Tuco 230 kV bus voltage stability limit for the outage of Jones Unit 1 is the most limiting event for power factors ranging from unity to 0.90 lagging, using Scenario 2. Figures 1, 2, and 3 illustrate the tie line flow limit results of the nine worst contingencies based on the aggregate tie line power factor for the 2005, 2007, and 2010 Summer Peak models, using Scenario 2. Figure 3a was added to account for limitations identified with the remaining higher priority request and assigned upgrades included. The Tuco 230 kV bus voltage stability limit for the outage of Tolk Unit 1 is the most limiting event for power factors ranging from unity to 0.90 lagging, using Scenario 2.

Table 5 summarizes the SPS to LP&L tie line limits by season and power factor. For interim service, LP&L generation will need to be dispatched in order to serve the Network load and to operate within the SPS to LP&L 230 kV tie line limits. In order to displace the required dispatch of LP&L generation, upgrades were determined by assuming an aggregate power factor of 0.95 lagging at the SPS to LP&L 230 kV tie lines. The total estimated engineering and construction cost required is \$19,650,000. The required upgrades are documented in Table 6. The required upgrades do not address LP&L transmission system limitations. Additional analysis performed with the higher priority request and assigned upgrades included determined that upgrades would be needed assuming a 0.95 lagging power factor at the ties. The total estimated engineering and construction cost required is \$16,000,000. The required upgrades are documented in Table 7. The required upgrades do not address LP&L transmission system limitations.

At the request of the customer, Figures 4 and 5 were added to depict the change in the tie line flow limits with the required upgrades incrementally added to the models. The order of the required upgrades was determined by taking into consideration the future needs of the higher priority service from SUNC to SPS for 150 MW for which the two 50 MVAR capacitor banks at Tuco 230 kV, the 50 MVAR capacitor bank at Swisher 230 kV, and second Tuco 230/115 kV Transformer addition have already been proposed, ATC provided per dollar, and a requirement to add only 150 MVAR of fixed shunt capacitors to the system before requiring the proposed SVC. The proposed SVC requirement is based upon the need to withstand large power swings like the outage of a Jones or Tolk unit. A thorough explanation of the added figures is provided at the end of the Study Results section. SPP may require additional analysis to be performed once the customer decides on the amount of upgrades needed to offset the amount of LP&L Generation dispatch required in order to serve the Network load and to operate within the SPS to LP&L 230 kV tie line limits. Figure 5a was added to depict the change in the tie line flow limits with the required upgrades from Table 7 incrementally added to the models. A thorough explanation of the added figure is provided at the end of the Study Results section.

2. Introduction

Xcel Energy Marketing has requested a system impact study for Network Integration Transmission Service from SPS to SPS for 320 MW. The principal objective of this study is to identify the restraints on the SPP Regional Tariff System that may limit the requested service and determine the least cost solutions required to alleviate the limiting facilities.

This study includes steady-state contingency analyses (PSS/E function ACCC) and Available Transfer Capability (ATC) analyses. The steady-state analyses consider the impact of the request on transmission line and transformer loadings, and bus voltages for outages of single transmission lines, transformers, and generating units, and selected multiple transmission lines and transformers on the SPP system and first tier Non - SPP systems.

The requested service was studied using two System Scenarios with SPS exporting and importing, respectively. The two scenarios were studied to capture worst case system limitations dependent on the bias of the transmission system. The service was modeled by transfers from SPS generation to LP&L generation up to LP&L generation dispatch of zero MW. The transfers modeled to LP&L generation were performed to determine maximum allowable flows from SPS to the Network Load. Nine of the most limiting contingency events were evaluated in the Summer Peak models based on the aggregate tie line power factor of the SPS to LP&L 230 kV tie lines. The maximum allowable aggregate tie line flow is based upon the most limiting critical contingency events and the aggregate tie line lagging power factor. Additional analysis was performed with a higher priority request and assigned upgrades included in the 2010 Summer Peak and 2010/11 Winter Peak. The outcome of the higher priority request has a significant impact on the upgrades required for the Network Service.

3. Study Methodology

A. Description

The system impact analysis was conducted to determine the steady-state impact of the requested service on the SPP and first tier Non - SPP control area systems. The steady-state analysis was done to ensure current SPP Criteria and NERC Planning Standards requirements are fulfilled. The Southwest Power Pool conforms to the NERC Planning Standards, which provide the strictest requirements, related to voltage violations and thermal overloads during normal conditions and during a contingency. It requires that all facilities be within normal operating ratings for normal system conditions and within emergency ratings after a contingency. Normal operating ratings and emergency operating ratings monitored are Rate A and B in the SPP MDWG models, respectively. The upper bound and lower bound of the normal voltage range monitored is 105% and 95%. The upper bound and lower bound of the emergency voltage range monitored is 110% and 90%. The SPS Tuco 230 kV bus voltage is monitored at 92.5% due to pre-determined system stability limitations.

The contingency set includes all SPP control area branches and ties 69kV and above, first tier Non - SPP control area branches and ties 115 kV and above, any defined contingencies for these control areas, and generation unit outages for the SPP control areas, AECI, and ENTR with SPP reserve share program redispatch. The monitor elements include all SPP control area branches, ties, and buses 69 kV and above, and all first tier Non – SPP control area branches and ties 69 kV and above. Voltage monitoring was performed for SPP control area buses 69 kV and above.

A 3 % transfer distribution factor (TDF) cutoff was applied to all SPP control area facilities. For first tier Non – SPP control area facilities, a 3 % TDF cutoff was applied to AECI, AMRN, and ENTR and a 2 % TDF cutoff was applied to MEC, NPPD, and OPPD. For voltage monitoring, a 0.02 per unit change in voltage must occur due to the transfer to be considered a valid limit to the transfer.

B. Model Updates

SPP used eight seasonal models to study the Network Service for the requested service period. The SPP 2004 Series Cases Update 4 2005 Summer Peak (05SP), 2005 Summer Shoulder (05SH), 2005 Fall Peak (05FA), 2005/2006 Winter Peak (05WP), 2007 Summer Peak (07SP), 2007/08 Winter Peak (07WP), 2010 Summer Peak (10SP), and 2010/11 Winter Peak (10WP) were used to study the impact of the requested service on the transmission system during the requested service period of 7/15/05 to 7/1/2019. The Spring Peak models apply to April and May, the Summer Peak models apply to June through September, the Fall Peak models apply to October and November, and the Winter Peak models apply to December through March.

The chosen base case models were modified to reflect the most current modeling information. From the eight seasonal models, two system scenarios were developed. Scenario 1 includes SWPP OASIS transmission requests not already included in the SPP 2004 Series Cases flowing in a West to East direction with ERCOT exporting and the SPS Control Area exporting to outside control areas and exporting to the planned Lamar HVDC Tie. Scenario 2 includes transmission requests not already included in the SPP 2004 Series Cases flowing in an East to West direction with ERCOT net importing and SPS importing from an outside control area and

importing from the planned Lamar HVDC Tie. The system scenarios were developed to minimize counter flows to the transfers studied.

The Network load for the 2005 Summer Peak was forecasted to be a maximum of 329 MW. Summer peaks were forecasted to increase 2.7% annually. The Network load amounts modeled for the spring peaks, fall peaks and winter peaks was 65% of the summer peaks. The Network load amount modeled in the summer shoulder is 85% of the summer peaks. Future Summer Peak and Non-Summer Peak loads were determined by scaling the 2005 summer peak values while maintaining constant real power and reactive power ratios. Table 5 documents the total Network load modeled in each seasonal case.

SPS currently has 55 MW of long-term firm point-to-point service to the Network load. The existing reserved service was modeled in the cases before any transfer analyses were performed. No changes were made to the Jones Unit 1 and 2 modeling parameters. The Qmax of both Jones Unit 1 and 2 is 120 MVAR.

C. Transfer Analysis

To determine what limitations occur with all LP&L generation off, the service was modeled from SPS generation to the Network load and to LP&L generation, until LP&L generation was dispatched at zero MW. Using the selected cases both with and without the transfers modeled, the PSS/E Activity ACCC was run on the cases and compared to determine the facility thermal overloads and voltage violations caused or impacted by the transfer. The PSS/E options chosen to conduct the analysis can be found in Appendix A.

D. Transfer Analysis Based on the SPS to LP&L Aggregate Tie-Line Power Factor

To determine maximum allowable aggregate tie line flow based upon the most limiting critical contingency events and aggregate tie line lagging power factor. Contingency cases were developed for the 2005, 2007, and 2010 Summer Peaks for both scenarios with the most limiting contingencies. Then a developed PSS/E IPLAN macro was used to adjust the aggregate tie line flow and power factor by pro rata scaling the real and reactive Network load while checking for thermal or voltage violations. The tie line MW limits were then graphed. The most limiting critical contingency events were determined by contingency analysis performed on the models with LP&L generation at zero MW.

E. Upgrade Analysis

Using the 2007 Summer Peak, 2007/08 Winter Peak, 2010 Summer Peak, and 2010/11 Winter Peak cases both with and without the required upgrades from Table 6 or Table 7 modeled and with and without the SPS generation to LP&L generation transfer, the PSS/E Activity ACCC was run on the cases and compared to determine the facility overloads caused or impacted by the required upgrades. The contingency set used included SPS facilities and tie lines, while monitoring the whole SPP and First-tier Non-SPP control area footprint. The 3% transfer distribution cutoff was applied to SPP Facilities identified. The PSS/E options chosen to conduct the analysis can be found in Appendix A.

4. Study Results

A. Study Analysis Results

Tables 1 through 4 contain the initial steady-state analysis results of the System Impact Study. The Tables are in the attached workbook *SPP-2004-006-3 Tables*. The tables identify the seasonal case in which the event occurred, the facility control area location, applicable ratings of the overloaded facility, the loading percentage or voltage with and without the transfer, the percent transfer distribution factor (TDF) if applicable, and the estimated ATC value using interpolation if calculated. Comments are provided in the tables to document any SPP or Non - SPP identification or assignment of the event, existing mitigations plans or criteria to disregard the event as a limiting constraint, upgrades and costs to mitigate a limiting constraint, or any specific study procedures associated with modeling an event. No tie line power factor analysis is included in these results. The tie line power factor is determined by the Network load power factor, transmission system impedance, and generation dispatch.

Tables 1.1 and 1.2 list the SPP facility overloads caused or impacted by the SPS generation to LP&L generation transfers modeled, using Scenario 1 and 2, respectively. Tables 2.1 and 2.2 lists the SPP voltage violations caused or impacted by the SPS generation to LP&L generation transfers modeled, using Scenario 1 and 2, respectively. Tables 3.1 and 3.2 list the Non-SPP facility overloads caused or impacted by the SPS generation to LP&L generation transfers modeled, using Scenarios 1 and 2, respectively. Tables 4.1 and 4.2 list the Non-SPP voltage violations caused or impacted by the SPS generation to LP&L generation transfers modeled, using Scenarios 1 and 2, respectively. Selected solutions with known engineering and construction costs are provided for the SPP Facility Overloads and Voltage violations found in the Tables.

From the results in the Tables, the nine most limiting events were determined to be the following: Jones Unit 1 outage, Jones Unit 2 outage, Tolk Unit 1 outage, Tolk Unit 2 outage, Tolk to Tuco 230 kV line outage, Jones to Lubbock East 230 kV line outage, Carlisle to Tuco 230 kV line outage, Amarillo South to Swisher 230 kV line outage, and Oklaunion to Tuco 345 kV line outage. The violations that occur for these contingencies can be found in the Tables. No LP&L outages were analyzed although LP&L bus voltages and branches were monitored for violations for the nine most limiting events.

Figures 1, 2, and 3 illustrate the results of the SPS to LP&L aggregate tie line limits based on aggregate tie line lagging power factor for 2005, 2007, and 2010 Summer Peaks, using Scenario 2. Each Figure contains plots of the tie line flow limits where valid thermal or voltage violations occur on the SPS and LP&L systems for each critical contingency based on the tie line lagging power factor. From the Figures, the most limiting contingency is the outage of the Jones Unit 1. Scenario 2 or SPS importing is the worst-case scenario for power factors ranging from unity to 0.90.

Two additional plots were added to Figures 1, 2, and 3 to capture the effects on the most limiting contingency with the ERCOT North DC Tie flow from North to South at 220 MW and the reduction of the Jones Unit 2 Qmax by 5%. The additional plot of the Jones Unit 1 outage with the ERCOTN flowing from North to South at 220 MW was selected to determine the maximum

allowable tie line flow based on the tie line power factor for the 2005, 2007, and 2010 Summer Peak. The additional plot with the Jones Unit 2 Qmax reduced by 5% is provided for sensitivity purposes only and was not selected as the most limiting to the service. Table 5 summarizes the SPS to LP&L tie line limits by season with and without the Higher Priority SECI to SPS 150 MW Request and Assigned Upgrades included. Assuming a 0.95 lagging power factor at the ties, the required upgrades for the Network Service without the Higher Priority SECI to SPS 150 MW Request and Assigned Upgrades included are summarized in Table 6.

Figure 3a was added to account for limitations identified with the remaining higher priority request and assigned upgrades included. From the results in the Tables, the five most limiting events were determined and plotted as previously described. The violations that occur for these contingencies can be found in the Tables. Figure 3a illustrates the results of the SPS to LP&L aggregate tie line limits based on aggregate tie line lagging power factor for 2010 Summer Peaks, using Scenario 2 with the remaining higher priority request and assigned upgrades included. Assuming a 0.95 lagging power factor at the ties, the required upgrades for the Network Service with the Higher Priority SECI to SPS 150 MW Request and Assigned Upgrades included are summarized in Table 7.

No SPP or Non-SPP thermal overloads or voltage violations were caused or impacted by the modeling the required upgrades listed in Table 6.

No SPP or Non-SPP thermal overloads or voltage violations were caused or impacted by the modeling the required upgrades listed in Table 7.

Tables 1.1a and 1.2a documents the modeling representation of the events identified in Tables 1.1 and 1.2 to include bus numbers and bus names.

At the request of the customer, Figures 4 and 5 were added to depict the change in the tie line flow limits with the required upgrades incrementally added to the models. The order of the required upgrades was determined by taking into consideration the future needs of the higher priority service from SUNC to SPS for 150 MW for which the two 50 MVAR capacitor banks at Tuco 230 kV, the 50 MVAR capacitor bank at Swisher 230 kV, and second Tuco 230/115 kV Transformer addition have already been proposed, ATC provided per dollar, and a requirement to add only 150 MVAR of fixed shunt capacitors to the system before requiring the proposed SVC. The proposed SVC requirement is based upon the need to withstand large power swings like the outage of a Jones or Tolk unit. The SUNC to SPS 150 MW request also requires a second Tuco 230/115 kV transformer which would eliminate the need for assigning a second Tuco 230/115 kV transformer for the requested service.

Figures 4 and 5 illustrate the results of the SPS to LP&L aggregate tie line limits based on aggregate tie line lagging power factor with the required upgrades incrementally added to the models for 2007 and 2010 Summer Peaks, using Scenario 2. Initially, the three worst outages were analyzed which include the Jones unit 1 outage, Tolk unit 1 outage, and Carlisle to Tuco 230 kV line outage. All but one Tolk unit 1 outage plot was removed after determining that the Jones unit 1 outage remains the worst outage with the upgrades modeled incrementally. The major limiting element for the Jones unit 1 outage and Tolk unit 1 outage is the Tuco 230 kV bus

voltage stability limit. The 250 MVAR of shunt capacitors and 150 MVAR SVC were proposed to eliminate the limitation. The major limiting element for the Carlisle to Tuco 230 kV line outage is the Tuco 230/115 kV transformer overload. A second 230/115 kV transformer was proposed to eliminate the limitation.

Since the most limiting event is the Tuco 230 kV bus voltage for the outage of Jones unit 1, the 100 MVAR of shunt capacitors at Tuco 230 kV bus was the first incremental upgrade modeled and plotted for both the Jones unit 1 outage and Carlisle to Jones 230 kV line outage. The corresponding plots of the same incremental upgrades modeled for different outages use the same color scheme and different legend symbol for the outage (See [Figures 4](#) and [5](#)). The second incremental upgrade modeled and plotted for both the Jones unit 1 outage and Carlisle to Jones 230 kV line outage is the 50 MVAR shunt capacitor at Swisher 230 kV bus. The plots show that ATC is gained by adding the 150 MVAR at Tuco and Swisher. The Carlisle to Tuco 230 kV line outage is also plotted with each incremental upgrade because as the Tuco 230 kV bus voltage stability limit is relieved with the 100 MVAR at Tuco and 50 MVAR at Swisher, the Tuco 230/115 kV transformer overload for the Carlisle to Tuco 230 kV line outage limit changes and begins to be the most limiting event in the 2010 Summer Peak (See [Figure 5](#)). The second Tuco 230/115 kV transformer is needed by 6/1/2008.

The third incremental upgrade modeled and plotted for both the Jones unit 1 outage and Carlisle to Jones 230 kV line outage is the SVC at Tuco 230 kV bus. The plots show that the Tuco 230 kV bus voltage for the Jones unit 1 outage is no longer the most limiting event. The Tuco 230/115 kV transformer overload for the Carlisle to Tuco 230 kV line outage would then be the most limiting event in both the 2007 and 2010 Summer Peak (See [Figures 4](#) and [5](#)). The fourth incremental upgrade modeled and plotted for the Jones unit 1 outage only is the addition of a second Tuco 230/115 kV transformer. And finally, the remaining 100 MVAR of shunt capacitors with 50 MVAR each at Carlisle 230 kV and Lubbock South 230 kV are modeled and plotted for the Jones unit 1 outage and Tolk unit 1 outage. These plots represent limits after all the selected upgrades are modeled, which primarily represent LP&L thermal limitations for the outages modeled. These remaining shunt capacitors were proposed to allow the SVC to stay within an appropriate system intact operating range.

[Figure 5a](#) was added to depict the change in the tie line flow limits with the required upgrades from [Table 7](#) incrementally added to the models. Since the most limiting event is the Tuco 230 kV bus voltage for the outage of Tolk unit 1, the SVC at Tuco 230 kV bus was the first incremental upgrade modeled and plotted for the Tolk unit 1 outage, Jones unit 1 outage, and Amarillo South to Swisher 230 kV line outage. The Tolk unit 1 outage, Jones unit 1 outage, and Amarillo South to Swisher 230 kV line outage were then plotted with the two rebuild requirements. The rebuilds are needed at the same time due to the facilities being in series.

5. Conclusion

Limits were identified in the 2005, 2007, and 2010 Summer Peak models with all LP&L generation off. Due to the inability to mitigate the limiting constraints identified through transmission upgrades by the 7/15/2005 start date, critical contingencies were analyzed to determine maximum allowable SPS to LP&L aggregate tie line flow based on the aggregate tie line power factor. The Tuco 230 kV bus voltage stability limit for the outage of Jones Unit 1 is the most limiting event for power factors ranging from unity to 0.90 lagging, using Scenario 2. Figures 1, 2, and 3 illustrate the tie line flow limit results of the nine worst contingencies based on the aggregate tie line power factor for the 2005, 2007, and 2010 Summer Peak models, using Scenario 2. Figure 3a was added to account for limitations identified with the remaining higher priority request and assigned upgrades included. The Tuco 230 kV bus voltage stability limit for the outage of Tolk Unit 1 is the most limiting event for power factors ranging from unity to 0.90 lagging, using Scenario 2.

Table 5 summarizes the SPS to LP&L tie line limits by season and power factor. For interim service, LP&L generation will need to be dispatched in order to serve the Network load and to operate within the SPS to LP&L 230 kV tie line limits. In order to displace the required dispatch of LP&L generation, upgrades were determined by assuming an aggregate power factor of 0.95 lagging at the SPS to LP&L 230 kV tie lines. The total estimated engineering and construction cost required is \$19,650,000. The required upgrades are documented in Table 6. The required upgrades do not address LP&L transmission system limitations. Additional analysis performed with the higher priority request and assigned upgrades included determined that upgrades would be needed assuming a 0.95 lagging power factor at the ties. The total estimated engineering and construction cost required is \$16,000,000. The required upgrades are documented in Table 7. The required upgrades do not address LP&L transmission system limitations.

At the request of the customer, Figures 4 and 5 were added to depict the change in the tie line flow limits with the required upgrades incrementally added to the models. The order of the required upgrades was determined by taking into consideration the future needs of the higher priority service from SUNC to SPS for 150 MW for which the two 50 MVAR capacitor banks at Tuco 230 kV, the 50 MVAR capacitor bank at Swisher 230 kV, and second Tuco 230/115 kV Transformer addition have already been proposed, ATC provided per dollar, and a requirement to add only 150 MVAR of fixed shunt capacitors to the system before requiring the proposed SVC. The proposed SVC requirement is based upon the need to withstand large power swings like the outage of a Jones or Tolk unit. A thorough explanation of the added figures is provided at the end of the Study Results section. SPP may require additional analysis to be performed once the customer decides on the amount of upgrades needed to offset the amount of LP&L Generation dispatch required in order to serve the Network load and to operate within the SPS to LP&L 230 kV tie line limits. Figure 5a was added to depict the change in the tie line flow limits with the required upgrades from Table 7 incrementally added to the models. A thorough explanation of the added figure is provided at the end of the Study Results section.

Figure 1: SPS to LP&L Tie Line MW Limits for 2005 Summer Peak Scenario 2 (Includes LP&L Limitations)




Figure 2: SPS to LP&L Tie Line MW Limits for 2007 Summer Peak Scenario 2 (Includes LP&L Limitations)




Figure 3: SPS to LP&L Tie Line MW Limits for 2010 Summer Peak Scenario 2 (Includes LP&L Limitations)




Figure 3a: SPS to LP&L Tie Line MW Limits for 2010 Summer Peak Scenario 2 with Higher Priority SECI to SPS 150 MW Request and Assigned Upgrades (Includes LP&L Limitations)




Figure 4: SPS to LP&L Tie Line MW Limits for 2007 Summer Peak Scenario 2 with incremental upgrades modeled (Includes LP&L Limitations)




Figure 5: SPS to LP&L Tie Line MW Limits for 2010 Summer Peak Scenario 2 with incremental upgrades modeled (Includes LP&L Limitations)





Figure 5a: SPS to LP&L Tie Line MW Limits for 2010 Summer Peak Scenario 2 with Higher Priority SECI to SPS 150 MW Request and Assigned Upgrades with incremental upgrades modeled (Includes LP&L Limitations)



Appendix A

PSS/E CHOICES IN RUNNING LOAD FLOW PROGRAM AND ACCC

BASE CASES:

Solutions - Fixed slope decoupled Newton-Raphson solution (FDNS)

1. Tap adjustment – Stepping
2. Area interchange control – Tie lines only
3. Var limits – Apply immediately
4. Solution options - X Phase shift adjustment
 - _ Flat start
 - _ Lock DC taps
 - _ Lock switched shunts

ACCC CASES:

Solutions – AC contingency checking (ACCC)

1. MW mismatch tolerance – 0.5
2. Contingency case rating – Rate B
3. Percent of rating – 100
4. Output code – Summary
5. Min flow change in overload report – 1mw
6. Excl cases w/ no overloads form report – YES
7. Exclude interfaces from report – NO
8. Perform voltage limit check – YES
9. Elements in available capacity table – 60000
10. Cutoff threshold for available capacity table – 99999.0
11. Min. contng. case Vltg chng for report – 0.02
12. Sorted output – None

Newton Solution:

1. Tap adjustment – Stepping
2. Area interchange control – Tie lines only
3. Var limits - Apply automatically
4. Solution options - X Phase shift adjustment
 - _ Flat start
 - _ Lock DC taps
 - _ Lock switched shunts

Table 1.1 - SPP Facility Overloads
Caused or Impacted by Transfer Using Scenario 1

Southwest Power Pool
System Impact Study

Study Case	Transfer Amount (MW)	From Area	To Area	Monitored Branch Overload	Rate <MVA>	BC % Loading	TC % Loading	%TDF	Outaged Branch Causing Overload	ATC (MW)	Solution	Estimated Cost
05SP	274			NONE IDENTIFIED						274		
05SH	224			NONE IDENTIFIED						224		
05FA	159			NONE IDENTIFIED						159		
05WP	159			NONE IDENTIFIED						159		
07SP	292			NONE IDENTIFIED						292		
07WP	171			NONE IDENTIFIED						171		
10SP	321			Contingency Not Converged					LP-SOUTH INT - LUBBOCK SOUTH INTERCHANGE 230KV	N/A	Contingency Converged with Selected Upgrades, No Limitations Identified	
10SP	321			Contingency Not Converged					LP-SOUTH INT 230/69KV TRANSFORMER	N/A	"	
10WP	189			NONE IDENTIFIED						189		
											Total Estimated Engineering and Construction Cost	\$0
10SP*	321			NONE IDENTIFIED						321		
10WP*	189			NONE IDENTIFIED						189		
											Total Estimated Engineering and Construction Cost	\$0

* Study Cases include higher priority service (SUNC to SPS 150 MW) with required network upgrades.

Table 2.1 - SPP Voltage Violations
Caused or Impacted by Transfer Using Scenario 1

Southwest Power Pool
System Impact Study

Study Case	Transfer Amount (MW)	AREA	Monitored Bus with Violation	BC Voltage (PU)	TC Voltage (PU)	Outaged Branch Causing Voltage Violation	ATC (MW)	Solution	Estimated Cost
10SP	321	SPS	51763 WOLFRTH6 230	0.9820	0.8422	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 51647 [CARLISL6230.00] CKT 1	321	"	
10SP	321	SPS	51763 WOLFRTH6 230	0.9820	0.8423	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 50509 [LP-MLWK269.000] CKT 1	321	"	
10SP	321	SPS	51763 WOLFRTH6 230	0.9816	0.8453	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51639 [JONES6 230.00] CKT 1	321	"	
10SP	321	SPS	51763 WOLFRTH6 230	0.9816	0.8458	OPEN LINE FROM BUS 50520 [LP-HOLL269.000] TO BUS 50521 [LP-HOLL6230.00] CKT 1	321	"	
10SP	321	SPS	51811 GRASSLN6 230	0.9912	0.8192	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 51647 [CARLISL6230.00] CKT 1	321	"	
10SP	321	SPS	51811 GRASSLN6 230	0.9912	0.8193	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 50509 [LP-MLWK269.000] CKT 1	321	"	
10SP	321	SPS	51811 GRASSLN6 230	0.9911	0.8291	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51639 [JONES6 230.00] CKT 1	321	"	
10SP	321	SPS	51811 GRASSLN6 230	0.9911	0.8297	OPEN LINE FROM BUS 50520 [LP-HOLL269.000] TO BUS 50521 [LP-HOLL6230.00] CKT 1	321	"	
10SP	321	SPS	51816 GRAHAM3 115	1.0165	0.8991	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 51647 [CARLISL6230.00] CKT 1	321	"	
10SP	321	SPS	51816 GRAHAM3 115	1.0165	0.8992	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 50509 [LP-MLWK269.000] CKT 1	321	"	
10SP	321	SPS	51861 BORDEN6 230	0.9943	0.8348	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 51647 [CARLISL6230.00] CKT 1	321	"	
10SP	321	SPS	51861 BORDEN6 230	0.9943	0.8349	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 50509 [LP-MLWK269.000] CKT 1	321	"	
10SP	321	SPS	51861 BORDEN6 230	0.9942	0.8436	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51639 [JONES6 230.00] CKT 1	321	"	
10SP	321	SPS	51861 BORDEN6 230	0.9942	0.8442	OPEN LINE FROM BUS 50520 [LP-HOLL269.000] TO BUS 50521 [LP-HOLL6230.00] CKT 1	321	"	
10SP	321	SPS	52036 DOSS3 115	1.0055	0.8778	OPEN LINE FROM BUS 51996 [AMERADA3115.00] TO BUS 52036 [DOSS3 115.00] CKT 1	321	"	
10SP	321		Contingency Not Converged			OPEN LINE FROM BUS 50517 [LP-SINT269.000] TO BUS 50518 [LP-SINT6230.00] CKT 1	N/A	Contingency Converged with Selected Upgrades, No Limitations Identified	
10SP	321		Contingency Not Converged			OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	N/A	"	
10WP	189	SPS	51689 LUBE6 230	0.9899	0.8921	OPEN LINE FROM BUS 51689 [LUBE6 230.00] TO BUS 51699 [JONES6 230.00] CKT 1	189	Not a Load Serving Bus	
Total Estimated Engineering and Construction Cost									\$17,300,000
10SP*	321	SPS	51689 LUBE6 230	0.9011	0.8565	OPEN LINE FROM BUS 51689 LUBE6 230 TO BUS 51699 JONES6 230 CKT1	321	Not a Load Serving Bus	
10WP*	189	SPS	51689 LUBE6 230	0.9932	0.8937	OPEN LINE FROM BUS 51689 LUBE6 230 TO BUS 51699 JONES6 230 CKT1	189	Not a Load Serving Bus	
Total Estimated Engineering and Construction Cost									\$0

* Study Cases include higher priority service (SUNC to SPS 150 MW) with required network upgrades.

Table 3.1 - Non-SPP Facility Overloads
Caused or Impacted by Transfer Using Scenario 1

Southwest Power Pool
System Impact Study

Study Case	Transfer Amount (MV)	From Area	To Area	Monitored Branch Over 100% Rate B	Rate <MVA>	BC % Loading	TC % Loading	%TDF	Outaged Branch Causing Overload	Comments
10SP	321	SPS	SPS	50517 LP-SINT2 69 to 50518 LP-SINT6 230 CKT 1	140	19.1	135.5	50.8	50507 LP-MLWK6 230 to 50509 LP-MLWK2 69 CKT 1	
10WP	189			NONE IDENTIFIED						
10SP*	321	SPS	SPS	50513 LP-COOP269.0 to 50516 LP-SLAT269.0 CKT 1	54	33.6	126.2	15.6	50513 LP-COOP269.0 to 50524 LP-WADS269.0 CKT1	
10SP*	321	SPS	SPS	50524 LP-WADS269.0 to 50527 LP-WADS6 230 CKT 1	140	17.3	122.8	46.0	50518 LP-SINT6 230 to 51681 LUBS6 230 CKT1	
10SP*	321	SPS	SPS	50524 LP-WADS269.0 to 50527 LP-WADS6 230 CKT 1	140	17.3	122.8	46.0	50517 LP-SINT269.0 to 50518 LP-SINT6 230 CKT1	
10SP*	321	SPS	SPS	50524 LP-WADS269.0 to 50527 LP-WADS6 230 CKT 1	140	16.8	120.2	45.1	50521 LP-HOLL6 230 to 51699 JONES6 230 CKT1	
10SP*	321	SPS	SPS	50524 LP-WADS269.0 to 50527 LP-WADS6 230 CKT 1	140	16.8	120.2	45.1	50520 LP-HOLL269.0 to 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	SPS	50524 LP-WADS269.0 to 50527 LP-WADS6 230 CKT 1	100	19.4	107.1	27.3	BASE CASE	
10SP*	321	SPS	SPS	50520 LP-HOLL269.0 to 50521 LP-HOLL6 230 CKT 1	140	16.0	134.7	51.7	50518 LP-SINT6 230 to 51681 LUBS6 230 CKT1	
10SP*	321	SPS	SPS	50520 LP-HOLL269.0 to 50521 LP-HOLL6 230 CKT 1	140	16.0	134.7	51.7	50517 LP-SINT269.0 to 50518 LP-SINT6 230 CKT1	
10SP*	321	SPS	SPS	50520 LP-HOLL269.0 to 50521 LP-HOLL6 230 CKT 1	140	13.9	128.1	49.8	50527 LP-WADS6 230 to 51689 LUBE6 230 CKT1	
10SP*	321	SPS	SPS	50520 LP-HOLL269.0 to 50521 LP-HOLL6 230 CKT 1	140	13.9	128.1	49.8	50524 LP-WADS269.0 to 50527 LP-WADS6 230 CKT1	
10SP*	321	SPS	SPS	50520 LP-HOLL269.0 to 50521 LP-HOLL6 230 CKT 1	100	13.4	118.2	32.6	BASE CASE	
10SP*	321	SPS	SPS	50516 LP-SLAT269.0 to 50517 LP-SINT269.0 CKT 1	143	52.5	101.3	21.7	50513 LP-COOP269.0 to 50524 LP-WADS269.0 CKT1	
10SP*	321	SPS	SPS	50517 LP-SINT269.0 to 50518 LP-SINT6 230 CKT 1	140	19.5	129.9	48.1	50521 LP-HOLL6 230 to 51699 JONES6 230 CKT1	
10SP*	321	SPS	SPS	50517 LP-SINT269.0 to 50518 LP-SINT6 230 CKT 1	140	19.5	129.9	48.1	50520 LP-HOLL269.0 to 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	SPS	50517 LP-SINT269.0 to 50518 LP-SINT6 230 CKT 1	140	18.2	126.1	47.1	50527 LP-WADS6 230 to 51689 LUBE6 230 CKT1	
10SP*	321	SPS	SPS	50517 LP-SINT269.0 to 50518 LP-SINT6 230 CKT 1	140	18.2	126.1	47.1	50524 LP-WADS269.0 to 50527 LP-WADS6 230 CKT1	
10SP*	321	SPS	SPS	50517 LP-SINT269.0 to 50518 LP-SINT6 230 CKT 1	100	22.2	118.9	30.1	BASE CASE	
10WP*	189			NONE IDENTIFIED						

* Study Cases include higher priority service (SUNC to SPS 150 MW) with required network upgrades.

Table 4.1 - Non-SPP Voltage Violations
Caused or Impacted by Transfer Using Scenario 1

Southwest Power Pool
System Impact Study

Study Case	Transfer Amount (MW)	AREA	Monitored Bus with Violation	BC Voltage (PU)	TC Voltage (PU)	Outaged Branch Causing Voltage Violation	Comments
10SP	321	SPS	50527 LP-WADS6 230	0.9880	0.8000	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
10SP	321	SPS	50527 LP-WADS6 230	0.9880	0.7994	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
10SP	321	SPS	50527 LP-WADS6 230	1.0767	0.3785	OPEN LINE FROM BUS 51435 [TOLKE6 230.00] TO BUS 51533 [TUCO6 230.00] CKT 1	
10SP	321		Contingency Not Converged			OPEN LINE FROM BUS 50517 [LP-SINT269.000] TO BUS 50518 [LP-SINT6230.00] CKT 1	
10SP	321		Contingency Not Converged			OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
10WP	189	SPS	50527 LP-WADS6 230	0.9900	0.8923	OPEN LINE FROM BUS 51689 [LUBE6 230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
10SP*	321	SPS	50507 LP-MLWK6 230	0.8669	0.7979	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 51647 CARLISL6 230 CKT1	
10SP*	321	SPS	50518 LP-SINT6 230	0.9301	0.8446	OPEN LINE FROM BUS 50518 LP-SINT6 230 TO BUS 51681 LUBS6 230 CKT1	
10SP*	321	SPS	50521 LP-HOLL6 230	0.9816	0.8440	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50527 LP-WADS6 230	1.0760	0.8045	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50527 LP-WADS6 230	0.9016	0.8562	OPEN LINE FROM BUS 51689 LUBE6 230 TO BUS 51699 JONES6 230 CKT1	
10WP*	189	SPS	50527 LP-WADS6 230	0.9933	0.8939	OPEN LINE FROM BUS 51689 LUBE6 230 TO BUS 51699 JONES6 230 CKT1	

* Study Cases include higher priority service (SUNC to SPS 150 MW) with required network upgrades.

Southwest Power Pool
System Impact Study

Study Case	Transfer Amount (MW)	AREA	Monitored Bus with Violation	BC Voltage (PU)	TC Voltage (PU)	Outaged Branch Causing Voltage Violation	ATC (MW)	Solution	Estimated Cost
10SP*	321		Contingency Not Converged			OPEN LINE FROM BUS 50517 [LP-SINT269.000] TO BUS 50518 [LP-SINT6230.00] CKT 1	N/A	Contingency Converged with Selected Upgrades, No Limitations Identified	
10SP*	321		Contingency Not Converged			OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	N/A	"	
10SP*	321		Contingency Not Converged			OPEN LINE FROM BUS 51533 [TUC06 230.00] TO BUS 51534 [TUC07 345.00] CKT 1	N/A	"	
10SP*	321		Contingency Not Converged			OPEN LINE FROM BUS 54119 [O.K.U.-7345.00] TO BUS 51534 [TUC07 345.00] CKT 1	N/A	"	
10SP*	321		Contingency Not Converged			REMOVE UNIT 1 FROM BUS 51441 [TOLK1 124.000] DISPATCH	N/A	"	
10SP*	321		Contingency Not Converged			REMOVE UNIT 1 FROM BUS 51442 [TOLK2 124.000] DISPATCH	N/A	"	
10SP*	321		Contingency Not Converged			REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	N/A	"	
10WP*	189		NONE IDENTIFIED				189	Total Estimated Engineering and Construction Cost	\$11,700,000

* Study Cases include higher priority service (SUNC to SPS 150 MW) with required network upgrades.

Southwest Power Pool
 System Impact Study

Study Case	Transfer Amount (MW)	From Area	To Area	Monitored Branch Over 100% Rate B	Rate <MVA>	BC % Loading	TC % Loading	%TDF	Outaged Branch Causing Overload	Comments
10SP*	321			Contingency Not Converged					54119 O.K.U.-7 345 to 51534 TUC07 345 CKT 1	
10SP*	321			Contingency Not Converged					REMOVE UNIT 1 FROM BUS 51441 [TOLK1 124.000] DISPATCH	
10SP*	321			Contingency Not Converged					REMOVE UNIT 1 FROM BUS 51442 [TOLK2 124.000] DISPATCH	
10SP*	321			Contingency Not Converged					REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
10WP*	189			NONE IDENTIFIED						

* Study Cases include higher priority service (SUNC to SPS 150 MW) with required network upgrades.

Southwest Power Pool
System Impact Study

Study Case	Transfer Amount (MW)	AREA	Monitored Bus with Violation	BC Voltage (PU)	TC Voltage (PU)	Outaged Branch Causing Voltage Violation	Comments
05SP	274	SPS	50507 LP-MLWK6 230	0.8667	0.7936	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 51647 [CARLISL6230.00] CKT 1	
05SP	274	SPS	50518 LP-SINT6 230	0.9298	0.8335	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
05SP	274	SPS	50507 LP-MLWK6 230	0.9612	0.8439	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50507 LP-MLWK6 230	0.9616	0.8482	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50527 LP-WADS6 230	0.9779	0.8431	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50518 LP-SINT6 230	0.9765	0.8495	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50527 LP-WADS6 230	0.9798	0.8490	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50521 LP-HOLL6 230	0.9804	0.8501	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50507 LP-MLWK6 230	0.9625	0.8619	OPEN LINE FROM BUS 51533 [TUCO6 230.00] TO BUS 51647 [CARLISL6230.00] CKT 1	
05SP	274	SPS	50518 LP-SINT6 230	0.9779	0.8553	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50521 LP-HOLL6 230	0.9892	0.8495	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
05SP	274	SPS	50521 LP-HOLL6 230	0.9820	0.8560	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50511 LP-THOM 69.0	1.0167	0.8377	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50510 LP-VCKS269.0	1.0182	0.8381	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50512 LP-MCCU269.0	1.0172	0.8390	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50523 LP-BRND269.0	1.0230	0.8367	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50527 LP-WADS6 230	1.0751	0.8110	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
05SP	274	SPS	50509 LP-MLWK269.0	1.0193	0.8403	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50515 LP-CHAL269.0	1.0184	0.8423	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50503 LP-ERSK269.0	1.0240	0.8399	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50526 LP-OLIV269.0	1.0167	0.8436	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50527 LP-WADS6 230	0.9797	0.8624	OPEN LINE FROM BUS 51689 [LUBE6 230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
05SP	274	SPS	50511 LP-THOM 69.0	1.0169	0.8477	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50510 LP-VCKS269.0	1.0184	0.8481	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50512 LP-MCCU269.0	1.0174	0.8490	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50523 LP-BRND269.0	1.0230	0.8467	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50504 LP-MACK269.0	1.0273	0.8467	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50509 LP-MLWK269.0	1.0195	0.8502	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50503 LP-ERSK269.0	1.0241	0.8498	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50513 LP-COOP269.0	1.0232	0.8503	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50515 LP-CHAL269.0	1.0186	0.8523	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50526 LP-OLIV269.0	1.0169	0.8535	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50506 LP-NE52 69.0	1.0272	0.8508	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50516 LP-SLAT269.0	1.0224	0.8527	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50507 LP-MLWK6 230	0.9560	0.8789	REMOVE UNIT 1 FROM BUS 51441 [TOLK1 124.000] DISPATCH	
05SP	274	SPS	50504 LP-MACK269.0	1.0275	0.8566	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50517 LP-SINT269.0	1.0251	0.8596	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50513 LP-COOP269.0	1.0234	0.8602	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50506 LP-NE52 69.0	1.0274	0.8606	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50516 LP-SLAT269.0	1.0226	0.8625	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50524 LP-WADS269.0	1.0253	0.8660	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50520 LP-HOLL269.0	1.0301	0.8660	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
05SP	274	SPS	50517 LP-SINT269.0	1.0254	0.8692	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50524 LP-WADS269.0	1.0256	0.8756	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SP	274	SPS	50520 LP-HOLL269.0	1.0303	0.8755	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
05SH	224	SPS	50527 LP-WADS6 230	0.9908	0.8885	OPEN LINE FROM BUS 51689 [LUBE6 230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
05FA	159		NONE IDENTIFIED				
05WP	159		NONE IDENTIFIED				
07SP	292	SPS	50507 LP-MLWK6 230	0.8666	0.3932	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 51647 [CARLISL6230.00] CKT 1	
07SP	292	SPS	50518 LP-SINT6 230	0.9298	0.3988	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
07SP	292	SPS	50521 LP-HOLL6 230	0.9893	0.4363	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
07SP	292	SPS	50509 LP-MLWK269.0	1.0053	0.4561	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 51647 [CARLISL6230.00] CKT 1	
07SP	292	SPS	50509 LP-MLWK269.0	1.0053	0.4563	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 50509 [LP-MLWK269.000] CKT 1	
07SP	292	SPS	50526 LP-OLIV269.0	1.0151	0.4157	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	

**Southwest Power Pool
System Impact Study**

Study Case	Transfer Amount (MW)	AREA	Monitored Bus with Violation	BC Voltage (PU)	TC Voltage (PU)	Outaged Branch Causing Voltage Violation	Comments
07SP	292	SPS	50526 LP-OLIV269.0	1.0152	0.4162	OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
07SP	292	SPS	50511 LP-THOM 69.0	1.0166	0.4129	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
07SP	292	SPS	50511 LP-THOM 69.0	1.0166	0.4134	OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
07SP	292	SPS	50515 LP-CHAL269.0	1.0175	0.4145	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
07SP	292	SPS	50515 LP-CHAL269.0	1.0175	0.4150	OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
07SP	292	SPS	50512 LP-MCCU269.0	1.0176	0.4196	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
07SP	292	SPS	50512 LP-MCCU269.0	1.0177	0.4201	OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
07SP	292	SPS	50510 LP-VCKS269.0	1.0187	0.4174	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
07SP	292	SPS	50510 LP-VCKS269.0	1.0187	0.4180	OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
07SP	292	SPS	50523 LP-BRND269.0	1.0230	0.4162	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
07SP	292	SPS	50523 LP-BRND269.0	1.0230	0.4167	OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
07SP	292	SPS	50516 LP-SLAT269.0	1.0210	0.4285	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
07SP	292	SPS	50516 LP-SLAT269.0	1.0210	0.4290	OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
07SP	292	SPS	50503 LP-ERSK269.0	1.0242	0.4211	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
07SP	292	SPS	50503 LP-ERSK269.0	1.0242	0.4216	OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
07SP	292	SPS	50509 LP-MLWK269.0	1.0215	0.4326	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
07SP	292	SPS	50509 LP-MLWK269.0	1.0215	0.4331	OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
07SP	292	SPS	50517 LP-SINT269.0	1.0228	0.4387	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
07SP	292	SPS	50517 LP-SINT269.0	1.0228	0.4392	OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
07SP	292	SPS	50513 LP-COOP269.0	1.0237	0.4384	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
07SP	292	SPS	50513 LP-COOP269.0	1.0237	0.4389	OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
07SP	292	SPS	50511 LP-THOM 69.0	1.0199	0.4551	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
07SP	292	SPS	50511 LP-THOM 69.0	1.0199	0.4556	OPEN LINE FROM BUS 50520 [LP-HOLL269.00] TO BUS 50521 [LP-HOLL6230.00] CKT 1	
07SP	292	SPS	50512 LP-MCCU269.0	1.0204	0.4575	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
07SP	292	SPS	50512 LP-MCCU269.0	1.0204	0.4579	OPEN LINE FROM BUS 50520 [LP-HOLL269.00] TO BUS 50521 [LP-HOLL6230.00] CKT 1	
07SP	292	SPS	50504 LP-MACK269.0	1.0277	0.4318	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
07SP	292	SPS	50504 LP-MACK269.0	1.0277	0.4323	OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
07SP	292	SPS	50510 LP-VCKS269.0	1.0213	0.4567	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
07SP	292	SPS	50510 LP-VCKS269.0	1.0214	0.4572	OPEN LINE FROM BUS 50520 [LP-HOLL269.00] TO BUS 50521 [LP-HOLL6230.00] CKT 1	
07SP	292	SPS	50511 LP-THOM 69.0	1.0212	0.4613	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
07SP	292	SPS	50526 LP-OLIV269.0	1.0201	0.4654	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
07SP	292	SPS	50526 LP-OLIV269.0	1.0201	0.4658	OPEN LINE FROM BUS 50520 [LP-OLIV269.00] TO BUS 50521 [LP-HOLL6230.00] CKT 1	
07SP	292	SPS	50506 LP-NES2 69.0	1.0276	0.4388	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
07SP	292	SPS	50506 LP-NES2 69.0	1.0277	0.4393	OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
07SP	292	SPS	50523 LP-BRND269.0	1.0239	0.4531	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
07SP	292	SPS	50515 LP-CHAL269.0	1.0218	0.4608	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
07SP	292	SPS	50512 LP-MCCU269.0	1.0220	0.4601	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
07SP	292	SPS	50523 LP-BRND269.0	1.0239	0.4536	OPEN LINE FROM BUS 50520 [LP-HOLL269.00] TO BUS 50521 [LP-HOLL6230.00] CKT 1	
07SP	292	SPS	50515 LP-CHAL269.0	1.0218	0.4612	OPEN LINE FROM BUS 50520 [LP-HOLL269.00] TO BUS 50521 [LP-HOLL6230.00] CKT 1	
07SP	292	SPS	50510 LP-VCKS269.0	1.0224	0.4614	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
07SP	292	SPS	50507 LP-MLWK6 230	0.9501	0.7222	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
07SP	292	SPS	50523 LP-BRND269.0	1.0254	0.4571	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
07SP	292	SPS	50503 LP-ERSK269.0	1.0257	0.4573	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
07SP	292	SPS	50503 LP-ERSK269.0	1.0257	0.4578	OPEN LINE FROM BUS 50520 [LP-HOLL269.00] TO BUS 50521 [LP-HOLL6230.00] CKT 1	
07SP	292	SPS	50515 LP-CHAL269.0	1.0233	0.4690	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
07SP	292	SPS	50526 LP-OLIV269.0	1.0218	0.4755	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
07SP	292	SPS	50509 LP-MLWK269.0	1.0239	0.4694	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
07SP	292	SPS	50507 LP-MLWK6 230	0.9505	0.7255	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
07SP	292	SPS	50503 LP-ERSK269.0	1.0274	0.4610	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
07SP	292	SPS	50524 LP-WADS269.0	1.0269	0.4728	OPEN LINE FROM BUS 50520 [LP-HOLL269.00] TO BUS 50521 [LP-HOLL6230.00] CKT 1	
07SP	292	SPS	50513 LP-COOP269.0	1.0266	0.4743	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
07SP	292	SPS	50524 LP-WADS269.0	1.0269	0.4733	OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
07SP	292	SPS	50516 LP-SLAT269.0	1.0259	0.4778	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
07SP	292	SPS	50516 LP-SLAT269.0	1.0259	0.4783	OPEN LINE FROM BUS 50520 [LP-HOLL269.00] TO BUS 50521 [LP-HOLL6230.00] CKT 1	

Southwest Power Pool
System Impact Study

Study Case	Transfer Amount (MW)	AREA	Monitored Bus with Violation	BC Voltage (PU)	TC Voltage (PU)	Outaged Branch Causing Voltage Violation	Comments
07SP	292	SPS	50504 LP-MACK269.0	1.0299	0.4669	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
07SP	292	SPS	50504 LP-MACK269.0	1.0299	0.4674	OPEN LINE FROM BUS 50520 [LP-HOLL269.00] TO BUS 50521 [LP-HOLL6230.00] CKT 1	
07SP	292	SPS	50513 LP-COOP269.0	1.0287	0.4739	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
07SP	292	SPS	50520 LP-HOLL269.0	1.0307	0.4675	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
07SP	292	SPS	50513 LP-COOP269.0	1.0288	0.4741	OPEN LINE FROM BUS 50524 [LP-WADS269.00] TO BUS 50527 [LP-WADS6230.00] CKT 1	
07SP	292	SPS	50520 LP-HOLL269.0	1.0307	0.4680	OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
07SP	292	SPS	50506 LP-NES2 69.0	1.0301	0.4718	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
07SP	292	SPS	50506 LP-NES2 69.0	1.0301	0.4722	OPEN LINE FROM BUS 50520 [LP-HOLL269.00] TO BUS 50521 [LP-HOLL6230.00] CKT 1	
07SP	292	SPS	50504 LP-MACK269.0	1.0318	0.4703	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
07SP	292	SPS	50516 LP-SLAT269.0	1.0278	0.4875	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
07SP	292	SPS	50506 LP-NES2 69.0	1.0322	0.4786	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
07SP	292	SPS	50517 LP-SINT269.0	1.0286	0.4931	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
07SP	292	SPS	50517 LP-SINT269.0	1.0286	0.4936	OPEN LINE FROM BUS 50520 [LP-HOLL269.00] TO BUS 50521 [LP-HOLL6230.00] CKT 1	
07SP	292	SPS	50524 LP-WADS269.0	1.0327	0.4917	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
07SP	292	SPS	50524 LP-WADS269.0	1.0328	0.4919	OPEN LINE FROM BUS 50524 [LP-WADS269.00] TO BUS 50527 [LP-WADS6230.00] CKT 1	
07SP	292	SPS	50524 LP-WADS269.0	1.0296	0.5019	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
07SP	292	SPS	50520 LP-HOLL269.0	1.0338	0.4930	OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
07SP	292	SPS	50520 LP-HOLL269.0	1.0338	0.4934	OPEN LINE FROM BUS 50520 [LP-HOLL269.00] TO BUS 50521 [LP-HOLL6230.00] CKT 1	
07SP	292	SPS	50517 LP-SINT269.0	1.0303	0.5061	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
07SP	292	SPS	50527 LP-WADS6 230	0.9694	0.6966	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
07SP	292	SPS	50518 LP-SINT6 230	0.9675	0.7072	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
07SP	292	SPS	50520 LP-HOLL269.0	1.0362	0.5110	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
07SP	292	SPS	50527 LP-WADS6 230	0.9710	0.7011	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
07SP	292	SPS	50518 LP-SINT6 230	0.9692	0.7116	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
07SP	292	SPS	50527 LP-WADS6 230	1.0757	0.4239	OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
07SP	292	SPS	50521 LP-HOLL6 230	0.9717	0.7067	REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
07SP	292	SPS	50521 LP-HOLL6 230	0.9732	0.7112	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
07SP	292	SPS	50507 LP-MLWK6 230	0.9682	0.7950	OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
07SP	292	SPS	50507 LP-MLWK6 230	0.9682	0.7952	OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
07SP	292	SPS	50527 LP-WADS6 230	0.9887	0.7840	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 50509 [LP-MLWK269.00] CKT 1	
07SP	292	SPS	50527 LP-WADS6 230	0.9889	0.7839	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 51647 [CARLISL6230.00] CKT 1	
07SP	292	SPS	50518 LP-SINT6 230	0.9858	0.7925	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 51647 [CARLISL6230.00] CKT 1	
07SP	292	SPS	50518 LP-SINT6 230	0.9862	0.7926	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 50509 [LP-MLWK269.00] CKT 1	
07SP	292	SPS	50521 LP-HOLL6 230	0.9907	0.7954	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 50509 [LP-MLWK269.00] CKT 1	
07SP	292	SPS	50521 LP-HOLL6 230	0.9909	0.7953	OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 51647 [CARLISL6230.00] CKT 1	
07SP	292		Contingency Not Converged			REMOVE UNIT 1 FROM BUS 51441 [TOLK1 124.000] DISPATCH	
07SP	292		Contingency Not Converged			REMOVE UNIT 1 FROM BUS 51442 [TOLK2 124.000] DISPATCH	
07WP	171		NONE IDENTIFIED				
10SP	321	SPS	50507 LP-MLWK6 230	0.9364	0.6404	OPEN LINE FROM BUS 51533 [TUCO6 230.00] TO BUS 51647 [CARLISL6230.00] CKT 1	
10SP	321	SPS	50507 LP-MLWK6 230	0.9377	0.6528	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50527 LP-WADS6 230	0.9586	0.6129	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50518 LP-SINT6 230	0.9572	0.6262	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50511 LP-THOM 69.0	1.0155	0.3521	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50512 LP-MCCU269.0	1.0157	0.3553	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50510 LP-VCKS269.0	1.0168	0.3525	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50509 LP-MLWK6 230	1.0166	0.3592	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50515 LP-CHAL269.0	1.0174	0.3596	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50526 LP-OLIV269.0	1.0160	0.3662	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50523 LP-BRND269.0	1.0230	0.3519	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50521 LP-HOLL6 230	0.9617	0.6254	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50503 LP-ERSK269.0	1.0237	0.3573	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50513 LP-COOP269.0	1.0216	0.3759	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50516 LP-SLAT269.0	1.0216	0.3799	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50504 LP-MACK269.0	1.0266	0.3689	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	

Southwest Power Pool
System Impact Study

Study Case	Transfer Amount (MW)	AREA	Monitored Bus with Violation	BC Voltage (PU)	TC Voltage (PU)	Outaged Branch Causing Voltage Violation	Comments
10SP	321	SPS	50506 LP-NES2 69.0	1.0267	0.3772	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50511 LP-THOM 69.0	1.0196	0.4068	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50512 LP-MCCU269.0	1.0200	0.4097	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50510 LP-VCKS269.0	1.0207	0.4084	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50517 LP-SINT269.0	1.0247	0.3981	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50524 LP-WADS269.0	1.0225	0.4079	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50523 LP-BRND269.0	1.0236	0.4061	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50515 LP-CHAL269.0	1.0219	0.4131	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50526 LP-OLIV269.0	1.0205	0.4185	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50511 LP-THOM 69.0	1.0200	0.4288	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50509 LP-MLWK269.0	1.0222	0.4210	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50511 LP-THOM 69.0	1.0201	0.4304	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50503 LP-ERSK269.0	1.0255	0.4110	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50527 LP-WADS6 230	0.9749	0.6081	OPEN LINE FROM BUS 51689 [LUBE6 230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
10SP	321	SPS	50512 LP-MCCU269.0	1.0205	0.4318	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50510 LP-VCKS269.0	1.0212	0.4297	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50512 LP-MCCU269.0	1.0205	0.4334	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50510 LP-VCKS269.0	1.0213	0.4312	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50523 LP-BRND269.0	1.0240	0.4283	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50515 LP-CHAL269.0	1.0222	0.4360	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50526 LP-OLIV269.0	1.0208	0.4420	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50523 LP-BRND269.0	1.0240	0.4298	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50515 LP-CHAL269.0	1.0222	0.4376	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50526 LP-OLIV269.0	1.0208	0.4436	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50511 LP-THOM 69.0	1.0201	0.4464	OPEN LINE FROM BUS 50555 [CR-PHIL4138.00] TO BUS 50558 [CR-TATE4138.00] CKT 1	
10SP	321	SPS	50520 LP-HOLL269.0	1.0301	0.4106	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP	321	SPS	50509 LP-MLWK269.0	1.0230	0.4390	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50512 LP-MCCU269.0	1.0205	0.4495	OPEN LINE FROM BUS 50555 [CR-PHIL4138.00] TO BUS 50558 [CR-TATE4138.00] CKT 1	
10SP	321	SPS	50509 LP-MLWK269.0	1.0230	0.4405	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50510 LP-VCKS269.0	1.0213	0.4472	OPEN LINE FROM BUS 50555 [CR-PHIL4138.00] TO BUS 50558 [CR-TATE4138.00] CKT 1	
10SP	321	SPS	50513 LP-COOP269.0	1.0265	0.4290	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50503 LP-ERSK269.0	1.0259	0.4336	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50516 LP-SLAT269.0	1.0263	0.4324	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50503 LP-ERSK269.0	1.0259	0.4352	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50504 LP-MACK269.0	1.0299	0.4223	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50523 LP-BRND269.0	1.0240	0.4459	OPEN LINE FROM BUS 50555 [CR-PHIL4138.00] TO BUS 50558 [CR-TATE4138.00] CKT 1	
10SP	321	SPS	50515 LP-CHAL269.0	1.0222	0.4537	OPEN LINE FROM BUS 50555 [CR-PHIL4138.00] TO BUS 50558 [CR-TATE4138.00] CKT 1	
10SP	321	SPS	50526 LP-OLIV269.0	1.0208	0.4597	OPEN LINE FROM BUS 50555 [CR-PHIL4138.00] TO BUS 50558 [CR-TATE4138.00] CKT 1	
10SP	321	SPS	50509 LP-MLWK269.0	1.0230	0.4562	OPEN LINE FROM BUS 50555 [CR-PHIL4138.00] TO BUS 50558 [CR-TATE4138.00] CKT 1	
10SP	321	SPS	50506 LP-NES2 69.0	1.0304	0.4301	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50513 LP-COOP269.0	1.0203	0.4693	OPEN LINE FROM BUS 50513 [LP-COOP269.00] TO BUS 50524 [LP-WADS269.00] CKT 1	
10SP	321	SPS	50503 LP-ERSK269.0	1.0259	0.4513	OPEN LINE FROM BUS 50555 [CR-PHIL4138.00] TO BUS 50558 [CR-TATE4138.00] CKT 1	
10SP	321	SPS	50513 LP-COOP269.0	1.0268	0.4522	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50513 LP-COOP269.0	1.0268	0.4538	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50516 LP-SLAT269.0	1.0265	0.4562	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50516 LP-SLAT269.0	1.0265	0.4578	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50504 LP-MACK269.0	1.0302	0.4453	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50517 LP-SINT269.0	1.0294	0.4497	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50504 LP-MACK269.0	1.0303	0.4469	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50506 LP-NES2 69.0	1.0307	0.4535	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50506 LP-NES2 69.0	1.0307	0.4551	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50524 LP-WADS269.0	1.0294	0.4603	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50516 LP-SLAT269.0	1.0265	0.4739	OPEN LINE FROM BUS 50555 [CR-PHIL4138.00] TO BUS 50558 [CR-TATE4138.00] CKT 1	
10SP	321	SPS	50504 LP-MACK269.0	1.0303	0.4631	OPEN LINE FROM BUS 50555 [CR-PHIL4138.00] TO BUS 50558 [CR-TATE4138.00] CKT 1	

Southwest Power Pool
System Impact Study

Study Case	Transfer Amount (MW)	AREA	Monitored Bus with Violation	BC Voltage (PU)	TC Voltage (PU)	Outaged Branch Causing Voltage Violation	Comments
10SP	321	SPS	50517 LP-SINT269.0	1.0295	0.4740	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50506 LP-NES2 69.0	1.0307	0.4713	OPEN LINE FROM BUS 50555 [CR-PHIL4138.00] TO BUS 50558 [CR-TATE4138.00] CKT 1	
10SP	321	SPS	50517 LP-SINT269.0	1.0295	0.4756	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50520 LP-HOLL269.0	1.0348	0.4624	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50524 LP-WADS269.0	1.0296	0.4840	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50524 LP-WADS269.0	1.0296	0.4856	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50507 LP-MLWK6 230	0.9554	0.7241	OPEN LINE FROM BUS 51041 [AMARLS6 230.00] TO BUS 51321 [SWISHER6230.00] CKT 1	
10SP	321	SPS	50517 LP-SINT269.0	1.0295	0.4916	OPEN LINE FROM BUS 50555 [CR-PHIL4138.00] TO BUS 50558 [CR-TATE4138.00] CKT 1	
10SP	321	SPS	50524 LP-WADS269.0	1.0296	0.5017	OPEN LINE FROM BUS 50555 [CR-PHIL4138.00] TO BUS 50558 [CR-TATE4138.00] CKT 1	
10SP	321	SPS	50520 LP-HOLL269.0	1.0349	0.4864	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50520 LP-HOLL269.0	1.0350	0.4880	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50507 LP-MLWK6 230	0.9605	0.7182	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50507 LP-MLWK6 230	0.9607	0.7191	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50520 LP-HOLL269.0	1.0350	0.5041	OPEN LINE FROM BUS 50555 [CR-PHIL4138.00] TO BUS 50558 [CR-TATE4138.00] CKT 1	
10SP	321	SPS	50518 LP-SINT6 230	0.9864	0.6603	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50527 LP-WADS6 230	0.9885	0.6585	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50521 LP-HOLL6 230	0.9908	0.6687	OPEN LINE FROM BUS 51681 [LUBS6 230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321	SPS	50527 LP-WADS6 230	0.9886	0.6764	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50527 LP-WADS6 230	0.9886	0.6776	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50518 LP-SINT6 230	0.9860	0.6879	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50518 LP-SINT6 230	0.9860	0.6891	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50521 LP-HOLL6 230	0.9908	0.6881	OPEN LINE FROM BUS 52205 [LEACO6 230.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50521 LP-HOLL6 230	0.9908	0.6892	OPEN LINE FROM BUS 50558 [CR-TATE4138.00] TO BUS 52231 [MIDLND-6230.00] CKT 1	
10SP	321	SPS	50518 LP-SINT6 230	0.9860	0.7009	OPEN LINE FROM BUS 50555 [CR-PHIL4138.00] TO BUS 50558 [CR-TATE4138.00] CKT 1	
10SP	321	SPS	50521 LP-HOLL6 230	0.9908	0.7013	OPEN LINE FROM BUS 50555 [CR-PHIL4138.00] TO BUS 50558 [CR-TATE4138.00] CKT 1	
10SP	321		Contingency Not Converged			OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 50509 [LP-MLWK269.00] CKT 1	
10SP	321		Contingency Not Converged			OPEN LINE FROM BUS 50507 [LP-MLWK6230.00] TO BUS 51647 [CARLISL6230.00] CKT 1	
10SP	321		Contingency Not Converged			OPEN LINE FROM BUS 50517 [LP-SINT269.00] TO BUS 50518 [LP-SINT6230.00] CKT 1	
10SP	321		Contingency Not Converged			OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
10SP	321		Contingency Not Converged			OPEN LINE FROM BUS 50520 [LP-HOLL269.00] TO BUS 50521 [LP-HOLL6230.00] CKT 1	
10SP	321		Contingency Not Converged			OPEN LINE FROM BUS 50521 [LP-HOLL6230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
10SP	321		Contingency Not Converged			OPEN LINE FROM BUS 50524 [LP-WADS269.00] TO BUS 50527 [LP-WADS6230.00] CKT 1	
10SP	321		Contingency Not Converged			OPEN LINE FROM BUS 50527 [LP-WADS6230.00] TO BUS 51689 [LUBE6 230.00] CKT 1	
10SP	321		Contingency Not Converged			OPEN LINE FROM BUS 51435 [TOLKE6 230.00] TO BUS 51533 [TUCO6 230.00] CKT 1	
10SP	321		Contingency Not Converged			OPEN LINE FROM BUS 51533 [TUCO6 230.00] TO BUS 51534 [TUCO7 345.00] CKT 1	
10SP	321		Contingency Not Converged			OPEN LINE FROM BUS 51733 [SUNDOWN6230.00] TO BUS 51763 [WOLFRTH6230.00] CKT 1	
10SP	321		Contingency Not Converged			OPEN LINE FROM BUS 54119 [O.K.U.-7345.00] TO BUS 51534 [TUCO7 345.00] CKT 1	
10SP	321		Contingency Not Converged			REMOVE UNIT 1 FROM BUS 51441 [TOLK1 124.00] DISPATCH	
10SP	321		Contingency Not Converged			REMOVE UNIT 1 FROM BUS 51442 [TOLK2 124.00] DISPATCH	
10SP	321		Contingency Not Converged			REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.00] DISPATCH	
10WP	189	SPS	50527 LP-WADS6 230	0.9928	0.8942	OPEN LINE FROM BUS 51689 [LUBE6 230.00] TO BUS 51699 [JONES6 230.00] CKT 1	
10SP*	321	SPS	50503 LP-ERSK269.0	1.0245	0.3929	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50503 LP-ERSK269.0	1.0245	0.3937	OPEN LINE FROM BUS 50520 LP-HOLL269.0 TO BUS 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	50503 LP-ERSK269.0	1.0272	0.3960	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50503 LP-ERSK269.0	1.0272	0.3961	OPEN LINE FROM BUS 50524 LP-WADS269.0 TO BUS 50527 LP-WADS6 230 CKT1	
10SP*	321	SPS	50503 LP-ERSK269.0	1.0238	0.4201	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 50509 LP-MLWK269.0 CKT1	
10SP*	321	SPS	50504 LP-MACK269.0	1.0283	0.4032	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50504 LP-MACK269.0	1.0283	0.4039	OPEN LINE FROM BUS 50520 LP-HOLL269.0 TO BUS 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	50504 LP-MACK269.0	1.0317	0.4059	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50504 LP-MACK269.0	1.0317	0.4060	OPEN LINE FROM BUS 50524 LP-WADS269.0 TO BUS 50527 LP-WADS6 230 CKT1	
10SP*	321	SPS	50504 LP-MACK269.0	1.0277	0.4376	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 50509 LP-MLWK269.0 CKT1	
10SP*	321	SPS	50506 LP-NES2 69.0	1.0284	0.4085	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50506 LP-NES2 69.0	1.0284	0.4093	OPEN LINE FROM BUS 50520 LP-HOLL269.0 TO BUS 50521 LP-HOLL6 230 CKT1	

Southwest Power Pool
System Impact Study

Study Case	Transfer Amount (MW)	AREA	Monitored Bus with Violation	BC Voltage (PU)	TC Voltage (PU)	Outaged Branch Causing Voltage Violation	Comments
10SP*	321	SPS	50506 LP-NES2 69.0	1.0322	0.4150	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50506 LP-NES2 69.0	1.0322	0.4151	OPEN LINE FROM BUS 50524 LP-WADS269.0 TO BUS 50527 LP-WADS6 230 CKT1	
10SP*	321	SPS	50506 LP-NES2 69.0	1.0276	0.4482	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP*	321	SPS	50507 LP-MLWK6 230	0.8656	0.3303	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 51647 CARLISL6 230 CKT1	
10SP*	321	SPS	50507 LP-MLWK6 230	0.9784	0.7081	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP*	321	SPS	50507 LP-MLWK6 230	0.9910	0.7424	OPEN LINE FROM BUS 51733 SUNDOWN6 230 TO BUS 51763 WOLFRTH6 230 CKT1	
10SP*	321	SPS	50507 LP-MLWK6 230	0.9913	0.8039	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50507 LP-MLWK6 230	0.9913	0.8042	OPEN LINE FROM BUS 50520 LP-HOLL269.0 TO BUS 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	50509 LP-MLWK269.0	1.0046	0.3831	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 50509 LP-MLWK269.0 CKT1	
10SP*	321	SPS	50509 LP-MLWK269.0	1.0041	0.3832	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 51647 CARLISL6 230 CKT1	
10SP*	321	SPS	50509 LP-MLWK269.0	1.0230	0.4071	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50509 LP-MLWK269.0	1.0230	0.4079	OPEN LINE FROM BUS 50520 LP-HOLL269.0 TO BUS 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	50509 LP-MLWK269.0	1.0233	0.4122	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50510 LP-VCKS269.0	1.0201	0.3924	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50510 LP-VCKS269.0	1.0201	0.3932	OPEN LINE FROM BUS 50520 LP-HOLL269.0 TO BUS 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	50510 LP-VCKS269.0	1.0222	0.3965	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50510 LP-VCKS269.0	1.0222	0.3966	OPEN LINE FROM BUS 50524 LP-WADS269.0 TO BUS 50527 LP-WADS6 230 CKT1	
10SP*	321	SPS	50510 LP-VCKS269.0	1.0128	0.4014	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 50509 LP-MLWK269.0 CKT1	
10SP*	321	SPS	50511 LP-THOM 69.0	1.0186	0.3907	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50511 LP-THOM 69.0	1.0186	0.3915	OPEN LINE FROM BUS 50520 LP-HOLL269.0 TO BUS 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	50511 LP-THOM 69.0	1.0209	0.3964	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50511 LP-THOM 69.0	1.0209	0.3965	OPEN LINE FROM BUS 50524 LP-WADS269.0 TO BUS 50527 LP-WADS6 230 CKT1	
10SP*	321	SPS	50511 LP-THOM 69.0	1.0130	0.4075	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 50509 LP-MLWK269.0 CKT1	
10SP*	321	SPS	50512 LP-MCCU269.0	1.0188	0.3932	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50512 LP-MCCU269.0	1.0188	0.3940	OPEN LINE FROM BUS 50520 LP-HOLL269.0 TO BUS 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	50512 LP-MCCU269.0	1.0218	0.3951	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50512 LP-MCCU269.0	1.0218	0.3952	OPEN LINE FROM BUS 50524 LP-WADS269.0 TO BUS 50527 LP-WADS6 230 CKT1	
10SP*	321	SPS	50512 LP-MCCU269.0	1.0141	0.4124	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 50509 LP-MLWK269.0 CKT1	
10SP*	321	SPS	50513 LP-COOP269.0	1.0285	0.4100	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50513 LP-COOP269.0	1.0285	0.4101	OPEN LINE FROM BUS 50524 LP-WADS269.0 TO BUS 50527 LP-WADS6 230 CKT1	
10SP*	321	SPS	50513 LP-COOP269.0	1.0246	0.4113	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50513 LP-COOP269.0	1.0246	0.4121	OPEN LINE FROM BUS 50520 LP-HOLL269.0 TO BUS 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	50513 LP-COOP269.0	1.0234	0.4468	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP*	321	SPS	50515 LP-CHAL269.0	1.0203	0.3966	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50515 LP-CHAL269.0	1.0203	0.3974	OPEN LINE FROM BUS 50520 LP-HOLL269.0 TO BUS 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	50515 LP-CHAL269.0	1.0230	0.4044	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50515 LP-CHAL269.0	1.0230	0.4045	OPEN LINE FROM BUS 50524 LP-WADS269.0 TO BUS 50527 LP-WADS6 230 CKT1	
10SP*	321	SPS	50515 LP-CHAL269.0	1.0171	0.4248	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 50509 LP-MLWK269.0 CKT1	
10SP*	321	SPS	50516 LP-SLAT269.0	1.0242	0.4152	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50516 LP-SLAT269.0	1.0242	0.4160	OPEN LINE FROM BUS 50520 LP-HOLL269.0 TO BUS 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	50516 LP-SLAT269.0	1.0275	0.4247	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50516 LP-SLAT269.0	1.0275	0.4248	OPEN LINE FROM BUS 50524 LP-WADS269.0 TO BUS 50527 LP-WADS6 230 CKT1	
10SP*	321	SPS	50516 LP-SLAT269.0	1.0228	0.4508	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP*	321	SPS	50517 LP-SINT269.0	1.0271	0.4325	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50517 LP-SINT269.0	1.0271	0.4332	OPEN LINE FROM BUS 50502 LP-HOLL269.0 TO BUS 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	50517 LP-SINT269.0	1.0298	0.4458	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50517 LP-SINT269.0	1.0298	0.4459	OPEN LINE FROM BUS 50524 LP-WADS269.0 TO BUS 50527 LP-WADS6 230 CKT1	
10SP*	321	SPS	50517 LP-SINT269.0	1.0257	0.4689	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP*	321	SPS	50518 LP-SINT6 230	0.9819	0.6842	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP*	321	SPS	50518 LP-SINT6 230	0.9853	0.7017	OPEN LINE FROM BUS 51733 SUNDOWN6 230 TO BUS 51763 WOLFRTH6 230 CKT1	
10SP*	321	SPS	50518 LP-SINT6 230	0.9855	0.7862	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 50509 LP-MLWK269.0 CKT1	
10SP*	321	SPS	50518 LP-SINT6 230	0.9851	0.7862	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 51647 CARLISL6 230 CKT1	
10SP*	321	SPS	50518 LP-SINT6 230	0.9857	0.7967	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50520 LP-HOLL269.0	1.0317	0.4322	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	

Southwest Power Pool
System Impact Study

Study Case	Transfer Amount (MW)	AREA	Monitored Bus with Violation	BC Voltage (PU)	TC Voltage (PU)	Outaged Branch Causing Voltage Violation	Comments
10SP*	321	SPS	50520 LP-HOLL269.0	1.0317	0.4329	OPEN LINE FROM BUS 50520 LP-HOLL269.0 TO BUS 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	50520 LP-HOLL269.0	1.0364	0.4514	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50520 LP-HOLL269.0	1.0364	0.4515	OPEN LINE FROM BUS 50524 LP-WADS269.0 TO BUS 50527 LP-WADS6 230 CKT1	
10SP*	321	SPS	50520 LP-HOLL269.0	1.0309	0.4816	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP*	321	SPS	50521 LP-HOLL6 230	0.9814	0.3825	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50521 LP-HOLL6 230	0.9867	0.6837	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP*	321	SPS	50521 LP-HOLL6 230	0.9908	0.7088	OPEN LINE FROM BUS 51733 SUNDOWN6 230 TO BUS 51763 WOLFRTH6 230 CKT1	
10SP*	321	SPS	50521 LP-HOLL6 230	0.9906	0.7893	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 50509 LP-MLWK269.0 CKT1	
10SP*	321	SPS	50521 LP-HOLL6 230	0.9907	0.7893	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 51647 CARLISL6 230 CKT1	
10SP*	321	SPS	50523 LP-BRND269.0	1.0230	0.3885	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50523 LP-BRND269.0	1.0230	0.3893	OPEN LINE FROM BUS 50520 LP-HOLL269.0 TO BUS 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	50523 LP-BRND269.0	1.0253	0.3919	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50523 LP-BRND269.0	1.0253	0.3920	OPEN LINE FROM BUS 50524 LP-WADS269.0 TO BUS 50527 LP-WADS6 230 CKT1	
10SP*	321	SPS	50523 LP-BRND269.0	1.0224	0.4108	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 50509 LP-MLWK269.0 CKT1	
10SP*	321	SPS	50524 LP-WADS269.0	1.0327	0.4296	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50524 LP-WADS269.0	1.0327	0.4297	OPEN LINE FROM BUS 50524 LP-WADS269.0 TO BUS 50527 LP-WADS6 230 CKT1	
10SP*	321	SPS	50524 LP-WADS269.0	1.0267	0.4422	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50524 LP-WADS269.0	1.0267	0.4429	OPEN LINE FROM BUS 50520 LP-HOLL269.0 TO BUS 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	50524 LP-WADS269.0	1.0251	0.4791	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP*	321	SPS	50526 LP-OLIV269.0	1.0187	0.4020	OPEN LINE FROM BUS 50521 LP-HOLL6 230 TO BUS 51699 JONES6 230 CKT1	
10SP*	321	SPS	50526 LP-OLIV269.0	1.0187	0.4027	OPEN LINE FROM BUS 50520 LP-HOLL269.0 TO BUS 50521 LP-HOLL6 230 CKT1	
10SP*	321	SPS	50526 LP-OLIV269.0	1.0214	0.4120	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50526 LP-OLIV269.0	1.0214	0.4121	OPEN LINE FROM BUS 50524 LP-WADS269.0 TO BUS 50527 LP-WADS6 230 CKT1	
10SP*	321	SPS	50526 LP-OLIV269.0	1.0172	0.4366	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP*	321	SPS	50527 LP-WADS6 230	1.0758	0.3704	OPEN LINE FROM BUS 50527 LP-WADS6 230 TO BUS 51689 LUBE6 230 CKT1	
10SP*	321	SPS	50527 LP-WADS6 230	0.9827	0.6735	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	
10SP*	321	SPS	50527 LP-WADS6 230	0.9882	0.6988	OPEN LINE FROM BUS 51733 SUNDOWN6 230 TO BUS 51763 WOLFRTH6 230 CKT1	
10SP*	321	SPS	50527 LP-WADS6 230	0.9879	0.7781	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 50509 LP-MLWK269.0 CKT1	
10SP*	321	SPS	50527 LP-WADS6 230	0.9881	0.7781	OPEN LINE FROM BUS 50507 LP-MLWK6 230 TO BUS 51647 CARLISL6 230 CKT1	
10SP*	321		Contingency Not Converged			OPEN LINE FROM BUS 50517 [LP-SINT269.000] TO BUS 50518 [LP-SINT6230.00] CKT 1	
10SP*	321		Contingency Not Converged			OPEN LINE FROM BUS 50518 [LP-SINT6230.00] TO BUS 51681 [LUBS6 230.00] CKT 1	
10SP*	321		Contingency Not Converged			OPEN LINE FROM BUS 51533 [TUCO6 230.00] TO BUS 51534 [TUCO7 345.00] CKT 1	
10SP*	321		Contingency Not Converged			OPEN LINE FROM BUS 54119 [O.K.U.-7345.00] TO BUS 51534 [TUCO7 345.00] CKT 1	
10SP*	321		Contingency Not Converged			REMOVE UNIT 1 FROM BUS 51441 [TOLK1 124.000] DISPATCH	
10SP*	321		Contingency Not Converged			REMOVE UNIT 1 FROM BUS 51442 [TOLK2 124.000] DISPATCH	
10SP*	321		Contingency Not Converged			REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	
10WP*	189		NONE IDENTIFIED				

* Study Cases include higher priority service (SUNC to SPS 150 MW) with required network upgrades.

Table 5 - Network Load Totals
and Tie Line MW Limits by Season

Southwest Power Pool
System Impact Study

Study Case	Network Load MW	Network Load MVAR	Transfer Amount (MW)	Existing Service Modeled to Network Load (MW)	LP&L Tie MW Limit @ 1.0 PF	LP&L Tie MW Limit @ 0.99 PF	LP&L Tie MW Limit @ 0.98 PF	LP&L Tie MW Limit @ 0.97 PF	LP&L Tie MW Limit @ 0.96 PF	LP&L Tie MW Limit @ 0.95 PF	LP&L Tie MW Limit @ 0.94 PF	LP&L Tie MW Limit @ 0.93 PF	LP&L Tie MW Limit @ 0.92 PF	LP&L Tie MW Limit @ 0.91 PF	LP&L Tie MW Limit @ 0.90 PF	
05SP	329	50.7	274	55	N/A	337	273	254	241	228	220	211	204	198	193	189
05SH	279	43	224	55	279(1)	N/A	N/A									
05FA	214	33	159	55	214(1)	N/A	N/A									
05WP	214	33	159	55	214(1)	N/A	N/A									
07SP	347	53.5	292	55	N/A	265	213	196	184	175	169	163	158	154	149	146
07WP	226	34.8	171	55	226(1)	N/A	N/A									
10SP	376	57.9	321	55	N/A	170	134	124	118	112	108	103	100	95	93	90
10WP	244	37.6	189	55	244(1)	N/A	N/A									
10SP*	376	57.9	321	55	N/A	332	290	273	262	252	245	238	232	226	220	215
10WP*	244	37.6	189	55	244(1)	N/A	N/A									

* Study Cases include higher priority service (SUNC to SPS 150 MW) with required network upgrades.

(1) Maximum Amount Evaluated

Table 6 - Summary of Upgrades Required
for Requested Service without Higher Priority
SECI to SPS 150 MW Request
and Assigned Upgrades Included

Southwest Power Pool
System Impact Study

Facility & Network Upgrade	Transmission Owner	Engineering & Construction Cost (\$)	Eng. & Const. Lead Time (Months)	Const. Only Lead Time (Months)	Date Needed (M/D/Y)	Scheduled Date In Service (M/D/Y)
*TUCO 230 kV Bus Voltage 2 50 MVAR Shunt Capacitors on 230 kV bus at TUCO	SPS	\$1,900,000	14	2	7/15/2005	6/1/2007
*TUCO 230 kV Bus Voltage 50 MVAR Shunt Capacitors on 230 kV bus at Swisher	SPS	\$1,100,000	14	2	7/15/2005	6/1/2007
TUCO 230 kV Bus Voltage Add +150/-50 SVC on 230 kV bus at TUCO	SPS	\$11,700,000	18	4	7/15/2005	6/1/2007
*TUCO 230/115 kV Transformer Add Second 230/115 kV Transformer	SPS	\$2,350,000	18	4	6/1/2008	6/1/2008
TUCO 230 kV Bus Voltage 50 MVAR Shunt Capacitors on 230 kV bus at Carlisle	SPS	\$1,400,000	14	2	7/15/2005	6/1/2007
TUCO 230 kV Bus Voltage 50 MVAR Shunt Capacitors on 230 kV bus at Lubbock South	SPS	\$1,200,000	14	2	7/15/2005	6/1/2007
Total		\$19,650,000				

*Upgrade Assigned to Higher Priority SECI to SPS 150 MW Request with an Scheduled In Service Date of 6/1/2007

Table 7 - Summary of Upgrades Required
for Requested Service with Higher Priority
SECI to SPS 150 MW Request
and Assigned Upgrades Included

Southwest Power Pool
System Impact Study

Facility & Network Upgrade	Transmission Owner	Engineering & Construction Cost (\$)	Eng. & Const. Lead Time (Months)	Const. Only Lead Time (Months)	Date Needed (M/D/Y)	Scheduled Date In Service (M/D/Y)
TUCO 230 kV Bus Voltage Add +150/-50 SVC on 230 kV bus at TUCO	SPS	\$11,700,000	18	4	7/15/2005	6/1/2007
PALODU - RANDALL COUNTY INTERCHANGE 115KV Rebuild 9 miles of 115 kV circuit with 397 ACSR on T-0-102 structures.	SPS	\$1,170,000	11	7	6/1/2009	6/1/2009
HAPPY INTERCHANGE - PALODU 115KV Rebuild 24 miles of 115 kV circuit with 397 ACSR on T-0-102 structures.	SPS	\$3,130,000	11	7	6/1/2009	6/1/2009
Total		\$16,000,000				

Southwest Power Pool

System Impact Study

Study Case	Transfer Amount (MW)	From Area	To Area	Monitored Branch Overload	Rate <MVA>	BC % Loading	TC % Loading	%TDF	Outaged Branch Causing Overload	ATC (MW)	Solution	Estimated Cost
05SP	274			NONE IDENTIFIED						274		
05SH	224			NONE IDENTIFIED						224		
05FA	159			NONE IDENTIFIED						159		
05WP	159			NONE IDENTIFIED						159		
07SP	292			NONE IDENTIFIED						292		
07WP	171			NONE IDENTIFIED						171		
10SP	321			Contingency Not Converged					50518 LP-SINT6 230 to 51681 LUBS6 230 CKT 1	N/A	Contingency Converged with Selected Upgrades, No Limitations Identified	
10SP	321			Contingency Not Converged					50517 LP-SINT2 69 to 50518 LP-SINT6 230 CKT 1	N/A	"	
10WP	189			NONE IDENTIFIED						189		
											Total Estimated Engineering and Construction Cost	\$0
10SP*	321			NONE IDENTIFIED						321		
10WP*	189			NONE IDENTIFIED						189		
											Total Estimated Engineering and Construction Cost	\$0

* Study Cases include higher priority service (SUNC to SPS 150 MW) with required network upgrades.

Study Case	Transfer Amount (MW)	From Area	To Area	Monitored Branch Over 100% Rate B	Rate <MVA>	BC % Loading	TC % Loading	%TDF	Outaged Branch Causing Overload	ATC (MW)	Solution	Estimated Cost
05SP	274			NONE IDENTIFIED						274		
05SH	224			NONE IDENTIFIED						224		
05FA	159			NONE IDENTIFIED						159		
05WP	159			NONE IDENTIFIED						159		
07SP	292			Contingency Not Converged					REMOVE UNIT 1 FROM BUS 51441 [TOLK1 124.000] DISPATCH	N/A		
07SP	292			Contingency Not Converged					REMOVE UNIT 1 FROM BUS 51442 [TOLK2 124.000] DISPATCH	N/A		
07WP	171			NONE IDENTIFIED						171		
10SP	321	SPS	SPS	51532 TUCO3 115 to 51533 TUCO6 230 CKT 1	252	95.3	108.3	10.2	51533 TUCO6 230 to 51647 CARLISL6 230 CKT 1	116	Add Second 230/115 kV Transformer	\$2,350,000
10SP	321	SPS	SPS	51020 RANDALL3 115 to 51021 RANDALL6 230 CKT 1	258.75	92.3	104.1	9.5	50915 NICHOL6 230 to 51041 AMARLS6 230 CKT 1	210	Relieved or Impact Removed by Selected Upgrades	
10SP	321	SPS	SPS	51966*MUSTGN3 115 51969 MUSTANG6 230 1	150	87.6	105.3	8.3	REMOVE UNIT 1 FROM BUS 51971 [MUSTG1 113.800] DISPATCH	225	"	
10SP	321	SPS	SPS	51966*MUSTGN3 115 51969 MUSTANG6 230 1	150	87.1	104.9	8.3	REMOVE UNIT 1 FROM BUS 51972 [MUSTG2 113.800] DISPATCH	233	"	
10SP	321	SPS	SPS	51020 RANDALL3 115 to 51082 PALODU 3 115 CKT 1	99	69.2	110.6	12.8	51041 AMARLS6 230 to 51321 SWISHER6 230 CKT 1	239	"	
10SP	321	SPS	SPS	51082 PALODU 3 115 to 51302 HAPPY3 115 CKT 1	99	67.6	109.1	12.8	51041 AMARLS6 230 to 51321 SWISHER6 230 CKT 1	251	"	
10SP	321	SPS	SPS	51532 TUCO3 115 to 51533 TUCO6 230 CKT 1	252	81.7	102.6	16.4	51533 TUCO6 230 to 51699 JONES6 230 CKT 1	282	"	
10SP	321	SPS	SPS	51360 COX3 115 to 51366 LH-COX3 115 CKT 1	90	59.9	104.6	12.5	51532 TUCO3 115 to 51533 TUCO6 230 CKT 1	288	"	
10SP	321	SPS	SPS	51366 LH-COX3 115 to 51402 HALECO3 115 CKT 1	90	60.1	104.5	12.5	51532 TUCO3 115 to 51533 TUCO6 230 CKT 1	288	"	
10SP	321	SPS	SPS	51366 LH-COX3 115 to 51402 HALECO3 115 CKT 1	90	54.9	101.2	13.0	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	313	"	
10SP	321	SPS	SPS	51360 COX3 115 to 51366 LH-COX3 115 CKT 1	90	54.6	101.2	13.1	REMOVE UNIT 1 FROM BUS 51702 [JONES2 121.000] DISPATCH	313	"	
10SP	321	SPS	SPS	51652 DOUD3 115 to 51746 SP-YUMA3 115 CKT 1	161	54.3	101.2	23.5	51533 TUCO6 230 to 51647 CARLISL6 230 CKT 1	313	"	
10SP	321			Contingency Not Converged					REMOVE UNIT 1 FROM BUS 51441 [TOLK1 124.000] DISPATCH	N/A	Contingency Converged with Selected Upgrades, No Limitations Identified	
10SP	321			Contingency Not Converged					REMOVE UNIT 1 FROM BUS 51442 [TOLK2 124.000] DISPATCH	N/A	"	
10SP	321			Contingency Not Converged					REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	N/A	"	
10SP	321			Contingency Not Converged					50507 LP-MLWK6 230 to 50509 LP-MLWK2 69 CKT 1	N/A	"	
10SP	321			Contingency Not Converged					50507 LP-MLWK6 230 to 51647 CARLISL6 230 CKT 1	N/A	"	
10SP	321			Contingency Not Converged					50517 LP-SINT2 69 to 50518 LP-SINT6 230 CKT 1	N/A	"	
10SP	321			Contingency Not Converged					50518 LP-SINT6 230 to 51681 LUBS6 230 CKT 1	N/A	"	
10SP	321			Contingency Not Converged					50520 LP-HOLL2 69 to 50521 LP-HOLL6 230 CKT 1	N/A	"	
10SP	321			Contingency Not Converged					50521 LP-HOLL6 230 to 51699 JONES6 230 CKT 1	N/A	"	
10SP	321			Contingency Not Converged					50524 LP-WADS2 69 to 50527 LP-WADS6 230 CKT 1	N/A	"	
10SP	321			Contingency Not Converged					50527 LP-WADS6 230 to 51689 LUBE6 230 CKT 1	N/A	"	
10SP	321			Contingency Not Converged					51533 TUCO6 230 to 51534 TUCO7 345 CKT 1	N/A	"	
10SP	321			Contingency Not Converged					51435 TOLKE6 230 to 51533 TUCO6 230 CKT 1	N/A	"	
10SP	321			Contingency Not Converged					51733 SUNDOWN6 230 to 51763 WOLFRTH6 230 CKT 1	N/A	"	
10SP	321			Contingency Not Converged					54119 O.K.U.-7 345 to 51534 TUCO7 345 CKT 1	N/A	"	
10WP	189			NONE IDENTIFIED						189	Total Estimated Engineering and Construction Cos!	\$2,350,000
10SP*	321	SPS	SPS	51020 RANDALL3 115 to 51082 PALODU 3 115 CKT 1	99	76.1	110.7	10.7	51041 AMARLS6 230 to 51321 SWISHER6 230 CKT1	222	Rebuild 9 miles of 115 kV circuit with 397 ACSR on T-0-102 structures.	\$1,170,000
10SP*	321	SPS	SPS	51082 PALODU 3 115 to 51302 HAPPY3 115 CKT 1	99	74.4	109.0	10.7	51041 AMARLS6 230 to 51321 SWISHER6 230 CKT1	237	Rebuild 24 miles of 115 kV circuit with 397 ACSR on T-0-102 structures.	\$3,130,000
10SP*	321	SPS	SPS	51020 RANDALL3 115 to 51021 RANDALL6 230 CKT 1	258.75	92.5	101.0	6.9	50915 NICHOL6 230 to 51041 AMARLS6 230 CKT1	282	Open Amarillo South 230/115KV Transformer to Relieve Facility	
10SP*	321			Contingency Not Converged					50517 LP-SINT2 69 to 50518 LP-SINT6 230 CKT 1	N/A	Contingency Converged with Selected Upgrades, No Limitations Identified	
10SP*	321			Contingency Not Converged					50518 LP-SINT6 230 to 51681 LUBS6 230 CKT 1	N/A	"	
10SP*	321			Contingency Not Converged					51533 TUCO6 230 to 51534 TUCO7 345 CKT 1	N/A	"	
10SP*	321			Contingency Not Converged					54119 O.K.U.-7 345 to 51534 TUCO7 345 CKT 1	N/A	"	
10SP*	321			Contingency Not Converged					REMOVE UNIT 1 FROM BUS 51441 [TOLK1 124.000] DISPATCH	N/A	"	
10SP*	321			Contingency Not Converged					REMOVE UNIT 1 FROM BUS 51442 [TOLK2 124.000] DISPATCH	N/A	"	
10SP*	321			Contingency Not Converged					REMOVE UNIT 1 FROM BUS 51701 [JONES1 122.000] DISPATCH	N/A	"	
10WP*	189			NONE IDENTIFIED						189	Total Estimated Engineering and Construction Cos!	\$4,300,000

* Study Cases include higher priority service (SUNC to SPS 150 MW) with required network upgrades.