



**SPP**

*Southwest  
Power Pool*

***System Impact Study  
SPP-2004-167D  
For Transmission Service  
Requested By:  
Western Resources, INC***

***From OKGE to WR***

***For a Reserved Amount Of  
300 MW  
From 01/01/05  
To 04/01/05***

# ***SPP Transmission Planning***

<b>1. EXECUTIVE SUMMARY .....</b>	<b>3</b>
<b>2. INTRODUCTION .....</b>	<b>4</b>
<b>3. STUDY METHODOLOGY.....</b>	<b>5</b>
A. DESCRIPTION.....	5
B. MODEL UPDATES.....	5
C. TRANSFER ANALYSIS .....	5
<b>4. STUDY RESULTS .....</b>	<b>6</b>
<b>5. CONCLUSION.....</b>	<b>8</b>

## **1. Executive Summary**

Western Resources, INC has requested a system impact study for monthly firm transmission service from OKGE to WR. The period of the transaction is from 01/01/05 to 04/01/05. The request is for reservation 760934 for the amount of 300 MW.

The 300 MW transaction from OKGE to WR has an impact on the following flowgates with no ATC: BVSNBVNESDEL, KILCREWOOWIC, and SCODEADELNEO. To provide the ATC necessary for this transfer, the impact on these flowgates must be relieved.

After studying many scenarios using curtailment of reservations and generation redispatch, there are several feasible scenarios that will relieve the flowgate(s) in question.

## 2. Introduction

Western Resources, INC has requested a system impact study for transmission service from OKGE to WR.

There are three constrained flowgates that require relief in order for this reservation to be accepted. The flowgates and the explanations are as follows:

- BVSNBVNESDEL: Bartlesville SE to North Bartlesville 138 kV line for the loss of Northeastern to Delaware 345 KV line
- KILCREWOOVIC: Kildare to Creswell 138 kV line for the loss of Woodring to Wichita 345 KV line
- SCODEADELNEO: South Coffeyville to Dearing 138 kV line for the loss of Delaware to Neosho 345 KV line

### **3. Study Methodology**

#### **A. Description**

Southwest Power Pool used the Managing and Utilizing System Transmission (MUST) program to obtain possible unit pairings that would relieve the constraint. MUST calculates impacts on monitored facilities for all units in the Eastern Interconnection. The SPP ATC Calculator is used to determine response factors for the time period of the reservation.

#### **B. Model Updates**

The appropriate Southwest Power Pool Seasonal model was used for the study. This model was updated to reflect the most current information available.

#### **C. Transfer Analysis**

Using the short-term calculator, the limiting constraints for the transfer are identified. The response factor of the transfer on each constraint is also determined.

The product of the transfer amount and the response factor is the impact of a transfer on a limiting flowgate that must be relieved. With multiple flowgates affected by a transfer, relief of the largest impact may also provide relief of smaller impacts.

Using MUST, specific generator pairs are chosen to reflect the units available for redispatch. The quotient of the amount of impact that must be relieved and the generation sensitivity factor calculated by the Viewer is the amount of redispatch necessary to relieve the impact on the affected flowgate.

## **4. Study Results**

After studying the impacts of request 760934, three flowgates require relief. The flowgates and associated amount of relief is as follows:

**Table 1**

<b>Flowgates</b>	<b>Sensitivity (%)</b>	<b>Duration</b>	<b>Required Relief (MW)</b>
BVSNBVNESDEL	6.7	January – April	20
KILCREWOOWIC	10.4	January – April	31
SCODEADELNEO	7.2	January – April	22

Table 2 displays a list of reservation paths that offer relief for the flowgates in question.

**Table 2**

<b>Transactions Path</b>	<b>BVSNBVNESDEL Sensitivity (%)</b>	<b>KILCREWOOWIC Sensitivity (%)</b>	<b>SCODEADELNEO Sensitivity (%)</b>
CSWS – AMRN	4.2	3.4	4.3
OKGE – EES	-	4.8	-
SPA – WR	4.3	5.5	4.8
SPS – AMRN	-	3.5	-

Table 3 displays the amount of capacity required for each reservation path to relieve the flowgates in question.

**Table 3**

<b>Transactions Path</b>	<b>BVSNBVNESDEL Sensitivity (%)</b>	<b>KILCREWOOWIC Sensitivity (%)</b>	<b>SCODEADELNEO Sensitivity (%)</b>
CSWS – AMRN	477	911	512
OKGE – EES	-	646	-
SPA – WR	465	563	459
SPS – AMRN	-	886	-

No feasible generation pairs were found to relieve the flowgates in question.

## **5. Conclusion**

Reservation curtailment and generation redispatch options were studied in order to relieve the necessary constraint. The results of this study shows that the constraints on the flowgates in question could be relieved by executing one or more of the options described in the Study Results section of this document. Before the Transmission Provider accepts the reservations, proof of one of these relief options must be presented to Southwest Power Pool. Noncompliance with this guideline will result in the refusal of the reservation.