



*Aggregate Facility Study*  
**SPP-2006-AG1-AFS-4**  
*For Transmission Service*  
*Requested by*  
***Aggregate Transmission Customers***

*SPP Engineering, SPP Tariff Studies*

## *Table of Contents*

1. Executive Summary.....	3
2. Introduction .....	4
A. FINANCIAL	
ANALYSIS.....	7
B. THIRD PARTY UPGRADES.....	8
3. Study Methodology .....	10
A. DESCRIPTION .....	10
B. MODEL DEVELOPMENT.....	11
C. TRANSFER ANALYSIS .....	12
D. CURTAILMENT AND REDISPATCH EVALUATION .....	12
4. Study Results.....	14
A. STUDY ANALYSIS RESULTS.....	14
B. STUDY DEFINITIONS .....	14
5. Conclusion.....	18
Appendix .....	20

## **1. Executive Summary**

Pursuant to Attachment Z of the Southwest Power Pool Open Access Transmission Tariff (OATT), 875 MW of long-term transmission service requests have been restudied in this final Aggregate Facility Study (AFS). This phase of the AFS consists of revisions to reflect the withdrawal of requests after the initial AFS was posted on June 2nd, 2006. The principal objective of the AFS is to identify system problems and potential modifications necessary to facilitate these transfers while maintaining or improving system reliability as well as summarizing the operating limits and determination of the financial characteristics associated with facility upgrades. Facility upgrade costs are allocated on a prorated basis to all requests positively impacting any individual overloaded facility. Further, Attachment Z provides for facility upgrade cost recovery by stating that “[a]ny charges paid by a customer in excess of the transmission access charges in compensation for the revenue requirements for allocated facility upgrade(s) shall be recovered by such customer from future transmission service revenues until the customer has been fully compensated.”

The total assigned facility upgrade Engineering and Construction (E &C) cost determined by this AFS restudy is \$20,038,000. Additionally \$ 0 of assigned E & C cost for 3<sup>rd</sup> party facility upgrades are assignable to the customer. The total upgrade leveled revenue requirement for all transmission requests is \$54,040,076. This is based on full allocation of leveled revenue requirements for upgrades to customers without consideration of base plan funding . The AFS data tables reflect the full allocation of upgrade costs to customers based on either the requested reservation period, the deferred reservation period without interim redispatch, or the reservation period with interim

redispatch if applicable based on customer intention to pursue redispatch agreements. Total upgrade leveled revenue requirements for all transmission requests after consideration of potential base plan funding is \$21,981,850. For those customers who have chosen to pursue redispatch in lieu of deferral of start of service, leveled revenue requirements will be based upon the deferred start date with redispatch. Redispatch was evaluated to provide only interim service during the time frame prior to completion of any assigned network upgrades.

Third-party facilities must be upgraded when it is determined they are constrained in order to accommodate the requested Transmission Service. These include both first-tier neighboring facilities outside SPP and Transmission Owner facilities within SPP that are not under the SPP OATT. In this AFS, 0 third-party facilities were identified. Total engineering and construction cost estimates for required third-party facility upgrades are \$0.

The posting of this study will open a 15-day window for Customer response. To remain in this Aggregate Transmission Service Study (ATSS), the Customer should select Option #1 on the Letter of Intent sent concurrently with the posting of this Facility Study. Otherwise, if the customer chooses to withdraw from this ATSS, Customer should select Option #2 on the Letter of Intent. This will result in SPP ANNULING the OASIS request and no further study of this request will occur.

The Customer's course of action as indicated by the Letter of Intent must be received by the Transmission Provider by September 8, 2006, otherwise the request will be determined as withdrawn and no further study of the request will occur.

At the conclusion of this ATSS, Service Agreements for each request for service will be tendered to the Customer. For requests requiring Network Upgrades, the full allocation of revenue requirements for facility upgrades will be assigned to the Customer contingent

upon verification of designated resources meeting Attachment J, Section III B criteria for base plan funding.

After receipt of a Service Agreement from the Transmission Provider, the Customer shall have 15 days to execute a Service Agreement or request the filing of an unexecuted Service Agreement or the request will be deemed terminated and withdrawn. Agreements for generation redispatch in lieu of deferral of start of service must be negotiated by the Transmission Customer and generation owner with a copy of the agreement provided to SPP prior to execution of the Service Agreement.

If customers withdraw from the ATSS after posting of this AFS, the AFS will be re-performed to determine final cost allocation and Available Transmission Capability (ATC) in consideration of the remaining ATSS participants. All allocated revenue requirements for facility upgrades are assigned to the customer in the AFS data tables. Potential base plan funding allowable is contingent upon verification of designated resources meeting Attachment J, Section III B criteria.

## **2. Introduction**

On January 21, 2005, the Federal Energy Regulatory Commission accepted Southwest Power Pool's proposed aggregate transmission study procedures in Docket ER05-109 to become effective February 1, 2005. The proposed cost allocation and cost recovery provisions were accepted for filing and suspended to become effective the earlier of five months from the requested effective date (July 1, 2005) or a further order of the Commission in the proceeding subject to refund. Since that time, the cost allocation and cost recovery provisions have been accepted with modification. The following link can be used to access the SPP Regulatory/FERC webpage:

([http://www.spp.org/Objects/FERC\\_filings.cfm](http://www.spp.org/Objects/FERC_filings.cfm)). The hyperlinks under the heading ER05-109 (Attach Z Filing) open Southwest Power Pool's October 29, 2004 filing

containing Attachment Z to the SPP OATT and the Commission's January 21, 2005 Order. In compliance with this Order, the third open season commenced on October 1, 2005. All requests for long-term transmission service received prior to February 1, 2006 with a signed study agreement were then included in the third Aggregate Transmission Service Study (ATSS).

Approximately 875MW of long-term transmission service has been restudied in this Aggregate Facility Study (AFS) with over \$20 Million in transmission upgrades being proposed. The results of the AFS are detailed in Tables 1 through 6. A highly tangible benefit of studying transmission requests aggregately under the SPP OATT Attachment Z is the sharing of costs among customers using the same facility. The detailed results show individual upgrade costs by study as well as potential base plan allowances as determined by Attachments J and Z. The following link can be used to access the SPP OATT: ([http://www.spp.org/Publications/SPP\\_Tariff.pdf](http://www.spp.org/Publications/SPP_Tariff.pdf)). In order to understand the extent to which base plan upgrades may be applied to both point-to-point and network transmission services, it is necessary to highlight the definition of Designated Resource. Per Section 1.9a of the SPP OATT, a Designated Resource is “[a]ny designated generation resource owned, purchased or leased by a Transmission Customer to serve load in the SPP Region. Designated Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Transmission Customer's load on a non-interruptible basis.” Therefore, not only network service, but also point-to-point service has potential for base plan funding if the conditions for classifying upgrades associated with designated resources as base plan upgrades as defined in Section III.B of Attachment J are met.

Pursuant to Attachment J, Section III B of the SPP OATT, the Transmission Customer must provide SPP information necessary to verify that the new or changed Designated Resource meets the following conditions:

1. Transmission Customer's commitment to the requested new or changed Designated Resource must have a duration of at least five years.
2. During the first year the Designated Resource is planned to be used by the Transmission Customer, the accredited capacity of the Transmission Customer's existing Designated Resources plus the lesser of (a) the planned maximum net dependable capacity applicable to the Transmission Customer or (b) the requested capacity; shall not exceed 125% of the Transmission Customer's projected system peak responsibility determined pursuant to SPP Criteria 2.

According to Attachment Z Section VI.A, Point-to-Point customers pay the higher of the monthly transmission access charge (base rate) or the monthly revenue requirement associated with the assigned facility upgrades including any prepayments for redispatch required during construction.

Network Integration Service customers pay the total monthly transmission access charges and the monthly revenue requirement associated with the facility upgrades including any prepayments for redispatch during construction.

Transmission Customers paying for a directly assigned network upgrade shall receive credits for new transmission service using the facility as specified in Attachment Z Section VII.

Facilities identified as limiting the requested Transmission Service have been reviewed to determine the required in-service date of each Network Upgrade. The year that each Network Upgrade is required to accommodate a request is determined by interpolating between the applicable model years given the respective loading data. Both previously assigned facilities and the facilities assigned to this request for Transmission Service were evaluated.

In some instances due to lead times for engineering and construction, Network Upgrades may not be available when required to accommodate a request for Transmission Service. When this occurs, the ATC with available Network Upgrades will be less than the capacity requested during either a portion of or all of the requested reservation period. As a result, the lowest seasonal allocated ATC within the requested reservation period will be offered to the Transmission Customer on an applicable annual basis as listed in Table 1. The ATC may be limited by transmission owner planned projects, expansion plan projects, or customer assigned upgrades.

Some constraints identified in the AFS were not assigned to the Customer as the Transmission Provider determined that upgrades are not required due to various reasons or the Transmission Owner has construction plans pending for these upgrades. These facilities are listed by reservation in Table 3. This table also includes constrained facilities in the current planning horizon that limit the rollover rights of the Transmission Customer. Table 6 lists possible redispatch pairs to allow start of service prior to completion of assigned network upgrades.

#### **A. Financial Analysis**

The AFS utilizes the allocated customer E & C cost in a present worth analysis to determine the monthly leveled revenue requirement of each facility upgrade over the term of the reservation. In some cases, network upgrades cannot be completed within the requested reservation period, thus deferred reservation periods will be utilized in the present worth analysis. The upgrade leveled revenue requirement includes interest, depreciation, and carrying costs.

Each request for Transmission Service is evaluated independently as the cost associated with each Network Upgrade is assigned to a request. When facilities are upgraded

throughout the reservation period, the Transmission Customer shall 1) pay the total E & C costs and other annual operating costs associated with the new facilities, and 2) receive credits associated with the depreciated book value of removed usable facilities, salvage value of removed non-usable facilities, and the carrying charges, excluding depreciation, associated with all removed usable facilities based on their respective book values.

In the event that the engineering and construction of a previously assigned Network Upgrade may be expedited, with no additional upgrades, to accommodate a new request for Transmission Service, then the levelized present worth of only the incremental expenses though the reservation period of the new request, excluding depreciation, shall be assigned to the new request. These incremental expenses, excluding depreciation, include 1) the levelized difference in present worth of the engineering and construction expenses given the change in date to complete construction to account for additional interest expense and reduced engineering and construction expense due to inflation, 2) the

levelized present worth of all expediting fees, and 3) the levelized present worth of the incremental annual carrying charges, excluding depreciation and interest, during the new reservation period taking into account both a) the reservation in which the project was originally assigned, and b) a reservation, if any, in which the project was previously expedited.

## **B. Third-Party Facilities**

For third-party facilities listed in Table 3 and Table 5, the Transmission Customer is responsible for funding the necessary upgrades of these facilities per Section 21.1 of the Transmission Provider's OATT. In this AFS, 0 third-party facilities were identified. Total engineering and construction cost estimates for required third-party facility upgrades are \$0. The Transmission Provider will undertake reasonable efforts to assist the

Transmission Customer in making arrangements for necessary engineering, permitting, and construction of the third-party facilities. Third-party facility upgrade engineering and construction cost estimates are not utilized to determine the present worth value of leveled revenue requirements for SPP system network upgrades.

All modeled facilities within the Transmission Provider system were monitored during the development of this Study as well as certain facilities in first-tier neighboring systems. Third-party facilities must be upgraded when it is determined that they are overloaded while accommodating the requested Transmission Service. These facilities also include those owned by members of the Transmission Provider who have not placed their facilities under the Transmission Provider's OATT.

Third-party facilities are evaluated for only those requests whose load sinks within the SPP footprint. The Customer must arrange for study of 3<sup>rd</sup> party facilities for load that sinks outside the SPP footprint with the applicable Transmission Providers.

### **3. Study Methodology**

#### **A. Description**

The system impact analysis was conducted to determine the steady-state impact of the requested service on the SPP and first tier Non - SPP control area systems. The steady-state analysis was done to ensure current SPP Criteria and NERC Reliability Standards requirements are fulfilled. The Southwest Power Pool conforms to the NERC Reliability Standards, which provide the strictest requirements, related to voltage violations and thermal overloads during normal conditions and during a contingency. It requires that all facilities be within normal operating ratings for normal system conditions and within emergency ratings after a contingency. Normal operating ratings and emergency operating ratings monitored are Rate A and B in the SPP MDWG models, respectively.

The upper bound and lower bound of the normal voltage range monitored is 105% and 95%. The upper bound and lower bound of the emergency voltage range monitored is 110% and 90%. The SPS Tuco 230 kV bus voltage is monitored at 92.5% due to pre-determined system stability limitations.

The contingency set includes all SPP control area branches and ties 69kV and above, first tier Non - SPP control area branches and ties 115 kV and above, any defined contingencies for these control areas, and generation unit outages for the control areas with SPP reserve share program redispatch. The monitor elements include all SPP control area branches, ties, and buses 69 kV and above, and all first tier Non – SPP control area branches and ties 69 kV and above. Voltage monitoring was performed for SPP control area buses 69 kV and above.

A 3 % transfer distribution factor (TDF) cutoff was applied to all SPP control area facilities. For first tier Non – SPP control area facilities, a 3 % TDF cutoff was applied to AECI, AMRN, and ENTR and a 2 % TDF cutoff was applied to MEC, NPPD, and OPPD. For voltage monitoring, a 0.02 per unit change in voltage must occur due to the transfer or modeling upgrades to be considered a valid limit to the transfer.

## **B. Model Development**

SPP used fifteen seasonal models to study the aggregate transfers of 875 MW over a variety of requested service periods. The SPP MDWG 2006 Series Cases Update 1 2006 Summer Peak (06SP), 2006 Summer Shoulder (06SH), 2006 Fall Peak (06FA), 2006/07 Winter Peak (06WP), 2007 April Minimum (07AP), 2007 Spring Peak (07G), 2007 Summer Peak (07SP), 2007 Summer Shoulder (07SH), 2007 Fall Peak (07FA), 2007/08 Winter Peak (07WP), 2008 Summer Peak (08SP), 2008/09 Winter Peak (08WP), 2011

Summer Peak (11SP), 2011/12 Winter Peak (11WP), and 2016 Summer Peak (16SP) were used to study the impact of the requested service on the transmission system. The Spring Peak models apply to April and May, the Summer Peak models apply to June through September, the Fall Peak models apply to October and November, and the Winter Peak models apply to December through March.

The chosen base case models were modified to reflect the most current modeling information. Four groups of requests were developed from the aggregate of 875 MW in order to minimize counterflows among requested service. Each request was included in two to four groups depending on the requested path. From the thirteen seasonal models, three system scenarios were developed. Scenario 1 includes SWPP OASIS transmission requests not already included in the SPP 2006 Series Cases flowing in a West to East direction with ERCOT exporting and SPS exporting to outside zones and exporting to the Lamar HVDC Tie. Scenario 2 includes transmission requests not already included in the SPP 2006 Series Cases flowing in an East to West direction with ERCOT net importing and SPS importing from an outside zone and exporting to the Lamar HVDC Tie. Scenario 3 includes transmission requests not already included in the SPP 2006 Series Cases flowing in a West to East direction with ERCOT net importing and SPS importing from an outside zone and importing from the Lamar HVDC Tie. Scenario 4 includes transmission requests not already included in the SPP 2006 Series Cases flowing in a North to South direction with ERCOT importing and SPS importing from outside zones and importing from the Lamar HVDC tie. The system scenarios were developed to minimize counter flows from previously confirmed, higher priority requests not included in the MDWG Base Case.

## **C. Transfer Analysis**

Using the selected cases both with and without the requested transfers modeled, the PSS/E Activity ACCC was run on the cases and compared to determine the facility overloads caused or impacted by the transfer. Transfer distribution factor cutoffs (SPP and 1<sup>st</sup>-Tier) and voltage threshold (0.02 change below 0.90 pu) were applied to determine the impacted facilities. The PSS/E options chosen to conduct the analysis can be found in Appendix A.

#### **D. Curtailment and Redispatch Evaluation**

During any period when SPP determines that a transmission constraint exists on the Transmission System, and such constraint may impair the reliability of the Transmission System, SPP will take whatever actions that are reasonably necessary to maintain the reliability of the Transmission System. To the extent SPP determines that the reliability of the Transmission System can be maintained by redispatching resources, SPP will evaluate curtailment of existing confirmed service or interim redispatch of units to provide service prior to completion of any assigned network upgrades. Any redispatch may not unduly discriminate between the Transmission Owners' use of the Transmission System on behalf of their Native Load Customers and any Transmission Customer's use of the Transmission System to serve its designated load. Redispatch was evaluated to provide only interim service during the time frame prior to completion of any assigned network upgrades.

SPP determined potential relief pairs to relieve the incremental MW impact on limiting facilities as identified in Table 6. Using the selected cases where the limiting facilities were identified, potential incremental and decremental units were identified by determining the generation amount available for increasing and decreasing from the units generation amount, maximum generation amount, and minimum generation amount. If the incremental or decremental amount was greater than 1 MW, the unit was considered as a potential incremental or decremental unit. Generation shift factors were calculated

for the potential incremental and decremental units using Managing and Utilizing System Transmission (MUST). From the generation shift factors for the incremental and decremental units, top 100 relief pairs with a greater than 3% TDF were determined from the incremental units with the lowest generation shift factors and decremental units with highest generation shift factors. The potential relief pairs **were** evaluated to determine impacts on limiting facilities in the SPP and 1st-Tier systems. The redispatch requirements would be called upon prior to implementing NERC TLR Level 5a.

## **4. Study Results**

### **A. Study Analysis Results**

Tables 1 through 6 contain the steady-state analysis results of the ASIS. Table 1 identifies the participating long-term transmission service requests included in the AFS. This table lists deferred start and stop dates both with and without redispatch (Based on customer selection to pursue redispatch from letter agreement option), the minimum annual allocated ATC without upgrades and season of first impact. Table 2 identifies total E & C cost allocated to each Transmission Customer, letter of credit requirements, third party E & C cost assignments, potential base plan E & C funding (lower of allocated E & C or Attachment J Section III B criteria) , total revenue requirements for assigned upgrades without consideration of potential base plan funding, point-to-point base rate charge, total revenue requirements for assigned upgrades with consideration of potential base plan funding, and final total cost allocation to the Transmission Customer. Table 3 provides additional details for each request including all assigned facility upgrades required, allocated E & C costs, deferred start and stop dates without redispatch, allocated revenue requirements for upgrades, upgrades not assigned to customer but required for service to be confirmed, facilities limiting rollover rights, credits to be paid for previously assigned AFS facility upgrades, and any third party upgrades required. This includes the season in the planning horizon where rollover rights

are limited. Table 4 lists all upgrade requirements with associated solutions needed to provide transmission service for the AFS, Minimum ATC per upgrade with season of impact, Earliest Date Upgrade is required (COD), Estimated Date of Upgrade Completion (EOC), and Estimated E & C cost. Table 5 lists identified Third-Party constrained facilities. Table 6 identifies potential redispatch pairs available to relieve the aggregate impacts on identified constraints to prevent deferral of start of service.

Potential base plan funding allowable is contingent upon meeting each of the conditions for classifying upgrades associated with designated resources as base plan upgrades as defined in Section III.B of Attachment J. The lesser of the planned maximum net dependable capacity or the requested capacity is multiplied by \$180,000 to determine potential base plan funding allowable. If this additional capacity exceeds the 125% resource to load criteria for a given year, the value of capacity not exceeding 125% of load will set the determinant for base plan funding consideration. For example, a customer submits a request to add a new resource of 50MW in 2010 that meets all other conditions for base plan funding. The Customer's load forecast for 2010 is 500MW with forecasted firm resources of 600MW. The additional 50MW of resources increases the resource to load ratio from 120% to 130%. Therefore the E & C cost for that portion of the 50MW request not exceeding 125% resource to load, or 25MW, would be compared to the E & C cost for the full 50MW to determine a prorata share of the cost that can be covered by base plan funding. Any allocated customer costs in excess of base plan funding will be assigned to the customer.

Regarding application of base plan funding for PTP requests, if PTP base rate exceeds upgrade revenue requirements without taking into effect the reduction of revenue requirements by potential base plan funding, then the base rate revenue pays back the

Transmission Owner for upgrades and no base plan funding is applicable as the access charge must be paid as it is the higher of “OR” pricing.

However, if initially the upgrade revenue requirements exceed the PTP base rate, then potential base plan funding would be applicable. The test of the higher of “OR” pricing would then be made against the remaining assignable revenue requirements versus PTP base rate. Examples are as follows:

**Example A:**

E & C allocated for upgrades is 74 million with revenue requirements of 140 million and PTP base rate of 101 million. Potential base plan funding is 47 million with the difference of 27 million E & C assignable to the customer. If the revenue requirements for the assignable portion is 54 million and the PTP base rate is 101 million, the customer will pay the higher “OR” pricing of 101 million base rate of which 54 million revenue requirements will be paid back to the Transmission Owners for the upgrades and the remaining revenue requirements of (140-54) or 86 million will be paid by base plan funding.

**Example B:**

E & C allocated for upgrades is 74 million with revenue requirements of 140 million and PTP base rate of 101 million. Potential base plan funding is 10 million with the difference of 64 million E & C assignable to the customer. If the revenue requirements for this assignable portion is 128 million and the PTP base rate is 101 million the customer will pay the higher “OR” pricing of 128 million revenue requirements to be paid back to the Transmission Owners and the remaining revenue requirements of (140-128) or 12 million will be paid by base plan funding.

**Example C:**

E & C allocated for upgrades is 25 million with revenue requirements of 50 million and PTP base rate of 101 million. Potential base plan funding is 10 million. Base plan funding is not applicable as the higher “OR” pricing of PTP base rate of 101 million must be paid and the 50 million revenue requirements will be paid from this.

The 125% resource to load determination is performed on a per request basis and is not based on a total of designated resource requests per Customer. A footnote will provide the maximum resource designation allowable for base plan funding consideration per Customer basis per year.

Base plan funding verification requires that each Transmission Customer with potential for base plan funding provide SPP power supply contracts or agreements verifying that the firm capacity of the requested designated resource is committed for a minimum five year duration.

## **B. Study Definitions**

The Commercial Operation Date (COD) is the earliest date the upgrade is required to alleviate a constraint considering all requests. End of Construction (EOC) is the estimated date the upgrade will be completed and in service. The Total Engineering and Construction Cost (E & C) is the upgrade solution cost as determined by the transmission owner. The Transmission Customer Allocation Cost is the estimated engineering and construction cost based upon the allocation of costs to all Transmission Customers in the AFS who positively impact facilities by at least 3% subsequently overloaded by the AFS. Minimum ATC is the portion of the requested capacity that can be accommodated without upgrading facilities. Annual ATC allocated to the Transmission Customer is determined by the least amount of allocated seasonal ATC within each year of a reservation period.

## **5. Conclusion**

The results of the AFS show that limiting constraints exist in many areas of the regional transmission system. Due to these constraints, transmission service cannot be granted unless noted in Table 3.

The posting of this study will open a 15-day window for Customer response. To remain in this Aggregate Transmission Service Study (ATSS), the Customer should select Option #1 on the Letter of Intent sent concurrently with the posting of this Facility Study. Otherwise, if the customer chooses to withdraw from this ATSS, Customer should select Option #2 on the Letter of Intent. This will result in SPP ANNULING the OASIS request and no further study of this request will occur.

The Customer's course of action as indicated by the Letter of Intent must be received by the Transmission Provider by September 8<sup>th</sup>, 2006, otherwise the request will be determined as withdrawn and no further study of the request will occur.

At the conclusion of this ATSS, Service Agreements for each request for service will be tendered to the Customer. For requests requiring Network Upgrades, the full allocation of revenue requirements for facility upgrades will be assigned to the Customer contingent upon verification of designated resources meeting Attachment J, Section III B criteria for base plan funding.

The Transmission Provider must receive an unconditional and irrevocable letter of credit in the amount of the total allocated Engineering and Construction costs assigned to the Customer concurrent with the execution of the Service Agreement. This letter of credit is required regardless of base plan funding consideration. This amount is for all

assignable Network Upgrades less any assigned facilities owned by the Network Customer's Transmission Operating Company. The amount of the letter of credit will be adjusted down on an annual basis to reflect amortization of these costs. The Transmission Provider will issue letters of authorization to construct facility upgrades to the constructing Transmission Owner. This date is determined by the engineering and construction lead time provided for each facility upgrade.

## Appendix A

### PSS/E CHOICES IN RUNNING LOAD FLOW PROGRAM AND ACCC

#### BASE CASES:

Solutions - Fixed slope decoupled Newton-Raphson solution (FDNS)

1. Tap adjustment – Stepping
2. Area interchange control – Tie lines and loads
3. Var limits – Apply immediately
4. Solution options -  Phase shift adjustment
  - \_ Flat start
  - \_ Lock DC taps
  - \_ Lock switched shunts

#### ACCC CASES:

Solutions – AC contingency checking (ACCC)

1. MW mismatch tolerance – 0.5
2. Contingency case rating – Rate B
3. Percent of rating – 100
4. Output code – Summary
5. Min flow change in overload report – 3mw
6. Excl cases w/ no overloads form report – YES
7. Exclude interfaces from report – NO
8. Perform voltage limit check – YES
9. Elements in available capacity table – 60000
10. Cutoff threshold for available capacity table – 99999.0
11. Min. contng. case Vltg chng for report – 0.02
12. Sorted output – None

#### Newton Solution:

1. Tap adjustment – Stepping
2. Area interchange control – Tie lines and loads
3. Var limits - Apply automatically
4. Solution options -  Phase shift adjustment
  - \_ Flat start
  - \_ Lock DC taps
  - \_ Lock switched shunts

**Table 1** - Long-Term Transmission Service Requests Included in Aggregate Facility Study

Customer	Study Number	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Minimum Allocated ATC (MW) within reservation period	Season of Minimum Allocated ATC within reservation period
AEPM	AG1-2006-006D	1019914	CSWS	CSWS	168	7/1/2008	7/1/2013			0	07FA
AEPM	AG1-2006-007D	1023236	<sup>1</sup> WFEC	CSWS	80	1/1/2007	1/1/2027			0	07SP
EDE	AG1-2006-027	1032183	EES	EDE	50	6/1/2010	6/1/2040			0	11SP
INDP	AG1-2006-051	1033791	KCPL	INDN	50	6/1/2010	6/1/2040			0	11SP
KCPS	AG1-2006-009	979750	KCPL	KCPL	168	6/1/2009	6/1/2029			0	11SP
KCPS	AG1-2006-070	1034307	<sup>1</sup> KCPL	EES	103	6/1/2006	6/1/2007			0	06SP
KMEA	AG1-2006-068	1034247	GRDA	WR	1	5/1/2010	5/1/2026			0	06SP
KPP	AG1-2006-042	1032991	WPEK	WPEK	80	6/1/2006	6/1/2016			0	07FA
OGE	AG1-2006-040	1032973	<sup>1</sup> OKGE	OKGE	120	9/1/2006	9/1/2031			0	07SP
OMPA	AG1-2006-010	977481	<sup>1</sup> GRDA	OKGE	25	5/1/2007	5/1/2040			0	07SP
WRGS	AG1-2006-029D	1031553	<sup>1</sup> KCPL	AECI	15	6/1/2006	6/1/2007			0	06SH
WRGS	AG1-2006-037D	1032955	<sup>1</sup> AECI	KCPL	15	6/1/2006	6/1/2007			0	06SP

<sup>1</sup>Start and Stop Dates are determined based on customers choosing option to pursue redispatch to start service at Requested Start and Stop Dates or earliest date possible.

**Table 2** - Total Revenue Requirements Associated with Long-Term Transmission Service Requests

Customer	Study Number	Reservation	Engineering and Construction Cost of Upgrades Allocated to Customer for Revenue Requirements	<sup>4</sup> Letter of Credit Amount Required	<sup>3</sup> Potential Base Plan Engineering and Construction Funding Allowable	<sup>5</sup> Total Revenue Requirements for Assigned Upgrades over term of reservation WITHOUT potential base plan funding allocation in consideration of redispatch if applicable	Total Revenue Requirements for Assigned Upgrades over term of reservation WITH potential base plan funding allocation in consideration of redispatch if applicable	Point-to-Point Base Rate over reservation period	<sup>6</sup> Total Cost of Reservation Assignable to Customer contingent upon base plan funding
AEPM	AG1-2006-006D	1019914	\$ 2,685,128	\$ 2,000,000	\$ 2,685,128	\$ 3,726,550	\$ -	\$ -	- Schedule 9 charges
AEPM	AG1-2006-007D	1023236	\$ 4,192,590	\$ 3,877,718	\$ 1,440,000	\$ 10,987,300	\$ 7,213,568	\$ -	\$ 7,213,568
EDE	AG1-2006-027	1032183	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	- Schedule 9 charges
INDP	AG1-2006-051	1033791	\$ 1,477,174	\$ 1,477,174	\$ -	\$ 5,988,578	\$ 5,988,578	\$ 15,840,000	\$ 15,840,000
KCPS	AG1-2006-009	979750	\$ 6,022,826	\$ 5,322,826	\$ 6,022,826	\$ 17,130,388	\$ -	\$ -	- Schedule 9 charges
KCPS	AG1-2006-070	1034307	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,050,600	\$ 1,050,600
KMEA	AG1-2006-068	1034247	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 249,600	\$ 249,600
KPP	AG1-2006-042	1032991	\$ 1,518,000	\$ 1,518,000	\$ 1,518,000	\$ 2,749,002	\$ -	\$ -	- Schedule 9 charges
OGE	AG1-2006-040	1032973	\$ 4,142,282	\$ 2,871,270	\$ 1,440,000	\$ 13,458,257	\$ 8,779,703	\$ -	\$ 8,779,703
OPMA	AG1-2006-010	977481	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	- Schedule 9 charges
WRGS	AG1-2006-029D	1031553	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 153,000	\$ 153,000
WRGS	AG1-2006-037D	1032955	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 158,400	\$ 158,400
			<b>\$ 20,038,000</b>	<b>\$ 13,105,954</b>	<b>\$ 54,040,076</b>	<b>\$ 21,981,850</b>			

Note 1: 92MW potential base plan funding for year 2008 for KPP WPEK requests.

Note 2: For PTP requests, total cost is based on the higher of the base rate or assigned upgrade revenue requirements. For Network requests, the total cost is based on the assigned upgrade revenue requirement. Allocation of base plan funding will be determined after verification of designated resource meeting Attachment J, Section II B Criteria.

Note 3: If potential base plan funding is applicable, this value is the lesser of the Engineering and Construction costs of assignable upgrades or the value of base plan funding calculated pursuant to Attachment J, Section III B criteria. Allocation of base plan funding is contingent upon verification of customer agreements meeting Attachment J, Section II B criteria. Not applicable if PTP base rate exceeds revenue requirements.

Note 4: Letter of Credit required for financial security for transmission owner for network upgrades is determined by allocated engineering and construction costs less engineering and construction costs for upgrades when network customer is the transmission owner plus network upgrades for assigned upgrades less than \$100,000 which are base plan funded but still require a letter of credit.

Note 5: Revenue Requirements are based upon customer's prior selection of intention to pursue redispatch if applicable.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer Study Number**  
AEPM AG1-2006-006D

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Available	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	1019914	CSWS	CSWS	168	7/1/2008	7/1/2013	7/1/2008	7/1/2013	\$ 2,685,128	\$ -	\$ 2,695,388	\$ -

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1019914	ALUMAX TAP - BANN 138KV CKT 1	6/1/2008	6/1/2008			\$ 685,128	\$ 1,000,000	\$ 1,350,112	
	ANADARKO 138/69KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 2,000,000	\$ 2,000,000	\$ 2,376,438	
	BANN - NW TEXARKANA-BANN T 138KV CKT 1	6/1/2012	6/1/2012			\$ 10,260	\$ 15,000	\$ -	
						Total	\$ 2,695,388	\$ 3,015,000	\$ 3,726,550

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1019914	ALUMAX TAP - NORTHWEST TEXARKANA 138KV CKT 1	6/1/2007	4/1/2008	10/1/2007	No
	LINWOOD - MCWILLIE STREET 138KV CKT 1	6/1/2007	4/1/2008	10/1/2007	No

**Customer Study Number**  
AEPM AG1-2006-007D

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Available	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	1023236	WFEC	CSWS	80	1/1/2007	1/1/2027	6/1/2008	6/1/2028	\$ 1,440,000	\$ -	\$ 4,212,330	\$ -

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1023236	36TH & LEWIS - 52ND & DELAWARE TAP 138KV CKT 1	6/1/2016	6/1/2016			\$ 15,000	\$ 15,000	\$ -	
	ALUMAX TAP - BANN 138KV CKT 1	6/1/2008	6/1/2008			\$ 314,872	\$ 1,000,000	\$ 917,374	
	BANN - NW TEXARKANA-BANN T 138KV CKT 1	6/1/2012	6/1/2012			\$ 4,740	\$ 15,000	\$ -	
	FT SUPPLY 138/69KV TRANSFORMER CKT 1	12/1/2006	6/1/2008	Yes		\$ 2,000,000	\$ 2,000,000	\$ 4,495,992	
	HAMON BUTLER - MOREWOOD 69KV CKT 1	6/1/2006	4/1/2008	Yes		\$ 1,278,730	\$ 3,400,000	\$ 3,038,093	
	KNOBHILL (KNOBHL4) 138/69/13.2KV TRANSFORMER CKT 1	6/1/2006	6/1/2008	Yes		\$ 598,988	\$ 1,750,000	\$ 2,535,841	
						Total	\$ 4,212,330	\$ 8,180,000	\$ 10,987,300

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1023236	ALUMAX TAP - NORTHWEST TEXARKANA 138KV CKT 1	6/1/2007	4/1/2008	10/1/2007	Yes
	LINWOOD - MCWILLIE STREET 138KV CKT 1	6/1/2007	4/1/2008	10/1/2007	Yes

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer Study Number**  
EDE AG1-2006-027

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
EDE	1032183	EES	EDE	50	6/1/2010	6/1/2040	6/1/2010	6/1/2040	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1032183	None					\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	
						Total	\$ - \$ - \$ - \$ -	

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1032183	BULL SHOALS - BULL SHOALS 161KV CKT 1	6/1/2010	6/1/2010		
	JAMESVILLE - SUB 415 - BLACKHAWK JCT. 69KV CKT 1	6/1/2013	6/1/2013		
	JONES - JONESBORO 161KV CKT 1	6/1/2009	6/1/2009		
	SUB 110 - ORONOGO JCT. (ORONOGO) 161/69/12.5KV TRANSFORMER CKT 1	6/1/2016	6/1/2016		
	SUB 124 - AURORA H.T. - SUB 152 - MONETT H.T. 69KV CKT 1	6/1/2011	6/1/2011		
	SUB 145 - JOPLIN WEST 7TH - SUB 64 - JOPLIN 10TH ST. 69KV CKT 1	6/1/2014	6/1/2014		

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1032183	SUB 110 - ORONOGO JCT. - SUB 167 - RIVERTON 161KV CKT 1	6/1/2011	6/1/2011		
	SUB 110 - ORONOGO JCT. (ORONOGO) 161/69/12.5KV TRANSFORMER CKT 1	6/1/2011	6/1/2011		

**Customer Study Number**  
INDP AG1-2006-051

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
INDP	1033791	KCPL	INDN	50	6/1/2010	6/1/2040	6/1/2010	6/1/2040	\$ - \$ 15,840,000 \$ 1,477,174 \$ -	\$ - \$ 15,840,000 \$ 1,477,174 \$ -	\$ - \$ 15,840,000 \$ 1,477,174 \$ -	

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1033791	166TH STREET - JAGGARD JUNCTION 115KV CKT 1	6/1/2009	6/1/2009			\$ 213,226 \$ 1,000,000 \$ 1,105,109		
	166TH STREET - JARBALO JUNCTION SWITCHING STATION 115KV CKT 1	6/1/2009	6/1/2009			\$ 405,130 \$ 1,900,000 \$ 577,384		
	JAGGARD JUNCTION - PENTAGON 115KV CKT 1	6/1/2009	6/1/2009			\$ 319,839 \$ 1,500,000 \$ 1,657,663		
	STRANGER CREEK - NW LEAVENWORTH 115KV	6/1/2010	6/1/2010			\$ 538,979 \$ 2,400,000 \$ 2,648,423		
						Total	\$ 1,477,174 \$ 6,800,000 \$ 5,988,578	

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1033791	IATAN - ST JOE 345KV CKT 1	12/1/2011	12/1/2011		
	IATAN5 161 - PLATTE CITY 161KV CKT 1	6/1/2011	6/1/2011		

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer Study Number**  
KCPS AG1-2006-009

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Available	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KCPS	979750	KCPL	KCPL	168	6/1/2009	6/1/2029	6/1/2009	6/1/2029	\$ 6,022,826	\$ -	\$ 6,022,826	\$ -

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
979750	166TH STREET - JAGGARD JUNCTION 115KV CKT 1	6/1/2009	6/1/2009			\$ 786,774	\$ 1,000,000	\$ 2,927,001
	166TH STREET - JARBALO JUNCTION SWITCHING STATION 115KV CKT 1	6/1/2009	6/1/2009			\$ 1,494,870	\$ 1,900,000	\$ 1,529,261
	COLLEGE - CRAIG 161KV CKT 1	6/1/2016	6/1/2016			\$ 700,000	\$ 700,000	\$ 1,719,531
	JAGGARD JUNCTION - PENTAGON 115KV CKT 1	6/1/2009	6/1/2009			\$ 1,180,161	\$ 1,500,000	\$ 4,390,502
	STRANGER CREEK - NW LEAVENWORTH 115KV	6/1/2010	6/1/2010			\$ 1,861,021	\$ 2,400,000	\$ 6,564,093
				Total		\$ 6,022,826	\$ 7,500,000	\$ 17,130,388

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
979750	AVONDALE - GLADSTONE 161KV CKT 1	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
979750	IATAN - ST JOE 345KV CKT 1	12/1/2011	12/1/2011		
979750	IATAN5 161 - PLATTE CITY 161KV CKT 1	6/1/2011	6/1/2011		

**Customer Study Number**  
KCPS AG1-2006-070

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Available	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KCPS	1034307	KCPL	EES	103	6/1/2006	6/1/2007	4/1/2008	4/1/2009	\$ -	\$ 1,050,600	\$ -	\$ -

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1034307	None					\$ -	\$ -	\$ -
				Total		\$ -	\$ -	\$ -

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1034307	BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1	6/1/2006	4/1/2008	10/1/2007	Yes

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer Study Number**  
KMEA AG1-2006-068

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Available	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	1034247	GRDA	WR	1	5/1/2010	5/1/2026	5/1/2010	5/1/2026	\$ - \$ 249,600	\$ - \$	\$ - \$	\$ - \$
									\$ - \$ 249,600	\$ - \$	\$ - \$	\$ - \$

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1034247	None					\$ - \$	\$ - \$	\$ - \$
						Total	\$ - \$	\$ - \$

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1034247	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	10/1/2006	6/1/2009	No	
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	10/1/2006	4/1/2009	No	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2016	6/1/2016		
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2016	6/1/2016		
	GRAY TAP - PENSACOLA 69KV CKT 1	6/1/2006	12/1/2008	10/1/2008	No

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1034247	412SUB - KANSAS TAP 161KV CKT 1	6/1/2015	6/1/2015		
	412SUB - KERR 161KV CKT 1	6/1/2015	6/1/2015		
	ARCADIA - REDBUD 345 KV CKT 1	6/1/2006	6/1/2006		
	ARCADIA - REDBUD 345 KV CKT 2	6/1/2006	6/1/2006		
	SUB 110 - ORONOGO JCT. - SUB 167 - RIVERTON 161KV CKT 1	6/1/2011	6/1/2011		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1034247	AEPW PLANNED UPGRADE FOR NW ARKANSAS	6/1/2006	6/1/2009	No	

**Customer Study Number**  
KPP AG1-2006-042

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Available	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KPP	1032991	WPEK	WPEK	80	6/1/2006	6/1/2016			\$ 1,518,000	\$ - \$ 1,518,000	\$ - \$	\$ - \$
									\$ 1,518,000	\$ - \$ 1,518,000	\$ - \$	\$ 2,749,002

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1032991	Greenleaf 34.5 kV System Improvements	6/1/2008	6/1/2008			\$ 797,000	\$ 797,000	\$ 1,403,696
	Greensburg 34.5 kV System Improvements	10/1/2007	10/1/2007			\$ 721,000	\$ 721,000	\$ 1,345,305
						Total	\$ 1,518,000	\$ 1,518,000
								\$ 2,749,002

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer Study Number**  
OGE AG1-2006-040

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Available	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
OGE	1032973	OKGE	OKGE	120	9/1/2006	9/1/2031	12/1/2008	12/1/2033	\$ 1,440,000	\$ -	\$ 4,142,282	\$ -

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1032973	FPL SWITCH - MOORELAND 138KV CKT 1 OKGE	6/1/2006	4/1/2008	Yes	\$ 120,000	\$ 120,000	\$ 575,562	
	FPL SWITCH - MOORELAND 138KV CKT 1 WFEC	6/1/2006	4/1/2008	Yes	\$ 750,000	\$ 750,000	\$ 1,923,027	
	HAMON BUTLER - MOREWOOD 69KV CKT 1	6/1/2006	4/1/2008	Yes	\$ 2,121,270	\$ 3,400,000	\$ 5,439,013	
	KNOBHILL (KNOBHL4) 138/69/13.2KV TRANSFORMER CKT 1	6/1/2006	6/1/2008	Yes	\$ 1,151,012	\$ 1,750,000	\$ 5,520,655	
				Total	\$ 4,142,282	\$ 6,020,000	\$ 13,458,257	

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1032973	COLONY - FT SMITH 161KV CKT 1	6/1/2011	6/1/2011		
	PENNSYLVANIA - WESTMOORE 138KV CKT 1	10/1/2007	4/1/2009	12/1/2008	Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1032973	IODINE - WOODWARD 138KV CKT 1	6/1/2006	12/1/2006		Yes

**Customer Study Number**  
OMPA AG1-2006-010

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Available	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
OMPA	977481	GRDA	OKGE	25	5/1/2007	5/1/2040	12/1/2008	12/1/2041	\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
977481	None					\$ -	\$ -	\$ -
				Total		\$ -	\$ -	\$ -

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
977481	GRAY TAP - PENSACOLA 69KV CKT 1	6/1/2006	12/1/2008	10/1/2008	Yes
	GRAY TAP - PENSACOLA 69KV CKT 1	6/1/2006	12/1/2008	10/1/2008	Yes
	PENNSYLVANIA - WESTMOORE 138KV CKT 1	10/1/2007	4/1/2009	12/1/2008	Yes
	ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3	6/1/2013	6/1/2013		
	WAUKOMIS TAP - WOODRING 138KV CKT 1	6/1/2011	6/1/2011		

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
977481	412SUB - KANSAS TAP 161KV CKT 1	6/1/2015	6/1/2015		
	412SUB - KERR 161KV CKT 1	6/1/2015	6/1/2015		
	ARCADIA - REDBUD 345 KV CKT 1	6/1/2006	6/1/2006		
	ARCADIA - REDBUD 345 KV CKT 2	6/1/2006	6/1/2006		
	SUB 110 - ORONOGO JCT. - SUB 167 - RIVERTON 161KV CKT 1	6/1/2011	6/1/2011		

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer Study Number**  
WRGS AG1-2006-029D

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispach	Deferred Stop Date Without Redispach	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
WRGS	1031553	KCPL	AECI	15	6/1/2006	6/1/2007	10/1/2006	10/1/2007	\$ - \$ 153,000	\$ - \$	\$ - \$	\$ - \$

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispach Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1031553	None					\$ - \$	\$ - \$	\$ - \$
						Total	\$ - \$	\$ - \$

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispach Available
1031553	SOUTH WAVERLY 161/69KV TRANSFORMER CKT 1 Redispach	6/1/2006	10/1/2006		Yes

**Customer Study Number**  
WRGS AG1-2006-037D

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispach	Deferred Stop Date Without Redispach	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
WRGS	1032955	AECI	KCPL	15	6/1/2006	6/1/2007	4/1/2008	4/1/2009	\$ - \$ 158,400	\$ - \$	\$ - \$	\$ - \$

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispach Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1032955	None					\$ - \$	\$ - \$	\$ - \$
						Total	\$ - \$	\$ - \$

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispach Available
1032955	BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1	6/1/2006	4/1/2008	10/1/2007	Yes

Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study

Transmission Owner	Upgrade	Solution	Minimum ATC per Upgrade (MW)	Season of Minimum Allocated ATC	Earliest Data Upgrade Required (COD)	Estimated Date of Upgrade Completion (EOC)	Estimated Engineering & Construction Cost
AEPW	36TH & LEWIS - 52ND & DELAWARE TAP 138KV CKT 1	Reset Relays @ 36th & Lewis	183	16SP	6/1/2016	6/1/2016	\$ 15,000
AEPW	ALUMAX TAP - BANN 138KV CKT 1	Replace six (6) 138 kV switches, five at Bann & one at Alumax Tap. Rebuild 0.67 miles of 1024 ACSR with 2156 ACSR. Replace wavetrap & jumpers @ Bann. Replace breaker 3300 @ Bann.	0	11SP	6/1/2008	6/1/2008	\$ 1,000,000
AEPW	BANN - NW TEXARKANA-BANN T 138KV CKT 1	Reset Relays	0	16SP	6/1/2012	6/1/2012	\$ 15,000
KACP	COLLEGE - CRAIG 161KV CKT 1	Reconductor 4 miles with 1192.5 ACSS, 558 normal/emergency rating and upgrade breakers	143	16SP	6/1/2016	6/1/2016	\$ 700,000
OKGE	FPL SWITCH - MOORELAND 138KV CKT 1 OKGE	OGE would rebuild .18 miles of 267AS33 with 795AS33. This would raise OGE's summer and winter rate to 287MVA. The limit will still be at WFEC's Mooreland at 390A & 600A.	54	06FA	6/1/2006	4/1/2008	\$ 120,000
OKGE	KNOBHILL (KNOBHIL4) 138/69/13.2KV TRANSFORMER CKT 1	Replace bus bar with 100MVA transformer	87	08SP	6/1/2006	6/1/2008	\$ 1,750,000
WEPL	Greenleaf 34.5 kV System Improvements	Build a new 5.1 mile 34.5 kV line from Greenleaf to the City of Washington	0	08SP	6/1/2008	6/1/2008	\$ 797,000
WEPL	Greensburg 34.5 kV System Improvements	Build a new 4.5 miles 34.5 kV line from Greensburg 115/34.5 kV Sub to the City of Greensburg	0	07FA	10/1/2007	10/1/2007	\$ 721,000
WERE	166TH STREET - JAGGARD JUNCTION 115KV CKT 1	Tear down and rebuild 3.66 mile 166-Jaggard 115 KV line	0	11SP	6/1/2009	6/1/2009	\$ 1,000,000
WERE	166TH STREET - JARBALO JUNCTION SWITCHING STATION 115KV CKT 1	Tear down and rebuild 7.22 mile Jarbalo-166 115 KV line	0	11SP	6/1/2009	6/1/2009	\$ 1,900,000
WERE	JAGGARD JUNCTION - PENTAGON 115KV CKT 1	Tear down and rebuild Jaggard - Pentagon 115 KV line	0	11SP	6/1/2009	6/1/2009	\$ 1,500,000
WERE	STRANGER CREEK - NW LEAVENWORTH 115KV	Tear down/rebuild Jarbalo-NW Leavenworth 115 KV line with double circuit tap to Stranger Creek	0	11SP	6/1/2010	6/1/2010	\$ 2,400,000
WFEC	ANADARKO 138/69KV TRANSFORMER CKT 1	Install 2nd 112 MVA auto in parallel with existing Ur	49	16SP	6/1/2011	6/1/2011	\$ 2,000,000
WFEC	FPL SWITCH - MOORELAND 138KV CKT 1 WFEC	Upgrade terminal equipment FPL Sw & Moorelan	54	06FA	6/1/2006	4/1/2008	\$ 750,000
WFEC	FT SUPPLY 138/69KV TRANSFORMER CKT 1	Install 2nd 70 MVA auto at Ft Suppl	67	07FA	12/1/2006	6/1/2008	\$ 2,000,000
WFEC	HAMON BUTLER - MOREWOOD 69KV CKT 1	Reconductor 1/0 to 336 ACSR - 15.0 miles	0	16SP	6/1/2006	4/1/2008	\$ 3,400,000

Construction Pending Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Transmission Owner	Upgrade	Solution	Minimum ATC per Upgrade (MW)	Season of Minimum Allocated ATC	Earliest Data Upgrade Required (COD)	Estimated Date of Upgrade Completion (EOC)
AEPW	AEPW PLANNED UPGRADE FOR NW ARKANSAS	NW Project phase II scheduled to be in-service 06/2001	0	06SP	6/1/2006	6/1/2003
MIPU	IATAN - ST JOE 345KV CKT 1	Circuit Breaker	165	11WP	12/1/2011	12/1/2011
MIPU	IATAN5 161 - PLATTE CITY 161KV CKT 1	Terminal Equipment	0	11WP	6/1/2011	6/1/2011
OKGE	IODINE - WOODWARD 138KV CKT 1	New line will be in service by 12/1/2001	37	06SH	6/1/2006	12/1/2006

Expansion Plan Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Transmission Owner	Upgrade	Solution	Minimum ATC per Upgrade (MW)	Season of Minimum Allocated ATC	Earliest Data Upgrade Required (COD)	Estimated Date of Upgrade Completion (EOC)
AEPW	ALUMAX TAP - NORTHWEST TEXARKANA 138KV CKT 1	Rebuild 1.68 miles of 1024 ACAR with 2156 ACSR, Replace wavetrap & jumpers with 2156 ACSR. Replace Switch 2285 @ Alumax Tap.	0	08SP	6/1/2007	4/1/2008
AEPW	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	Tie Line, Reconductor 1.09 miles of 795 ACSR with 1590 ACSR	0	16SP	6/1/2016	6/1/2016
AEPW	LINWOOD - MCWILLIE STREET 138KV CKT 1	Rebuild 2.09 miles of 664 ACSR with 1272 ACSR	0	07SP	6/1/2007	4/1/2008
EMDE	JAMESVILLE - SUB 415 - BLACKHAWK JCT. 69KV CKT 1	Replace Jumpers to breaker #6950 at Blackhawk Jct	0	16SP	6/1/2013	6/1/2013
EMDE	SUB 110 - ORONOGO JCT. (ORONOGO) 161/69/12.5KV TRANSFORMER CKT 1	Replace 75 MVA Auto-xfrm at Oronogo Jct with 150 MVA Auto-xmr and install 69 kV bank breaker Auto-xfrm will have an impedance similar to Aurora 59468, 59537, 59704.	0	16SP	6/1/2016	6/1/2016
EMDE	SUB 124 - AURORA H.T. - SUB 152 - MONETT H.T. 69KV CKT 1	Change CT Ratio on breaker #6936 at Aurora #124	0	11SP	6/1/2011	6/1/2011
EMDE	SUB 145 - JOPLIN WEST 7TH - SUB 64 - JOPLIN 10TH ST. 69KV CKT 1	Replace 600 amp disconnects and leads to breaker #6965 at Joplin #6	0	16SP	6/1/2014	6/1/2014
GRDA	GRAY TAP - PENSACOLA 69KV CKT 1	Rebuild of Pensacola - Jayline (not owned by GRDA - have tried to convince owner)	0	06SP	6/1/2006	12/1/2008
KACP	AVONDALE - GLADSTONE 161KV CKT 1	Replace 800 amp wavetrap at Gladstone with 1200 amp wavetrap	0	16SP	6/1/2014	6/1/2014
KACP	SOUTH WAVERLY 161/69KV TRANSFORMER CKT 1 Redispatch	Redispatch for the 06 Summer Shoulde	0	06SH	6/1/2006	10/1/2006
MIPU	BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1	Conductor	0	06SP	6/1/2006	4/1/2008
OKGE	COLONY - FT SMITH 161KV CKT 1	Reconductor 2.2 miles to Drake ACCC/TW and change terminal equipment at Ft. Smith & Colony to 2000A.	0	11SP	6/1/2011	6/1/2011
OKGE	PENNSYLVANIA - WESTMOORE 138KV CKT 1	Replace the disconnect switches for breaker 108 at Pennsylvania Substation. Replace the 1200A tra Increase CTR. Relay replacement may be required.	0	07FA	10/1/2007	4/1/2009
OKGE	WAUKOMIS TAP - WOODRING 138KV CKT 1	Reconductor 2.75 miles of line with Drake ACCC conductor and increase CTF	0	11SP	6/1/2011	6/1/2011
SWPA	BULL SHOALS - BULL SHOALS 161KV CKT 1	Replace bus at Bull Shoals	0	16SP	6/1/2010	6/1/2010
SWPA	JONES - JONESBORO 161KV CKT 1	Change the ratio on the metering CT's to 1200/5 and adjust the meter	0	11SP	6/1/2009	6/1/2009
WERE	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	Rebuild 16.66 mile Circleville-Hoyt HTI Junction 115 KV line	0	07FA	10/1/2006	6/1/2006
WERE	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	Rebuild 15.15 mile line with 1192.5 kcmil ACSR and replace CT	0	08WP	10/1/2006	4/1/2009
WERE	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	Tie Line, Rebuild 5.02-mile 138kV line from Dearing to S Coffeyville Tap and replace Dearing 138kV main bus and connections.	0	16SP	6/1/2016	6/1/2016
WERE	ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3	Add third 345-138 KV transformer at Rose Hill	0	16SP	6/1/2013	6/1/2013

Previously Assigned Aggregate Study Upgrades requiring credits to Previous Aggregate Study Customers

Transmission Owner	Upgrade	Solution	Earliest Data Upgrade Required (COD)	Estimated Date of Upgrade Completion (EOC)
EMDE	SUB 110 - ORONOGO JCT. - SUB 167 - RIVERTON 161KV CKT 1	Reconductor Oronogo 59467 to Riverton 59469 with Bundled 556 ACSI	6/1/2011	6/1/2011
EMDE	SUB 110 - ORONOGO JCT. (ORONOGO) 161/69/12.5KV TRANSFORMER CKT 1	Install new 161/12 KV 22.4 transm and take load off 69 KV system	6/1/2011	6/1/2011
GRRD	412SUB - KANSAS TAP 161KV CKT 1	Reconductor 9.7 miles with 1590MCM ACSR	6/1/2015	6/1/2015
GRRD	412SUB - KERR 161KV CKT 1	Reconductor 12.5 miles with 1590MCM ACSR	6/1/2015	6/1/2015
OKGE	ARCADIA - REDBUD 345 KV CKT 1	Sponsored Project to Update Terminal Equipment	6/1/2006	6/1/2006
OKGE	ARCADIA - REDBUD 345 KV CKT 2	Sponsored Project to Update Terminal Equipment	6/1/2006	6/1/2006

**Table 5** - Third Party Facility Constraints

Transmission Owner	Upgrade	Solution	Minimum ATC per Upgrade (MW)	Season of Minimum Allocated ATC	Earliest Date Upgrade Required (COD)	Estimated Date of Upgrade Completion (EOC)	Estimated Engineering & Construction Cost
	None						

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Upgrade: ALUMAX TAP - NORTHWEST TEXARKANA 138KV CKT 1  
 Limiting Facility: ALUMAX TAP - NORTHWEST TEXARKANA 138KV CKT 1  
 Direction: To->From  
 Line Outage: SPP-AEPW-29  
 Flowgate: 53245533001SPP-AEPW-291107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1023236		2.9							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'COMANCHE 138KV'	160	0.01244	-0.10002	29
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'COMANCHE 69KV'	63	0.01239	-0.09997	29
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'SOUTHWESTERN STATION 138KV'	327	0.01212	-0.0997	29
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'WELSH 345KV'	990	0.01228	-0.09986	29
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'COGENTRIX 345KV'	665	0.00882	-0.0964	30
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'NORTHEASTERN STATION 138KV'	405	0.00807	-0.09565	30
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'NORTHEASTERN STATION 138KV'	95	0.00807	-0.09565	30
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'NORTHEASTERN STATION 345KV'	645	0.00807	-0.09565	30
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'RIVERSIDE STATION 138KV'	646	0.00877	-0.09635	30
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'TULSA POWER STATION 138KV'	92.99999	0.0087	-0.09628	30
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'TULSA POWER STATION 138KV'	147	0.0087	-0.09628	30
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'WELEETKA 138KV'	70	0.00961	-0.09719	30
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'FITZHUGH 161KV'	126	0.00382	-0.0914	32
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'LEBROCK 345KV'	365	-0.00885	-0.07873	37
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'NARROWS 69KV'	22	-0.00834	-0.07924	37
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'PIRKEY GENERATION 138KV'	248	-0.01312	-0.07446	39
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'EASTMAN 138KV'	355	-0.01562	-0.07196	40
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'COMANCHE 138KV'	160	0.01244	-0.07321	40
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'COMANCHE 69KV'	63	0.01239	-0.07316	40
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'SOUTHWESTERN STATION 138KV'	327	0.01212	-0.07289	40
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'WELSH 345KV'	990	0.01228	-0.07305	40
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'KNOXLEE 138KV'	262.5121	-0.01564	-0.07194	41
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'WELEETKA 138KV'	70	0.00961	-0.07038	41
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.08758	AEPW	'WILKES 345KV'	311	-0.01738	-0.0702	42
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'COGENTRIX 345KV'	665	0.00882	-0.06959	42
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'NORTHEASTERN STATION 138KV'	405	0.00807	-0.06884	42
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'NORTHEASTERN STATION 138KV'	95	0.00807	-0.06884	42
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'NORTHEASTERN STATION 345KV'	645	0.00807	-0.06884	42
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'RIVERSIDE STATION 138KV'	646	0.00877	-0.06954	42
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'TULSA POWER STATION 138KV'	92.99999	0.0087	-0.06947	42
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'TULSA POWER STATION 138KV'	147	0.0087	-0.06947	42
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'FITZHUGH 161KV'	126	0.00382	-0.06459	45
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'LEBROCK 345KV'	365	-0.00885	-0.05192	56
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'NARROWS 69KV'	22	-0.00834	-0.05243	56
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'PIRKEY GENERATION 138KV'	248	-0.01312	-0.04765	61
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'EASTMAN 138KV'	355	-0.01562	-0.04515	65
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'KNOXLEE 138KV'	262.5121	-0.01564	-0.04513	65
AEPW	WILKES 138KV'	116.6958	-0.06077	AEPW	'WILKES 345KV'	311	-0.01738	-0.04339	67
AEPW	LIEBERMAN 138KV'	137	-0.02651	AEPW	'COMANCHE 138KV'	160	0.01244	-0.03895	75
AEPW	LIEBERMAN 138KV'	137	-0.02651	AEPW	'SOUTHWESTERN STATION 138KV'	327	0.01212	-0.03863	75
AEPW	LIEBERMAN 138KV'	137	-0.02651	AEPW	'WELSH 345KV'	990	0.01228	-0.03879	75
AEPW	LIEBERMAN 138KV'	137	-0.02651	AEPW	'WELEETKA 138KV'	70	0.00961	-0.03612	81
AEPW	LIEBERMAN 138KV'	137	-0.02651	AEPW	'COGENTRIX 345KV'	665	0.00882	-0.03533	82
AEPW	LIEBERMAN 138KV'	137	-0.02651	AEPW	'RIVERSIDE STATION 138KV'	646	0.00877	-0.03528	83
AEPW	LIEBERMAN 138KV'	137	-0.02651	AEPW	'TULSA POWER STATION 138KV'	92.99999	0.0087	-0.03521	83
AEPW	LIEBERMAN 138KV'	137	-0.02651	AEPW	'TULSA POWER STATION 138KV'	147	0.0087	-0.03521	83
AEPW	ARSENAL HILL 69KV'	75	-0.02242	AEPW	'COMANCHE 138KV'	160	0.01244	-0.03486	84
AEPW	ARSENAL HILL 69KV'	75	-0.02242	AEPW	'SOUTHWESTERN STATION 138KV'	327	0.01212	-0.03454	84
AEPW	ARSENAL HILL 69KV'	75	-0.02242	AEPW	'WELSH 345KV'	990	0.01228	-0.0347	84
AEPW	LIEBERMAN 138KV'	137	-0.02651	AEPW	'NORTHEASTERN STATION 138KV'	405	0.00807	-0.03458	84
AEPW	LIEBERMAN 138KV'	137	-0.02651	AEPW	'NORTHEASTERN STATION 138KV'	95	0.00807	-0.03458	84
AEPW	LIEBERMAN 138KV'	137	-0.02651	AEPW	'NORTHEASTERN STATION 345KV'	645	0.00807	-0.03458	84
AEPW	ARSENAL HILL 69KV'	75	-0.02242	AEPW	'WELEETKA 138KV'	70	0.00961	-0.03203	91
AEPW	ARSENAL HILL 69KV'	75	-0.02242	AEPW	'COGENTRIX 345KV'	665	0.00882	-0.03124	93
AEPW	ARSENAL HILL 69KV'	75	-0.02242	AEPW	'RIVERSIDE STATION 138KV'	646	0.00877	-0.03119	93
AEPW	ARSENAL HILL 69KV'	75	-0.02242	AEPW	'TULSA POWER STATION 138KV'	92.99999	0.0087	-0.03112	94
AEPW	ARSENAL HILL 69KV'	75	-0.02242	AEPW	'TULSA POWER STATION 138KV'	147	0.0087	-0.03112	94
AEPW	ARSENAL HILL 69KV'	75	-0.02242	AEPW	'NORTHEASTERN STATION 138KV'	405	0.00807	-0.03049	96
AEPW	ARSENAL HILL 69KV'	75	-0.02242	AEPW	'NORTHEASTERN STATION 138KV'	95	0.00807	-0.03049	96
AEPW	ARSENAL HILL 69KV'	75	-0.02242	AEPW	'NORTHEASTERN STATION 345KV'	645	0.00807	-0.03049	96
AEPW	LIEBERMAN 138KV'	137	-0.02651	AEPW	'FITZHUGH 161KV'	126	0.00382	-0.03033	96

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1  
 Limiting Facility: BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1  
 Direction: To->From  
 Line Outage: ORRICK - SIBLEY 161KV CKT 1  
 Flowgate: 59205592351592445920211106SP  
 Date Redispatch Needed: 6/1/06 - 10/1/06  
 Season Flowgate Identified: 2006 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1032955		0.8							
1034307		4.1							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
MIPU	'GREENWOOD 161KV'	255.8	-0.18518	MIPU	'SIBLEY 161KV'	230.2336	0.19121	-0.37639	13
MIPU	'ARIES 161KV'	595	-0.14198	MIPU	'SIBLEY 161KV'	230.2336	0.19121	-0.33319	14
MIPU	'GREENWOOD 161KV'	255.8	-0.18518	MIPU	'SIBLEY 69KV'	45.99999	0.16359	-0.34877	14
MIPU	'ARIES 161KV'	595	-0.14198	MIPU	'SIBLEY 69KV'	45.99999	0.16359	-0.30557	16
MIPU	'RALPH GREEN 69KV'	73.7	-0.11371	MIPU	'SIBLEY 161KV'	230.2336	0.19121	-0.30492	16
MIPU	'RALPH GREEN 69KV'	73.7	-0.11371	MIPU	'SIBLEY 69KV'	45.99999	0.16359	-0.2773	17
MIPU	'NEVADA 69KV'	20.3	-0.04556	MIPU	'SIBLEY 161KV'	230.2336	0.19121	-0.23677	20
MIPU	'GREENWOOD 161KV'	255.8	-0.18518	MIPU	'LAKE ROAD 161KV'	35	0.03552	-0.2207	22
MIPU	'GREENWOOD 161KV'	255.8	-0.18518	MIPU	'LAKE ROAD 34KV'	92	0.03552	-0.2207	22
MIPU	'NEVADA 69KV'	20.3	-0.04556	MIPU	'SIBLEY 69KV'	45.99999	0.16359	-0.20915	23
MIPU	'ARIES 161KV'	595	-0.14198	MIPU	'LAKE ROAD 161KV'	35	0.03552	-0.1775	27
MIPU	'ARIES 161KV'	595	-0.14198	MIPU	'LAKE ROAD 34KV'	92	0.03552	-0.1775	27
MIPU	'RALPH GREEN 69KV'	73.7	-0.11371	MIPU	'LAKE ROAD 161KV'	35	0.03552	-0.14923	32
MIPU	'RALPH GREEN 69KV'	73.7	-0.11371	MIPU	'LAKE ROAD 34KV'	92	0.03552	-0.14923	32

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

MIPU	GREENWOOD 161KV	255.8	-0.18518	MIPU	SOUTH HARPER 161KV	232.4752	-0.04893	-0.13625	35
MIPU	ARIES 161KV	595	-0.14198	MIPU	SOUTH HARPER 161KV	232.4752	-0.04893	-0.09305	52
MIPU	NEVADA 69KV	20.3	-0.04556	MIPU	LAKE ROAD 161KV	35	0.03552	-0.08108	60
MIPU	NEVADA 69KV	20.3	-0.04556	MIPU	LAKE ROAD 34KV	92	0.03552	-0.08108	60
KACP	MARSHALL 161KV	39.1	-0.03666	KACP	HAWTHORN 161KV	455	0.04087	-0.07753	62
KACP	MARSHALL 161KV	39.1	-0.03666	KACP	HAWTHORN 161KV	314	0.04087	-0.07753	62
KACP	MARSHALL 161KV	39.1	-0.03666	KACP	NORTHEAST 13KV	36	0.03795	-0.07461	65
KACP	MARSHALL 161KV	39.1	-0.03666	KACP	NORTHEAST 13KV	36	0.03795	-0.07461	65
KACP	MARSHALL 161KV	39.1	-0.03666	KACP	NORTHEAST 13KV	38	0.03795	-0.07461	65
KACP	MARSHALL 161KV	39.1	-0.03666	KACP	NORTHEAST 161KV	35	0.03795	-0.07461	65
KACP	MARSHALL 161KV	39.1	-0.03666	KACP	NORTHEAST 161KV	38	0.03795	-0.07461	65
KACP	MONTROSE 161KV	27.81479	-0.02891	KACP	HAWTHORN 161KV	27.89355	0.03795	-0.07461	65
KACP	MONTROSE 161KV	27.81479	-0.02891	KACP	HAWTHORN 161KV	314	0.04087	-0.06978	69
KACP	MONTROSE 161KV	27.81479	-0.02891	KACP	NORTHEAST 13KV	36	0.03795	-0.06686	72
KACP	MONTROSE 161KV	27.81479	-0.02891	KACP	NORTHEAST 13KV	36	0.03795	-0.06686	72
KACP	MONTROSE 161KV	27.81479	-0.02891	KACP	NORTHEAST 161KV	38	0.03795	-0.06686	72
KACP	MONTROSE 161KV	27.81479	-0.02891	KACP	NORTHEAST 161KV	35	0.03795	-0.06686	72
KACP	MONTROSE 161KV	27.81479	-0.02891	KACP	NORTHEAST 161KV	38	0.03795	-0.06686	72
MIPU	RALPH GREEN 69KV	73.7	-0.11371	MIPU	SOUTH HARPER 161KV	232.4752	-0.04893	-0.06478	75
KACP	MARSHALL 161KV	39.1	-0.03666	KACP	IATAN 345KV	396	0.01542	-0.05206	93

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1  
 Limiting Facility: BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1  
 Direction: To->From  
 Line Outage: ORRICK - SIBLEY 161KV CKT 1  
 Flowgate: 59205592351592445920211107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1032955		0.8		4.7					
1034307		4.0		4.7					
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
MIPU	GREENWOOD 161KV	255.8	-0.18515	MIPU	SIBLEY 161KV	232.7943	0.19105	-0.3762	13
MIPU	ARIES 161KV	595	-0.14194	MIPU	SIBLEY 161KV	232.7943	0.19105	-0.3329	14
MIPU	GREENWOOD 161KV	255.8	-0.18515	MIPU	SIBLEY 69KV	45.99995	0.16339	-0.34854	14
MIPU	ARIES 161KV	595	-0.14194	MIPU	SIBLEY 69KV	45.99995	0.16339	-0.30533	16
MIPU	GREENWOOD 161KV	255.8	-0.18515	MIPU	LAKE ROAD 161KV	35	0.03534	-0.22049	21
MIPU	GREENWOOD 161KV	255.8	-0.18515	MIPU	LAKE ROAD 34KV	92	0.03534	-0.22049	21
MIPU	ARIES 161KV	595	-0.14194	MIPU	LAKE ROAD 161KV	35	0.03534	-0.17728	27
MIPU	ARIES 161KV	595	-0.14194	MIPU	LAKE ROAD 34KV	92	0.03534	-0.17728	27
MIPU	GREENWOOD 161KV	255.8	-0.18515	MIPU	SOUTH HARPER 161KV	274.6863	-0.04884	-0.13631	35
MIPU	ARIES 161KV	595	-0.14194	MIPU	SOUTH HARPER 161KV	274.6863	-0.04884	-0.0931	51
MIPU	NEVADA 69KV	20.3	-0.04529	MIPU	LAKE ROAD 161KV	35	0.03534	-0.08063	59
MIPU	NEVADA 69KV	20.3	-0.04529	MIPU	LAKE ROAD 34KV	92	0.03534	-0.08063	59
KACP	MARSHALL 161KV	39.1	-0.03669	KACP	HAWTHORN 161KV	455	0.04042	-0.07711	61
KACP	MARSHALL 161KV	39.1	-0.03669	KACP	HAWTHORN 161KV	314	0.04042	-0.07711	61
KACP	MARSHALL 161KV	39.1	-0.03669	KACP	NORTHEAST 13KV	36	0.03717	-0.07386	64
KACP	MARSHALL 161KV	39.1	-0.03669	KACP	NORTHEAST 13KV	36	0.03717	-0.07386	64
KACP	MARSHALL 161KV	39.1	-0.03669	KACP	NORTHEAST 13KV	38	0.03717	-0.07386	64
KACP	MARSHALL 161KV	39.1	-0.03669	KACP	NORTHEAST 161KV	35	0.03717	-0.07386	64
KACP	MARSHALL 161KV	39.1	-0.03669	KACP	NORTHEAST 161KV	38	0.03717	-0.07386	64
KACP	MARSHALL 161KV	39.1	-0.03669	KACP	NORTHEAST 161KV	32.55078	0.03717	-0.07386	64
KACP	MONTROSE 161KV	27.68605	-0.0288	KACP	HAWTHORN 161KV	455	0.04042	-0.06922	68
KACP	MONTROSE 161KV	27.68605	-0.0288	KACP	HAWTHORN 161KV	314	0.04042	-0.06922	68
KACP	MONTROSE 161KV	27.68605	-0.0288	KACP	NORTHEAST 13KV	36	0.03717	-0.06597	72
KACP	MONTROSE 161KV	27.68605	-0.0288	KACP	NORTHEAST 13KV	36	0.03717	-0.06597	72
KACP	MONTROSE 161KV	27.68605	-0.0288	KACP	NORTHEAST 13KV	38	0.03717	-0.06597	72
KACP	MONTROSE 161KV	27.68605	-0.0288	KACP	NORTHEAST 13KV	38	0.03717	-0.06597	72
KACP	MONTROSE 161KV	27.68605	-0.0288	KACP	NORTHEAST 161KV	35	0.03717	-0.06597	72
KACP	MONTROSE 161KV	27.68605	-0.0288	KACP	NORTHEAST 161KV	35	0.03717	-0.06597	72
KACP	MONTROSE 161KV	27.68605	-0.0288	KACP	NORTHEAST 161KV	38	0.03717	-0.06597	72
KACP	MONTROSE 161KV	27.68605	-0.0288	KACP	NORTHEAST 161KV	32.55078	0.03717	-0.06597	72
MIPU	RALPH GREEN 69KV	73.7	-0.11364	MIPU	SOUTH HARPER 161KV	274.6863	-0.04884	-0.06468	73
KACP	MARSHALL 161KV	39.1	-0.03669	KACP	IATAN 345KV	396	0.01542	-0.05211	91

Maximum Decrement and Maximum Increment were determine from the Sink and Source Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1  
 Limiting Facility: BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1  
 Direction: To->From  
 Line Outage: ORRICK - RICHMOND 161KV CKT 1  
 Flowgate: 59205592351592445923611106SP  
 Date Redispatch Needed: 6/1/06 - 10/1/06  
 Season Flowgate Identified: 2006 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1032955		0.8		4.8					
1034307		4.1		4.8					
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
MIPU	GREENWOOD 161KV	255.8	-0.18515	MIPU	SIBLEY 161KV	230.2336	0.19121	-0.37639	13
MIPU	ARIES 161KV	595	-0.14198	MIPU	SIBLEY 161KV	230.2336	0.19121	-0.33319	14
MIPU	GREENWOOD 161KV	255.8	-0.18515	MIPU	SIBLEY 69KV	45.99995	0.16359	-0.34877	14
MIPU	ARIES 161KV	595	-0.14198	MIPU	SIBLEY 69KV	45.99995	0.16359	-0.30557	16
MIPU	RALPH GREEN 69KV	73.7	-0.11371	MIPU	SIBLEY 161KV	230.2336	0.19121	-0.30492	16
MIPU	RALPH GREEN 69KV	73.7	-0.11371	MIPU	SIBLEY 69KV	45.99995	0.16359	-0.2773	17
MIPU	NEVADA 69KV	20.3	-0.04556	MIPU	SIBLEY 161KV	230.2336	0.19121	-0.23677	20
MIPU	GREENWOOD 161KV	255.8	-0.18518	MIPU	LAKE ROAD 161KV	35	0.03552	-0.2207	22
MIPU	GREENWOOD 161KV	255.8	-0.18518	MIPU	LAKE ROAD 34KV	92	0.03552	-0.2207	22
MIPU	NEVADA 69KV	20.3	-0.04556	MIPU	SIBLEY 69KV	45.99995	0.16359	-0.20915	23
MIPU	ARIES 161KV	595	-0.14198	MIPU	LAKE ROAD 161KV	35	0.03552	-0.1775	27
MIPU	ARIES 161KV	595	-0.14198	MIPU	LAKE ROAD 34KV	92	0.03552	-0.1775	27
MIPU	RALPH GREEN 69KV	73.7	-0.11371	MIPU	LAKE ROAD 161KV	35	0.03552	-0.14923	32
MIPU	RALPH GREEN 69KV	73.7	-0.11371	MIPU	LAKE ROAD 34KV	92	0.03552	-0.14923	32
MIPU	GREENWOOD 161KV	255.8	-0.18518	MIPU	SOUTH HARPER 161KV	232.4752	-0.04893	-0.13625	35
MIPU	ARIES 161KV	595	-0.14198	MIPU	SOUTH HARPER 161KV	232.4752	-0.04893	-0.09305	52
MIPU	NEVADA 69KV	20.3	-0.04556	MIPU	LAKE ROAD 161KV	35	0.03552	-0.08108	60

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

MIPU	NEVADA 69KV	20.3	-0.04556	MIPU	LAKE ROAD 34KV	92	0.03552	-0.08108	60
KACP	MARSHALL 161KV'	39.1	-0.03666	KACP	HAWTHORN 161KV'	455	0.04087	-0.07753	62
KACP	MARSHALL 161KV'	39.1	-0.03666	KACP	HAWTHORN 161KV'	314	0.04087	-0.07753	62
KACP	MARSHALL 161KV'	39.1	-0.03666	KACP	NORTHEAST 13KV'	36	0.03795	-0.07461	65
KACP	MARSHALL 161KV'	39.1	-0.03666	KACP	NORTHEAST 13KV'	36	0.03795	-0.07461	65
KACP	MARSHALL 161KV'	39.1	-0.03666	KACP	NORTHEAST 13KV'	38	0.03795	-0.07461	65
KACP	MARSHALL 161KV'	39.1	-0.03666	KACP	NORTHEAST 161KV'	35	0.03795	-0.07461	65
KACP	MARSHALL 161KV'	39.1	-0.03666	KACP	NORTHEAST 161KV'	38	0.03795	-0.07461	65
KACP	MARSHALL 161KV'	39.1	-0.03666	KACP	NORTHEAST 161KV'	27.89355	0.03795	-0.07461	65
KACP	MONTROSE 161KV'	27.81479	-0.02891	KACP	HAWTHORN 161KV'	455	0.04087	-0.06978	69
KACP	MONTROSE 161KV'	27.81479	-0.02891	KACP	HAWTHORN 161KV'	314	0.04087	-0.06978	69
KACP	MONTROSE 161KV'	27.81479	-0.02891	KACP	NORTHEAST 13KV'	36	0.03795	-0.06686	72
KACP	MONTROSE 161KV'	27.81479	-0.02891	KACP	NORTHEAST 13KV'	36	0.03795	-0.06686	72
KACP	MONTROSE 161KV'	27.81479	-0.02891	KACP	NORTHEAST 13KV'	38	0.03795	-0.06686	72
KACP	MONTROSE 161KV'	27.81479	-0.02891	KACP	NORTHEAST 161KV'	35	0.03795	-0.06686	72
KACP	MONTROSE 161KV'	27.81479	-0.02891	KACP	NORTHEAST 161KV'	38	0.03795	-0.06686	72
KACP	MONTROSE 161KV'	27.81479	-0.02891	KACP	NORTHEAST 161KV'	27.89355	0.03795	-0.06686	72
MIPU	RALPH GREEN 69KV'	73.7	-0.11371	MIPU	SOUTH HARPER 161KV'	232.4752	-0.04893	-0.06478	75
KACP	MARSHALL 161KV'	39.1	-0.03666	KACP	IATAN 345KV'	396	0.0154	-0.05206	93

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1  
 Limiting Facility: BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1  
 Direction: To->From  
 Line Outage: ORRICK - RICHMOND 161KV CKT 1  
 Flowgate: 59205592351592445923611107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount	Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1032955		0.8			255.8	-0.18515	MIPU	'SIBLEY 161KV'	232.7943	0.19105	-0.3762	13
1034307		4.0			595	-0.14194	MIPU	'SIBLEY 161KV'	232.7943	0.19105	-0.33299	14
					255.8	-0.18515	MIPU	'SIBLEY 69KV'	45.99999	0.16339	-0.34854	14
					595	-0.14194	MIPU	'SIBLEY 69KV'	45.99999	0.16339	-0.30533	16
					255.8	-0.18515	MIPU	'LAKE ROAD 161KV'	35	0.03634	-0.22049	21
					255.8	-0.18515	MIPU	'LAKE ROAD 34KV'	92	0.03534	-0.22049	21
					595	-0.14194	MIPU	'LAKE ROAD 161KV'	35	0.03534	-0.17728	27
					595	-0.14194	MIPU	'LAKE ROAD 34KV'	92	0.03534	-0.17728	27
					255.8	-0.18515	MIPU	'SOUTH HARPER 161KV'	274.6863	-0.04884	-0.13631	35
					595	-0.14194	MIPU	'SOUTH HARPER 161KV'	274.6863	-0.04884	-0.0931	51
					20.3	-0.04529	MIPU	'LAKE ROAD 161KV'	35	0.03534	-0.08063	59
					20.3	-0.04529	MIPU	'LAKE ROAD 34KV'	92	0.03534	-0.08063	59
					39.1	-0.03669	KACP	'HAWTHORN 161KV'	455	0.04042	-0.07711	61
					39.1	-0.03669	KACP	'HAWTHORN 161KV'	314	0.04042	-0.07711	61
					39.1	-0.03669	KACP	'NORTHEAST 13KV'	36	0.03717	-0.07386	64
					39.1	-0.03669	KACP	'NORTHEAST 13KV'	36	0.03717	-0.07386	64
					39.1	-0.03669	KACP	'NORTHEAST 13KV'	38	0.03717	-0.07386	64
					39.1	-0.03669	KACP	'NORTHEAST 161KV'	35	0.03717	-0.07386	64
					39.1	-0.03669	KACP	'NORTHEAST 161KV'	38	0.03717	-0.07386	64
					39.1	-0.03669	KACP	'NORTHEAST 161KV'	32.55078	0.03717	-0.07386	64
					27.68605	-0.0288	KACP	'HAWTHORN 161KV'	455	0.04042	-0.06922	68
					27.68605	-0.0288	KACP	'HAWTHORN 161KV'	314	0.04042	-0.06922	68
					27.68605	-0.0288	KACP	'NORTHEAST 13KV'	36	0.03717	-0.06597	72
					27.68605	-0.0288	KACP	'NORTHEAST 13KV'	36	0.03717	-0.06597	72
					27.68605	-0.0288	KACP	'NORTHEAST 13KV'	38	0.03717	-0.06597	72
					27.68605	-0.0288	KACP	'NORTHEAST 161KV'	35	0.03717	-0.06597	72
					27.68605	-0.0288	KACP	'NORTHEAST 161KV'	38	0.03717	-0.06597	72
					27.68605	-0.0288	KACP	'NORTHEAST 161KV'	32.55078	0.03717	-0.06597	72
					73.7	-0.11364	MIPU	'SOUTH HARPER 161KV'	274.6863	-0.04884	-0.06468	73
					39.1	-0.03669	KACP	'IATAN 345KV'	396	0.01542	-0.05211	91

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1  
 Limiting Facility: BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1  
 Direction: To->From  
 Line Outage: PLEASANT HILL () 345/161/13.8KV TRANSFORMER CKT 1  
 Flowgate: 59205592351PHILL73751106SP  
 Date Redispatch Needed: 6/1/06 - 10/1/06  
 Season Flowgate Identified: 2006 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount	Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1032955		0.5			255.8	-0.2726	MIPU	'SIBLEY 161KV'	230.2336	0.15485	-0.42745	8
1034307		3.1			595	-0.24243	MIPU	'SIBLEY 161KV'	230.2336	0.15485	-0.39728	9
					255.8	-0.2726	MIPU	'SIBLEY 69KV'	45.99999	0.13272	-0.40532	9
					595	-0.24243	MIPU	'SIBLEY 69KV'	45.99999	0.13272	-0.37515	10
					73.7	-0.16187	MIPU	'SIBLEY 161KV'	230.2336	0.15485	-0.31672	11
					255.8	-0.2726	MIPU	'LAKE ROAD 161KV'	35	0.02878	-0.30138	12
					255.8	-0.2726	MIPU	'LAKE ROAD 34KV'	92	0.02878	-0.30138	12
					73.7	-0.16187	MIPU	'SIBLEY 69KV'	45.99999	0.13272	-0.29459	12
					595	-0.24243	MIPU	'LAKE ROAD 161KV'	35	0.02878	-0.27121	13
					595	-0.24243	MIPU	'LAKE ROAD 34KV'	92	0.02878	-0.27121	13
					255.8	-0.2726	MIPU	'SOUTH HARPER 161KV'	232.4752	-0.05024	-0.22236	16
					20.3	-0.06432	MIPU	'SIBLEY 161KV'	230.2336	0.15485	-0.21917	17
					20.3	-0.06432	MIPU	'SIBLEY 69KV'	45.99999	0.13272	-0.19704	18
					595	-0.24243	MIPU	'SOUTH HARPER 161KV'	232.4752	-0.05024	-0.19219	19
					73.7	-0.16187	MIPU	'LAKE ROAD 161KV'	35	0.02878	-0.19065	19
					73.7	-0.16187	MIPU	'LAKE ROAD 34KV'	92	0.02878	-0.19065	19
					73.7	-0.16187	MIPU	'SOUTH HARPER 161KV'	232.4752	-0.05024	-0.11163	32
					20.3	-0.06432	MIPU	'LAKE ROAD 161KV'	35	0.02878	-0.0931	39
					20.3	-0.06432	MIPU	'LAKE ROAD 34KV'	92	0.02878	-0.0931	39
					27.81479	-0.04268	KACP	'HAWTHORN 161KV'	455	0.03194	-0.07462	49

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

KACP	MONROSE 161KV'	27.81479	-0.04268	KACP	HAWTHORN 161KV'	314	0.03194	-0.07462	49
KACP	MONROSE 161KV'	27.81479	-0.04268	KACP	'NORTHEAST 13KV'	36	0.02881	-0.07149	51
KACP	MONROSE 161KV'	27.81479	-0.04268	KACP	'NORTHEAST 13KV'	36	0.02881	-0.07149	51
KACP	MONROSE 161KV'	27.81479	-0.04268	KACP	'NORTHEAST 161KV'	38	0.02881	-0.07149	51
KACP	MONROSE 161KV'	27.81479	-0.04268	KACP	'NORTHEAST 161KV'	35	0.02881	-0.07149	51
KACP	MONROSE 161KV'	27.81479	-0.04268	KACP	'NORTHEAST 161KV'	38	0.02881	-0.07149	51
KACP	MARSHALL 161KV'	39.1	-0.02274	KACP	'HAWTHORN 161KV'	27.89355	0.02881	-0.07149	51
KACP	MARSHALL 161KV'	39.1	-0.02274	KACP	'HAWTHORN 161KV'	455	0.03194	-0.05468	66
KACP	MARSHALL 161KV'	39.1	-0.02274	KACP	'HAWTHORN 161KV'	314	0.03194	-0.05468	66
KACP	MONROSE 161KV'	27.81479	-0.04268	KACP	'IATAN 345KV'	396	0.0114	-0.05408	67
KACP	MARSHALL 161KV'	39.1	-0.02274	KACP	'NORTHEAST 13KV'	36	0.02881	-0.05155	70
KACP	MARSHALL 161KV'	39.1	-0.02274	KACP	'NORTHEAST 13KV'	36	0.02881	-0.05155	70
KACP	MARSHALL 161KV'	39.1	-0.02274	KACP	'NORTHEAST 13KV'	38	0.02881	-0.05155	70
KACP	MARSHALL 161KV'	39.1	-0.02274	KACP	'NORTHEAST 161KV'	35	0.02881	-0.05155	70
KACP	MARSHALL 161KV'	39.1	-0.02274	KACP	'NORTHEAST 161KV'	38	0.02881	-0.05155	70
KACP	MARSHALL 161KV'	39.1	-0.02274	KACP	'NORTHEAST 161KV'	27.89355	0.02881	-0.05155	70
KACP	MARSHALL 161KV'	39.1	-0.02274	KACP	'IATAN 345KV'	396	0.0114	-0.03414	106

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1

Limiting Facility: BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1

Direction: To->From

Line Outage: PLEASANT HILL () 345/161/13.8KV TRANSFORMER CKT 1

Flowgate: 59205592351PHILL73751107SP

Date Redispatch Needed: 6/1/07 - 10/1/07

Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount		Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
		0.5	0.5						
1032955				Source Control Area	Source	Maximum Increment(MW)	GSF		
MIPU	'ARIES 161KV'	595	-0.24241	MIPU	'SIBLEY 161KV'	232.7943	0.15465	-0.39706	1
MIPU	'ARIES 161KV'	595	-0.24241	MIPU	'SIBLEY 69KV'	45.99999	0.1325	-0.37491	1
MIPU	'GREENWOOD 161KV'	255.8	-0.2726	MIPU	'SIBLEY 161KV'	232.7943	0.15465	-0.42725	1
MIPU	'GREENWOOD 161KV'	255.8	-0.2726	MIPU	'SIBLEY 69KV'	45.99999	0.1325	-0.4051	1
MIPU	'ARIES 161KV'	595	-0.24241	MIPU	'LAKE ROAD 161KV'	35	0.02858	-0.27099	2
MIPU	'ARIES 161KV'	595	-0.24241	MIPU	'LAKE ROAD 34KV'	92	0.02858	-0.27099	2
MIPU	'GREENWOOD 161KV'	255.8	-0.2726	MIPU	'LAKE ROAD 161KV'	35	0.02858	-0.30118	2
MIPU	'GREENWOOD 161KV'	255.8	-0.2726	MIPU	'LAKE ROAD 34KV'	92	0.02858	-0.30118	2
MIPU	'GREENWOOD 161KV'	255.8	-0.2726	MIPU	'SOUTH HARPER 161KV'	274.6863	-0.05019	-0.22241	2
MIPU	'RALPH GREEN 69KV'	73.7	-0.16184	MIPU	'SIBLEY 161KV'	232.7943	0.15465	-0.31649	2
MIPU	'RALPH GREEN 69KV'	73.7	-0.16184	MIPU	'SIBLEY 69KV'	45.99999	0.1325	-0.29434	2
MIPU	'ARIES 161KV'	595	-0.24241	MIPU	'SOUTH HARPER 161KV'	274.6863	-0.05019	-0.19222	3
MIPU	'RALPH GREEN 69KV'	73.7	-0.16184	MIPU	'LAKE ROAD 161KV'	35	0.02858	-0.19042	3
MIPU	'RALPH GREEN 69KV'	73.7	-0.16184	MIPU	'LAKE ROAD 34KV'	92	0.02858	-0.19042	3
MIPU	'RALPH GREEN 69KV'	73.7	-0.16184	MIPU	'SOUTH HARPER 161KV'	274.6863	-0.05019	-0.11165	4
MIPU	'NEVADA 69KV'	20.3	-0.06403	MIPU	'LAKE ROAD 161KV'	35	0.02858	-0.09261	5
MIPU	'NEVADA 69KV'	20.3	-0.06403	MIPU	'LAKE ROAD 34KV'	92	0.02858	-0.09261	5
KACP	'MONROSE 161KV'	27.68605	-0.0426	KACP	'HAWTHORN 161KV'	455	0.03149	-0.07409	7
KACP	'MONROSE 161KV'	27.68605	-0.0426	KACP	'HAWTHORN 161KV'	314	0.03149	-0.07409	7
KACP	'MONROSE 161KV'	27.68605	-0.0426	KACP	'NORTHEAST 13KV'	36	0.02805	-0.07065	7
KACP	'MONROSE 161KV'	27.68605	-0.0426	KACP	'NORTHEAST 13KV'	36	0.02805	-0.07065	7
KACP	'MONROSE 161KV'	27.68605	-0.0426	KACP	'NORTHEAST 161KV'	38	0.02805	-0.07065	7
KACP	'MONROSE 161KV'	27.68605	-0.0426	KACP	'NORTHEAST 161KV'	38	0.02805	-0.07065	7
KACP	'MONROSE 161KV'	27.68605	-0.0426	KACP	'NORTHEAST 161KV'	32.55078	0.02805	-0.07065	7
KACP	'MONROSE 161KV'	27.68605	-0.0426	KACP	'NORTHEAST 161KV'	455	0.03149	-0.0544	9
KACP	'MARSHALL 161KV'	39.1	-0.0229	KACP	'HAWTHORN 161KV'	314	0.03149	-0.0544	9
KACP	'MARSHALL 161KV'	39.1	-0.0229	KACP	'HAWTHORN 161KV'	396	0.01139	-0.05399	9
KACP	'MONROSE 161KV'	27.68605	-0.0426	KACP	'IATAN 345KV'	36	0.02805	-0.05096	10
KACP	'MARSHALL 161KV'	39.1	-0.02291	KACP	'NORTHEAST 13KV'	36	0.02805	-0.05096	10
KACP	'MARSHALL 161KV'	39.1	-0.02291	KACP	'NORTHEAST 13KV'	38	0.02805	-0.05096	10
KACP	'MARSHALL 161KV'	39.1	-0.02291	KACP	'NORTHEAST 161KV'	35	0.02805	-0.05096	10
KACP	'MARSHALL 161KV'	39.1	-0.02291	KACP	'NORTHEAST 161KV'	38	0.02805	-0.05096	10
KACP	'MARSHALL 161KV'	39.1	-0.02291	KACP	'NORTHEAST 161KV'	32.55078	0.02805	-0.05096	10
SWPA	'STOCKTON 161KV'	7.900002	-0.03235	SWPA	'CLARENCE CANNON DAM 69KV'	39.2	0.00498	-0.03733	13
KACP	'MARSHALL 161KV'	39.1	-0.02291	KACP	'IATAN 345KV'	396	0.01139	-0.0343	14
KACP	'MARSHALL 161KV'	39.1	-0.02291	KACP	'IATAN 345KV'	235	-0.00028	-0.03207	15
KACP	'MONROSE 161KV'	27.68605	-0.0426	KACP	'BULL CREEK 161KV'	308	-0.00865	-0.03395	14
SWPA	'STOCKTON 161KV'	7.900002	-0.03235	SWPA	'SIKESTON 161KV'	958	-0.01131	-0.03129	16
KACP	'MONROSE 161KV'	27.68605	-0.0426	KACP	'LACYGNE UNIT 345KV'	63	-0.00167	-0.03068	16
SWPA	'STOCKTON 161KV'	7.900002	-0.03235	SWPA	'JONESBORO 161KV'	7.2	-0.00098	-0.03137	16
SWPA	'STOCKTON 161KV'	7.900002	-0.03235	SWPA	'KENNETT 69KV'	7	-0.00075	-0.0316	16
SWPA	'STOCKTON 161KV'	7.900002	-0.03235	SWPA	'MALDEN 69KV'	5.5	-0.00138	-0.03097	16
SWPA	'STOCKTON 161KV'	7.900002	-0.03235	SWPA	'PARAGOULD 69KV'	6	-0.00092	-0.03143	16

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC

Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1

Direction: From->To

Line Outage: WOODWARD - WOODWARD 69KV CKT 1

Flowgate: 55785559991547825609611106FA

Date Redispatch Needed: 10/1/06 - 12/1/06

Season Flowgate Identified: 2006 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount		Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
		31.1	31.1						
1032973				Source Control Area	Source	Maximum Increment(MW)	GSF		
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	'HORSESHOE LAKE 138KV'	91	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	'HORSESHOE LAKE 138KV'	380	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	'HORSESHOE LAKE 69KV'	16	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	'HORSESHOE LAKE 69KV'	16	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	MCCLELLAN 138KV'	42	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	MCCLELLAN 138KV'	42	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	MUSKOGEE 161KV'	166	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	MUSKOGEE 161KV'	31	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	MUSKOGEE 161KV'	31	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	MUSKOGEE 161KV'	166	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	MUSKOGEE 345KV'	20	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	MUSKOGEE 345KV'	20	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	MUSTANG 138KV'	365.5	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	MUSTANG 138KV'	365.5	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	MUSTANG 69KV'	106	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	MUSTANG 69KV'	106	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	ONE OAK 345KV'	236	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	ONE OAK 345KV'	236	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	REDBUD 345KV'	421.65	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	REDBUD 345KV'	900	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	REDBUD 345KV'	421.65	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	REDBUD 345KV'	900	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	SEMINOLE 138KV'	262.1816	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	SEMINOLE 138KV'	262.1816	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	SEMINOLE 345KV'	507.6	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	SEMINOLE 345KV'	507.6	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	SOONER 138KV'	24.99997	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	SOONER 138KV'	24.99997	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	SOUTH 4TH ST 69KV'	42.7	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	SOUTH 4TH ST 69KV'	42.7	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31
OKGE	TINKER 5G 138KV'	62	0	OKGE	'FPLWND2 34KV'	102	1	-1	31
OKGE	TINKER 5G 138KV'	62	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	31

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: WOODWARD - WOODWARD 69KV CKT 1  
 Flowgate: 55785559991547825609611106SH  
 Date Redispatch Needed: 6/1/06 - 10/1/06  
 Season Flowgate Identified: 2006 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount								
1032973		20.5	20.5							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'HORSESHEOE LAKE 138KV'	91	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'HORSESHEOE LAKE 138KV'	380.5	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'HORSESHEOE LAKE 138KV'	380	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'HORSESHEOE LAKE 138KV'	380	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'HORSESHEOE LAKE 138KV'	380	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'HORSESHEOE LAKE 138KV'	380.5	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'HORSESHEOE LAKE 138KV'	91	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'HORSESHEOE LAKE 69KV'	16	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'HORSESHEOE LAKE 69KV'	16	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'MCCLAIN 138KV'	42	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'MCCLAIN 138KV'	42	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'MUSKOGEE 161KV'	31	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'MUSKOGEE 161KV'	166	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'MUSKOGEE 161KV'	166	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'MUSKOGEE 161KV'	31	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'MUSKOGEE 345KV'	20	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'MUSKOGEE 345KV'	20	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'MUSTANG 138KV'	365.5	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'MUSTANG 138KV'	365.5	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'MUSTANG 69KV'	106	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'MUSTANG 69KV'	106	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'ONE OAK 345KV'	236	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'ONE OAK 345KV'	236	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'REDBUD 345KV'	460	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'SEMINOLE 138KV'	47.215	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'SEMINOLE 138KV'	47.215	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'SEMINOLE 345KV'	406.08	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'SEMINOLE 345KV'	406.08	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'SOONER 138KV'	24.99997	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'SOONER 138KV'	24.99997	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'SOUTH 4TH ST 69KV'	42.7	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'SOUTH 4TH ST 69KV'	42.7	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	
OKGE	'TINKER 5G 138KV'	62	0	OKGE	'FPLWND2 34KV'	102	1	-1	21	
OKGE	'TINKER 5G 138KV'	62	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	21	

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: WOODWARD - WOODWARD 69KV CKT 1  
 Flowgate: 55785559991547825609611306SP  
 Date Redispatch Needed: 6/1/06 - 10/1/06  
 Season Flowgate Identified: 2006 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount								
1032973		11.5	11.5							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	12	
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	12	
OKGE	'HORSESHEOE LAKE 138KV'	380.5	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	12	
OKGE	'HORSESHEOE LAKE 138KV'	337.7	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	12	
OKGE	'HORSESHEOE LAKE 138KV'	380.5	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	12	

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	HORSESHOE LAKE 138KV	337.7	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	12
OKGE	MCCLAIN 138KV'	42	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	12
OKGE	MCCLAIN 138KV'	42	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	12
OKGE	MUSKOGEE 161KV'	31	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	12
OKGE	MUSKOGEE 161KV'	166	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	12
OKGE	MUSKOGEE 161KV'	31	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	12
OKGE	MUSKOGEE 161KV'	166	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	12
OKGE	MUSTANG 138KV	147.3059	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	12
OKGE	MUSTANG 138KV	147.3059	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	12
OKGE	'ONE OAK 345KV'	204	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	12
OKGE	'ONE OAK 345KV'	204	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	12
OKGE	'REDBUD 345KV'	460	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	12
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	12
OKGE	'REDBUD 345KV'	460	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	12
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	12
OKGE	SEMINOLE 138KV'	17.47644	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	12
OKGE	SEMINOLE 138KV'	17.47644	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	12
OKGE	SOONER 138KV'	24.99997	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	12
OKGE	SOONER 138KV'	24.99997	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	12
OKGE	SOUTH 4TH ST 69KV'	42.7	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	12
OKGE	SOUTH 4TH ST 69KV'	42.7	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	12
OKGE	TINKER 5G 138KV'	62	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	12
OKGE	TINKER 5G 138KV'	62	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	12

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: DEWEY - IODINE 138KV CKT 1  
 Flowgate: 55785559991547875479611107AP  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 April Minimum

Reservation	Relief Amount	Aggregate Relief Amount							
1023236	1.4	32.4							
1032973	31.0	32.4							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'AES 161KV'	160	0.00003	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97306	33
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97287	33
OKGE	HORSESHOE LAKE 138KV'	380	0.00022	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97287	33
OKGE	HORSESHOE LAKE 69KV'	91	0.00022	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97287	33
OKGE	HORSESHOE LAKE 69KV'	16	0.00021	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97288	33
OKGE	MCCLAIN 138KV'	520	0.00036	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97273	33
OKGE	MUSKOGEE 161KV'	166	0.00004	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97305	33
OKGE	MUSKOGEE 161KV'	31	0.00004	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97305	33
OKGE	MUSKOGEE 345KV'	717.4685	0.00005	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97304	33
OKGE	MUSTANG 138KV'	365.5	0.00036	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97273	33
OKGE	MUSTANG 69KV'	106	0.00004	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97269	33
OKGE	'ONE OAK 345KV'	236	0.00012	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97297	33
OKGE	'REDBUD 345KV'	421.65	0.00014	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97295	33
OKGE	'REDBUD 345KV'	900	0.00014	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97295	33
OKGE	SEMINOLE 138KV'	508.3745	0.00019	OKGE	'FPLWND2 34KV'	102	0.97309	-0.9729	33
OKGE	SEMINOLE 345KV'	996.6	0.00019	OKGE	'FPLWND2 34KV'	102	0.97309	-0.9729	33
OKGE	SMITH COGEN 138KV'	110	0.00034	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97275	33
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	'FPLWND2 34KV'	102	0.97309	-0.9734	33
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97471	33
OKGE	TINKER 5G 138KV'	62	0.00025	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97284	33
OKGE	'AES 161KV'	160	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	40
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	40
OKGE	HORSESHOE LAKE 138KV'	380	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	40
OKGE	HORSESHOE LAKE 138KV'	91	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	40
OKGE	MCCLAIN 138KV'	16	0.00021	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81237	40
OKGE	MUSKOGEE 161KV'	520	0.00036	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81222	40
OKGE	MUSKOGEE 161KV'	31	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81254	40
OKGE	MUSKOGEE 161KV'	166	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81254	40
OKGE	MUSKOGEE 345KV'	717.4685	0.00005	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81253	40
OKGE	MUSTANG 138KV'	365.5	0.00036	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81222	40
OKGE	MUSTANG 69KV'	106	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81218	40
OKGE	'ONE OAK 345KV'	236	0.00012	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81246	40
OKGE	'REDBUD 345KV'	900	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	40
OKGE	'REDBUD 345KV'	421.65	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	40
OKGE	'SEMINOLE 138KV'	508.3745	0.00019	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81239	40
OKGE	SEMINOLE 345KV'	996.6	0.00019	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81239	40
OKGE	'SMITH COGEN 138KV'	110	0.00034	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81224	40
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81289	40
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8142	40
OKGE	TINKER 5G 138KV'	62	0.00025	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81233	40

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Reservation	Relief Amount	Aggregate Relief Amount							
1023236	0.7	15.7							
1032973	15.0	15.7							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'AES 161KV'	40	0.00003	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97306	16
OKGE	HORSESHOE LAKE 138KV'	91	0.00022	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97287	16
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97287	16
OKGE	HORSESHOE LAKE 138KV'	380	0.00022	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97287	16
OKGE	HORSESHOE LAKE 69KV'	16	0.00022	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97287	16
OKGE	MCCLAIN 138KV'	42	0.00034	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97275	16

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	MUSKOGEE 161KV'	166	0.00003	OKGE	FPLWND2 34KV'	101.9988	0.97309	-0.97306	16
OKGE	MUSKOGEE 161KV'	31	0.00003	OKGE	FPLWND2 34KV'	101.9988	0.97309	-0.97306	16
OKGE	MUSKOGEE 345KV'	20	0.00005	OKGE	FPLWND2 34KV'	101.9988	0.97309	-0.97304	16
OKGE	MUSTANG 138KV'	365.5	0.00036	OKGE	FPLWND2 34KV'	101.9988	0.97309	-0.97273	16
OKGE	MUSTANG 69KV'	106	0.00041	OKGE	FPLWND2 34KV'	101.9988	0.97309	-0.97268	16
OKGE	ONE OAK 345KV'	236	0.00012	OKGE	FPLWND2 34KV'	101.9988	0.97309	-0.97297	16
OKGE	REDBUD 345KV'	900	0.00014	OKGE	FPLWND2 34KV'	101.9988	0.97309	-0.97295	16
OKGE	REDBUD 345KV'	421.65	0.00014	OKGE	FPLWND2 34KV'	101.9988	0.97309	-0.97295	16
OKGE	SEMINOLE 138KV'	401.2314	0.00019	OKGE	FPLWND2 34KV'	101.9988	0.97309	-0.9729	16
OKGE	SEMINOLE 345KV'	608.1636	0.00019	OKGE	FPLWND2 34KV'	101.9988	0.97309	-0.9729	16
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	FPLWND2 34KV'	101.9988	0.97309	-0.9734	16
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	FPLWND2 34KV'	101.9988	0.97309	-0.97471	16
OKGE	TINKER 5G 138KV'	62	0.00025	OKGE	FPLWND2 34KV'	101.9988	0.97309	-0.97284	16
OKGE	AES 161KV'	40	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	19
OKGE	HORSESHOE LAKE 138KV'	380	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	19
OKGE	HORSESHOE LAKE 138KV'	91	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	19
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	19
OKGE	HORSESHOE LAKE 69KV'	106	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81217	19
OKGE	HORSESHOE LAKE 69KV'	16	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	19
OKGE	MCCLAIN 138KV'	42	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81224	19
OKGE	MUSKOGEE 161KV'	166	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	19
OKGE	MUSKOGEE 161KV'	31	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	19
OKGE	MUSKOGEE 345KV'	20	0.00005	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81239	19
OKGE	MUSTANG 138KV'	365.5	0.00036	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81239	19
OKGE	MUSTANG 69KV'	106	0.0004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81239	19
OKGE	ONE OAK 345KV'	336	0.00012	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.97297	9
OKGE	REDBUD 345KV'	421.65	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.97295	9
OKGE	REDBUD 345KV'	900	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.97295	9
OKGE	SEMINOLE 138KV'	395.2155	0.00019	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.9729	9
OKGE	SEMINOLE 345KV'	558.5093	0.00019	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.9729	9
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.9734	9
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.97471	9
OKGE	TINKER 5G 138KV'	62	0.00025	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.97284	9
OKGE	AES 161KV'	10	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	11
OKGE	CONTINENTAL EMPIRE 138KV'	63	-0.00045	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81303	11
OKGE	HORSESHOE LAKE 138KV'	380	0.00023	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81235	11
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00023	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81235	11
OKGE	HORSESHOE LAKE 69KV'	91	0.00023	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81235	11
OKGE	MCCLAIN 138KV'	16	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	11
OKGE	MUSKOGEE 161KV'	42	0.00036	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81222	11
OKGE	MUSKOGEE 161KV'	166	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81254	11
OKGE	MUSKOGEE 345KV'	20	0.00005	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81253	11
OKGE	MUSTANG 138KV'	365.5	0.00036	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81222	11
OKGE	MUSTANG 69KV'	106	0.0004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81218	11
OKGE	ONE OAK 345KV'	336	0.00012	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81246	11
OKGE	REDBUD 345KV'	421.65	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	11
OKGE	REDBUD 345KV'	900	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	11
OKGE	SEMINOLE 138KV'	395.2155	0.00019	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81239	11
OKGE	SEMINOLE 345KV'	558.5093	0.00019	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81239	11
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.97289	11
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8142	11
OKGE	TINKER 5G 138KV'	62	0.00025	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81233	11
WFEC	MORLND 138KV'	166.1695	-0.02454	WFEC	'SLEEPING BEAR 138KV'	80	0.05339	-0.07793	110

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC

Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1

Direction: From->To

Line Outage: DEWEY - IODINE 138KV CKT 1

Flowgate: 5578555999154785479611207FA

Date Redispatch Needed: 12/1/06 - 4/1/07

Season Flowgate Identified: 2006 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1023236	0.4	8.6							
1032973	8.2	8.6							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	AES 161KV'	10	0.00003	OKGE	FPLWND2 34KV'	102	0.97309	-0.97306	9
OKGE	'CONTINENTAL EMPIRE 138KV'	63	-0.00045	OKGE	FPLWND2 34KV'	102	0.97309	-0.97354	9
OKGE	HORSESHOE LAKE 138KV'	380	0.00023	OKGE	FPLWND2 34KV'	102	0.97309	-0.97286	9
OKGE	HORSESHOE LAKE 138KV'	91	0.00023	OKGE	FPLWND2 34KV'	102	0.97309	-0.97286	9
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00023	OKGE	FPLWND2 34KV'	102	0.97309	-0.97286	9
OKGE	HORSESHOE LAKE 69KV'	16	0.00022	OKGE	FPLWND2 34KV'	102	0.97309	-0.97287	9
OKGE	MCCLAIN 138KV'	42	0.00036	OKGE	FPLWND2 34KV'	102	0.97309	-0.97273	9
OKGE	MUSKOGEE 161KV'	31	0.00004	OKGE	FPLWND2 34KV'	102	0.97309	-0.97305	9
OKGE	MUSKOGEE 161KV'	166	0.00004	OKGE	FPLWND2 34KV'	102	0.97309	-0.97305	9
OKGE	MUSKOGEE 345KV'	20	0.00005	OKGE	FPLWND2 34KV'	102	0.97309	-0.97304	9
OKGE	MUSTANG 138KV'	365.5	0.00036	OKGE	FPLWND2 34KV'	102	0.97309	-0.97273	9
OKGE	MUSTANG 69KV'	106	0.0004	OKGE	FPLWND2 34KV'	102	0.97309	-0.97269	9
OKGE	ONE OAK 345KV'	336	0.00012	OKGE	FPLWND2 34KV'	102	0.97309	-0.97297	9
OKGE	REDBUD 345KV'	421.65	0.00014	OKGE	FPLWND2 34KV'	102	0.97309	-0.97295	9
OKGE	REDBUD 345KV'	900	0.00014	OKGE	FPLWND2 34KV'	102	0.97309	-0.97295	9
OKGE	SEMINOLE 138KV'	395.2155	0.00019	OKGE	FPLWND2 34KV'	102	0.97309	-0.9729	9
OKGE	SEMINOLE 345KV'	558.5093	0.00019	OKGE	FPLWND2 34KV'	102	0.97309	-0.9729	9
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	FPLWND2 34KV'	102	0.97309	-0.9734	9
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	FPLWND2 34KV'	102	0.97309	-0.97471	9
OKGE	TINKER 5G 138KV'	62	0.00025	OKGE	FPLWND2 34KV'	102	0.97309	-0.97284	9
OKGE	AES 161KV'	10	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	11
OKGE	CONTINENTAL EMPIRE 138KV'	63	-0.00045	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81303	11
OKGE	HORSESHOE LAKE 138KV'	380	0.00023	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81235	11
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00023	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81235	11
OKGE	HORSESHOE LAKE 69KV'	91	0.00023	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81235	11
OKGE	MCCLAIN 138KV'	16	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	11
OKGE	MUSKOGEE 161KV'	42	0.00036	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81222	11
OKGE	MUSKOGEE 161KV'	166	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81254	11
OKGE	MUSKOGEE 345KV'	20	0.00005	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81253	11
OKGE	MUSTANG 138KV'	365.5	0.00036	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81222	11
OKGE	MUSTANG 69KV'	106	0.0004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81218	11
OKGE	ONE OAK 345KV'	336	0.00012	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81246	11
OKGE	REDBUD 345KV'	421.65	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	11
OKGE	REDBUD 345KV'	900	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	11
OKGE	SEMINOLE 138KV'	395.2155	0.00019	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81239	11
OKGE	SEMINOLE 345KV'	558.5093	0.00019	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81239	11
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.97289	11
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8142	11
OKGE	TINKER 5G 138KV'	62	0.00025	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81233	11
WFEC	MORLND 138KV'	166.1695	-0.02454	WFEC	'SLEEPING BEAR 138KV'	80	0.05339	-0.07793	110

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Source		Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1023236		0.4	10.6						
1032973		10.2	10.6						
Source Control Area	Source								
OKGE	'CONTINENTAL EMPIRE 138KV'	64	-0.00045	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97353	11
OKGE	'HORSESHOE LAKE 138KV'	91	0.00022	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97286	11
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97286	11
OKGE	'HORSESHOE LAKE 138KV'	380	0.00022	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97286	11
OKGE	'HORSESHOE LAKE 69KV'	16	0.00021	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97287	11
OKGE	'MCCLAIN 138KV'	42	0.00034	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97274	11
OKGE	'MUSKOGEE 161KV'	31	0.00003	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97305	11
OKGE	'MUSKOGEE 161KV'	166	0.00003	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97305	11
OKGE	'MUSKOGEE 345KV'	20	0.00004	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97304	11
OKGE	'MUSTANG 138KV'	365.5	0.00035	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97273	11
OKGE	'MUSTANG 69KV'	106	0.00004	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97268	11
OKGE	'ONE OAK 345KV'	323	0.00013	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97295	11
OKGE	'REDBUD 345KV'	900	0.00014	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97294	11
OKGE	'REDBUD 345KV'	421.65	0.00014	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97294	11
OKGE	'SEMINOLE 138KV'	34.42731	0.00018	OKGE	'FPLWND2 34KV'	102	0.97308	-0.9729	11
OKGE	'SEMINOLE 345KV'	507.6	0.00018	OKGE	'FPLWND2 34KV'	102	0.97308	-0.9729	11
OKGE	'SMITH COGEN 138KV'	110	0.00034	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97274	11
OKGE	'SOONER 138KV'	24.99997	-0.00031	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97339	11
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'FPLWND2 34KV'	102	0.97308	-0.9747	11
OKGE	'TINKER 5G 138KV'	62	0.00024	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	13
OKGE	'TINKER 5G 138KV'	62	0.00024	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	13
OKGE	'MUSKOGEE 161KV'	166	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	13
OKGE	'MUSKOGEE 161KV'	31	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	13
OKGE	'MUSKOGEE 345KV'	20	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81254	13
OKGE	'MUSTANG 138KV'	365.5	0.00035	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81223	13
OKGE	'MUSTANG 69KV'	106	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81218	13
OKGE	'ONE OAK 345KV'	323	0.00013	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81245	13
OKGE	'REDBUD 345KV'	421.65	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	13
OKGE	'REDBUD 345KV'	900	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	13
OKGE	'SEMINOLE 138KV'	34.42731	0.00018	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8124	13
OKGE	'SEMINOLE 345KV'	507.6	0.00018	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8124	13
OKGE	'SMITH COGEN 138KV'	110	0.00034	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81224	13
OKGE	'SOONER 138KV'	24.99997	-0.00031	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81289	13
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8142	13
OKGE	'TINKER 5G 138KV'	62	0.00024	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81234	13
WFEC	'MORLND 138KV'	320	-0.02454	WFEC	'SLEEPING BEAR 138KV'	80	0.05338	-0.07792	136

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: DEWEY - IODINE 138KV CKT 1  
 Flowgate: 55785559991547875479611207SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount		Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
		1023236	0.1						
		1032973	0.6						
Source Control Area	Source	Maximum Increment(MW)	GSF						
OKGE	'HORSESHOE LAKE 138KV'	380	0.00022	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97287	1
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97287	1
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	1
OKGE	'HORSESHOE LAKE 138KV'	380	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	1
OKGE	'MCCLAIN 138KV'	42	0.00034	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97275	1
OKGE	'MUSKOGEE 161KV'	166	0.00003	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97306	1
OKGE	'MUSKOGEE 161KV'	31	0.00003	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97306	1
OKGE	'MUSKOGEE 161KV'	166	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	1
OKGE	'MUSKOGEE 161KV'	31	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	1
OKGE	'MUSKOGEE 345KV'	20	0.00004	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97305	1
OKGE	'MUSKOGEE 345KV'	20	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81254	1
OKGE	'MUSTANG 138KV'	365.5	0.00035	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97274	1
OKGE	'MUSTANG 138KV'	365.5	0.00035	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81223	1
OKGE	'MUSTANG 69KV'	57,46093	0.0004	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97269	1
OKGE	'MUSTANG 69KV'	57,46093	0.0004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81218	1
OKGE	'ONE OAK 345KV'	274	0.00013	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97296	1
OKGE	'ONE OAK 345KV'	274	0.00013	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81245	1
OKGE	'REDBUD 345KV'	900	0.00014	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97295	1
OKGE	'REDBUD 345KV'	421.65	0.00014	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97295	1
OKGE	'REDBUD 345KV'	421.65	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	1
OKGE	'REDBUD 345KV'	900	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	1
OKGE	'SEMINOLE 138KV'	20,90036	0.00018	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97291	1
OKGE	'SEMINOLE 138KV'	20,90036	0.00018	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81214	1
OKGE	'SOONER 138KV'	24.99997	-0.00031	OKGE	'FPLWND2 34KV'	102	0.97309	-0.9734	1
OKGE	'SOONER 138KV'	24.99997	-0.00031	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81289	1
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97471	1
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8142	1
OKGE	'TINKER 5G 138KV'	62	0.00024	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97285	1
OKGE	'TINKER 5G 138KV'	62	0.00024	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81234	1
OKGE	'WOODWARD 24KV'	9.3	0.81258	OKGE	'FPLWND2 34KV'	102	0.97309	-0.16051	4
WFEC	'MORLND 138KV'	173,8576	-0.02454	WFEC	'SLEEPING BEAR 138KV'	80	0.05338	-0.07792	8

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: DEWEY - IODINE 138KV CKT 1  
 Flowgate: 55785559991547875479611207WP

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1023236		0.3		7.8					
1032973		7.5		7.8					
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'AES_161KV'	78.99999	0.00003	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97305	8
OKGE	'HORSESHOE LAKE 138KV'	91	0.00022	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97286	8
OKGE	'HORSESHOE LAKE 138KV'	380	0.00022	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97286	8
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97286	8
OKGE	'HORSESHOE LAKE 69KV'	16	0.00021	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97287	8
OKGE	'MCCLAIN 138KV'	42	0.00034	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97274	8
OKGE	'MUSKOGEE 161KV'	31	0.00003	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97305	8
OKGE	'MUSKOGEE 161KV'	166	0.00003	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97305	8
OKGE	'MUSKOGEE 345KV'	20	0.00004	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97304	8
OKGE	'MUSTANG 138KV'	365.5	0.00035	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97273	8
OKGE	'MUSTANG 69KV'	106	0.00004	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97268	8
OKGE	'ONE OAK 345KV'	319	0.00012	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97296	8
OKGE	'REDBUD 345KV'	900	0.00014	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97294	8
OKGE	'REDBUD 345KV'	421.65	0.00014	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97294	8
OKGE	'SEMINOLE 138KV'	309.6299	0.00018	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.9729	8
OKGE	'SEMINOLE 345KV'	507.6	0.00018	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.9729	8
OKGE	'SOONER 138KV'	24.99997	-0.00031	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97339	8
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.9747	8
OKGE	'TINKER 5G 138KV'	62	0.00024	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97284	8
OKGE	'AES_161KV'	78.99999	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	10
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	10
OKGE	'HORSESHOE LAKE 138KV'	91	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	10
OKGE	'HORSESHOE LAKE 69KV'	380	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	10
OKGE	'MCCLAIN 138KV'	16	0.00021	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81237	10
OKGE	'MCCLAIN 161KV'	42	0.00034	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81224	10
OKGE	'MUSKOGEE 161KV'	31	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	10
OKGE	'MUSKOGEE 161KV'	166	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	10
OKGE	'MUSKOGEE 345KV'	20	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81254	10
OKGE	'MUSTANG 138KV'	365.5	0.00035	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81223	10
OKGE	'MUSTANG 69KV'	106	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81218	10
OKGE	'ONE OAK 345KV'	319	0.00012	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81246	10
OKGE	'REDBUD 345KV'	421.65	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	10
OKGE	'REDBUD 345KV'	900	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	10
OKGE	'SEMINOLE 138KV'	309.6299	0.00018	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8124	10
OKGE	'SEMINOLE 345KV'	507.6	0.00018	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8124	10
OKGE	'SOONER 138KV'	24.99997	-0.00031	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81289	10
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8142	10
OKGE	'TINKER 5G 138KV'	62	0.00024	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81234	10
WFEC	'MORLND 138KV'	148.9085	-0.02454	WFEC	'SLEEPING BEAR 138KV'	80	0.05338	-0.07792	101

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: IODINE - WOODWARD 138KV CKT 1  
 Flowgate: 55785559391547965478511107AP  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 April Minimum

Reservation	Relief Amount	Aggregate Relief Amount							
1023236		1.4		34.3					
1032973		32.8		34.3					
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'AES_161KV'	160	0.00003	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97306	35
OKGE	'HORSESHOE LAKE 138KV'	91	0.00022	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97287	35
OKGE	'HORSESHOE LAKE 138KV'	380	0.00022	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97287	35
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97287	35
OKGE	'HORSESHOE LAKE 69KV'	16	0.00021	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97288	35
OKGE	'MCCLAIN 138KV'	520	0.00036	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97273	35
OKGE	'MUSKOGEE 161KV'	166	0.00004	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97305	35
OKGE	'MUSKOGEE 161KV'	31	0.00004	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97305	35
OKGE	'MUSKOGEE 345KV'	717.4685	0.00005	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97304	35
OKGE	'MUSTANG 138KV'	365.5	0.00036	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97273	35
OKGE	'MUSTANG 69KV'	106	0.00004	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97269	35
OKGE	'ONE OAK 345KV'	236	0.00012	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97297	35
OKGE	'REDBUD 345KV'	421.65	0.00014	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97295	35
OKGE	'REDBUD 345KV'	900	0.00014	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97295	35
OKGE	'SEMINOLE 138KV'	508.3745	0.00019	OKGE	'FPLWND2 34KV'	102	0.97309	-0.9729	35
OKGE	'SEMINOLE 345KV'	996.6	0.00019	OKGE	'FPLWND2 34KV'	102	0.97309	-0.9729	35
OKGE	'SMITH COGEN 138KV'	110	0.00034	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97275	35
OKGE	'SOONER 138KV'	24.99997	-0.00031	OKGE	'FPLWND2 34KV'	102	0.97309	-0.9734	35
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97471	35
OKGE	'TINKER 5G 138KV'	62	0.00025	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97284	35
OKGE	'AES_161KV'	160	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	42
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	42
OKGE	'HORSESHOE LAKE 138KV'	91	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	42
OKGE	'HORSESHOE LAKE 138KV'	380	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	42
OKGE	'HORSESHOE LAKE 69KV'	16	0.00021	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81237	42
OKGE	'MCCLAIN 138KV'	520	0.00036	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81222	42
OKGE	'MUSKOGEE 161KV'	31	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81254	42
OKGE	'MUSKOGEE 161KV'	166	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81254	42
OKGE	'MUSKOGEE 345KV'	717.4685	0.00005	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81253	42
OKGE	'MUSTANG 138KV'	365.5	0.00036	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81222	42
OKGE	'MUSTANG 69KV'	106	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81218	42
OKGE	'ONE OAK 345KV'	236	0.00012	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81246	42
OKGE	'REDBUD 345KV'	900	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	42
OKGE	'REDBUD 345KV'	421.65	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	42
OKGE	'SEMINOLE 138KV'	508.3745	0.00019	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81239	42
OKGE	'SEMINOLE 345KV'	996.6	0.00019	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81239	42
OKGE	'SMITH COGEN 138KV'	110	0.00034	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81224	42
OKGE	'SOONER 138KV'	24.99997	-0.00031	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81289	42
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8142	42
OKGE	'TINKER 5G 138KV'	62	0.00025	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81233	42

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.  
 Factor = Source GSF - Sink GSF  
 Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: IODINE - WOODWARD 138KV CKT 1  
 Flowgate: 55785559991547965478511107FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount						
1023236	0.6	13.9						
1032973	13.3	13.9						
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor
OKGE	'CONTINENTAL EMPIRE 138KV'	64	-0.00045	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97353
OKGE	'HORSESHOE LAKE 138KV'	91	0.00022	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97286
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97286
OKGE	'HORSESHOE LAKE 138KV'	380	0.00022	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97286
OKGE	'HORSESHOE LAKE 69KV'	16	0.00021	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97287
OKGE	'MUSKOGEE 161KV'	31	0.00003	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97305
OKGE	'MUSKOGEE 161KV'	166	0.00003	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97305
OKGE	'MUSKOGEE 345KV'	20	0.00004	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97304
OKGE	'MUSTANG 138KV'	365.5	0.00035	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97273
OKGE	'MUSTANG 69KV'	106	0.00004	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97268
OKGE	'ONE OAK 345KV'	236	0.00013	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97295
OKGE	'REDBUD 345KV'	900	0.00014	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97294
OKGE	'REDBUD 345KV'	421.65	0.00014	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97294
OKGE	'SEMINOLE 138KV'	99.80365	0.00018	OKGE	'FPLWND2 34KV'	102	0.97308	-0.9729
OKGE	'SEMINOLE 345KV'	507.6	0.00018	OKGE	'FPLWND2 34KV'	102	0.97308	-0.9729
OKGE	'SMITH COGEN 138KV'	110	0.00034	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97274
OKGE	'SOONER 138KV'	24.99997	-0.00031	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97339
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'FPLWND2 34KV'	102	0.97308	-0.9747
OKGE	'TINKER 5G 138KV'	62	0.00024	OKGE	'FPLWND2 34KV'	102	0.97308	-0.97284
OKGE	'CONTINENTAL EMPIRE 138KV'	64	-0.00045	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81303
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236
OKGE	'HORSESHOE LAKE 138KV'	91	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236
OKGE	'HORSESHOE LAKE 138KV'	380	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236
OKGE	'HORSESHOE LAKE 69KV'	16	0.00021	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81237
OKGE	'MUSKOGEE 161KV'	31	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255
OKGE	'MUSKOGEE 161KV'	166	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255
OKGE	'MUSKOGEE 345KV'	20	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81254
OKGE	'MUSTANG 138KV'	365.5	0.00035	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81223
OKGE	'MUSTANG 69KV'	106	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81218
OKGE	'ONE OAK 345KV'	236	0.00013	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81245
OKGE	'REDBUD 345KV'	900	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244
OKGE	'REDBUD 345KV'	421.65	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244
OKGE	'SEMINOLE 138KV'	99.80365	0.00018	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8124
OKGE	'SEMINOLE 345KV'	507.6	0.00018	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8124
OKGE	'SMITH COGEN 138KV'	110	0.00034	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81224
OKGE	'SOONER 138KV'	24.99997	-0.00031	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81289
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8142
OKGE	'TINKER 5G 138KV'	62	0.00024	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81234
OKGE	'MORLND 138KV'	320	-0.02454	WFEC	'SLEEPING BEAR 138KV'	80	0.05338	-0.07792

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.  
 Factor = Source GSF - Sink GSF  
 Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: IODINE - WOODWARD 138KV CKT 1  
 Flowgate: 55785559991547965478511206WP  
 Date Redispatch Needed: 12/1/06 - 4/1/07  
 Season Flowgate Identified: 2006 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount						
1023236	0.5	12.1						
1032973	11.5	12.1						
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor
OKGE	'AES 161KV'	10	0.00003	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97306
OKGE	'CONTINENTAL EMPIRE 138KV'	63	-0.00045	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97354
OKGE	'HORSESHOE LAKE 138KV'	91	0.00023	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97286
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00023	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97286
OKGE	'HORSESHOE LAKE 138KV'	380	0.00023	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97286
OKGE	'HORSESHOE LAKE 69KV'	16	0.00022	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97287
OKGE	'MCCLAIN 138KV'	42	0.00036	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97273
OKGE	'MUSKOGEE 161KV'	166	0.00004	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97305
OKGE	'MUSKOGEE 161KV'	31	0.00004	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97305
OKGE	'MUSKOGEE 245KV'	20	0.00005	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97304
OKGE	'MUSTANG 138KV'	365.5	0.00036	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97273
OKGE	'MUSTANG 69KV'	106	0.00004	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97269
OKGE	'ONE OAK 345KV'	336	0.00012	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97297
OKGE	'REDBUD 345KV'	900	0.00014	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97295
OKGE	'REDBUD 345KV'	421.65	0.00014	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97295
OKGE	'SEMINOLE 138KV'	395.2155	0.00019	OKGE	'FPLWND2 34KV'	102	0.97309	-0.9729
OKGE	'SEMINOLE 345KV'	558.5093	0.00019	OKGE	'FPLWND2 34KV'	102	0.97309	-0.9729
OKGE	'SOONER 138KV'	24.99997	-0.00031	OKGE	'FPLWND2 34KV'	102	0.97309	-0.9734
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97471
OKGE	'TINKER 5G 138KV'	62	0.00025	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97284
OKGE	'AES 161KV'	10	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255
OKGE	'CONTINENTAL EMPIRE 138KV'	63	-0.00045	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81303
OKGE	'HORSESHOE LAKE 138KV'	91	0.00023	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81235
OKGE	'HORSESHOE LAKE 138KV'	380	0.00023	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81235
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00023	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81235
OKGE	'HORSESHOE LAKE 69KV'	16	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236
OKGE	'MCCLAIN 138KV'	42	0.00036	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81222
OKGE	'MUSKOGEE 161KV'	166	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81254
OKGE	'MUSKOGEE 161KV'	31	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81254
OKGE	'MUSKOGEE 345KV'	20	0.00005	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81253

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	MUSTANG 138KV'	365.5	0.00036	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81222	15
OKGE	MUSTANG 69KV'	106	0.0004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81218	15
OKGE	ONE OAK 345KV'	336	0.00012	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81246	15
OKGE	REDBUD 345KV'	900	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	15
OKGE	REDBUD 345KV'	421.65	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	15
OKGE	SEMINOLE 138KV'	395.2155	0.00019	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81239	15
OKGE	SEMINOLE 345KV'	558.5093	0.00019	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81239	15
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81289	15
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8142	15
OKGE	TINKER 5G 138KV'	62	0.00025	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81233	15
WFEC	MORLND 138KV'	166.1695	-0.02454	WFEC	'SLEEPING BEAR 138KV'	80	0.05339	-0.07793	155

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC

Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1

Direction: From->To

Line Outage: IODINE - WOODWARD 138KV CKT 1

Flowgate: 55785559991547965478511207SH

Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade

Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount									
		Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1023236	0.2			380	0.00022	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97287	5
1032973	4.3			380.5	0.00022	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97287	5
		OKGE	HORSESHEOE LAKE 138KV'	42	0.00034	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97275	5
		OKGE	MCCLAIR 138KV'	166	0.00003	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97306	5
		OKGE	MUSKOGEE 161KV'	31	0.00003	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97306	5
		OKGE	MUSKOGEE 345KV'	20	0.00004	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97305	5
		OKGE	MUSTANG 138KV'	365.5	0.00035	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97274	5
		OKGE	MUSTANG 69KV'	57.46093	0.0004	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97269	5
		OKGE	ONE OAK 345KV'	274	0.00013	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97296	5
		OKGE	REDBUD 345KV'	900	0.00014	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97295	5
		OKGE	REDBUD 345KV'	421.65	0.00014	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97295	5
		OKGE	SEMINOLE 138KV'	20.90036	0.00018	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97291	5
		OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	'FPLWND2 34KV'	102	0.97309	-0.9734	5
		OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97471	5
		OKGE	TINKER 5G 138KV'	62	0.00024	OKGE	'FPLWND2 34KV'	102	0.97309	-0.97285	5
		OKGE	HORSESHEOE LAKE 138KV'	380	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	6
		OKGE	HORSESHEOE LAKE 138KV'	380.5	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	6
		OKGE	MCCLAIR 138KV'	42	0.00034	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81224	6
		OKGE	MUSKOGEE 161KV'	31	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	6
		OKGE	MUSKOGEE 161KV'	166	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	6
		OKGE	MUSKOGEE 345KV'	20	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81254	6
		OKGE	MUSTANG 138KV'	365.5	0.00035	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81223	6
		OKGE	MUSTANG 69KV'	57.46093	0.0004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81218	6
		OKGE	ONE OAK 345KV'	274	0.00013	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81245	6
		OKGE	REDBUD 345KV'	421.65	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	6
		OKGE	REDBUD 345KV'	900	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	6
		OKGE	SEMINOLE 138KV'	20.90036	0.00018	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8124	6
		OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81289	6
		OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8142	6
		OKGE	TINKER 5G 138KV'	62	0.00024	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81234	6
WFEC	MORLND 138KV'			173.8576	-0.02454	WFEC	'SLEEPING BEAR 138KV'	80	0.05338	-0.07792	58

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC

Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1

Direction: From->To

Line Outage: IODINE - WOODWARD 138KV CKT 1

Flowgate: 55785559991547965478511207WP

Date Redispatch Needed: 12/1/07 - 4/1/08

Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount									
		Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1023236	0.5			78.99999	0.00003	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97305	12
1032973	10.8			380.5	0.00022	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97286	12
		OKGE	HORSESHEOE LAKE 138KV'	380	0.00022	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97286	12
		OKGE	HORSESHEOE LAKE 138KV'	91	0.00022	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97286	12
		OKGE	HORSESHEOE LAKE 69KV'	16	0.00021	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97287	12
		OKGE	MCCLAIR 138KV'	42	0.00034	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97274	12
		OKGE	MUSKOGEE 161KV'	34	0.00003	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97305	12
		OKGE	MUSKOGEE 161KV'	166	0.00003	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97305	12
		OKGE	MUSKOGEE 345KV'	20	0.00004	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97304	12
		OKGE	MUSTANG 138KV'	365.5	0.00035	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97273	12
		OKGE	MUSTANG 69KV'	106	0.0004	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97268	12
		OKGE	ONE OAK 345KV'	319	0.00012	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97296	12
		OKGE	REDBUD 345KV'	900	0.00014	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97294	12
		OKGE	REDBUD 345KV'	421.65	0.00014	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97294	12
		OKGE	SEMINOLE 138KV'	309.6299	0.00018	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.9729	12
		OKGE	SEMINOLE 345KV'	507.6	0.00018	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.9729	12
		OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97339	12
		OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.9747	12
		OKGE	TINKER 5G 138KV'	62	0.00024	OKGE	'FPLWND2 34KV'	101.9968	0.97308	-0.97284	12
		OKGE	AES 161KV'	78.99999	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	14
		OKGE	HORSESHEOE LAKE 138KV'	91	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	14
		OKGE	HORSESHEOE LAKE 138KV'	380	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	14
		OKGE	HORSESHEOE LAKE 69KV'	16	0.00021	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81237	14
		OKGE	MCCLAIR 138KV'	42	0.00034	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81224	14
		OKGE	MUSKOGEE 161KV'	166	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	14
		OKGE	MUSKOGEE 161KV'	31	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	14

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	MUSKOGEE 345KV'	20	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81254	14
OKGE	MUSTANG 138KV'	365.5	0.00035	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81223	14
OKGE	MUSTANG 69KV'	106	0.0004	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81218	14
OKGE	ONE OAK 345KV'	319	0.00012	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81246	14
OKGE	REDBUD 345KV'	900	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	14
OKGE	REDBUD 345KV'	421.65	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	14
OKGE	SEMINOLE 138KV'	309.6299	0.00018	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8124	14
OKGE	SEMINOLE 345KV'	507.6	0.00018	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8124	14
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81289	14
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8142	14
OKGE	TINKER 5G 138KV'	62	0.00024	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81234	14
WFEC	MORLND 138KV'	148.9085	-0.02454	WFEC	'SLEEPING BEAR 138KV'	80	0.05338	-0.07792	145

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: IODINE - WOODWARD 138KV CKT 1  
 Flowgate: 55785559991547965478511407G  
 Date Redispach Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1023236		0.8		18.7					
1032973		17.9		18.7					
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	AES 161KV'	40	0.00003	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97306	19
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97287	19
OKGE	HORSESHOE LAKE 138KV'	91	0.00022	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97287	19
OKGE	HORSESHOE LAKE 138KV'	380	0.00022	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97287	19
OKGE	HORSESHOE LAKE 69KV'	16	0.00022	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97287	19
OKGE	MCCLAIN 138KV'	42	0.00034	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97275	19
OKGE	MUSKOGEE 161KV'	31	0.00003	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97306	19
OKGE	MUSKOGEE 161KV'	166	0.00003	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97306	19
OKGE	MUSKOGEE 345KV'	20	0.00005	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97304	19
OKGE	MUSTANG 138KV'	365.5	0.00036	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97273	19
OKGE	MUSTANG 69KV'	106	0.00041	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97268	19
OKGE	ONE OAK 345KV'	319	0.00012	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97297	19
OKGE	REDBUD 345KV'	421.65	0.00014	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97295	19
OKGE	REDBUD 345KV'	900	0.00014	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97295	19
OKGE	SEMINOLE 138KV'	404.9767	0.00019	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.9729	19
OKGE	SEMINOLE 345KV'	572.6229	0.00019	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.9729	19
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.9734	19
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97471	19
OKGE	TINKER 5G 138KV'	62	0.00025	OKGE	'FPLWND2 34KV'	101.9988	0.97309	-0.97284	19
OKGE	AES 161KV'	40	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	23
OKGE	HORSESHOE LAKE 138KV'	91	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	23
OKGE	HORSESHOE LAKE 138KV'	380	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	23
OKGE	HORSESHOE LAKE 69KV'	16	0.00022	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81236	23
OKGE	MCCLAIN 138KV'	42	0.00034	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81224	23
OKGE	MUSKOGEE 161KV'	31	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	23
OKGE	MUSKOGEE 161KV'	166	0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81255	23
OKGE	MUSKOGEE 345KV'	20	0.00005	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81253	23
OKGE	MUSTANG 138KV'	365.5	0.00036	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81222	23
OKGE	MUSTANG 69KV'	106	0.00041	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81217	23
OKGE	ONE OAK 345KV'	319	0.00012	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81246	23
OKGE	REDBUD 345KV'	900	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	23
OKGE	REDBUD 345KV'	421.65	0.00014	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81244	23
OKGE	SEMINOLE 138KV'	404.9767	0.00019	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81239	23
OKGE	SEMINOLE 345KV'	572.6229	0.00019	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81239	23
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81289	23
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.8142	23
OKGE	TINKER 5G 138KV'	62	0.00025	OKGE	'SLEEPING BEAR 34KV'	120	0.81258	-0.81233	23
WFEC	MORLND 138KV'	320	-0.02454	WFEC	'SLEEPING BEAR 138KV'	80	0.05339	-0.07793	240

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: FT SUPPLY - IODINE 138KV CKT 1  
 Flowgate: 55785559991547965478511207AP  
 Date Redispach Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 April Minimum

Reservation	Relief Amount	Aggregate Relief Amount							
1023236		4.3		19.2					
1032973		14.8		19.2					
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.01423	OKGE	'FPLWND2 34KV'	102	0.88636	-0.90059	21
OKGE	AES 161KV'	160	0.00036	OKGE	'FPLWND2 34KV'	102	0.88636	-0.886	22
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00236	OKGE	'FPLWND2 34KV'	102	0.88636	-0.884	22
OKGE	HORSESHOE LAKE 138KV'	91	0.00236	OKGE	'FPLWND2 34KV'	102	0.88636	-0.884	22
OKGE	HORSESHOE LAKE 138KV'	380	0.00236	OKGE	'FPLWND2 34KV'	102	0.88636	-0.884	22
OKGE	HORSESHOE LAKE 69KV'	16	0.00227	OKGE	'FPLWND2 34KV'	102	0.88636	-0.88409	22
OKGE	MCCLAIN 138KV'	520	0.00378	OKGE	'FPLWND2 34KV'	102	0.88636	-0.88258	22
OKGE	MUSKOGEE 161KV'	166	0.00042	OKGE	'FPLWND2 34KV'	102	0.88636	-0.88594	22
OKGE	MUSKOGEE 345KV'	31	0.00042	OKGE	'FPLWND2 34KV'	102	0.88636	-0.88594	22
OKGE	MUSKOGEE 345KV'	714.519	0.00053	OKGE	'FPLWND2 34KV'	102	0.88636	-0.88583	22
OKGE	MUSTANG 138KV'	365.5	0.00388	OKGE	'FPLWND2 34KV'	102	0.88636	-0.88248	22
OKGE	MUSTANG 69KV'	106	0.00421	OKGE	'FPLWND2 34KV'	102	0.88636	-0.88215	22
OKGE	ONE OAK 345KV'	336	0.00153	OKGE	'FPLWND2 34KV'	102	0.88636	-0.88483	22
OKGE	REDBUD 345KV'	421.65	0.0016	OKGE	'FPLWND2 34KV'	102	0.88636	-0.88476	22
OKGE	REDBUD 345KV'	900	0.0016	OKGE	'FPLWND2 34KV'	102	0.88636	-0.88476	22
OKGE	SEMINOLE 138KV'	507.6138	0.00182	OKGE	'FPLWND2 34KV'	102	0.88636	-0.88454	22
OKGE	SEMINOLE 345KV'	996.6	0.00189	OKGE	'FPLWND2 34KV'	102	0.88636	-0.88447	22
OKGE	SMITH COGEN 138KV'	110	0.00368	OKGE	'FPLWND2 34KV'	102	0.88636	-0.88268	22

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	SOONER 138KV'	24.99997	-0.0024	OKGE	FPLWND2 34KV'	102	0.88636	-0.88876	22
OKGE	TINKER 5G 138KV'	62	0.00256	OKGE	FPLWND2 34KV'	102	0.88636	-0.8838	22
OKGE	AES 161KV'	160	0.00036	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62983	30
OKGE	MUSKOGEE 161KV'	166	0.00042	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62977	30
OKGE	MUSKOGEE 161KV'	31	0.00042	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62977	30
OKGE	MUSKOGEE 345KV'	714.519	0.00053	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62666	30
OKGE	ONE OAK 345KV'	336	0.00153	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62866	30
OKGE	REDBUD 345KV'	421.65	0.0016	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62859	30
OKGE	REDBUD 345KV'	900	0.0016	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62859	30
OKGE	SEMINOLE 138KV'	507.6138	0.00182	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62837	30
OKGE	SEMINOLE 345KV'	996.6	0.00189	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.6283	30
OKGE	SOONER 138KV'	24.99997	-0.0024	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.63259	30
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.01423	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.64442	30
OKGE	HORSESHOE LAKE 138KV'	91	0.00236	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62783	31
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00236	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62783	31
OKGE	HORSESHOE LAKE 138KV'	380	0.00236	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62783	31
OKGE	HORSESHOE LAKE 69KV'	16	0.00227	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62792	31
OKGE	MCCLAIN 138KV'	520	0.00378	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62641	31
OKGE	MUSTANG 138KV'	365.5	0.00388	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62631	31
OKGE	MUSTANG 69KV'	106	0.00421	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62598	31
OKGE	SMITH COGEN 138KV'	110	0.00368	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62651	31
OKGE	TINKER 5G 138KV'	62	0.00256	OKGE	'SLEEPING BEAR 34KV'	120	0.63019	-0.62763	31

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: VICI - WOODWARD 69KV CKT 1  
 Flowgate: 55785559991560825609611106FA  
 Date Redispatch Needed: 10/1/06 - 12/1/06  
 Season Flowgate Identified: 2006 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount							
Source Control Area	Source	Maximum Increment(MW)	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
1032973		16.7							
OKGE	CONTINENTAL EMPIRE 138KV'	63	0.00026	OKGE	FPLWND2 34KV'	102	0.99327	-0.99301	17
OKGE	HORSESHOE LAKE 138KV'	380	-0.00003	OKGE	FPLWND2 34KV'	102	0.99327	-0.9933	17
OKGE	HORSESHOE LAKE 138KV'	380.5	-0.00003	OKGE	FPLWND2 34KV'	102	0.99327	-0.9933	17
OKGE	HORSESHOE LAKE 138KV'	91	-0.00003	OKGE	FPLWND2 34KV'	102	0.99327	-0.9933	17
OKGE	HORSESHOE LAKE 69KV'	16	-0.00003	OKGE	FPLWND2 34KV'	102	0.99327	-0.9933	17
OKGE	MCCLAIN 138KV'	42	-0.00007	OKGE	FPLWND2 34KV'	102	0.99327	-0.99334	17
OKGE	MUSKOGEE 161KV'	166	0.00001	OKGE	FPLWND2 34KV'	102	0.99327	-0.99326	17
OKGE	MUSKOGEE 161KV'	31	0.00001	OKGE	FPLWND2 34KV'	102	0.99327	-0.99326	17
OKGE	MUSKOGEE 345KV'	20	0	OKGE	FPLWND2 34KV'	102	0.99327	-0.99327	17
OKGE	MUSTANG 138KV'	365.5	-0.00006	OKGE	FPLWND2 34KV'	102	0.99327	-0.9933	17
OKGE	MUSTANG 69KV'	106	-0.00007	OKGE	FPLWND2 34KV'	102	0.99327	-0.99334	17
OKGE	ONE OAK 345KV'	236	0.00001	OKGE	FPLWND2 34KV'	102	0.99327	-0.99326	17
OKGE	REDBUD 345KV'	421.65	0	OKGE	FPLWND2 34KV'	102	0.99327	-0.99327	17
OKGE	REDBUD 345KV'	900	0	OKGE	FPLWND2 34KV'	102	0.99327	-0.99327	17
OKGE	SEMINOLE 138KV'	262.1816	-0.00004	OKGE	FPLWND2 34KV'	102	0.99327	-0.99331	17
OKGE	SEMINOLE 345KV'	507.6	-0.00003	OKGE	FPLWND2 34KV'	102	0.99327	-0.9933	17
OKGE	SOONER 138KV'	24.99997	0.00019	OKGE	FPLWND2 34KV'	102	0.99327	-0.99308	17
OKGE	SOUTH 4TH ST 69KV'	42.7	0.00121	OKGE	FPLWND2 34KV'	102	0.99327	-0.99206	17
OKGE	TINKER 5G 138KV'	62	-0.00004	OKGE	FPLWND2 34KV'	102	0.99327	-0.99331	17
OKGE	CONTINENTAL EMPIRE 138KV'	63	0.00026	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.8466	20
OKGE	HORSESHOE LAKE 138KV'	91	-0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84689	20
OKGE	HORSESHOE LAKE 138KV'	380.5	-0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84689	20
OKGE	HORSESHOE LAKE 138KV'	380	-0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84689	20
OKGE	HORSESHOE LAKE 69KV'	16	-0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84689	20
OKGE	MCCLAIN 138KV'	42	-0.00007	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84693	20
OKGE	MUSKOGEE 161KV'	166	0.00001	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84685	20
OKGE	MUSKOGEE 345KV'	31	0.00001	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84685	20
OKGE	MUSKOGEE 345KV'	20	0	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84686	20
OKGE	MUSTANG 138KV'	365.5	-0.00006	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84692	20
OKGE	MUSTANG 69KV'	106	-0.00007	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84693	20
OKGE	ONE OAK 345KV'	236	0.00001	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84685	20
OKGE	REDBUD 345KV'	421.65	0	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84686	20
OKGE	REDBUD 345KV'	900	0	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84686	20
OKGE	SEMINOLE 138KV'	262.1816	-0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84689	20
OKGE	SEMINOLE 345KV'	507.6	-0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84689	20
OKGE	SOONER 138KV'	24.99997	0.00019	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84667	20
OKGE	SOUTH 4TH ST 69KV'	42.7	0.00121	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84656	20
OKGE	TINKER 5G 138KV'	62	-0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84669	20

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: VICI - WOODWARD 69KV CKT 1  
 Flowgate: 55785559991560825609611206SH  
 Date Redispatch Needed: 6/1/06 - 10/1/06  
 Season Flowgate Identified: 2006 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount							
Source Control Area	Source	Maximum Increment(MW)	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
1032973		8.0							
OKGE	CONTINENTAL EMPIRE 138KV'	63	0.00026	OKGE	FPLWND2 34KV'	102	0.99327	-0.99301	8
OKGE	HORSESHOE LAKE 138KV'	380	-0.00003	OKGE	FPLWND2 34KV'	102	0.99327	-0.9933	8
OKGE	HORSESHOE LAKE 138KV'	91	-0.00003	OKGE	FPLWND2 34KV'	102	0.99327	-0.9933	8
OKGE	HORSESHOE LAKE 138KV'	380.5	-0.00003	OKGE	FPLWND2 34KV'	102	0.99327	-0.9933	8
OKGE	HORSESHOE LAKE 69KV'	16	-0.00003	OKGE	FPLWND2 34KV'	102	0.99327	-0.9933	8
OKGE	MCCLAIN 138KV'	42	-0.00007	OKGE	FPLWND2 34KV'	102	0.99327	-0.99334	8
OKGE	MUSKOGEE 161KV'	166	0.00001	OKGE	FPLWND2 34KV'	102	0.99327	-0.99326	8
OKGE	MUSKOGEE 161KV'	31	0.00001	OKGE	FPLWND2 34KV'	102	0.99327	-0.99326	8
OKGE	MUSKOGEE 345KV'	20	0	OKGE	FPLWND2 34KV'	102	0.99327	-0.99327	8
OKGE	MUSTANG 138KV'	365.5	-0.00006	OKGE	FPLWND2 34KV'	102	0.99327	-0.9933	8
OKGE	MUSTANG 69KV'	106	-0.00007	OKGE	FPLWND2 34KV'	102	0.99327	-0.99334	8

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	'ONE OAK 345KV'	293	0.00001	OKGE	'FPLWND2 34KV'	102	0.99327	-0.99326	8
OKGE	'REDBUD 345KV'	253	0	OKGE	'FPLWND2 34KV'	102	0.99327	-0.99327	8
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'FPLWND2 34KV'	102	0.99327	-0.99327	8
OKGE	'SEMINOLE 138KV'	34.15036	-0.00004	OKGE	'FPLWND2 34KV'	102	0.99327	-0.99331	8
OKGE	'SEMINOLE 345KV'	385.6923	-0.00003	OKGE	'FPLWND2 34KV'	102	0.99327	-0.9933	8
OKGE	'SOONER 138KV'	24.99997	0.00019	OKGE	'FPLWND2 34KV'	102	0.99327	-0.99308	8
OKGE	'SOUTH 4TH ST 69KV'	42.7	0.00121	OKGE	'FPLWND2 34KV'	102	0.99327	-0.99206	8
OKGE	'TINKER 5G 138KV'	62	-0.00004	OKGE	'FPLWND2 34KV'	102	0.99327	-0.99331	8
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0.00026	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.8466	9
OKGE	'HORSESHOE LAKE 138KV'	91	-0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84689	9
OKGE	'HORSESHOE LAKE 138KV'	380	-0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84689	9
OKGE	'HORSESHOE LAKE 138KV'	380.5	-0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84689	9
OKGE	'HORSESHOE LAKE 69KV'	16	-0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84689	9
OKGE	'MCCLAIN 138KV'	42	-0.00007	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84693	9
OKGE	'MUSKOGEE 161KV'	31	0.00001	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84685	9
OKGE	'MUSKOGEE 161KV'	166	0.00001	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84685	9
OKGE	'MUSKOGEE 345KV'	20	0	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84686	9
OKGE	'MUSTANG 138KV'	365.5	-0.00006	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84692	9
OKGE	'MUSTANG 69KV'	106	-0.00007	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84693	9
OKGE	'ONE OAK 345KV'	293	0.00001	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84685	9
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84686	9
OKGE	'REDBUD 345KV'	253	0	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84686	9
OKGE	'SEMINOLE 138KV'	34.15036	-0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.8469	9
OKGE	'SEMINOLE 345KV'	385.6923	-0.00003	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84689	9
OKGE	'SOONER 138KV'	24.99997	0.00019	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84667	9
OKGE	'SOUTH 4TH ST 69KV'	42.7	0.00121	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.84565	9
OKGE	'TINKER 5G 138KV'	62	-0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.84686	-0.8469	9

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1  
 Flowgate: 55785559991WOODODWRD24211106FA  
 Date Redispatch Needed: 10/1/06 - 12/1/06  
 Season Flowgate Identified: 2006 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1032973	66.1	66.1							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	66
OKGE	'HORSESHOE LAKE 138KV'	91	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'HORSESHOE LAKE 138KV'	380	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'HORSESHOE LAKE 138KV'	91	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	66
OKGE	'HORSESHOE LAKE 138KV'	380	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	66
OKGE	'MCCLAIN 138KV'	42	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'MCCLAIN 138KV'	42	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	66
OKGE	'MUSKOGEE 161KV'	166	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'MUSKOGEE 161KV'	31	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'MUSKOGEE 161KV'	166	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	66
OKGE	'MUSKOGEE 161KV'	31	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	66
OKGE	'MUSTANG 138KV'	365.5	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'MUSTANG 138KV'	365.5	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	66
OKGE	'MUSTANG 69KV'	106	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'MUSTANG 69KV'	106	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	66
OKGE	'ONE OAK 345KV'	236	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'ONE OAK 345KV'	236	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	66
OKGE	'REDBUD 345KV'	900	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'REDBUD 345KV'	900	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	66
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	66
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'FPLWND2 34KV'	120	1	-1	66
OKGE	'SEMINOLE 138KV'	262.1816	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'SEMINOLE 138KV'	262.1816	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	66
OKGE	'SEMINOLE 345KV'	507.6	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'SEMINOLE 345KV'	507.6	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	66
OKGE	'SOONER 138KV'	24.99997	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'SOONER 138KV'	24.99997	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	66
OKGE	'SOUTH 4TH ST 69KV'	42.7	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'SOUTH 4TH ST 69KV'	42.7	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	66
OKGE	'TINKER 5G 138KV'	62	0	OKGE	'FPLWND2 34KV'	102	1	-1	66
OKGE	'TINKER 5G 138KV'	62	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	66

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1  
 Flowgate: 55785559991WOODODWRD24211206SH  
 Date Redispatch Needed: 6/1/06 - 10/1/06  
 Season Flowgate Identified: 2006 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount							
1032973	64.6	64.6							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'FPLWND2 34KV'	102	1	-1	65
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	65
OKGE	'HORSESHOE LAKE 138KV'	91	0	OKGE	'FPLWND2 34KV'	102	1	-1	65
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'FPLWND2 34KV'	102	1	-1	65
OKGE	'HORSESHOE LAKE 138KV'	380	0	OKGE	'FPLWND2 34KV'	102	1	-1	65
OKGE	'HORSESHOE LAKE 138KV'	91	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	65
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	65
OKGE	'HORSESHOE LAKE 138KV'	380	0	OKGE	'FPLWND2 34KV'	120	1	-1	65
OKGE	'MCCLAIN 138KV'	42	0	OKGE	'FPLWND2 34KV'	102	1	-1	65
OKGE	'MCCLAIN 138KV'	42	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	65

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	MUSKOGEE 161KV'	31	0	OKGE	FPLWND2 34KV'	102	1	-1	65
OKGE	MUSKOGEE 161KV'	166	0	OKGE	'FPLWND2 34KV'	102	1	-1	65
OKGE	MUSKOGEE 161KV'	166	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	65
OKGE	MUSKOGEE 161KV'	31	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	65
OKGE	MUSTANG 138KV'	365.5	0	OKGE	'FPLWND2 34KV'	102	1	-1	65
OKGE	MUSTANG 138KV'	365.5	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	65
OKGE	MUSTANG 69KV'	106	0	OKGE	'FPLWND2 34KV'	102	1	-1	65
OKGE	MUSTANG 69KV'	106	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	65
OKGE	ONE OAK 345KV'	293	0	OKGE	'FPLWND2 34KV'	102	1	-1	65
OKGE	ONE OAK 345KV'	293	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	65
OKGE	REDBUD 345KV'	421.65	0	OKGE	'FPLWND2 34KV'	102	1	-1	65
OKGE	REDBUD 345KV'	253	0	OKGE	'FPLWND2 34KV'	102	1	-1	65
OKGE	REDBUD 345KV'	421.65	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	65
OKGE	REDBUD 345KV'	253	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	65
OKGE	SEMINOLE 138KV'	34.15036	0	OKGE	'FPLWND2 34KV'	102	1	-1	65
OKGE	SEMINOLE 138KV'	34.15036	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	65
OKGE	SEMINOLE 345KV'	385.6923	0	OKGE	'FPLWND2 34KV'	102	1	-1	65
OKGE	SEMINOLE 345KV'	385.6923	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	65
OKGE	SOONER 138KV'	24.99997	0	OKGE	'FPLWND2 34KV'	102	1	-1	65
OKGE	SOONER 138KV'	24.99997	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	65
OKGE	SOUTH 4TH ST 69KV'	42.7	0	OKGE	'FPLWND2 34KV'	102	1	-1	65
OKGE	SOUTH 4TH ST 69KV'	42.7	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	65
OKGE	TINKER 5G 138KV	62	0	OKGE	'FPLWND2 34KV'	102	1	-1	65
OKGE	TINKER 5G 138KV	62	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	65

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC

Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1

Direction: From->To

Line Outage: WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1

Flowgate: 55785559991WOODODWRD24211206SP

Date Redispatch Needed: 6/1/06 - 10/1/06

Season Flowgate Identified: 2006 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1032973		63.2							
Source Control Area	Source	Maximum Increment(MW)	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
OKGE	CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	63
OKGE	CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	63
OKGE	HORSESHEO LAKE 138KV'	337.7	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	63
OKGE	HORSESHEO LAKE 138KV'	380.5	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	63
OKGE	HORSESHEO LAKE 138KV'	337.7	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	63
OKGE	HORSESHEO LAKE 138KV'	380.5	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	63
OKGE	MCCLAIN 138KV'	42	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	63
OKGE	MCCLAIN 138KV'	42	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	63
OKGE	MUSKOGEE 161KV'	166	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	63
OKGE	MUSKOGEE 161KV'	31	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	63
OKGE	MUSKOGEE 161KV'	166	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	63
OKGE	MUSKOGEE 161KV'	31	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	63
OKGE	MUSTANG 138KV'	142.3459	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	63
OKGE	MUSTANG 138KV'	142.3459	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	63
OKGE	ONE OAK 345KV'	261	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	63
OKGE	ONE OAK 345KV'	261	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	63
OKGE	REDBUD 345KV'	253	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	63
OKGE	REDBUD 345KV'	421.65	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	63
OKGE	REDBUD 345KV'	253	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	63
OKGE	REDBUD 345KV'	421.65	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	63
OKGE	SEMINOLE 138KV'	21.7803	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	63
OKGE	SEMINOLE 138KV'	21.7803	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	63
OKGE	SOONER 138KV'	24.99997	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	63
OKGE	SOONER 138KV'	24.99997	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	63
OKGE	SOUTH 4TH ST 69KV'	42.7	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	63
OKGE	SOUTH 4TH ST 69KV'	42.7	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	63

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC

Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1

Direction: From->To

Line Outage: WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1

Flowgate: 55785559991WOODODWRD24214206WP

Date Redispatch Needed: 12/1/06 - 4/1/07

Season Flowgate Identified: 2006 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1032973		13.7							
Source Control Area	Source	Maximum Increment(MW)	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
OKGE	AES 161KV'	10	0.00038	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89923	15
OKGE	CONTINENTAL EMPIRE 138KV'	63	-0.00402	OKGE	'FPLWND2 34KV'	102	0.89961	-0.90363	15
OKGE	HORSESHEO LAKE 138KV'	91	0.00264	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89697	15
OKGE	HORSESHEO LAKE 138KV'	380.5	0.00264	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89697	15
OKGE	HORSESHEO LAKE 138KV'	380	0.00264	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89697	15
OKGE	HORSESHEO LAKE 69KV'	16	0.00252	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89709	15
OKGE	MCCLAIN 138KV'	42	0.00414	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89547	15
OKGE	MUSKOGEE 161KV'	34	0.00045	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89916	15
OKGE	MUSKOGEE 161KV'	166	0.00045	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89916	15
OKGE	MUSKOGEE 345KV'	20	0.00057	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89904	15
OKGE	MUSTANG 138KV'	365.5	0.00425	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89536	15
OKGE	MUSTANG 69KV'	106	0.00459	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89502	15
OKGE	ONE OAK 345KV'	336	0.00166	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89795	15
OKGE	REDBUD 345KV'	421.65	0.00175	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89786	15
OKGE	REDBUD 345KV'	900	0.00175	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89786	15
OKGE	SEMINOLE 138KV'	398.7187	0.00199	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89762	15
OKGE	SEMINOLE 345KV'	558.5093	0.00206	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89755	15
OKGE	SOONER 138KV'	24.99997	-0.00271	OKGE	'FPLWND2 34KV'	102	0.89961	-0.90232	15
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.0164	OKGE	'FPLWND2 34KV'	102	0.89961	-0.91601	15
OKGE	TINKER 5G 138KV'	62	0.00279	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89682	15
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.0164	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.75121	18

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	'AES 161KV'	10	0.00038	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73443	19
OKGE	'CONTINENTAL EMPIRE 138KV'	63	-0.00402	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73883	19
OKGE	'HORSESHOE LAKE 138KV'	380	0.00264	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73217	19
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00264	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73217	19
OKGE	'HORSESHOE LAKE 138KV'	91	0.00264	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73217	19
OKGE	'HORSESHOE LAKE 69KV'	16	0.00252	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73229	19
OKGE	'MCCLAIN 138KV'	42	0.00414	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73067	19
OKGE	'MUSKOGEE 161KV'	31	0.00045	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73436	19
OKGE	'MUSKOGEE 161KV'	166	0.00045	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73436	19
OKGE	'MUSKOGEE 345KV'	20	0.00057	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73424	19
OKGE	'MUSTANG 138KV'	365.5	0.00425	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73056	19
OKGE	'MUSTANG 69KV'	106	0.00459	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73022	19
OKGE	'ONE OAK 345KV'	336	0.00166	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73315	19
OKGE	'REDBUD 345KV'	421.65	0.00175	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73306	19
OKGE	'REDBUD 345KV'	900	0.00175	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73306	19
OKGE	'SEMINOLE 138KV'	398.7187	0.00199	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73282	19
OKGE	'SEMINOLE 345KV'	558.5093	0.00206	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73275	19
OKGE	'SOONER 138KV'	24.99997	-0.00271	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73752	19
OKGE	'TINKER 5G 138KV'	62	0.00279	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73202	19

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC

Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1

Direction: From->To

Line Outage: WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1

Flowgate: 55785559991WOODODWRD24214207AP

Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade

Season Flowgate Identified: 2007 April Minimum

Reservation	Relief Amount	Aggregate Relief Amount		Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
		Source	Maximum Increment(MW)						
1032973			25.6						
Source Control Area	Source			Sink Control Area	Sink				
OKGE	'AES 161KV'	160	0.00038	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89923	28
OKGE	'HORSESHOE LAKE 69KV'	16	0.00248	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89713	28
OKGE	'MUSKOGEE 161KV'	31	0.00045	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89916	28
OKGE	'MUSKOGEE 161KV'	166	0.00045	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89816	28
OKGE	'MUSKOGEE 345KV'	714.519	0.00057	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89904	28
OKGE	'ONE OAK 345KV'	336	0.00167	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89794	28
OKGE	'REDBUD 345KV'	900	0.00175	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89786	28
OKGE	'REDBUD 345KV'	421.65	0.00175	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89786	28
OKGE	'SEMINOLE 138KV'	511.8863	0.00199	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89762	28
OKGE	'SEMINOLE 345KV'	996.6	0.00207	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89754	28
OKGE	'SOONER 138KV'	24.99997	-0.00271	OKGE	'FPLWND2 34KV'	102	0.89961	-0.90232	28
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.0164	OKGE	'FPLWND2 34KV'	102	0.89961	-0.91601	28
OKGE	'HORSESHOE LAKE 138KV'	380	0.00258	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89703	29
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00258	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89703	29
OKGE	'HORSESHOE LAKE 138KV'	91	0.00258	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89703	29
OKGE	'MCCLAIN 138KV'	520	0.00416	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89545	29
OKGE	'MUSTANG 138KV'	365.5	0.00427	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89534	29
OKGE	'MUSTANG 69KV'	106	0.00462	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89499	29
OKGE	'SMITH COGEN 138KV'	110	0.00405	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89556	29
OKGE	'TINKER 5G 138KV'	62	0.0028	OKGE	'FPLWND2 34KV'	102	0.89961	-0.89681	29
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.0164	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.75121	34
OKGE	'AES 161KV'	160	0.00038	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73443	35
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00258	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73223	35
OKGE	'HORSESHOE LAKE 138KV'	380	0.00258	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73223	35
OKGE	'HORSESHOE LAKE 138KV'	91	0.00258	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73223	35
OKGE	'HORSESHOE LAKE 69KV'	16	0.00248	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73233	35
OKGE	'MCCLAIN 138KV'	520	0.00416	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73065	35
OKGE	'MUSKOGEE 161KV'	166	0.00045	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73436	35
OKGE	'MUSKOGEE 161KV'	31	0.00045	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73436	35
OKGE	'MUSKOGEE 345KV'	714.519	0.00057	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73424	35
OKGE	'MUSTANG 138KV'	365.5	0.00427	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73054	35
OKGE	'MUSTANG 69KV'	106	0.00462	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73019	35
OKGE	'ONE OAK 345KV'	336	0.00167	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73314	35
OKGE	'REDBUD 345KV'	421.65	0.00175	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73306	35
OKGE	'REDBUD 345KV'	900	0.00175	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73306	35
OKGE	'SEMINOLE 138KV'	511.8863	0.00199	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73282	35
OKGE	'SEMINOLE 345KV'	996.6	0.00207	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73274	35
OKGE	'SMITH COGEN 138KV'	110	0.00405	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73076	35
OKGE	'SOONER 138KV'	24.99997	-0.00271	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73752	35
OKGE	'TINKER 5G 138KV'	62	0.0028	OKGE	'SLEEPING BEAR 34KV'	120	0.73481	-0.73201	35

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC

Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1

Direction: From->To

Line Outage: WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1

Flowgate: 55785559991WOODODWRD24214207FA

Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade

Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount		Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
		Source	Maximum Increment(MW)						
1032973			27.1						
Source Control Area	Source			Sink Control Area	Sink				
OKGE	'CONTINENTAL EMPIRE 138KV'	64	-0.004	OKGE	'FPLWND2 34KV'	102	0.89958	-0.90358	30
OKGE	'HORSESHOE LAKE 138KV'	380	0.00256	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89702	30
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00256	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89702	30
OKGE	'HORSESHOE LAKE 138KV'	91	0.00256	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89702	30
OKGE	'HORSESHOE LAKE 69KV'	16	0.00246	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89712	30
OKGE	'MUSKOGEE 161KV'	31	0.00044	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89914	30
OKGE	'MUSKOGEE 161KV'	166	0.00044	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89914	30
OKGE	'MUSKOGEE 345KV'	20	0.00053	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89905	30
OKGE	'MUSTANG 138KV'	365.5	0.00419	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89539	30
OKGE	'MUSTANG 69KV'	106	0.00455	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89503	30
OKGE	'ONE OAK 345KV'	323	0.00169	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89789	30
OKGE	'REDBUD 345KV'	900	0.00174	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89784	30

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	REDBUD 345KV'	421.65	0.00174	OKGE	FPLWND2 34KV'		102	0.89958	-0.89784	30
OKGE	SEMINOLE 138KV'	32.69373	0.00197	OKGE	FPLWND2 34KV'		102	0.89958	-0.89761	30
OKGE	SEMINOLE 345KV'	507.6	0.00204	OKGE	FPLWND2 34KV'		102	0.89958	-0.89754	30
OKGE	SMITH COGEN 138KV'	110	0.00399	OKGE	FPLWND2 34KV'		102	0.89958	-0.89559	30
OKGE	SOONER 138KV'	24.99997	-0.0027	OKGE	FPLWND2 34KV'		102	0.89958	-0.90228	30
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.0164	OKGE	FPLWND2 34KV'		102	0.89958	-0.91598	30
OKGE	TINKER 5G 138KV'	62	0.00277	OKGE	FPLWND2 34KV'		102	0.89958	-0.89681	30
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.0164	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.75118	36
OKGE	CONTINENTAL EMPIRE 138KV'	64	-0.004	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73878	37
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00256	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73222	37
OKGE	HORSESHOE LAKE 138KV'	380	0.00256	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73222	37
OKGE	HORSESHOE LAKE 138KV'	91	0.00256	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73222	37
OKGE	HORSESHOE LAKE 69KV'	16	0.00246	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73232	37
OKGE	MUSKOGEE 161KV'	31	0.00044	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73434	37
OKGE	MUSKOGEE 161KV'	166	0.00044	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73434	37
OKGE	MUSKOGEE 345KV'	20	0.00053	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73425	37
OKGE	MUSTANG 138KV'	365.5	0.00419	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73059	37
OKGE	MUSTANG 69KV'	106	0.00455	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73023	37
OKGE	ONE OAK 345KV'	323	0.00169	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73309	37
OKGE	REDBUD 345KV'	900	0.00174	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73304	37
OKGE	REDBUD 345KV'	421.65	0.00174	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73304	37
OKGE	SEMINOLE 138KV'	32.69373	0.00197	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73281	37
OKGE	SEMINOLE 345KV'	507.6	0.00204	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73274	37
OKGE	SMITH COGEN 138KV'	110	0.00399	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73079	37
OKGE	SOONER 138KV'	24.99997	-0.0027	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73748	37
OKGE	TINKER 5G 138KV'	62	0.00277	OKGE	'SLEEPING BEAR 34KV'		120	0.73478	-0.73201	37

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1  
 Flowgate: 55785559991WOODODWRD24214207G  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount		Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
		Source	Maximum Increment(MW)							
1032973			26.4							
Source Control Area	Source									
OKGE	AES 161KV'	40	0.00038	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.89923	29
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00259	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.89702	29
OKGE	HORSESHOE LAKE 138KV'	91	0.00259	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.89702	29
OKGE	HORSESHOE LAKE 138KV'	380	0.00259	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.89702	29
OKGE	HORSESHOE LAKE 69KV'	16	0.00249	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.89712	29
OKGE	MCCLAIN 138KV'	42	0.00394	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.89567	29
OKGE	MUSKOGEE 161KV'	31	0.00045	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.89916	29
OKGE	MUSKOGEE 161KV'	166	0.00045	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.89916	29
OKGE	MUSKOGEE 345KV'	20	0.00045	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.89916	29
OKGE	ONE OAK 345KV'	319	0.0166	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.89795	29
OKGE	REDBUD 345KV'	421.65	0.00175	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.89786	29
OKGE	REDBUD 345KV'	900	0.00175	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.89786	29
OKGE	SEMINOLE 138KV'	405.99338	0.00199	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.89762	29
OKGE	SEMINOLE 345KV'	574.3335	0.00207	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.89754	29
OKGE	SOONER 138KV'	24.99997	-0.00271	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.90232	29
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.0164	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.91601	29
OKGE	TINKER 5G 138KV'	62	0.00281	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.8968	29
OKGE	MUSTANG 138KV'	365.5	0.00429	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.89532	30
OKGE	MUSTANG 69KV'	106	0.00464	OKGE	FPLWND2 34KV'		101.9988	0.89961	-0.89497	30
OKGE	SOUTH 4TH ST. 69KV'	42.7	-0.0164	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.75121	35
OKGE	AES 161KV'	40	0.00038	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.73443	36
OKGE	HORSESHOE LAKE 138KV'	91	0.00259	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.73222	36
OKGE	HORSESHOE LAKE 138KV'	380	0.00259	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.73222	36
OKGE	HORSESHOE LAKE 69KV'	16	0.00249	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.73232	36
OKGE	MCCLAIN 138KV'	42	0.00394	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.73087	36
OKGE	MUSKOGEE 161KV'	31	0.00045	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.73436	36
OKGE	MUSKOGEE 161KV'	166	0.00045	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.73436	36
OKGE	MUSKOGEE 345KV'	20	0.00057	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.73424	36
OKGE	MUSTANG 138KV'	365.5	0.00429	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.73052	36
OKGE	MUSTANG 69KV'	106	0.00464	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.73017	36
OKGE	ONE OAK 345KV'	319	0.0166	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.73315	36
OKGE	REDBUD 345KV'	900	0.00175	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.73306	36
OKGE	REDBUD 345KV'	421.65	0.00175	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.73306	36
OKGE	SEMINOLE 138KV'	405.99338	0.00199	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.73282	36
OKGE	SEMINOLE 345KV'	574.3335	0.00207	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.73274	36
OKGE	SOONER 138KV'	24.99997	-0.00271	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.73752	36
OKGE	TINKER 5G 138KV'	62	0.00281	OKGE	'SLEEPING BEAR 34KV'		120	0.73481	-0.732	36

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1  
 Flowgate: 55785559991WOODODWRD24214207SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount		Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
		Source	Maximum Increment(MW)							
1032973			13.4							
Source Control Area	Source									
OKGE	HORSESHOE LAKE 138KV'	380	0.00256	OKGE	FPLWND2 34KV'		102	0.89958	-0.89702	15
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00256	OKGE	FPLWND2 34KV'		102	0.89958	-0.89702	15
OKGE	MCCLAIN 138KV'	42	0.00387	OKGE	FPLWND2 34KV'		102	0.89958	-0.89571	15
OKGE	MUSKOGEE 161KV'	166	0.00045	OKGE	FPLWND2 34KV'		102	0.89958	-0.89913	15
OKGE	MUSKOGEE 161KV'	31	0.00045	OKGE	FPLWND2 34KV'		102	0.89958	-0.89913	15
OKGE	MUSKOGEE 345KV'	20	0.00053	OKGE	FPLWND2 34KV'		102	0.89958	-0.89905	15
OKGE	MUSTANG 138KV'	365.5	0.00419	OKGE	FPLWND2 34KV'		102	0.89958	-0.89539	15

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	MUSTANG 69KV'	57.46093	0.00455	OKGE	FPLWND2 34KV'	102	0.89958	-0.89503	15
OKGE	ONE OAK 345KV'	299	0.00169	OKGE	FPLWND2 34KV'	102	0.89958	-0.89789	15
OKGE	REDBUD 345KV'	421.65	0.00174	OKGE	FPLWND2 34KV'	102	0.89958	-0.89784	15
OKGE	REDBUD 345KV'	900	0.00174	OKGE	FPLWND2 34KV'	102	0.89958	-0.89784	15
OKGE	SEMINOLE 138KV'	21.28235	0.00197	OKGE	FPLWND2 34KV'	102	0.89958	-0.89761	15
OKGE	SOONER 138KV'	24.99997	-0.00269	OKGE	FPLWND2 34KV'	102	0.89958	-0.90227	15
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.0164	OKGE	FPLWND2 34KV'	102	0.89958	-0.91598	15
OKGE	TINKER 5G 138KV'	62	0.00277	OKGE	FPLWND2 34KV'	102	0.89958	-0.89681	15
OKGE	HORSESHOE LAKE 138KV'	380	0.00256	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73222	18
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00256	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73222	18
OKGE	MCCLAIN 138KV'	42	0.00387	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73091	18
OKGE	MUSKOGEE 161KV'	166	0.00045	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73433	18
OKGE	MUSKOGEE 161KV'	31	0.00045	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73433	18
OKGE	MUSKOGEE 345KV'	20	0.00053	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73425	18
OKGE	MUSTANG 138KV'	365.5	0.00419	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73059	18
OKGE	MUSTANG 69KV'	57.46093	0.00455	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73023	18
OKGE	ONE OAK 345KV'	299	0.00169	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73309	18
OKGE	REDBUD 345KV'	900	0.00174	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73304	18
OKGE	REDBUD 345KV'	421.65	0.00174	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73304	18
OKGE	SEMINOLE 138KV'	21.28235	0.00197	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73281	18
OKGE	SOONER 138KV'	24.99997	-0.00269	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73747	18
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.0164	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.75118	18
OKGE	TINKER 5G 138KV'	62	0.00277	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73201	18

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1  
 Flowgate: 55785559991WOODODWRD24214207SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1032973		2.3							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.0164	OKGE	'FPLWND2 34KV'	102	0.89958	-0.91598	2
OKGE	'HORSESHOE LAKE 138KV'	293.3623	0.00256	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89702	3
OKGE	'HORSESHOE LAKE 138KV'	293.3623	0.00256	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73222	3
OKGE	'MCCLAIN 138KV'	42	0.00387	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89571	3
OKGE	'MCCLAIN 138KV'	42	0.00387	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73091	3
OKGE	'MUSKOGEE 161KV'	166	0.00045	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89913	3
OKGE	'MUSKOGEE 161KV'	31	0.00045	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89913	3
OKGE	'MUSKOGEE 161KV'	31	0.00045	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73433	3
OKGE	'MUSKOGEE 161KV'	166	0.00045	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73433	3
OKGE	'MUSKOGEE 345KV'	20	0.00053	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89905	3
OKGE	'MUSKOGEE 345KV'	20	0.00053	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73425	3
OKGE	'ONE OAK 345KV'	261	0.00169	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89789	3
OKGE	'ONE OAK 345KV'	261	0.00169	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73309	3
OKGE	'REDBUD 345KV'	421.65	0.00174	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89784	3
OKGE	'REDBUD 345KV'	900	0.00174	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89784	3
OKGE	'REDBUD 345KV'	421.65	0.00174	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73304	3
OKGE	'REDBUD 345KV'	900	0.00174	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73304	3
OKGE	'SEMINOLE 138KV'	22.65768	0.00197	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89761	3
OKGE	'SEMINOLE 138KV'	22.65768	0.00197	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73281	3
OKGE	'SOONER 138KV'	24.99997	-0.00269	OKGE	'FPLWND2 34KV'	102	0.89958	-0.90227	3
OKGE	'SOONER 138KV'	24.99997	-0.00269	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73747	3
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.0164	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.75118	3
OKGE	'TINKER 5G 138KV'	62	0.00277	OKGE	'FPLWND2 34KV'	102	0.89958	-0.89681	3
OKGE	'TINKER 5G 138KV'	62	0.00277	OKGE	'SLEEPING BEAR 34KV'	120	0.73478	-0.73201	3
OKGE	'WOODWARD 24KV'	9.3	0.73478	OKGE	'FPLWND2 34KV'	102	0.89958	-0.1648	14

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 OKGE & FPL SWITCH - MOORELAND 138KV CKT 1 WFEC  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1  
 Flowgate: 55785559991WOODODWRD24214207WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1032973		11.3							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'SOONER 138KV'	24.99997	-0.00271	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.90228	12
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.01641	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.91598	12
OKGE	'AES 161KV'	78.99993	0.00036	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.89921	13
OKGE	'HORSESHOE LAKE 138KV'	380	0.00255	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.89702	13
OKGE	'HORSESHOE LAKE 138KV'	91	0.00255	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.89702	13
OKGE	'HORSESHOE LAKE 69KV'	16	0.00245	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.89712	13
OKGE	'MCCLAIN 138KV'	42	0.00386	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.89571	13
OKGE	'MUSKOGEE 161KV'	166	0.00043	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.89914	13
OKGE	'MUSKOGEE 161KV'	31	0.00043	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.89914	13
OKGE	'MUSKOGEE 345KV'	20	0.00051	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.89906	13
OKGE	'MUSTANG 138KV'	365.5	0.00418	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.89539	13
OKGE	'MUSTANG 69KV'	106	0.00454	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.89503	13
OKGE	'ONE OAK 345KV'	336	0.00168	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.89789	13
OKGE	'REDBUD 345KV'	900	0.00173	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.89784	13
OKGE	'REDBUD 345KV'	421.65	0.00173	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.89784	13
OKGE	'SEMINOLE 138KV'	319.239	0.00195	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.89762	13
OKGE	'SEMINOLE 345KV'	507.6	0.00203	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.89754	13
OKGE	'TINKER 5G 138KV'	62	0.00276	OKGE	'FPLWND2 34KV'	101.9968	0.89957	-0.89681	13
OKGE	'AES 161KV'	78.99999	0.00036	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73441	15
OKGE	'HORSESHOE LAKE 138KV'	380	0.00255	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73222	15
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00255	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73222	15
OKGE	'HORSESHOE LAKE 138KV'	91	0.00255	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73222	15

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	HORSESHEOE LAKE 69KV'	16	0.00245	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73232	15
OKGE	MCCLAIN 138KV'	42	0.00386	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73091	15
OKGE	MUSKOGEE 161KV'	31	0.00043	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73434	15
OKGE	MUSKOGEE 161KV'	166	0.00043	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73434	15
OKGE	MUSKOGEE 345KV'	20	0.00051	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73426	15
OKGE	MUSTANG 138KV'	365.5	0.00418	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73059	15
OKGE	MUSTANG 69KV'	106	0.00454	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73023	15
OKGE	ONE OAK 345KV'	336	0.00168	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73309	15
OKGE	REDBUD 345KV'	900	0.00173	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73304	15
OKGE	REDBUD 345KV'	421.65	0.00173	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73304	15
OKGE	SEMINOLE 138KV'	319.239	0.00195	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73282	15
OKGE	SEMINOLE 345KV'	507.6	0.00203	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73274	15
OKGE	SOONER 138KV'	24.99997	-0.00271	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73748	15
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.01641	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.75118	15
OKGE	TINKER 5G 138KV'	62	0.00276	OKGE	'SLEEPING BEAR 34KV'	120	0.73477	-0.73201	15

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: FT SUPPLY - IODINE 138KV CKT 1  
 Flowgate: 55919559201559205595711107G  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1023236		10.1	10.1						
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WFEC	MORLND 138KV'	320	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	10

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: FT SUPPLY - IODINE 138KV CKT 1  
 Flowgate: 55919559201559205595713106WP  
 Date Redispatch Needed: 12/1/06 - 4/1/07  
 Season Flowgate Identified: 2006 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1023236		12.6	12.6						
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WFEC	ANADARKO 138KV'	6,501,755	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	13
WFEC	ANADARKO 138KV'	90	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	13
WFEC	ANADARKO 69KV	76	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	13
WFEC	MORLND 138KV'	166,1695	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	13

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: FT SUPPLY - IODINE 138KV CKT 1  
 Flowgate: 55919559201559205595713107AP  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 April Minimum

Reservation	Relief Amount	Aggregate Relief Amount							
1023236		11.3	11.3						
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WFEC	ANADARKO 138KV'	260,5816	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	11
WFEC	ANADARKO 138KV'	90	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	11
WFEC	ANADARKO 69KV	76	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	11
WFEC	HUGO 138KV'	191,9206	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	11
WFEC	MORLND 138KV'	320	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	11

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: FT SUPPLY - IODINE 138KV CKT 1  
 Flowgate: 55919559201559205595713107FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1023236		13.2	13.2						
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WFEC	ANADARKO 138KV'	90	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	13
WFEC	ANADARKO 138KV'	56,21384	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	13
WFEC	ANADARKO 69KV	76	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	13
WFEC	MORLND 138KV'	320	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	13

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138/69KV TRANSFORMER CKT 1

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Limiting Facility: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: FT SUPPLY - IODINE 138KV CKT 1  
 Flowgate: 5591959201559205595713107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
WFEC	'ANADARKO 138KV'	90	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	12	
WFEC	'ANADARKO 138KV'	6,439758	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	12	
WFEC	'ANADARKO 69KV'	76	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	12	
WFEC	'MORLND 138KV'	39,60681	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	12	

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: FT SUPPLY - IODINE 138KV CKT 1  
 Flowgate: 5591959201559205595713107WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
WFEC	'ANADARKO 138KV'	90	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	13	
WFEC	'ANADARKO 138KV'	6,419029	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	13	
WFEC	'ANADARKO 69KV'	76	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	13	
WFEC	'MORLND 138KV'	148,9085	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	13	

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: FT SUPPLY - IODINE 138KV CKT 1  
 Flowgate: 5591959201559205595713307SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
WFEC	'ANADARKO 138KV'	9,366776	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	13	
WFEC	'ANADARKO 138KV'	90	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	13	
WFEC	'ANADARKO 69KV'	76	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	13	
WFEC	'MORLND 138KV'	173,8576	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	13	

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: IODINE - MOORELAND 138KV CKT 1  
 Flowgate: 5591959201559575599911107G  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
WFEC	'MORLND 138KV'	320	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	7	

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: IODINE - MOORELAND 138KV CKT 1  
 Flowgate: 5591959201559575599913106WP  
 Date Redispatch Needed: 12/1/06 - 4/1/07  
 Season Flowgate Identified: 2006 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
WFEC	'ANADARKO 138KV'	90	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	9	
WFEC	'ANADARKO 138KV'	6,501755	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	9	
WFEC	'ANADARKO 69KV'	76	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	9	
WFEC	'MORLND 138KV'	166,1695	0	WFEC	'SLEEPING BEAR 138KV'	80	1	-1	9	

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138/69KV TRANSFORMER CKT 1

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Limiting Facility: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: IODINE - MOORELAND 138KV CKT 1  
 Flowgate: 55919559201559575599913107AP  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 April Minimum

Reservation	Relief Amount	Aggregate Relief Amount									
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)		
WFEC	'ANADARKO 138KV'	260.5816	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	10		
WFEC	'ANADARKO 138KV'	90	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	10		
WFEC	'ANADARKO 69KV'	76	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	10		
WFEC	'HUGO 138KV'	191.9206	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	10		
WFEC	'MORLND 138KV'	320	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	10		

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: IODINE - MOORELAND 138KV CKT 1  
 Flowgate: 55919559201559575599913107FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount									
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)		
WFEC	'ANADARKO 138KV'	56.21384	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	10		
WFEC	'ANADARKO 138KV'	90	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	10		
WFEC	'ANADARKO 69KV'	76	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	10		
WFEC	'MORLND 138KV'	320	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	10		

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: IODINE - MOORELAND 138KV CKT 1  
 Flowgate: 55919559201559575599913107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount									
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)		
WFEC	'ANADARKO 138KV'	90	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	8		
WFEC	'ANADARKO 138KV'	6.439758	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	8		
WFEC	'ANADARKO 69KV'	76	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	8		
WFEC	'MORLND 138KV'	39.60681	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	8		

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: IODINE - MOORELAND 138KV CKT 1  
 Flowgate: 55919559201559575599913107WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount									
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)		
WFEC	'ANADARKO 138KV'	90	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	9		
WFEC	'ANADARKO 138KV'	6.419029	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	9		
WFEC	'ANADARKO 69KV'	76	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	9		
WFEC	'MORLND 138KV'	148.9085	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	9		

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138/69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: IODINE - MOORELAND 138KV CKT 1  
 Flowgate: 55919559201559575599913307SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount									
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)		
WFEC	'ANADARKO 138KV'	9.366776	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	9		
WFEC	'ANADARKO 138KV'	90	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	9		
WFEC	'ANADARKO 69KV'	76	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	9		
WFEC	'MORLND 138KV'	173.8576	0 WFEC	'SLEEPING BEAR 138KV'		80	1	-1	9		

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Redispatch Amount = Relief Amount / Factor

Upgrade: GRAY TAP - PENSACOLA 69KV CKT 1  
 Limiting Facility: GRAY TAP - PENSACOLA 69KV CKT 1  
 Direction: To->From  
 Line Outage: KANSAS - KANSAS TAP 161KV CKT 1  
 Flowgate: 54465544281545165451413108SP  
 Date Redispatch Needed: Starting 2008 6/1 - 10/1 Until EOC  
 Season Flowgate Identified: 2008 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount								
977481		0.6								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
GRDA	KERR 161KV'	28.5	0.01034	GRDA	'PENSACOLA 69KV'	6.50354	0.12967	-0.11933	5	
GRDA	SALINA 161KV'	72.45568	0.01034	GRDA	'PENSACOLA 69KV'	6.50354	0.12967	-0.11933	5	
GRDA	KERR 115KV'	28.5	0.01611	GRDA	'PENSACOLA 69KV'	6.50354	0.12967	-0.11356	6	

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: GRAY TAP - PENSACOLA 69KV CKT 1  
 Limiting Facility: GRAY TAP - PENSACOLA 69KV CKT 1  
 Direction: To->From  
 Line Outage: KANSAS (KANAUOTO1) 161/69/13.8KV TRANSFORMER CKT 1  
 Flowgate: 54465544281KANSAUTO15213108SP  
 Date Redispatch Needed: Starting 2008 6/1 - 10/1 Until EOC  
 Season Flowgate Identified: 2008 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount								
977481		0.6								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
GRDA	KERR 161KV'	28.5	0.01034	GRDA	'PENSACOLA 69KV'	6.50354	0.12967	-0.11933	5	
GRDA	SALINA 161KV'	72.45568	0.01034	GRDA	'PENSACOLA 69KV'	6.50354	0.12967	-0.11933	5	
GRDA	KERR 115KV'	28.5	0.01611	GRDA	'PENSACOLA 69KV'	6.50354	0.12967	-0.11356	6	

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: HAMON BUTLER - MOREWOOD 69KV CKT 1  
 Limiting Facility: HAMON BUTLER - MOREWOOD 69KV CKT 1  
 Direction: From->To  
 Line Outage: MOORELAND - MOREWOOD SW 138KV CKT 1  
 Flowgate: 55942560001559995600111206SP  
 Date Redispatch Needed: 6/1/06 - 10/1/06  
 Season Flowgate Identified: 2006 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount								
1032973		6.8								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
OKGE	MUSKOGEE 161KV'	31	0.001	OKGE	'SLEEPING BEAR 34KV'	120	0.08619	-0.08519	80	
OKGE	MUSKOGEE 161KV'	166	0.001	OKGE	'SLEEPING BEAR 34KV'	120	0.08619	-0.08519	80	
OKGE	HORSESHOE LAKE 138KV'	337.7	0.00194	OKGE	'SLEEPING BEAR 34KV'	120	0.08619	-0.08425	81	
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00194	OKGE	'SLEEPING BEAR 34KV'	120	0.08619	-0.08425	81	
OKGE	MCCLAIN 138KV'	42	0.00178	OKGE	'SLEEPING BEAR 34KV'	120	0.08619	-0.08441	81	
OKGE	REDBUD 345KV'	421.65	0.00226	OKGE	'SLEEPING BEAR 34KV'	120	0.08619	-0.08393	81	
OKGE	REDBUD 345KV'	253	0.00226	OKGE	'SLEEPING BEAR 34KV'	120	0.08619	-0.08393	81	
OKGE	MUSTANG 138KV'	142.3459	0.00252	OKGE	'SLEEPING BEAR 34KV'	120	0.08619	-0.08367	82	
OKGE	ONE OAK 345KV'	261	0.00297	OKGE	'SLEEPING BEAR 34KV'	120	0.08619	-0.08322	82	
OKGE	MCCLAIN 138KV'	42	0.00178	OKGE	'FPLWND2 34KV'	101.9968	0.08263	-0.08085	84	
OKGE	MUSKOGEE 161KV'	166	0.001	OKGE	'FPLWND2 34KV'	101.9968	0.08263	-0.08163	84	
OKGE	MUSKOGEE 161KV'	31	0.001	OKGE	'FPLWND2 34KV'	101.9968	0.08263	-0.08163	84	
OKGE	HORSESHOE LAKE 138KV'	337.7	0.00194	OKGE	'FPLWND2 34KV'	101.9968	0.08263	-0.08069	85	
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00194	OKGE	'FPLWND2 34KV'	101.9968	0.08263	-0.08069	85	
OKGE	MUSTANG 138KV'	142.3459	0.00252	OKGE	'FPLWND2 34KV'	101.9968	0.08263	-0.08011	85	
OKGE	REDBUD 345KV'	253	0.00226	OKGE	'FPLWND2 34KV'	101.9968	0.08263	-0.08037	85	
OKGE	REDBUD 345KV'	421.65	0.00226	OKGE	'FPLWND2 34KV'	101.9968	0.08263	-0.08037	85	
OKGE	ONE OAK 345KV'	261	0.00297	OKGE	'FPLWND2 34KV'	101.9968	0.08263	-0.07966	86	
OKGE	CONTINENTAL EMPIRE 138KV'	63	0.00765	OKGE	'SLEEPING BEAR 34KV'	120	0.08619	-0.07854	87	
OKGE	CONTINENTAL EMPIRE 138KV'	63	0.00765	OKGE	'FPLWND2 34KV'	101.9968	0.08263	-0.07498	91	
OKGE	SOUTH 4TH ST 69KV'	42.7	0.02113	OKGE	'SLEEPING BEAR 34KV'	120	0.08619	-0.06506	105	
OKGE	SOUTH 4TH ST 69KV'	42.7	0.02113	OKGE	'FPLWND2 34KV'	101.9968	0.08263	-0.06151	111	

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: HAMON BUTLER - MOREWOOD 69KV CKT 1  
 Limiting Facility: HAMON BUTLER - MOREWOOD 69KV CKT 1  
 Direction: From->To  
 Line Outage: MOORELAND - MOREWOOD SW 138KV CKT 1  
 Flowgate: 55942560001559995600111206WP  
 Date Redispatch Needed: 12/1/06 - 4/1/07  
 Season Flowgate Identified: 2006 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount								
1023236		2.9								
1032973		4.3								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
OKGE	MUSKOGEE 161KV'	31	0.00099	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08929	81	
OKGE	SEMINOLE 138KV'	395.2155	0.00043	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08985	81	
OKGE	SEMINOLE 345KV'	558.5093	0.00091	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08937	81	
OKGE	HORSESHOE LAKE 138KV'	380	0.00194	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08834	82	
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00194	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08834	82	
OKGE	HORSESHOE LAKE 138KV'	91	0.00194	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08834	82	
OKGE	MCCLAIN 138KV'	42	0.00172	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08856	82	
OKGE	REDBUD 345KV'	900	0.00223	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08805	82	

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	REDBUD 345KV'	421.65	0.00223	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08805	82
OKGE	TINKER 5G 138KV'	62	0.00166	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08862	82
OKGE	MUSTANG 138KV'	365.5	0.00244	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08784	83
OKGE	MUSTANG 69KV'	106	0.00321	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08707	83
OKGE	ONE OAK 345KV'	336	0.00294	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08734	83
OKGE	SEMINOLE 138KV'	395.2155	0.00043	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08421	86
OKGE	MUSKOGEE 161KV'	31	0.00059	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08365	87
OKGE	SEMINOLE 345KV'	558.5093	0.00091	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08373	87
OKGE	CONTINENTAL EMPIRE 138KV'	63	0.00775	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08253	88
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00194	OKGE	'FPLWND2 34KV'	102	0.08464	-0.0827	88
OKGE	HORSESHOE LAKE 138KV'	380	0.00194	OKGE	'FPLWND2 34KV'	102	0.08464	-0.0827	88
OKGE	HORSESHOE LAKE 138KV'	91	0.00194	OKGE	'FPLWND2 34KV'	102	0.08464	-0.0827	88
OKGE	MCCLAIN 138KV'	42	0.00172	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08292	88
OKGE	MUSTANG 138KV'	365.5	0.00244	OKGE	'FPLWND2 34KV'	102	0.08464	-0.0822	88
OKGE	REDBUD 345KV'	421.65	0.00223	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08241	88
OKGE	REDBUD 345KV'	900	0.00223	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08241	88
OKGE	TINKER 5G 138KV'	62	0.00166	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08298	88
OKGE	MUSTANG 69KV'	106	0.00321	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08143	89
OKGE	ONE OAK 345KV'	336	0.00294	OKGE	'FPLWND2 34KV'	102	0.08464	-0.0817	89
OKGE	CONTINENTAL EMPIRE 138KV'	63	0.00775	OKGE	'FPLWND2 34KV'	102	0.08464	-0.07689	94
OKGE	SOUTH 4TH ST 69KV'	42.7	0.02149	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.06879	106
OKGE	SOUTH 4TH ST 69KV'	42.7	0.02149	OKGE	'FPLWND2 34KV'	102	0.08464	-0.06315	115

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: HAMON BUTLER - MOREWOOD 69KV CKT 1  
 Limiting Facility: HAMON BUTLER - MOREWOOD 69KV CKT 1  
 Direction: From->To  
 Line Outage: MOORELAND - MOREWOOD SW 138KV CKT 1  
 Flowgate: 55942560001559995600111207AP  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 April Minimum

Reservation	Relief Amount	Aggregate Relief Amount							
1023236	0.8	2.1							
1032973	1.2	2.1							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	AES 161KV'	160	0.0006	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08967	23
OKGE	HORSESHOE LAKE 138KV'	380	0.00194	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08833	23
OKGE	HORSESHOE LAKE 138KV'	91	0.00194	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08833	23
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00194	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08833	23
OKGE	HORSESHOE LAKE 69KV'	16	0.00172	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08855	23
OKGE	MCCLAIN 138KV'	520	0.00172	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08855	23
OKGE	MUSKOGEE 161KV'	31	0.001	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08927	23
OKGE	MUSKOGEE 161KV'	166	0.001	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08927	23
OKGE	MUSKOGEE 345KV'	714.519	0.00097	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.0893	23
OKGE	SEMINOLE 138KV'	507.6138	0.00043	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08984	23
OKGE	SEMINOLE 345KV'	996.6	0.00092	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08935	23
OKGE	TINKER 5G 138KV'	62	0.00166	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08861	23
OKGE	MUSTANG 138KV'	365.5	0.00244	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08783	24
OKGE	MUSTANG 69KV'	106	0.00321	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08706	24
OKGE	ONE OAK 345KV'	336	0.00295	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08732	24
OKGE	REDBUD 345KV'	421.65	0.00223	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08804	24
OKGE	REDBUD 345KV'	900	0.00223	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08804	24
OKGE	SMITH COGEN 138KV'	110	0.00228	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08799	24
OKGE	AES 161KV'	160	0.0006	OKGE	'FPLWND2 34KV'	102	0.08463	-0.08403	25
OKGE	HORSESHOE LAKE 138KV'	91	0.00194	OKGE	'FPLWND2 34KV'	102	0.08463	-0.08269	25
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00194	OKGE	'FPLWND2 34KV'	102	0.08463	-0.08269	25
OKGE	HORSESHOE LAKE 138KV'	380	0.00194	OKGE	'FPLWND2 34KV'	102	0.08463	-0.08269	25
OKGE	HORSESHOE LAKE 69KV'	16	0.00172	OKGE	'FPLWND2 34KV'	102	0.08463	-0.08291	25
OKGE	MCCLAIN 138KV'	520	0.00172	OKGE	'FPLWND2 34KV'	102	0.08463	-0.08291	25
OKGE	MUSKOGEE 161KV'	31	0.001	OKGE	'FPLWND2 34KV'	102	0.08463	-0.08363	25
OKGE	MUSKOGEE 161KV'	166	0.001	OKGE	'FPLWND2 34KV'	102	0.08463	-0.08363	25
OKGE	MUSKOGEE 345KV'	714.519	0.00097	OKGE	'FPLWND2 34KV'	102	0.08463	-0.08366	25
OKGE	MUSTANG 138KV'	365.5	0.00244	OKGE	'FPLWND2 34KV'	102	0.08463	-0.08219	25
OKGE	MUSTANG 69KV'	106	0.00321	OKGE	'FPLWND2 34KV'	102	0.08463	-0.08142	25
OKGE	ONE OAK 345KV'	336	0.00295	OKGE	'FPLWND2 34KV'	102	0.08463	-0.08168	25
OKGE	REDBUD 345KV'	900	0.00223	OKGE	'FPLWND2 34KV'	102	0.08463	-0.0824	25
OKGE	REDBUD 345KV'	421.65	0.00223	OKGE	'FPLWND2 34KV'	102	0.08463	-0.0824	25
OKGE	SEMINOLE 138KV'	507.6138	0.00043	OKGE	'FPLWND2 34KV'	102	0.08463	-0.0842	25
OKGE	SEMINOLE 345KV'	996.6	0.00092	OKGE	'FPLWND2 34KV'	102	0.08463	-0.08371	25
OKGE	SMITH COGEN 138KV'	110	0.00228	OKGE	'FPLWND2 34KV'	102	0.08463	-0.08235	25
OKGE	SOONER 138KV'	24.9997	0.0068	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.08347	25
OKGE	TINKER 5G 138KV'	62	0.00166	OKGE	'FPLWND2 34KV'	102	0.08463	-0.08297	25
OKGE	SOONER 138KV'	24.9997	0.0068	OKGE	'FPLWND2 34KV'	102	0.08463	-0.07783	27
OKGE	SOUTH 4TH ST 69KV'	42.7	0.02149	OKGE	'SLEEPING BEAR 34KV'	120	0.09027	-0.06878	30
OKGE	SOUTH 4TH ST 69KV'	42.7	0.02149	OKGE	'FPLWND2 34KV'	102	0.08463	-0.06314	33

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: HAMON BUTLER - MOREWOOD 69KV CKT 1  
 Limiting Facility: HAMON BUTLER - MOREWOOD 69KV CKT 1  
 Direction: From->To  
 Line Outage: MOORELAND - MOREWOOD SW 138KV CKT 1  
 Flowgate: 55942560001559995600111207SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount							
1023236	1.1	2.8							
1032973	1.7	2.8							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00195	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08834	32
OKGE	HORSESHOE LAKE 138KV'	380	0.00195	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08834	32
OKGE	MCCLAIN 138KV'	42	0.00175	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08854	32
OKGE	MUSKOGEE 161KV'	166	0.001	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08929	32
OKGE	MUSKOGEE 161KV'	31	0.001	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08929	32
OKGE	MUSKOGEE 345KV'	20	0.00098	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08931	32
OKGE	MUSTANG 138KV'	365.5	0.00244	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08785	32

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	ONE OAK 345KV'	274	0.00295	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08734	32
OKGE	REDBUD 345KV'	421.65	0.00224	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08805	32
OKGE	REDBUD 345KV'	900	0.00224	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08805	32
OKGE	SEMINOLE 138KV'	21.4325	0.00044	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08985	32
OKGE	TINKER 5G 138KV'	62	0.00167	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08862	32
OKGE	MUSTANG 69KV'	55.60448	0.00321	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08708	33
OKGE	HORSESHOE LAKE 138KV'	380	0.00195	OKGE	'FPLWND2 34KV'	102	0.08465	-0.0827	34
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00195	OKGE	'FPLWND2 34KV'	102	0.08465	-0.0827	34
OKGE	MCCLAIN 138KV'	42	0.00175	OKGE	'FPLWND2 34KV'	102	0.08465	-0.0829	34
OKGE	MUSKOGEE 161KV'	166	0.001	OKGE	'FPLWND2 34KV'	102	0.08465	-0.08365	34
OKGE	MUSKOGEE 161KV'	31	0.001	OKGE	'FPLWND2 34KV'	102	0.08465	-0.08365	34
OKGE	MUSKOGEE 345KV'	20	0.00098	OKGE	'FPLWND2 34KV'	102	0.08465	-0.08367	34
OKGE	MUSTANG 138KV'	365.5	0.00244	OKGE	'FPLWND2 34KV'	102	0.08465	-0.08221	34
OKGE	REDBUD 345KV'	421.65	0.00224	OKGE	'FPLWND2 34KV'	102	0.08465	-0.08241	34
OKGE	REDBUD 345KV'	900	0.00224	OKGE	'FPLWND2 34KV'	102	0.08465	-0.08241	34
OKGE	SEMINOLE 138KV'	21.4325	0.00044	OKGE	'FPLWND2 34KV'	102	0.08465	-0.08421	34
OKGE	SOONER 138KV'	24.99997	0.0068	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08349	34
OKGE	TINKER 5G 138KV'	62	0.00167	OKGE	'FPLWND2 34KV'	102	0.08465	-0.08298	34
OKGE	MUSTANG 69KV'	55.60448	0.00321	OKGE	'FPLWND2 34KV'	102	0.08465	-0.08144	35
OKGE	ONE OAK 345KV'	274	0.00295	OKGE	'FPLWND2 34KV'	102	0.08465	-0.0817	35
OKGE	SOONER 138KV'	24.99997	0.0068	OKGE	'FPLWND2 34KV'	102	0.08465	-0.07785	36
OKGE	SOUTH 4TH ST 69KV'	42.7	0.02149	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.0688	41
OKGE	SOUTH 4TH ST 69KV'	42.7	0.02149	OKGE	'FPLWND2 34KV'	102	0.08465	-0.06316	45

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: HAMON BUTLER - MOREWOOD 69KV CKT 1  
 Limiting Facility: HAMON BUTLER - MOREWOOD 69KV CKT 1  
 Direction: From->To  
 Line Outage: MOORELAND - MOREWOOD SW 138KV CKT 1  
 Flowgate: 55942560001559995600111407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1023236		4.6	11.4						
1032973		6.8	11.4						
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	TINKER 5G 138KV'	62	0.00167	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08862	129
OKGE	HORSESHOE LAKE 138KV'	291.8916	0.00194	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08835	130
OKGE	REDBUD 345KV'	421.65	0.00224	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08805	130
OKGE	REDBUD 345KV'	900	0.00224	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08805	130
OKGE	ONE OAK 345KV'	261	0.00295	OKGE	'SLEEPING BEAR 34KV'	120	0.09029	-0.08734	131
OKGE	MUSKOGEE 161KV'	166	0.00099	OKGE	'FPLWND2 34KV'	102	0.08465	-0.08366	137
OKGE	HORSESHOE LAKE 138KV'	291.8916	0.00194	OKGE	'FPLWND2 34KV'	102	0.08465	-0.08271	138
OKGE	TINKER 5G 138KV'	62	0.00167	OKGE	'FPLWND2 34KV'	102	0.08465	-0.08298	138
OKGE	REDBUD 345KV'	421.65	0.00224	OKGE	'FPLWND2 34KV'	102	0.08465	-0.08241	139
OKGE	REDBUD 345KV'	900	0.00224	OKGE	'FPLWND2 34KV'	102	0.08465	-0.08241	139
OKGE	ONE OAK 345KV'	261	0.00295	OKGE	'FPLWND2 34KV'	102	0.08465	-0.0817	140

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: HAMON BUTLER - MOREWOOD 69KV CKT 1  
 Limiting Facility: HAMON BUTLER - MOREWOOD 69KV CKT 1  
 Direction: From->To  
 Line Outage: MOORELAND - MOREWOOD SW 138KV CKT 1  
 Flowgate: 55942560001559995600111407WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1023236		2.5	6.2						
1032973		3.7	6.2						
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	AES 161KV'	78.99995	0.00058	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.0897	69
OKGE	MUSKOGEE 161KV'	166	0.00098	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.0893	69
OKGE	MUSKOGEE 161KV'	31	0.00098	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.0893	69
OKGE	SEMINOLE 138KV'	305.394	0.00043	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08985	69
OKGE	SEMINOLE 345KV'	507.6	0.00091	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08937	69
OKGE	TINKER 5G 138KV'	62	0.00165	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08863	69
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00193	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08835	70
OKGE	HORSESHOE LAKE 138KV'	91	0.00193	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08835	70
OKGE	HORSESHOE LAKE 138KV'	380	0.00193	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08835	70
OKGE	MCCLAIN 138KV'	42	0.00173	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08855	70
OKGE	MUSTANG 138KV'	365.5	0.00242	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08786	70
OKGE	ONE OAK 345KV'	319	0.00294	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08734	70
OKGE	REDBUD 345KV'	421.65	0.00223	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08805	70
OKGE	REDBUD 345KV'	900	0.00223	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08805	70
OKGE	MUSTANG 69KV'	106	0.00319	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08709	71
OKGE	AES 161KV'	78.99995	0.00058	OKGE	'FPLWND2 34KV'	101.9968	0.08464	-0.08406	73
OKGE	SEMINOLE 138KV'	305.394	0.00043	OKGE	'FPLWND2 34KV'	101.9968	0.08464	-0.08421	73
OKGE	HORSESHOE LAKE 138KV'	380	0.00193	OKGE	'FPLWND2 34KV'	101.9968	0.08464	-0.08271	74
OKGE	HORSESHOE LAKE 138KV'	91	0.00193	OKGE	'FPLWND2 34KV'	101.9968	0.08464	-0.08271	74
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00193	OKGE	'FPLWND2 34KV'	101.9968	0.08464	-0.08271	74
OKGE	MCCLAIN 138KV'	42	0.00173	OKGE	'FPLWND2 34KV'	101.9968	0.08464	-0.08291	74
OKGE	MUSKOGEE 161KV'	34	0.00098	OKGE	'FPLWND2 34KV'	101.9968	0.08464	-0.08366	74
OKGE	MUSKOGEE 161KV'	166	0.00098	OKGE	'FPLWND2 34KV'	101.9968	0.08464	-0.08366	74
OKGE	SEMINOLE 345KV'	507.6	0.00091	OKGE	'FPLWND2 34KV'	101.9968	0.08464	-0.08373	74
OKGE	SOONER 138KV'	24.99997	0.00678	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.0835	74
OKGE	TINKER 5G 138KV'	62	0.00165	OKGE	'FPLWND2 34KV'	101.9968	0.08464	-0.08299	74
OKGE	MUSTANG 138KV'	365.5	0.00242	OKGE	'FPLWND2 34KV'	101.9968	0.08464	-0.08222	75
OKGE	ONE OAK 345KV'	319	0.00294	OKGE	'FPLWND2 34KV'	101.9968	0.08464	-0.0817	75
OKGE	REDBUD 345KV'	421.65	0.00223	OKGE	'FPLWND2 34KV'	101.9968	0.08464	-0.08241	75
OKGE	MUSTANG 69KV'	106	0.00319	OKGE	'FPLWND2 34KV'	101.9968	0.08464	-0.08145	76
OKGE	SOUTH 4TH ST 69KV'	42.7	0.02148	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.0688	89
OKGE	SOUTH 4TH ST 69KV'	42.7	0.02148	OKGE	'FPLWND2 34KV'	101.9968	0.08464	-0.06316	97

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Redispatch Amount = Relief Amount / Factor

Upgrade: IODINE - WOODWARD 138kV CKT 1  
 Limiting Facility: MOORELAND 138/69kV TRANSFORMER CKT 1  
 Direction: To->From  
 Line Outage: FPL SWITCH - MOORELAND 138kV CKT 1  
 Flowgate: 55995559991559995578511206SH  
 Date Redispatch Needed: 6/1/06 - 10/1/06  
 Season Flowgate Identified: 2006 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount	Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1032973		10.0										
		10.0										
Source Control Area	Source											
OKGE	'CONTINENTAL EMPIRE 138KV'	63	-0.00055	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50514	20
OKGE	'CONTINENTAL EMPIRE 138KV'	63	-0.00055	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50514	20
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00027	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50432	20
OKGE	'HORSESHOE LAKE 138KV'	380	0.00027	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50432	20
OKGE	'HORSESHOE LAKE 138KV'	91	0.00027	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50432	20
OKGE	'HORSESHOE LAKE 138KV'	380	0.00027	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50432	20
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00027	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50432	20
OKGE	'HORSESHOE LAKE 138KV'	91	0.00027	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50432	20
OKGE	'HORSESHOE LAKE 69KV'	16	0.00027	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50432	20
OKGE	'HORSESHOE LAKE 69KV'	16	0.00027	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50432	20
OKGE	'MCCLAIN 138KV'	42	0.00044	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50415	20
OKGE	'MCCLAIN 138KV'	42	0.00044	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50415	20
OKGE	'MUSKOGEE 161KV'	31	0.00004	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50455	20
OKGE	'MUSKOGEE 161KV'	166	0.00004	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50455	20
OKGE	'MUSKOGEE 161KV'	31	0.00004	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50455	20
OKGE	'MUSKOGEE 161KV'	166	0.00004	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50455	20
OKGE	'MUSTANG 138KV'	365.5	0.00044	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50415	20
OKGE	'MUSTANG 138KV'	365.5	0.00044	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50415	20
OKGE	'MUSTANG 69KV'	106	0.00049	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50411	20
OKGE	'MUSTANG 69KV'	106	0.00049	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50411	20
OKGE	'ONE OAK 345KV'	293	0.00015	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50444	20
OKGE	'ONE OAK 345KV'	293	0.00015	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50444	20
OKGE	'REDBUD 345KV'	253	0.00017	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50442	20
OKGE	'REDBUD 345KV'	421.65	0.00017	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50442	20
OKGE	'REDBUD 345KV'	253	0.00017	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50442	20
OKGE	'REDBUD 345KV'	421.65	0.00017	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50442	20
OKGE	'SEMINOLE 138KV'	34.15036	0.00023	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50436	20
OKGE	'SEMINOLE 138KV'	34.15036	0.00023	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50436	20
OKGE	'SEMINOLE 345KV'	385.6923	0.00023	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50436	20
OKGE	'SEMINOLE 345KV'	385.6923	0.00023	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50436	20
OKGE	'SOONER 138KV'	24.99997	-0.00038	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50497	20
OKGE	'SOONER 138KV'	24.99997	-0.00038	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50497	20
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00198	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50657	20
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00198	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50657	20
OKGE	'TINKER 5G 138KV'	62	0.0003	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50429	20
OKGE	'TINKER 5G 138KV'	62	0.0003	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50429	20

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: IODINE - WOODWARD 138kV CKT 1  
 Limiting Facility: MOORELAND 138/69kV TRANSFORMER CKT 1  
 Direction: To->From  
 Line Outage: FPL SWITCH - MOORELAND 138kV CKT 1  
 Flowgate: 55995559991559995578511206FA  
 Date Redispatch Needed: 10/1/06 - 12/1/06  
 Season Flowgate Identified: 2006 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount	Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1032973		20.1										
		20.1										
Source Control Area	Source											
OKGE	'CONTINENTAL EMPIRE 138KV'	63	-0.00055	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50514	40
OKGE	'CONTINENTAL EMPIRE 138KV'	63	-0.00055	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50514	40
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00027	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50432	40
OKGE	'HORSESHOE LAKE 138KV'	380	0.00027	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50432	40
OKGE	'HORSESHOE LAKE 138KV'	91	0.00027	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50432	40
OKGE	'HORSESHOE LAKE 138KV'	380	0.00027	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50432	40
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00027	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50432	40
OKGE	'HORSESHOE LAKE 138KV'	91	0.00027	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50432	40
OKGE	'HORSESHOE LAKE 69KV'	16	0.00026	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50433	40
OKGE	'HORSESHOE LAKE 69KV'	16	0.00026	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50433	40
OKGE	'MCCLAIN 138KV'	42	0.00044	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50415	40
OKGE	'MCCLAIN 138KV'	42	0.00044	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50415	40
OKGE	'MUSKOGEE 161KV'	166	0.00004	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50455	40
OKGE	'MUSKOGEE 161KV'	31	0.00004	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50455	40
OKGE	'MUSKOGEE 161KV'	166	0.00004	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50455	40
OKGE	'MUSKOGEE 345KV'	20	0.00006	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50453	40
OKGE	'MUSKOGEE 345KV'	20	0.00006	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50453	40
OKGE	'MUSTANG 138KV'	365.5	0.00044	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50415	40
OKGE	'MUSTANG 138KV'	365.5	0.00044	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50415	40
OKGE	'MUSTANG 69KV'	106	0.00049	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50411	40
OKGE	'MUSTANG 69KV'	106	0.00049	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50411	40
OKGE	'ONE OAK 345KV'	336	0.00015	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50444	40
OKGE	'ONE OAK 345KV'	336	0.00015	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50444	40
OKGE	'REDBUD 345KV'	421.65	0.00017	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50442	40
OKGE	'REDBUD 345KV'	900	0.00017	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50442	40
OKGE	'REDBUD 345KV'	900	0.00017	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50442	40
OKGE	'REDBUD 345KV'	421.65	0.00017	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50442	40
OKGE	'SEMINOLE 138KV'	241.6956	0.00023	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50436	40
OKGE	'SEMINOLE 138KV'	241.6956	0.00023	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50436	40
OKGE	'SEMINOLE 345KV'	507.6	0.00023	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50436	40
OKGE	'SEMINOLE 345KV'	507.6	0.00023	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50436	40
OKGE	'SOONER 138KV'	24.99997	-0.00038	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50497	40
OKGE	'SOONER 138KV'	24.99997	-0.00038	OKGE	'SLEEPING BEAR 34KV'				120	0.50459	-0.50497	40
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00198	OKGE	'FPLWND2 34KV'				102	0.50459	-0.50658	40

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00199	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50658	40
OKGE	TINKER 5G 138KV'	62	0.0003	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50429	40
OKGE	TINKER 5G 138KV'	62	0.0003	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50429	40

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: IODINE - WOODWARD 138kV CKT 1

Limiting Facility: MOORELAND - WOODWARD 69KV CKT 1

Direction: To->From

Line Outage: FPL SWITCH - MOORELAND 138KV CKT 1

Flowgate: 5599556096155999557851106SH

Date Redispatch Needed: 6/1/06 - 10/1/06

Season Flowgate Identified: 2006 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount								
1032973		13.7								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
OKGE	'CONTINENTAL EMPIRE 138KV'	63	-0.00055	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50514	27	
OKGE	'CONTINENTAL EMPIRE 138KV'	63	-0.00055	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50514	27	
OKGE	'HORSESHOE LAKE 138KV'	380	0.00027	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50432	27	
OKGE	'HORSESHOE LAKE 138KV'	91	0.00027	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50432	27	
OKGE	'HORSESHOE LAKE 138KV'	380	0.00027	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50432	27	
OKGE	'HORSESHOE LAKE 138KV'	91	0.00027	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50432	27	
OKGE	'HORSESHOE LAKE 69KV'	16	0.00027	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50432	27	
OKGE	'HORSESHOE LAKE 69KV'	16	0.00027	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50432	27	
OKGE	'MCCLAIN 138KV'	42	0.00044	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50415	27	
OKGE	'MCCLAIN 138KV'	42	0.00044	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50415	27	
OKGE	'MUSKOGEE 161KV'	31	0.00004	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50455	27	
OKGE	'MUSKOGEE 161KV'	166	0.00004	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50455	27	
OKGE	'MUSKOGEE 161KV'	31	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50455	27	
OKGE	'MUSKOGEE 161KV'	166	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50455	27	
OKGE	'MUSKOGEE 345KV'	20	0.00006	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50453	27	
OKGE	'MUSKOGEE 345KV'	20	0.00006	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50453	27	
OKGE	'MUSTANG 138KV'	365.5	0.00044	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50415	27	
OKGE	'MUSTANG 138KV'	365.5	0.00044	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50415	27	
OKGE	'MUSTANG 69KV'	106	0.00049	OKGE	'FPLWND2 34KV'	102	0.50459	-0.5041	27	
OKGE	'MUSTANG 69KV'	106	0.00049	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.5041	27	
OKGE	'ONE OAK 345KV'	236	0.00015	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50444	27	
OKGE	'ONE OAK 345KV'	236	0.00015	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50444	27	
OKGE	'REDBUD 345KV'	421.65	0.00017	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50442	27	
OKGE	'REDBUD 345KV'	460	0.00017	OKGE	'SLEEPING BEAR 34KV'	102	0.50459	-0.50442	27	
OKGE	'REDBUD 345KV'	460	0.00017	OKGE	'FPLWND2 34KV'	120	0.50459	-0.50442	27	
OKGE	'REDBUD 345KV'	421.65	0.00017	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50442	27	
OKGE	'SEMINOLE 138KV'	47.215	0.00023	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50436	27	
OKGE	'SEMINOLE 138KV'	47.215	0.00023	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50436	27	
OKGE	'SEMINOLE 345KV'	406.08	0.00023	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50436	27	
OKGE	'SEMINOLE 345KV'	406.08	0.00023	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50436	27	
OKGE	'SOONER 138KV'	24.99997	-0.00038	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50497	27	
OKGE	'SOONER 138KV'	24.99997	-0.00038	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50497	27	
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00198	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50657	27	
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00198	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50657	27	
OKGE	'TINKER 5G 138KV'	62	0.0003	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50429	27	
OKGE	'TINKER 5G 138KV'	62	0.0003	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50429	27	

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: IODINE - WOODWARD 138kV CKT 1

Limiting Facility: MOORELAND - WOODWARD 69KV CKT 1

Direction: To->From

Line Outage: FPL SWITCH - MOORELAND 138KV CKT 1

Flowgate: 5599556096155999557851106FA

Date Redispatch Needed: 10/1/06 - 12/1/06

Season Flowgate Identified: 2006 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount								
1032973		21.4								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
OKGE	'CONTINENTAL EMPIRE 138KV'	63	-0.00055	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50514	42	
OKGE	'CONTINENTAL EMPIRE 138KV'	63	-0.00055	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50514	42	
OKGE	'MUSKOGEE 161KV'	166	0.00004	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50455	42	
OKGE	'MUSKOGEE 161KV'	166	0.00004	OKGE	'SLEEPING BEAR 34KV'	102	0.50459	-0.50455	42	
OKGE	'MUSKOGEE 161KV'	31	0.00004	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50455	42	
OKGE	'MUSKOGEE 161KV'	166	0.00004	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50455	42	
OKGE	'MUSKOGEE 345KV'	20	0.00006	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50453	42	
OKGE	'MUSKOGEE 345KV'	20	0.00006	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50453	42	
OKGE	'ONE OAK 345KV'	336	0.00015	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50444	42	
OKGE	'ONE OAK 345KV'	336	0.00016	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50444	42	
OKGE	'REDBUD 345KV'	900	0.00017	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50442	42	
OKGE	'REDBUD 345KV'	421.65	0.00017	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50442	42	
OKGE	'REDBUD 345KV'	421.65	0.00017	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50442	42	
OKGE	'REDBUD 345KV'	900	0.00017	OKGE	'FPLWND2 34KV'	120	0.50459	-0.50442	42	
OKGE	'SEMINOLE 138KV'	243.9512	0.00023	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50436	42	
OKGE	'SEMINOLE 138KV'	243.9512	0.00023	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50436	42	
OKGE	'SEMINOLE 345KV'	507.6	0.00023	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50436	42	
OKGE	'SEMINOLE 345KV'	507.6	0.00023	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50436	42	
OKGE	'SOONER 138KV'	24.99997	-0.00038	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50497	42	
OKGE	'SOONER 138KV'	24.99997	-0.00038	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50497	42	
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00199	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50658	42	
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00199	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50658	42	
OKGE	'HORSESHOE LAKE 138KV'	91	0.00027	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50432	43	
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00027	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50432	43	
OKGE	'HORSESHOE LAKE 138KV'	380	0.00027	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50432	43	
OKGE	'HORSESHOE LAKE 138KV'	91	0.00027	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50432	43	
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00027	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50432	43	
OKGE	'HORSESHOE LAKE 69KV'	16	0.00026	OKGE	'FPLWND2 34KV'	102	0.50459	-0.50433	43	
OKGE	'HORSESHOE LAKE 69KV'	16	0.00026	OKGE	'SLEEPING BEAR 34KV'	120	0.50459	-0.50433	43	

**Table 6** - Potential Redispach Relief Pairs to Prevent Deferral of Service

OKGE	MCCLAIN 138KV'	42	0.00044	OKGE	FPLWN2D 34KV'	102	0.50459	-0.50415	43
OKGE	MCCLAIN 138KV'	42	0.00044	OKGE	SLEEPING BEAR 34KV'	120	0.50459	-0.50415	43
OKGE	MUSTANG 138KV'	365.5	0.00044	OKGE	FPLWN2D 34KV'	102	0.50459	-0.50415	43
OKGE	MUSTANG 138KV'	365.5	0.00044	OKGE	SLEEPING BEAR 34KV'	120	0.50459	-0.50415	43
OKGE	MUSTANG 69KV'	106	0.00049	OKGE	FPLWN2D 34KV'	102	0.50459	-0.5041	43
OKGE	MUSTANG 69KV'	106	0.00049	OKGE	SLEEPING BEAR 34KV'	120	0.50459	-0.5041	43
OKGE	TINKER 5G 138KV'	62	0.0003	OKGE	FPLWN2D 34KV'	102	0.50459	-0.50429	43
OKGE	TINKER 5G 138KV'	62	0.0003	OKGE	SLEEPING BEAR 34KV'	120	0.50459	-0.50429	43

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified. Factors - Source GSE, Sink GSE

Factor = Source GSF - Sink GSF  
Redispatch Amount = Relief Amo

Redispatch Amount = Relief Amount / Factor

Upgrade: IODINE - WOODWARD 138KV CKT 1  
Limiting Facility: MOORELAND - WOODWARD 69KV CKT 1  
Direction: To->From  
Line Outage: FPL SWITCH - MOORELAND 138KV CKT 1  
Flowgate: 559956096155999578511206SP  
Date Redispatch Needed: 6/1/06 - 10/06  
Season Flowgate Identified: 2006 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
	1032973	0.1	0.1						
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'CONTINENTAL EMPIRE 138KV'	63	-0.00055	OKGE	FPLWND2 34KV"	101.9968	0.50459	-0.50514	1
OKGE	'CONTINENTAL EMPIRE 138KV'	63	-0.00055	OKGE	'SLEEPING BEAR 34KV"	120	0.50459	-0.50514	1
OKGE	'HORSESHOE LAKE 138KV'	337.7	0.00027	OKGE	FPLWND2 34KV"	101.9968	0.50459	-0.50432	1
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00027	OKGE	FPLWND2 34KV"	101.9968	0.50459	-0.50432	1
OKGE	'HORSESHOE LAKE 138KV'	337.7	0.00027	OKGE	'SLEEPING BEAR 34KV"	120	0.50459	-0.50432	1
OKGE	'HORSESHOE LAKE 138KV'	380.5	0.00027	OKGE	'SLEEPING BEAR 34KV"	120	0.50459	-0.50432	1
OKGE	'MCCLAIN 138KV'	42	0.00044	OKGE	FPLWND2 34KV"	101.9968	0.50459	-0.50415	1
OKGE	'MCCLAIN 138KV'	42	0.00044	OKGE	'SLEEPING BEAR 34KV"	120	0.50459	-0.50415	1
OKGE	'MUSKOGEE 161KV'	166	0.00004	OKGE	FPLWND2 34KV"	101.9968	0.50459	-0.50455	1
OKGE	'MUSKOGEE 161KV'	31	0.00004	OKGE	FPLWND2 34KV"	101.9968	0.50459	-0.50455	1
OKGE	'MUSKOGEE 161KV'	166	0.00004	OKGE	'SLEEPING BEAR 34KV"	120	0.50459	-0.50455	1
OKGE	'MUSKOGEE 161KV'	31	0.00004	OKGE	'SLEEPING BEAR 34KV"	120	0.50459	-0.50455	1
OKGE	'MUSKOGEE 345KV'	20	0.00006	OKGE	FPLWND2 34KV"	101.9968	0.50459	-0.50453	1
OKGE	'MUSKOGEE 345KV'	20	0.00006	OKGE	'SLEEPING BEAR 34KV"	120	0.50459	-0.50453	1
OKGE	'MUSTANG 138KV'	142.3459	0.00044	OKGE	FPLWND2 34KV"	101.9968	0.50459	-0.50415	1
OKGE	'MUSTANG 138KV'	142.3459	0.00044	OKGE	'SLEEPING BEAR 34KV"	120	0.50459	-0.50415	1
OKGE	'ONE OAK 345KV'	261	0.00015	OKGE	FPLWND2 34KV"	101.9968	0.50459	-0.50444	1
OKGE	'ONE OAK 345KV'	261	0.00015	OKGE	'SLEEPING BEAR 34KV"	120	0.50459	-0.50444	1
OKGE	'REDBUD 345KV'	253	0.00017	OKGE	FPLWND2 34KV"	101.9968	0.50459	-0.50442	1
OKGE	'REDBUD 345KV'	421.65	0.00017	OKGE	FPLWND2 34KV"	101.9968	0.50459	-0.50442	1
OKGE	'REDBUD 345KV'	253	0.00017	OKGE	'SLEEPING BEAR 34KV"	120	0.50459	-0.50442	1
OKGE	'REDBUD 345KV'	421.65	0.00017	OKGE	'SLEEPING BEAR 34KV"	120	0.50459	-0.50442	1
OKGE	'SEMINOLE 138KV'	21.7803	0.00023	OKGE	FPLWND2 34KV"	101.9968	0.50459	-0.50436	1
OKGE	'SEMINOLE 138KV'	21.7803	0.00023	OKGE	'SLEEPING BEAR 34KV"	120	0.50459	-0.50436	1
OKGE	'SOONER 138KV'	24.99997	-0.00038	OKGE	FPLWND2 34KV"	101.9968	0.50459	-0.50497	1
OKGE	'SOONER 138KV'	24.99997	-0.00038	OKGE	'SLEEPING BEAR 34KV"	120	0.50459	-0.50497	1
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00198	OKGE	FPLWND2 34KV"	101.9968	0.50459	-0.50657	1
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00198	OKGE	'SLEEPING BEAR 34KV"	120	0.50459	-0.50657	1
OKGE	'TINKER 5G 138KV'	62	0.0003	OKGE	FPLWND2 34KV"	101.9968	0.50459	-0.50429	1
OKGE	'TINKER 5G 138KV'	62	0.0003	OKGE	'SLEEPING BEAR 34KV"	120	0.50459	-0.50429	1

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF  
Reservoir Amount - Relief Amount

**Redispatch Amount = Relief Amount / Factor**

Upgrade: IODINE - WOODWARD 138KV CKT 1  
Limiting Facility: WOODWARD - WOODWARD 69KV CKT 1  
Direction: From->To  
Line Outage: FPL SWITCH - MOORELAND 138KV CKT 1  
Flowgate: 5609654782155999575811106SH  
Date Redispatch Needed: 6/1/06 / 10/06  
Season Flowgate Identified: 2006 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount									
	1032973	80.2	80.2								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)		
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'FPLWND2 34KV'	102	1	-1	80		
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	80		
OKGE	'HORSESHOE LAKE 138KV'	91	0	OKGE	'FPLWND2 34KV'	102	1	-1	80		
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'FPLWND2 34KV'	102	1	-1	80		
OKGE	'HORSESHOE LAKE 138KV'	380	0	OKGE	'FPLWND2 34KV'	102	1	-1	80		
OKGE	'HORSESHOE LAKE 138KV'	91	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	80		
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	80		
OKGE	'HORSESHOE LAKE 138KV'	380	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	80		
OKGE	'MCCLAIN 138KV'	42	0	OKGE	'FPLWND2 34KV'	102	1	-1	80		
OKGE	'MCCLAIN 138KV'	42	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	80		
OKGE	'MUSKOGEEE 161KV'	31	0	OKGE	'FPLWND2 34KV'	102	1	-1	80		
OKGE	'MUSKOGEEE 161KV'	166	0	OKGE	'FPLWND2 34KV'	102	1	-1	80		
OKGE	'MUSKOGEEE 161KV'	31	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	80		
OKGE	'MUSKOGEEE 161KV'	166	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	80		
OKGE	'MUSTANG 138KV'	365.5	0	OKGE	'FPLWND2 34KV'	102	1	-1	80		
OKGE	'MUSTANG 138KV'	365.5	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	80		
OKGE	'MUSTANG 69KV'	106	0	OKGE	'FPLWND2 34KV'	102	1	-1	80		
OKGE	'MUSTANG 69KV'	106	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	80		
OKGE	'ONE OAK 345KV'	236	0	OKGE	'FPLWND2 34KV'	102	1	-1	80		
OKGE	'ONE OAK 345KV'	236	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	80		
OKGE	'REDBUD 345KV'	460	0	OKGE	'FPLWND2 34KV'	102	1	-1	80		
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'FPLWND2 34KV'	102	1	-1	80		
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	80		
OKGE	'REDBUD 345KV'	460	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	80		
OKGE	'SEMINOLE 138KV'	47.215	0	OKGE	'FPLWND2 34KV'	102	1	-1	80		
OKGE	'SEMINOLE 138KV'	47.215	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	80		
OKGE	'SEMINOLE 345KV'	406.08	0	OKGE	'FPLWND2 34KV'	102	1	-1	80		
OKGE	'SEMINOLE 345KV'	406.08	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	80		
OKGE	'SOUTH 4TH ST 69KV'	42.7	0	OKGE	'FPLWND2 34KV'	102	1	-1	80		
OKGE	'SOUTH 4TH ST 69KV'	42.7	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	80		

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Upgrade: IODINE - WOODWARD 138kV CKT 1  
 Limiting Facility: WOODWARD - WOODWARD 69KV CKT 1  
 Direction: From->To  
 Line Outage: FPL SWITCH - MOORELAND 138KV CKT 1  
 Flowgate: 56096547821559995578511206FA  
 Date Redispatch Needed: 10/1/06 - 12/1/06  
 Season Flowgate Identified: 2006 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount	Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1032973	71.9	71.9										
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'HORSESHOE LAKE 138KV'	91	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'HORSESHOE LAKE 138KV'	380	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'HORSESHOE LAKE 138KV'	91	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		
OKGE	'HORSESHOE LAKE 138KV'	380	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		
OKGE	'MCCLAIN 138KV'	42	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'MCCLAIN 138KV'	42	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		
OKGE	'MUSKOGEE 161KV'	31	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'MUSKOGEE 161KV'	166	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'MUSKOGEE 161KV'	31	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		
OKGE	'MUSKOGEE 161KV'	166	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		
OKGE	'MUSTANG 138KV'	365.5	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'MUSTANG 138KV'	365.5	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		
OKGE	'MUSTANG 69KV'	106	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'MUSTANG 69KV'	106	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		
OKGE	'ONE OAK 345KV'	336	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'ONE OAK 345KV'	336	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'REDBUD 345KV'	900	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		
OKGE	'REDBUD 345KV'	900	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		
OKGE	'SEMINOLE 138KV'	243.9512	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'SEMINOLE 138KV'	243.9512	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		
OKGE	'SEMINOLE 345KV'	507.6	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'SEMINOLE 345KV'	507.6	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		
OKGE	'SOONER 138KV'	24.99997	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'SOONER 138KV'	24.99997	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		
OKGE	'SOUTH 4TH ST 69KV'	42.7	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'SOUTH 4TH ST 69KV'	42.7	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		
OKGE	'TINKER 5G 138KV'	62	0	OKGE	'FPLWND2 34KV'		102	1	-1	72		
OKGE	'TINKER 5G 138KV'	62	0	OKGE	'SLEEPING BEAR 34KV'		120	1	-1	72		

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: IODINE - WOODWARD 138kV CKT 1  
 Limiting Facility: WOODWARD - WOODWARD 69KV CKT 1  
 Direction: From->To  
 Line Outage: FPL SWITCH - MOORELAND 138KV CKT 1  
 Flowgate: 56096547821559995578511406SP  
 Date Redispatch Needed: 6/1/06 - 10/1/06  
 Season Flowgate Identified: 2006 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount	Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1032973	71.0	71.0										
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'FPLWND2 34KV'				101.9968	1	-1	71
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'SLEEPING BEAR 34KV'				120	1	-1	71
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'FPLWND2 34KV'				101.9968	1	-1	71
OKGE	'HORSESHOE LAKE 138KV'	337.7	0	OKGE	'FPLWND2 34KV'				101.9968	1	-1	71
OKGE	'HORSESHOE LAKE 138KV'	337.7	0	OKGE	'SLEEPING BEAR 34KV'				120	1	-1	71
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'SLEEPING BEAR 34KV'				120	1	-1	71
OKGE	'MCCLAIN 138KV'	42	0	OKGE	'FPLWND2 34KV'				101.9968	1	-1	71
OKGE	'MCCLAIN 138KV'	42	0	OKGE	'SLEEPING BEAR 34KV'				120	1	-1	71
OKGE	'MUSKOGEE 161KV'	166	0	OKGE	'FPLWND2 34KV'				101.9968	1	-1	71
OKGE	'MUSKOGEE 161KV'	31	0	OKGE	'FPLWND2 34KV'				101.9968	1	-1	71
OKGE	'MUSKOGEE 161KV'	31	0	OKGE	'SLEEPING BEAR 34KV'				120	1	-1	71
OKGE	'MUSKOGEE 161KV'	166	0	OKGE	'SLEEPING BEAR 34KV'				120	1	-1	71
OKGE	'MUSTANG 138KV'	144.3298	0	OKGE	'FPLWND2 34KV'				101.9968	1	-1	71
OKGE	'MUSTANG 138KV'	144.3298	0	OKGE	'SLEEPING BEAR 34KV'				120	1	-1	71
OKGE	'ONE OAK 345KV'	261	0	OKGE	'FPLWND2 34KV'				101.9968	1	-1	71
OKGE	'ONE OAK 345KV'	261	0	OKGE	'SLEEPING BEAR 34KV'				120	1	-1	71
OKGE	'REDBUD 345KV'	253	0	OKGE	'FPLWND2 34KV'				101.9968	1	-1	71
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'FPLWND2 34KV'				101.9968	1	-1	71
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'SLEEPING BEAR 34KV'				120	1	-1	71
OKGE	'REDBUD 345KV'	253	0	OKGE	'SLEEPING BEAR 34KV'				120	1	-1	71
OKGE	'SOONER 138KV'	24.99997	0	OKGE	'FPLWND2 34KV'				101.9968	1	-1	71
OKGE	'SOONER 138KV'	24.99997	0	OKGE	'SLEEPING BEAR 34KV'				120	1	-1	71
OKGE	'SOUTH 4TH ST 69KV'	42.7	0	OKGE	'FPLWND2 34KV'				101.9968	1	-1	71
OKGE	'SOUTH 4TH ST 69KV'	42.7	0	OKGE	'SLEEPING BEAR 34KV'				120	1	-1	71

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: IODINE - WOODWARD 138kV CKT 1  
 Limiting Facility: WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: FPL SWITCH - MOORELAND 138KV CKT 1  
 Flowgate: WOODODWRD21421559995578511106FA  
 Date Redispatch Needed: 10/1/06 - 12/1/06  
 Season Flowgate Identified: 2006 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount
1032973	82.2	82.2

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'FPLWND2 34KV'	102	1	-1	82
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	82
OKGE	'HORSESHOE LAKE 138KV'	91	0	OKGE	'FPLWND2 34KV'	102	1	-1	82
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'FPLWND2 34KV'	102	1	-1	82
OKGE	'HORSESHOE LAKE 138KV'	380	0	OKGE	'FPLWND2 34KV'	102	1	-1	82
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	82
OKGE	'HORSESHOE LAKE 138KV'	380	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	82
OKGE	'HORSESHOE LAKE 138KV'	91	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	82
OKGE	'MCCLAIN 138KV'	42	0	OKGE	'FPLWND2 34KV'	102	1	-1	82
OKGE	'MCCLAIN 138KV'	42	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	82
OKGE	'MUSKOGEE 161KV'	166	0	OKGE	'FPLWND2 34KV'	102	1	-1	82
OKGE	'MUSKOGEE 161KV'	31	0	OKGE	'FPLWND2 34KV'	102	1	-1	82
OKGE	'MUSKOGEE 161KV'	166	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	82
OKGE	'MUSKOGEE 161KV'	31	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	82
OKGE	'MUSTANG 138KV'	365.5	0	OKGE	'FPLWND2 34KV'	102	1	-1	82
OKGE	'MUSTANG 138KV'	365.5	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	82
OKGE	'MUSTANG 69KV'	106	0	OKGE	'FPLWND2 34KV'	102	1	-1	82
OKGE	'MUSTANG 69KV'	106	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	82
OKGE	'ONE OAK 345KV'	236	0	OKGE	'FPLWND2 34KV'	102	1	-1	82
OKGE	'ONE OAK 345KV'	236	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	82
OKGE	'REDBUD 345KV'	900	0	OKGE	'FPLWND2 34KV'	102	1	-1	82
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'FPLWND2 34KV'	102	1	-1	82
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	82
OKGE	'REDBUD 345KV'	900	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	82
OKGE	'SEMINOLE 138KV'	262.1816	0	OKGE	'FPLWND2 34KV'	102	1	-1	82
OKGE	'SEMINOLE 138KV'	262.1816	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	82
OKGE	'SEMINOLE 345KV'	507.6	0	OKGE	'FPLWND2 34KV'	102	1	-1	82
OKGE	'SEMINOLE 345KV'	507.6	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	82
OKGE	'SOUTH 4TH ST 69KV'	42.7	0	OKGE	'FPLWND2 34KV'	102	1	-1	82
OKGE	'SOUTH 4TH ST 69KV'	42.7	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	82
OKGE	'TINKER 5G 138KV'	62	0	OKGE	'FPLWND2 34KV'	102	1	-1	82
OKGE	'TINKER 5G 138KV'	62	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	82

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: IODINE - WOODWARD 138KV CKT 1  
 Limiting Facility: WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: FPL SWITCH - MOORELAND 138KV CKT 1  
 Flowgate: WODODWRD21421559995578511106SH  
 Date Redispatch Needed: 6/1/06 - 10/1/06  
 Season Flowgate Identified: 2006 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount							
1032973		83.2	83.2						
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'FPLWND2 34KV'	102	1	-1	83
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	83
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'FPLWND2 34KV'	102	1	-1	83
OKGE	'HORSESHOE LAKE 138KV'	91	0	OKGE	'FPLWND2 34KV'	102	1	-1	83
OKGE	'HORSESHOE LAKE 138KV'	380	0	OKGE	'FPLWND2 34KV'	102	1	-1	83
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	83
OKGE	'HORSESHOE LAKE 138KV'	380	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	83
OKGE	'MCCLAIN 138KV'	91	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	83
OKGE	'MCCLAIN 138KV'	42	0	OKGE	'FPLWND2 34KV'	102	1	-1	83
OKGE	'MCCLAIN 138KV'	42	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	83
OKGE	'MUSKOGEE 161KV'	166	0	OKGE	'FPLWND2 34KV'	102	1	-1	83
OKGE	'MUSKOGEE 161KV'	31	0	OKGE	'FPLWND2 34KV'	102	1	-1	83
OKGE	'MUSKOGEE 161KV'	166	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	83
OKGE	'MUSKOGEE 161KV'	31	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	83
OKGE	'MUSTANG 138KV'	365.5	0	OKGE	'FPLWND2 34KV'	102	1	-1	83
OKGE	'MUSTANG 138KV'	365.5	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	83
OKGE	'MUSTANG 69KV'	106	0	OKGE	'FPLWND2 34KV'	102	1	-1	83
OKGE	'MUSTANG 69KV'	106	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	83
OKGE	'ONE OAK 345KV'	236	0	OKGE	'FPLWND2 34KV'	102	1	-1	83
OKGE	'ONE OAK 345KV'	236	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	83
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'FPLWND2 34KV'	102	1	-1	83
OKGE	'REDBUD 345KV'	460	0	OKGE	'FPLWND2 34KV'	102	1	-1	83
OKGE	'REDBUD 345KV'	460	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	83
OKGE	'REDBUD 345KV'	421.65	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	83
OKGE	'SEMINOLE 138KV'	47.215	0	OKGE	'FPLWND2 34KV'	102	1	-1	83
OKGE	'SEMINOLE 138KV'	47.215	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	83
OKGE	'SEMINOLE 345KV'	406.08	0	OKGE	'FPLWND2 34KV'	102	1	-1	83
OKGE	'SEMINOLE 345KV'	406.08	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	83
OKGE	'SOUTH 4TH ST 69KV'	42.7	0	OKGE	'FPLWND2 34KV'	102	1	-1	83
OKGE	'SOUTH 4TH ST 69KV'	42.7	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	83

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: IODINE - WOODWARD 138KV CKT 1  
 Limiting Facility: WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: FPL SWITCH - MOORELAND 138KV CKT 1  
 Flowgate: WODODWRD21421559995578511106SP  
 Date Redispatch Needed: 6/1/06 - 10/1/06  
 Season Flowgate Identified: 2006 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1032973		81.3	81.3						
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	81
OKGE	'CONTINENTAL EMPIRE 138KV'	63	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	81
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	81
OKGE	'HORSESHOE LAKE 138KV'	337.7	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	81
OKGE	'HORSESHOE LAKE 138KV'	380.5	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	81
OKGE	'HORSESHOE LAKE 138KV'	337.7	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	81

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	MCCLAIN 138KV'	42	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	81
OKGE	MCCLAIN 138KV'	42	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	81
OKGE	MUSKOGEE 161KV'	166	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	81
OKGE	MUSKOGEE 161KV'	31	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	81
OKGE	MUSKOGEE 161KV'	166	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	81
OKGE	MUSKOGEE 161KV'	31	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	81
OKGE	MUSTANG 138KV'	147.8137	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	81
OKGE	MUSTANG 138KV'	147.8137	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	81
OKGE	ONE OAK 345KV'	204	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	81
OKGE	ONE OAK 345KV'	204	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	81
OKGE	REDBUD 345KV'	421.65	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	81
OKGE	REDBUD 345KV'	460	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	81
OKGE	REDBUD 345KV'	460	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	81
OKGE	REDBUD 345KV'	421.65	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	81
OKGE	SOUTH 4TH ST 69KV'	42.7	0	OKGE	'FPLWND2 34KV'	101.9968	1	-1	81
OKGE	SOUTH 4TH ST 69KV'	42.7	0	OKGE	'SLEEPING BEAR 34KV'	120	1	-1	81

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: KNOBBILL (KNOBHL4) 138/69/13.2KV TRANSFORMER CKT 1  
 Limiting Facility: KNOBBILL (KNOBHL4) 138/69/13.2KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: CLEO CORNER - GLASS MOUNTAIN 138KV CKT 1  
 Flowgate: KNOBBLIL4142154785478811307SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1023236		3.1							
1032973		5.1							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.0368	OKGE	'FPLWND2 34KV'	102	0.12343	-0.16023	51
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.0368	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.1494	55
OKGE	'SOONER 138KV'	24.99997	-0.00627	OKGE	'FPLWND2 34KV'	102	0.12343	-0.1297	63
OKGE	'MUSKOGEE 161KV'	166	-0.00016	OKGE	'FPLWND2 34KV'	102	0.12343	-0.12359	66
OKGE	'MUSKOGEE 161KV'	31	-0.00016	OKGE	'FPLWND2 34KV'	102	0.12343	-0.12359	66
OKGE	'ONE OAK 345KV'	179	-0.00018	OKGE	'FPLWND2 34KV'	102	0.12343	-0.12361	66
OKGE	'REDBUD 345KV'	900	0.00028	OKGE	'FPLWND2 34KV'	102	0.12343	-0.12315	66
OKGE	'REDBUD 345KV'	421.65	0.00028	OKGE	'FPLWND2 34KV'	102	0.12343	-0.12315	66
OKGE	'HORSESHOE LAKE 138KV'	293.7871	0.00116	OKGE	'FPLWND2 34KV'	102	0.12343	-0.12227	67
OKGE	'MCCLAIN 138KV'	42	0.00235	OKGE	'FPLWND2 34KV'	102	0.12343	-0.12108	67
OKGE	'TINKER 5G 138KV'	62	0.0015	OKGE	'FPLWND2 34KV'	102	0.12343	-0.12193	67
OKGE	'SOONER 138KV'	24.99997	-0.00627	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11887	69
OKGE	'MUSKOGEE 161KV'	166	-0.00016	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11276	72
OKGE	'MUSKOGEE 161KV'	31	-0.00016	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11276	72
OKGE	'ONE OAK 345KV'	179	-0.00018	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11278	72
OKGE	'HORSESHOE LAKE 138KV'	293.7871	0.00116	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11144	73
OKGE	'REDBUD 345KV'	421.65	0.00028	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11232	73
OKGE	'REDBUD 345KV'	900	0.00028	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11232	73
OKGE	'TINKER 5G 138KV'	62	0.0015	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11111	73
OKGE	'MCCLAIN 138KV'	42	0.00235	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11025	74

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: KNOBBILL (KNOBHL4) 138/69/13.2KV TRANSFORMER CKT 1  
 Limiting Facility: KNOBBILL (KNOBHL4) 138/69/13.2KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: GLASS MOUNTAIN - MOORELAND 138KV CKT 1  
 Flowgate: KNOOBBLIL4142154785599911307SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1023236		3.3							
1032973		5.5							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.0368	OKGE	'FPLWND2 34KV'	102	0.12343	-0.16023	55
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.0368	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.1494	59
OKGE	'SOONER 138KV'	24.99997	-0.00627	OKGE	'FPLWND2 34KV'	102	0.12343	-0.1297	68
OKGE	'HORSESHOE LAKE 138KV'	293.7871	0.00116	OKGE	'FPLWND2 34KV'	102	0.12343	-0.12227	72
OKGE	'MUSKOGEE 161KV'	31	-0.00016	OKGE	'FPLWND2 34KV'	102	0.12343	-0.12359	72
OKGE	'MUSKOGEE 161KV'	166	-0.00016	OKGE	'FPLWND2 34KV'	102	0.12343	-0.12359	72
OKGE	'ONE OAK 345KV'	179	-0.00018	OKGE	'FPLWND2 34KV'	102	0.12343	-0.12361	72
OKGE	'REDBUD 345KV'	900	0.00028	OKGE	'FPLWND2 34KV'	102	0.12343	-0.12315	72
OKGE	'REDBUD 345KV'	421.65	0.00028	OKGE	'FPLWND2 34KV'	102	0.12343	-0.12315	72
OKGE	'TINKER 5G 138KV'	62	0.0015	OKGE	'FPLWND2 34KV'	102	0.12343	-0.12193	72
OKGE	'MCCLAIN 138KV'	42	0.00235	OKGE	'FPLWND2 34KV'	102	0.12343	-0.12108	73
OKGE	'SOONER 138KV'	24.99997	-0.00627	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11887	74
OKGE	'MUSKOGEE 161KV'	31	-0.00016	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11276	78
OKGE	'MUSKOGEE 161KV'	166	-0.00016	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11276	78
OKGE	'ONE OAK 345KV'	179	-0.00018	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11278	78
OKGE	'HORSESHOE LAKE 138KV'	293.7871	0.00116	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11144	79
OKGE	'REDBUD 345KV'	900	0.00028	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11232	79
OKGE	'REDBUD 345KV'	421.65	0.00028	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11232	79
OKGE	'MCCLAIN 138KV'	42	0.00235	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11025	80
OKGE	'TINKER 5G 138KV'	62	0.0015	OKGE	'SLEEPING BEAR 34KV'	120	0.1126	-0.11111	80

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: KNOBBILL (KNOBHL4) 138/69/13.2KV TRANSFORMER CKT 1  
 Limiting Facility: KNOBBILL (KNOBHL4) 138/69/13.2KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: OKGEMTL-5  
 Flowgate: KNOOBBLIL41421OKGEMTL-51306SP  
 Date Redispatch Needed: 6/1/06 - 10/1/06  
 Season Flowgate Identified: 2006 Summer Peak

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Reservation	Relief Amount	Aggregate Relief Amount
1032973	0.2	0.2
Source Control Area	Source	Maximum Increment(MW) GSF Sink Control Area Sink Maximum Decrement(MW) GSF Factor Redispatch Amount (MW)
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04191 OKGE 'FPLWND2 34KV' 101.9968 0.09565 -0.13756 1
WFEC	'ANADARKO 138KV'	90 0.00539 WFEC 'MORLND 138KV' 260.8777 0.09573 -0.09034 2
WFEC	'ANADARKO 138KV'	3.150276 0.00539 WFEC 'MORLND 138KV' 260.8777 0.09573 -0.09034 2
WFEC	'ANADARKO 69KV'	76 0.00519 WFEC 'MORLND 138KV' 260.8777 0.09573 -0.09054 2
OKGE	'CONTINENTAL EMPIRE 138KV'	63 -0.00598 OKGE 'FPLWND2 34KV' 101.9968 0.09565 -0.10163 2
OKGE	'CONTINENTAL EMPIRE 138KV'	63 -0.00598 OKGE 'SLEEPING BEAR 34KV' 120 0.09024 -0.09622 2
OKGE	'HORSESHOE LAKE 138KV'	337.7 0.00073 OKGE 'FPLWND2 34KV' 101.9968 0.09565 -0.09492 2
OKGE	'HORSESHOE LAKE 138KV'	380.5 0.00073 OKGE 'FPLWND2 34KV' 101.9968 0.09565 -0.09492 2
OKGE	'HORSESHOE LAKE 138KV'	337.7 0.00073 OKGE 'SLEEPING BEAR 34KV' 120 0.09024 -0.08951 2
OKGE	'HORSESHOE LAKE 138KV'	380.5 0.00073 OKGE 'SLEEPING BEAR 34KV' 120 0.09024 -0.08951 2
OKGE	'MCCLAIN 138KV'	42 0.00158 OKGE 'FPLWND2 34KV' 101.9968 0.09565 -0.09407 2
OKGE	'MCCLAIN 138KV'	42 0.00158 OKGE 'SLEEPING BEAR 34KV' 120 0.09024 -0.08866 2
OKGE	'MUSKOGEE 161KV'	166 -0.00014 OKGE 'FPLWND2 34KV' 101.9968 0.09565 -0.09579 2
OKGE	'MUSKOGEE 161KV'	31 -0.00014 OKGE 'FPLWND2 34KV' 101.9968 0.09565 -0.09579 2
OKGE	'MUSKOGEE 161KV'	166 -0.00014 OKGE 'SLEEPING BEAR 34KV' 120 0.09024 -0.09038 2
OKGE	'MUSKOGEE 161KV'	31 -0.00014 OKGE 'SLEEPING BEAR 34KV' 120 0.09024 -0.09038 2
OKGE	'MUSTANG 138KV'	147.3059 0.00139 OKGE 'FPLWND2 34KV' 101.9968 0.09565 -0.09426 2
OKGE	'MUSTANG 138KV'	147.3059 0.00139 OKGE 'SLEEPING BEAR 34KV' 120 0.09024 -0.08885 2
OMPA	'OMPA-FAIRVIEW 69KV'	1.8 -0.10568 OMPA 'OMPA-KINGFISHER BOWMAN 69KV' 19.7 0.00179 -0.10747 2
OMPA	'OMPA-FAIRVIEW 69KV'	1.8 -0.10568 OMPA 'OMPA-PONCA CITY 69KV' 93.64704 -0.00635 -0.09933 2
OKGE	'ONE OAK 345KV'	204 -0.00021 OKGE 'FPLWND2 34KV' 101.9968 0.09565 -0.09586 2
OKGE	'ONE OAK 345KV'	204 -0.00021 OKGE 'SLEEPING BEAR 34KV' 120 0.09024 -0.09045 2
OKGE	'REDBUD 345KV'	460 0.00013 OKGE 'FPLWND2 34KV' 101.9968 0.09565 -0.09552 2
OKGE	'REDBUD 345KV'	421.65 0.00013 OKGE 'FPLWND2 34KV' 101.9968 0.09565 -0.09552 2
OKGE	'REDBUD 345KV'	421.65 0.00013 OKGE 'SLEEPING BEAR 34KV' 120 0.09024 -0.09011 2
OKGE	'REDBUD 345KV'	460 0.00013 OKGE 'SLEEPING BEAR 34KV' 120 0.09024 -0.09011 2
OKGE	'SEMINOLE 138KV'	17.47644 0.00096 OKGE 'FPLWND2 34KV' 101.9968 0.09565 -0.09469 2
OKGE	'SEMINOLE 138KV'	17.47644 0.00096 OKGE 'SLEEPING BEAR 34KV' 120 0.09024 -0.08928 2
OKGE	'SOONER 138KV'	24.99997 -0.00433 OKGE 'FPLWND2 34KV' 101.9968 0.09565 -0.09988 2
OKGE	'SOONER 138KV'	24.99997 -0.00433 OKGE 'SLEEPING BEAR 34KV' 120 0.09024 -0.09457 2
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04191 OKGE 'SLEEPING BEAR 34KV' 120 0.09024 -0.13215 2
OKGE	'TINKER 5G 138KV'	62 0.00093 OKGE 'FPLWND2 34KV' 101.9968 0.09565 -0.09472 2
OKGE	'TINKER 5G 138KV'	62 0.00093 OKGE 'SLEEPING BEAR 34KV' 120 0.09024 -0.08931 2
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04191 OKGE 'MCCLAIN 138KV' 478 0.00158 -0.04349 5
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04191 OKGE 'MUSKOGEE 345KV' 1516 -0.00006 -0.04185 5
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04191 OKGE 'MUSTANG 138KV' 218.1941 0.00139 -0.0433 5
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04191 OKGE 'MUSTANG 69KV' 106 0.00159 -0.0435 5
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04191 OKGE 'ONE OAK 345KV' 132 -0.00021 -0.0417 5
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04191 OKGE 'REDBUD 345KV' 440 0.00013 -0.04204 5
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04191 OKGE 'SEMINOLE 138KV' 487.5236 0.00096 -0.04287 5
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04191 OKGE 'SEMINOLE 345KV' 996 0.00081 -0.04272 5
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04191 OKGE 'SMITH COGEN 138KV' 110 0.00134 -0.04325 5
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04191 OKGE 'SOONER 138KV' 505 -0.00433 -0.03758 5
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04191 OKGE 'SOONER 345KV' 513 -0.0028 -0.03911 5

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: KNOBBILL (KNOBHL4) 138/69/13.2KV TRANSFORMER CKT 1  
 Limiting Facility: KNOBBILL (KNOBHL4) 138/69/13.2KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: OKGEMTL-5  
 Flowgate: KNOOBHL41421OKGEMTL-54307SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1023236	0.5	1.5
1032973	0.9	1.5
Source Control Area	Source	Maximum Increment(MW) GSF Sink Control Area Sink Maximum Decrement(MW) GSF Factor Redispatch Amount (MW)
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04229 OKGE 'FPLWND2 34KV' 102 0.09159 -0.13388 11
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04229 OKGE 'SLEEPING BEAR 34KV' 120 0.08188 -0.12417 12
OKGE	'SOONER 138KV'	24.99997 -0.00436 OKGE 'FPLWND2 34KV' 102 0.09159 -0.09595 15
OKGE	'HORSESHOE LAKE 138KV'	293.7871 0.00076 OKGE 'FPLWND2 34KV' 102 0.09159 -0.09083 16
OKGE	'MCCLAIN 138KV'	42 0.00155 OKGE 'FPLWND2 34KV' 102 0.09159 -0.09004 16
OKGE	'MUSKOGEE 161KV'	166 -0.00013 OKGE 'FPLWND2 34KV' 102 0.09159 -0.09172 16
OKGE	'MUSKOGEE 161KV'	31 -0.00013 OKGE 'FPLWND2 34KV' 102 0.09159 -0.09172 16
OKGE	'MUSKOGEE 345KV'	20 -0.00007 OKGE 'FPLWND2 34KV' 102 0.09159 -0.09166 16
OKGE	'ONE OAK 345KV'	204 -0.00014 OKGE 'FPLWND2 34KV' 102 0.09159 -0.09173 16
OKGE	'REDBUD 345KV'	900 0.00017 OKGE 'FPLWND2 34KV' 102 0.09159 -0.09142 16
OKGE	'REDBUD 345KV'	421.65 0.00017 OKGE 'FPLWND2 34KV' 102 0.09159 -0.09142 16
OKGE	'SEMINOLE 138KV'	20.03766 0.00099 OKGE 'FPLWND2 34KV' 102 0.09159 -0.0906 16
OKGE	'TINKER 5G 138KV'	62 0.00099 OKGE 'FPLWND2 34KV' 102 0.09159 -0.0906 16
OKGE	'SOONER 138KV'	24.99997 -0.00436 OKGE 'SLEEPING BEAR 34KV' 120 0.08188 -0.08624 17
OKGE	'HORSESHOE LAKE 138KV'	293.7871 0.00076 OKGE 'SLEEPING BEAR 34KV' 120 0.08188 -0.08112 18
OKGE	'MCCLAIN 138KV'	42 0.00155 OKGE 'SLEEPING BEAR 34KV' 120 0.08188 -0.08033 18
OKGE	'MUSKOGEE 161KV'	31 -0.00013 OKGE 'SLEEPING BEAR 34KV' 120 0.08188 -0.08201 18
OKGE	'MUSKOGEE 161KV'	166 -0.00013 OKGE 'SLEEPING BEAR 34KV' 120 0.08188 -0.08201 18
OKGE	'MUSKOGEE 345KV'	20 -0.00007 OKGE 'SLEEPING BEAR 34KV' 120 0.08188 -0.08195 18
OKGE	'ONE OAK 345KV'	204 -0.00014 OKGE 'SLEEPING BEAR 34KV' 120 0.08188 -0.08202 18
OKGE	'REDBUD 345KV'	421.65 0.00017 OKGE 'SLEEPING BEAR 34KV' 120 0.08188 -0.08171 18
OKGE	'REDBUD 345KV'	900 0.00017 OKGE 'SLEEPING BEAR 34KV' 120 0.08188 -0.08171 18
OKGE	'SEMINOLE 138KV'	20.03766 0.00099 OKGE 'SLEEPING BEAR 34KV' 120 0.08188 -0.08089 18
OKGE	'TINKER 5G 138KV'	62 0.00099 OKGE 'SLEEPING BEAR 34KV' 120 0.08188 -0.08089 18
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04229 OKGE 'MCCLAIN 138KV' 478 0.00155 -0.04384 33
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04229 OKGE 'MUSTANG 138KV' 365.5 0.00148 -0.04377 33
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04229 OKGE 'MUSTANG 69KV' 106 0.00169 -0.04398 33
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04229 OKGE 'SMITH COGEN 138KV' 110 0.00144 -0.04373 33
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04229 OKGE 'AES 161KV' 320 -0.00001 -0.04228 34
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04229 OKGE 'HORSESHOE LAKE 138KV' 380 0.00076 -0.04305 34
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04229 OKGE 'HORSESHOE LAKE 138KV' 86.71289 0.00076 -0.04305 34
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04229 OKGE 'HORSESHOE LAKE 138KV' 91 0.00076 -0.04305 34
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04229 OKGE 'HORSESHOE LAKE 69KV' 16 0.00079 -0.04308 34
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04229 OKGE 'MUSKOGEE 345KV' 1516 -0.00007 -0.04222 34
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04229 OKGE 'SEMINOLE 138KV' 484.9624 0.00099 -0.04328 34
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04229 OKGE 'SEMINOLE 345KV' 996 0.00085 -0.04314 34
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04229 OKGE 'ONE OAK 345KV' 132 -0.00014 -0.04215 35
OKGE	'SOUTH 4TH ST 69KV'	42.7 -0.04229 OKGE 'SOONER 345KV' 513 -0.00281 -0.03948 37

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	SOUTH 4TH ST 69KV	42.7	-0.04229	OKGE	SOONER 138KV	505	-0.00436	-0.03793	38
Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.									
Factor = Source GSF - Sink GSF									
Redispatch Amount = Relief Amount / Factor									
Upgrade:	PENNSYLVANIA - WESTMORE 138KV CKT 1								
Limiting Facility:	PENNSYLVANIA - WESTMORE 138KV CKT 1								
Direction:	To->From								
Line Outage:	CIMARRON - CZECH HALL 138KV CKT 1								
Flowgate:	54925548871548985489412307FA								
Date Redispatch Needed:	Starting 2007 10/1 - 12/ Until EOC of Upgrade								
Season Flowgate Identified:	2007 Fall Peak								
Reservation	Relief Amount	Aggregate Relief Amount							
1032326		2.8	2.8						
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'COGENTRIX 345KV'	200	-0.00424	-0.35647	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'COMANCHE 138KV'	160	-0.00564	-0.35507	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'COMANCHE 69KV'	63	-0.00565	-0.35506	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'EASTMAN 138KV'	355	-0.01329	-0.34742	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'FITZHUGH 161KV'	126	-0.00242	-0.35829	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'KNOXLEE 138KV'	284	-0.00944	-0.35127	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'LEBROCK 345KV'	365	-0.01842	-0.34229	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'NORTHEASTERN STATION 138KV'	405	-0.00393	-0.35678	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'NORTHEASTERN STATION 138KV'	95	-0.00393	-0.35678	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'NORTHEASTERN STATION 345KV'	645	-0.00391	-0.3568	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'OEC 345KV'	269	-0.00412	-0.35659	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'PIRKEY GENERATION 138KV'	248	-0.02472	-0.33599	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'RIVERSIDE STATION 138KV'	669	-0.00425	-0.35646	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'SOUTHWESTERN STATION 138KV'	355	-0.00558	-0.35513	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'TULSA POWER STATION 138KV'	112	-0.00421	-0.3565	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'TULSA POWER STATION 138KV'	147	-0.00421	-0.3565	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'WELEETKA 138KV'	70	-0.00513	-0.35558	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'WELSH 345KV'	990	-0.01281	-0.3479	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'WILKES 138KV'	388,4218	-0.02872	-0.33199	8
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'WILKES 345KV'	311	-0.01662	-0.34409	8
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'FITZHUGH 161KV'	126	-0.00242	-0.20952	13
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'NORTHEASTERN STATION 138KV'	405	-0.00393	-0.20801	13
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'NORTHEASTERN STATION 138KV'	95	-0.00393	-0.20801	13
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'NORTHEASTERN STATION 345KV'	645	-0.00391	-0.20803	13
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'OEC 345KV'	269	-0.00412	-0.20782	13
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'TULSA POWER STATION 138KV'	112	-0.00421	-0.20773	13
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'TULSA POWER STATION 138KV'	147	-0.00421	-0.20773	13
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'COGENTRIX 345KV'	200	-0.00424	-0.2077	14
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'COMANCHE 138KV'	160	-0.00564	-0.2063	14
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'COMANCHE 69KV'	63	-0.00565	-0.20629	14
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'EASTMAN 138KV'	355	-0.01329	-0.19865	14
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'KNOXLEE 138KV'	284	-0.00944	-0.2025	14
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'LEBROCK 345KV'	365	-0.01842	-0.19352	14
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'RIVERSIDE STATION 138KV'	669	-0.00425	-0.20769	14
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'SOUTHWESTERN STATION 138KV'	355	-0.00558	-0.20636	14
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'WELEETKA 138KV'	70	-0.00513	-0.20681	14
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'WELSH 345KV'	990	-0.01281	-0.19913	14
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'WILKES 345KV'	311	-0.01662	-0.19532	14
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'PIRKEY GENERATION 138KV'	248	-0.02472	-0.18722	15
AEPW	'LIEBERMAN 138KV'	137	-0.21194	AEPW	'WILKES 138KV'	388,4218	-0.02872	-0.18322	15
AEPW	'ARSENAL HILL 69KV'	75	-0.36071	AEPW	'LIEBERMAN 138KV'	91	-0.21194	-0.14877	19
Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.									
Factor = Source GSF - Sink GSF									
Redispatch Amount = Relief Amount / Factor									
Upgrade:	PENNSYLVANIA - WESTMORE 138KV CKT 1								
Limiting Facility:	PENNSYLVANIA - WESTMORE 138KV CKT 1								
Direction:	To->From								
Line Outage:	CIMARRON - CZECH HALL 138KV CKT 1								
Flowgate:	54925548871548985489412307FA								
Date Redispatch Needed:	Starting 2007 10/1 - 12/ Until EOC of Upgrade								
Season Flowgate Identified:	2007 Fall Peak								
Reservation	Relief Amount	Aggregate Relief Amount							
1032973		4.5	4.5						
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'SMITH COGEN 138KV'	110	-0.21281	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.53475	8
OKGE	'MUSTANG 138KV'	365.5	-0.16736	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.4893	9
OKGE	'MUSTANG 69KV'	106	-0.15652	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.47846	9
OKGE	'HORSESHOE LAKE 138KV'	380	-0.05493	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.37687	12
OKGE	'HORSESHOE LAKE 138KV'	91	-0.05493	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.37687	12
OKGE	'HORSESHOE LAKE 138KV'	380.5	-0.05493	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.37687	12
OKGE	'HORSESHOE LAKE 69KV'	16	-0.05468	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.37662	12
OKGE	'ONE OAK 345KV'	236	-0.01201	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.33395	13
OKGE	'REDBUD 345KV'	900	-0.01473	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.33667	13
OKGE	'REDBUD 345KV'	421,65	-0.01473	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.33667	13
OKGE	'TINKER 5G 138KV'	62	-0.03232	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.35426	13
OKGE	'CONTINENTAL EMPIRE 138KV'	64	-0.00716	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.3291	14
OKGE	'MUSKOGEE 161KV'	166	-0.00241	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.32435	14
OKGE	'MUSKOGEE 161KV'	31	-0.00241	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.32435	14
OKGE	'MUSKOGEE 345KV'	201	-0.00225	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.32419	14
OKGE	'SEMINOLE 138KV'	47,69101	0.00867	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.31327	14
OKGE	'SEMINOLE 345KV'	406.08	0.00924	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.3127	14
OKGE	'SOONER 138KV'	24,99997	-0.00825	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.33019	14
OKGE	'SOUTH 4TH ST 69KV'	42.7	-0.00605	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.32799	14
OKGE	'WOODWARD 24KV'	9.3	0.0058	OKGE	'MCCLAIN 138KV'	478	0.32194	-0.31614	14
OKGE	'SMITH COGEN 138KV'	110	-0.21281	OKGE	'SEMINOLE 138KV'	457,309	0.00867	-0.22148	20
OKGE	'SMITH COGEN 138KV'	110	-0.21281	OKGE	'SEMINOLE 345KV'	590,52	0.00924	-0.22205	20
OKGE	'SMITH COGEN 138KV'	110	-0.21281	OKGE	'AES 161KV'	320	-0.00018	-0.21263	21
OKGE	'SMITH COGEN 138KV'	110	-0.21281	OKGE	'FPLWND2 34KV'	43,0032	0.0052	-0.21801	21
OKGE	'SMITH COGEN 138KV'	110	-0.21281	OKGE	'MUSKOGEE 345KV'	1516	-0.00225	-0.21056	21
OKGE	'SMITH COGEN 138KV'	110	-0.21281	OKGE	'ONE OAK 345KV'	100	-0.01201	-0.2008	22
OKGE	'SMITH COGEN 138KV'	110	-0.21281	OKGE	'SOONER 138KV'	505	-0.00825	-0.20456	22
OKGE	'SMITH COGEN 138KV'	110	-0.21281	OKGE	'SOONER 345KV'	513	-0.00735	-0.20546	22
OKGE	'MUSTANG 138KV'	365.5	-0.16736	OKGE	'SEMINOLE 345KV'	590,52	0.00924	-0.1766	25

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	MUSTANG 138KV'	365.5	-0.16736	OKGE	FPLWND2 34KV'	43.0032	0.0052	-0.17256	26
OKGE	MUSTANG 138KV'	365.5	-0.16736	OKGE	'SEMINOLE 138KV'	457.309	0.00867	-0.17603	26
OKGE	MUSTANG 138KV'	365.5	-0.16736	OKGE	'AES 161KV'	320	-0.00018	-0.16718	27
OKGE	MUSTANG 138KV'	365.5	-0.16736	OKGE	'MUSKOGEE 345KV'	1516	-0.00225	-0.16511	27
OKGE	MUSTANG 69KV'	106	-0.15652	OKGE	'SEMINOLE 138KV'	457.309	0.00867	-0.16519	27
OKGE	MUSTANG 69KV'	106	-0.15652	OKGE	'SEMINOLE 345KV'	590.52	0.00924	-0.16576	27
OKGE	MUSTANG 138KV'	365.5	-0.16736	OKGE	'SOONER 138KV'	505	-0.00825	-0.15911	28
OKGE	MUSTANG 138KV'	365.5	-0.16736	OKGE	'SOONER 345KV'	513	-0.00735	-0.16001	28
OKGE	MUSTANG 69KV'	106	-0.15652	OKGE	FPLWND2 34KV'	43.0032	0.0052	-0.16172	28
OKGE	MUSTANG 138KV'	365.5	-0.16736	OKGE	'ONE OAK 345KV'	100	-0.01201	-0.15535	29
OKGE	MUSTANG 69KV'	106	-0.15652	OKGE	'AES 161KV'	320	-0.00018	-0.15634	29
OKGE	MUSTANG 69KV'	106	-0.15652	OKGE	'MUSKOGEE 345KV'	1516	-0.00225	-0.15427	29
OKGE	MUSTANG 69KV'	106	-0.15652	OKGE	'SOONER 138KV'	505	-0.00825	-0.14827	30
OKGE	MUSTANG 69KV'	106	-0.15652	OKGE	'SOONER 345KV'	513	-0.00735	-0.14917	30
OKGE	MUSTANG 69KV'	106	-0.15652	OKGE	'ONE OAK 345KV'	100	-0.01201	-0.14451	31
OKGE	HORSESHEOE LAKE 138KV'	380.5	-0.05493	OKGE	'SEMINOLE 345KV'	590.52	0.00924	-0.06417	70
OKGE	HORSESHEOE LAKE 138KV'	91	-0.05493	OKGE	'SEMINOLE 345KV'	590.52	0.00924	-0.06417	70
OKGE	HORSESHEOE LAKE 138KV'	380	-0.05493	OKGE	'SEMINOLE 345KV'	590.52	0.00924	-0.06417	70
OKGE	HORSESHEOE LAKE 138KV'	380.5	-0.05493	OKGE	'SEMINOLE 138KV'	457.309	0.00867	-0.0636	71
OKGE	HORSESHEOE LAKE 138KV'	91	-0.05493	OKGE	'SEMINOLE 138KV'	457.309	0.00867	-0.0636	71
OKGE	HORSESHEOE LAKE 138KV'	380	-0.05493	OKGE	'FPLWND2 34KV'	457.309	0.00867	-0.0636	71
OKGE	HORSESHEOE LAKE 138KV'	91	-0.05493	OKGE	FPLWND2 34KV'	43.0032	0.0052	-0.06013	75
OKGE	HORSESHEOE LAKE 138KV'	380.5	-0.05493	OKGE	FPLWND2 34KV'	43.0032	0.0052	-0.06013	75
OKGE	HORSESHEOE LAKE 138KV'	380	-0.05493	OKGE	'FPLWND2 34KV'	43.0032	0.0052	-0.06013	75
OKGE	HORSESHEOE LAKE 138KV'	91	-0.05493	OKGE	'AES 161KV'	320	-0.00018	-0.05475	82
OKGE	HORSESHEOE LAKE 138KV'	380.5	-0.05493	OKGE	'AES 161KV'	320	-0.00018	-0.05475	82
OKGE	HORSESHEOE LAKE 138KV'	380	-0.05493	OKGE	'AES 161KV'	320	-0.00018	-0.05475	82
OKGE	HORSESHEOE LAKE 138KV'	380.5	-0.05493	OKGE	'MUSKOGEE 345KV'	1516	-0.00225	-0.05268	85
OKGE	HORSESHEOE LAKE 138KV'	91	-0.05493	OKGE	'MUSKOGEE 345KV'	1516	-0.00225	-0.05268	85
OKGE	HORSESHEOE LAKE 138KV'	380	-0.05493	OKGE	'MUSKOGEE 345KV'	1516	-0.00225	-0.05268	85
OKGE	HORSESHEOE LAKE 138KV'	380	-0.05493	OKGE	'SOONER 345KV'	513	-0.00735	-0.04758	94
OKGE	HORSESHEOE LAKE 138KV'	91	-0.05493	OKGE	'SOONER 345KV'	513	-0.00735	-0.04758	94
OKGE	HORSESHEOE LAKE 138KV'	380.5	-0.05493	OKGE	'SOONER 345KV'	513	-0.00735	-0.04758	94
OKGE	HORSESHEOE LAKE 138KV'	91	-0.05493	OKGE	'SOONER 138KV'	505	-0.00825	-0.04668	96
OKGE	HORSESHEOE LAKE 138KV'	380	-0.05493	OKGE	'SOONER 138KV'	505	-0.00825	-0.04668	96
OKGE	HORSESHEOE LAKE 138KV'	380.5	-0.05493	OKGE	'SOONER 138KV'	505	-0.00825	-0.04668	96
OKGE	HORSESHEOE LAKE 138KV'	91	-0.05493	OKGE	'ONE OAK 345KV'	100	-0.01201	-0.04292	105
OKGE	HORSESHEOE LAKE 138KV'	380.5	-0.05493	OKGE	'ONE OAK 345KV'	100	-0.01201	-0.04292	105
OKGE	HORSESHEOE LAKE 138KV'	380	-0.05493	OKGE	'ONE OAK 345KV'	100	-0.01201	-0.04292	105
OKGE	TINKER 5G 138KV'	62	-0.03232	OKGE	'SEMINOLE 345KV'	590.52	0.00924	-0.04156	108
OKGE	TINKER 5G 138KV'	62	-0.03232	OKGE	'SEMINOLE 138KV'	457.309	0.00867	-0.04099	110
OKGE	TINKER 5G 138KV'	62	-0.03232	OKGE	'FPLWND2 34KV'	43.0032	0.0052	-0.03752	120
OKGE	TINKER 5G 138KV'	62	-0.03232	OKGE	'AES 161KV'	320	-0.00018	-0.03214	140
OKGE	TINKER 5G 138KV'	62	-0.03232	OKGE	'MUSKOGEE 345KV'	1516	-0.00225	-0.03007	149

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: PENNSYLVANIA - WESTMORE 138KV CKT 1  
 Limiting Facility: PENNSYLVANIA - WESTMORE 138KV CKT 1  
 Direction: To->From  
 Line Outage: HOLLYWOOD - INDIAN HILLS 138KV CKT 1  
 Flowgate: 54925548871549535495412307FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount							
977481		0.8	0.8						
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'SMITH COGEN 138KV'	110	-0.19229	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.54727	1
OKGE	'CONTINENTAL EMPIRE 138KV'	64	-0.01233	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.36731	2
OKGE	'HORSESHEOE LAKE 138KV'	91	-0.0583	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.41328	2
OKGE	'HORSESHEOE LAKE 138KV'	380.5	-0.0583	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.41328	2
OKGE	'HORSESHEOE LAKE 69KV'	16	-0.0583	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.41328	2
OKGE	'HORSESHEOE LAKE 69KV'	166	-0.0016	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.35658	2
OKGE	'MUSKOGEE 161KV'	31	-0.0016	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.35658	2
OKGE	'MUSKOGEE 345KV'	20	-0.00178	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.35676	2
OKGE	'MUSTANG 138KV'	365.5	-0.13538	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.49036	2
OKGE	'MUSTANG 69KV'	106	-0.13972	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.49447	2
OKGE	'ONE OAK 345KV'	236	-0.01875	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.37373	2
OKGE	'REDBUD 345KV'	421.65	-0.01763	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.37261	2
OKGE	'REDBUD 345KV'	900	-0.01763	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.37261	2
OKGE	'SEMINOLE 138KV'	47,69101	0.01443	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.34055	2
OKGE	'SEMINOLE 345KV'	406,08	0.01418	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.34048	2
OKGE	'SOONER 138KV'	24,99997	-0.01389	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.36887	2
OKGE	'SOUTH 4TH ST 69KV'	42,7	-0.01312	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.3681	2
OKGE	'TINKER 5G 138KV'	62	-0.02998	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.38496	2
OKGE	'WOODWARD 24KV'	9,3	-0.00592	OKGE	'MCCLAIN 138KV'	478	0.35498	-0.3609	2
OKGE	'SMITH COGEN 138KV'	110	-0.19229	OKGE	'AES 161KV'	320	0.00089	-0.19318	4
OKGE	'SMITH COGEN 138KV'	110	-0.19229	OKGE	'FPLWND2 34KV'	43.0032	-0.00582	-0.18647	4
OKGE	'SMITH COGEN 138KV'	110	-0.19229	OKGE	'MUSKOGEE 345KV'	1516	-0.00178	-0.19051	4
OKGE	'SMITH COGEN 138KV'	110	-0.19229	OKGE	'SEMINOLE 138KV'	457.309	0.01443	-0.20672	4
OKGE	'SMITH COGEN 138KV'	110	-0.19229	OKGE	'SEMINOLE 345KV'	590.52	0.01418	-0.20647	4
OKGE	'SMITH COGEN 138KV'	110	-0.19229	OKGE	'SOONER 345KV'	505	-0.01389	-0.1784	4
OKGE	'SMITH COGEN 138KV'	110	-0.19229	OKGE	'SOONER 345KV'	513	-0.01395	-0.17834	4
OKGE	'MUSTANG 138KV'	365.5	-0.13538	OKGE	'SEMINOLE 138KV'	457.309	0.01443	-0.14981	5
OKGE	'MUSTANG 138KV'	365.5	-0.13538	OKGE	'SEMINOLE 345KV'	590.52	0.01418	-0.14956	5
OKGE	'MUSTANG 69KV'	106	-0.13972	OKGE	'SEMINOLE 138KV'	457.309	0.01443	-0.15415	5
OKGE	'MUSTANG 69KV'	106	-0.13972	OKGE	'SEMINOLE 345KV'	590.52	0.01418	-0.1539	5
OKGE	'SMITH COGEN 138KV'	110	-0.19229	OKGE	'ONE OAK 345KV'	100	-0.01875	-0.17354	5
OKGE	'MUSTANG 138KV'	365.5	-0.13538	OKGE	'AES 161KV'	320	0.00089	-0.13627	6
OKGE	'MUSTANG 138KV'	365.5	-0.13538	OKGE	'FPLWND2 34KV'	43.0032	-0.00582	-0.12956	6
OKGE	'MUSTANG 138KV'	365.5	-0.13538	OKGE	'MUSKOGEE 345KV'	1516	-0.00178	-0.1336	6
OKGE	'MUSTANG 69KV'	106	-0.13972	OKGE	'AES 161KV'	320	0.00089	-0.14061	6
OKGE	'MUSTANG 69KV'	106	-0.13972	OKGE	'FPLWND2 34KV'	43.0032	-0.00582	-0.1339	6
OKGE	'MUSTANG 69KV'	106	-0.13972	OKGE	'MUSKOGEE 345KV'	1516	-0.00178	-0.13794	6
OKGE	'MUSTANG 69KV'	106	-0.13972	OKGE	'SOONER 138KV'	505	-0.01389	-0.12583	6
OKGE	'MUSTANG 69KV'	106	-0.13972	OKGE	'SOONER 345KV'	513	-0.01395	-0.12577	6
OKGE	'MUSTANG 138KV'	365.5	-0.13538	OKGE	'ONE OAK 345KV'	100	-0.01875	-0.11663	7
OKGE	'MUSTANG 138KV'	365.5	-0.13538	OKGE	'SOONER 138KV'	505	-0.01389	-0.12149	7
OKGE	'MUSTANG 138KV'	365.5	-0.13538	OKGE	'SOONER 345KV'	513	-0.01395	-0.12143	7
OKGE	'MUSTANG 69KV'	106	-0.13972	OKGE	'ONE OAK 345KV'	100	-0.01875	-0.12097	7
OKGE	'HORSESHEOE LAKE 138KV'	380.5	-0.0583	OKGE	'SEMINOLE 138KV'	457.309	0.01443	-0.07273	11

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	HORSESHOE LAKE 138KV	91	-0.0583	OKGE	'SEMINOLE 138KV'	457.309	0.01443	-0.07273	11
OKGE	HORSESHOE LAKE 138KV'	380	-0.0583	OKGE	'SEMINOLE 138KV'	457.309	0.01443	-0.07273	11
OKGE	HORSESHOE LAKE 138KV'	380.5	-0.0583	OKGE	'SEMINOLE 345KV'	590.52	0.01418	-0.07248	11
OKGE	HORSESHOE LAKE 138KV'	380	-0.0583	OKGE	'SEMINOLE 345KV'	590.52	0.01418	-0.07248	11
OKGE	HORSESHOE LAKE 138KV'	91	-0.0583	OKGE	'SEMINOLE 345KV'	590.52	0.01418	-0.07248	11
OKGE	HORSESHOE LAKE 69KV'	16	-0.056	OKGE	'SEMINOLE 138KV'	457.309	0.01443	-0.07043	11
OKGE	HORSESHOE LAKE 69KV'	16	-0.056	OKGE	'SEMINOLE 345KV'	590.52	0.01418	-0.07018	11
OKGE	HORSESHOE LAKE 138KV'	380	-0.0583	OKGE	'AES 161KV'	320	0.00089	-0.05919	14
OKGE	HORSESHOE LAKE 138KV'	91	-0.0583	OKGE	'AES 161KV'	320	0.00089	-0.05919	14
OKGE	HORSESHOE LAKE 138KV'	380.5	-0.0583	OKGE	'AES 161KV'	320	0.00089	-0.05919	14
OKGE	HORSESHOE LAKE 138KV'	380	-0.0583	OKGE	'MUSKOGEE 345KV'	1516	-0.00178	-0.05652	14
OKGE	HORSESHOE LAKE 138KV'	380.5	-0.0583	OKGE	'MUSKOGEE 345KV'	1516	-0.00178	-0.05652	14
OKGE	HORSESHOE LAKE 138KV'	91	-0.0583	OKGE	'MUSKOGEE 345KV'	1516	-0.00178	-0.05652	14
OKGE	HORSESHOE LAKE 69KV'	16	-0.056	OKGE	'AES 161KV'	320	0.00089	-0.05689	14
OKGE	HORSESHOE LAKE 138KV'	380.5	-0.0583	OKGE	'FPLWND2 34KV'	43.0032	-0.00582	-0.05248	15
OKGE	HORSESHOE LAKE 138KV'	380	-0.0583	OKGE	'FPLWND2 34KV'	43.0032	-0.00582	-0.05248	15
OKGE	HORSESHOE LAKE 138KV'	91	-0.0583	OKGE	'FPLWND2 34KV'	43.0032	-0.00582	-0.05248	15
OKGE	HORSESHOE LAKE 69KV'	16	-0.056	OKGE	'MUSKOGEE 345KV'	1516	-0.00178	-0.05422	15
OKGE	HORSESHOE LAKE 69KV'	16	-0.056	OKGE	'FPLWND2 34KV'	43.0032	-0.00582	-0.05018	16
OKGE	HORSESHOE LAKE 138KV'	380	-0.0583	OKGE	'SOONER 138KV'	505	-0.01389	-0.04441	18
OKGE	HORSESHOE LAKE 138KV'	91	-0.0583	OKGE	'SOONER 138KV'	505	-0.01389	-0.04441	18
OKGE	HORSESHOE LAKE 138KV'	380.5	-0.0583	OKGE	'SOONER 138KV'	505	-0.01389	-0.04441	18
OKGE	HORSESHOE LAKE 138KV'	380	-0.0583	OKGE	'SOONER 345KV'	513	-0.01395	-0.04435	18
OKGE	HORSESHOE LAKE 138KV'	380.5	-0.0583	OKGE	'SOONER 345KV'	513	-0.01395	-0.04435	18
OKGE	TINKER 5G 138KV'	62	-0.02998	OKGE	'SEMINOLE 138KV'	457.309	0.01443	-0.04441	18
OKGE	TINKER 5G 138KV'	62	-0.02998	OKGE	'SEMINOLE 345KV'	590.52	0.01418	-0.04416	18
OKGE	HORSESHOE LAKE 69KV'	16	-0.056	OKGE	'SOONER 138KV'	505	-0.01389	-0.04211	19
OKGE	HORSESHOE LAKE 69KV'	16	-0.056	OKGE	'SOONER 345KV'	513	-0.01395	-0.04205	19
OKGE	HORSESHOE LAKE 138KV'	91	-0.0583	OKGE	'ONE OAK 345KV'	100	-0.01875	-0.03955	20
OKGE	HORSESHOE LAKE 138KV'	380	-0.0583	OKGE	'ONE OAK 345KV'	100	-0.01875	-0.03955	20
OKGE	HORSESHOE LAKE 138KV'	380.5	-0.0583	OKGE	'ONE OAK 345KV'	100	-0.01875	-0.03955	20
WFEC	MORLND 138KV'	320	-0.00582	WFEC	'ANADARKO 138KV'	227.0117	0.03305	-0.03887	21
OKGE	HORSESHOE LAKE 69KV'	16	-0.056	OKGE	'ONE OAK 345KV'	100	-0.01875	-0.03725	22
OKGE	ONE OAK 345KV'	236	-0.01875	OKGE	'SEMINOLE 138KV'	457.309	0.01443	-0.03318	24
OKGE	ONE OAK 345KV'	236	-0.01875	OKGE	'SEMINOLE 345KV'	590.52	0.01418	-0.03293	24
OKGE	REDBUD 345KV'	900	-0.01763	OKGE	'SEMINOLE 138KV'	457.309	0.01443	-0.03206	25
OKGE	REDBUD 345KV'	421.65	-0.01763	OKGE	'SEMINOLE 138KV'	457.309	0.01443	-0.03206	25
OKGE	REDBUD 345KV'	900	-0.01763	OKGE	'SEMINOLE 345KV'	590.52	0.01418	-0.03181	25
OKGE	REDBUD 345KV'	421.65	-0.01763	OKGE	'SEMINOLE 345KV'	590.52	0.01418	-0.03181	25
AEPW	COGETRUX 345KV'	229	-0.0049	AEPW	'SOUTHWESTERN STATION 138KV'	29	0.02625	-0.03115	26
AEPW	NORTHEASTERN STATION 138KV'	198	-0.00457	AEPW	'SOUTHWESTERN STATION 138KV'	29	0.02625	-0.03082	26
AEPW	NORTHEASTERN STATION 345KV'	94.99097	-0.00435	AEPW	'SOUTHWESTERN STATION 138KV'	29	0.02625	-0.03036	26
AEPW	OEC 345KV'	1210	-0.00407	AEPW	'SOUTHWESTERN STATION 138KV'	29	0.02625	-0.03032	26
AEPW	RIVERSIDE STATION 138KV'	535	-0.00442	AEPW	'SOUTHWESTERN STATION 138KV'	29	0.02625	-0.03067	26
OKGE	TINKER 5G 138KV'	62	-0.02998	OKGE	'AES 161KV'	320	0.00089	-0.03087	26
AEPW	TULSA POWER STATION 138KV'	147	-0.00475	AEPW	'SOUTHWESTERN STATION 138KV'	29	0.02625	-0.031	26
AEPW	TULSA POWER STATION 138KV'	147	-0.00475	AEPW	'SOUTHWESTERN STATION 138KV'	29	0.02625	-0.031	26
AEPW	TULSA POWER STATION 69KV'	24	-0.00475	AEPW	'SOUTHWESTERN STATION 138KV'	29	0.02625	-0.031	26
AEPW	TULSA POWER STATION 69KV'	33	-0.00475	AEPW	'SOUTHWESTERN STATION 138KV'	29	0.02625	-0.031	26
AEPW	TULSA POWER STATION 69KV'	23	-0.00475	AEPW	'SOUTHWESTERN STATION 138KV'	29	0.02625	-0.031	26
AEPW	MID-CONTINENT 138KV'	142.11	-0.00392	AEPW	'SOUTHWESTERN STATION 138KV'	29	0.02625	-0.03017	27

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade:  
Limiting Facility:  
SOUTH WAVERLY 161/69KV TRANSFORMER CKT 1

Direction:  
From->To  
Line Outage:  
NORTON - NORTON 161KV CKT 1

Flowgate:  
5806358094196105580641206SH

Date Redispatch Needed:  
6/1/06 - 10/1/06

Season Flowgate Identified:  
2006 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1031553	1.0	1.0
Source Control Area	Source	Maximum Increment(MW)
KACP	'CITY OF HIGGINSVILLE 69KV'	36
KACP	'CITY OF HIGGINSVILLE 69KV'	36
KACP	'CITY OF HIGGINSVILLE 69KV'	36
KACP	'CITY OF HIGGINSVILLE 69KV'	36
KACP	'CITY OF HIGGINSVILLE 69KV'	36
KACP	'CITY OF HIGGINSVILLE 69KV'	36
KACP	'CITY OF HIGGINSVILLE 69KV'	36
KACP	'CITY OF HIGGINSVILLE 69KV'	36
KACP	'CITY OF HIGGINSVILLE 69KV'	36
KACP	'BULL CREEK 161KV'	308
KACP	'GRAND AVENUE 161KV'	65
KACP	'HAWTHORN 161KV'	59.29614
KACP	'MONROE 161KV'	27.3195
KACP	'NORTHEAST 13KV'	59
KACP	'NORTHEAST 13KV'	58
KACP	'NORTHEAST 13KV'	56
KACP	'NORTHEAST 13KV'	56
KACP	'NORTHEAST 161KV'	58
KACP	'NORTHEAST 161KV'	58
KACP	'NORTHEAST 161KV'	58
KACP	'PAOLA COMBUSTION TURBINES 161KV'	77

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor