

Aggregate Facility Study
SPP-2007-AG3-AFS-6
For Transmission Service
Requested by
Aggregate Transmission Customers

SPP Engineering, SPP Tariff Studies

SPP AGGREGATE FACILITY STUDY (SPP-2007-AG3-AFS-6)

January 23, 2008

Page 1 of 61

Table of Contents

| 1. Executive Summary | |
|----------------------------------|---|
| • | |
| 2. Introduction | 5 |
| A. Financial Analysis | |
| B. Third Party Facilities | |
| 3. Study Methodology | |
| A. Description | |
| | |
| C. Transmission Request Modeling | |
| | |
| | |
| | |
| A. Study Analysis Results | |
| B. Study Definitions | |
| | |
| 6. Appendix A | |
| | |

1. Executive Summary

Pursuant to Attachment Z1 of the Southwest Power Pool Open Access Transmission Tariff (OATT), 1494 MW of long-term transmission service requests have been restudied in this Aggregate Facility Study (AFS). The first phase of the AFS consisted of a revision of the impact study to reflect the withdrawal of requests for which an Aggregate Facility Study Agreement was not executed. The principal objective of the AFS is to identify system problems and potential modifications necessary to facilitate these transfers while maintaining or improving system reliability as well as summarizing the operating limits and determination of the financial characteristics associated with facility upgrades. Facility upgrade costs are allocated on a prorated basis to all requests positively impacting any individual overloaded facility. Further, Attachment Z2 provides for facility upgrade cost recovery by stating that "Transmission Customers paying Directly Assigned Upgrade Costs for Service Upgrades or that are in excess of the Safe Harbor Cost Limit for Network Upgrades associated with new or changed Designated Resources and Project Sponsors paying Directly Assigned Upgrade Costs for Sponsored Upgrades shall receive revenue credits in accordance with Attachment Z2. Generation Interconnection Customers paying for Network Upgrades shall receive credits for new transmission service using the facility as specified in Attachment Z1."

The total assigned facility upgrade Engineering and Construction (E &C) cost determined by the AFS is \$41 Million. Additionally an indeterminate amount of assigned E & C cost for 3rd party facility upgrades are assignable to the customer. The total upgrade levelized revenue requirement for all transmission requests is \$131 Million. This is based on full allocation of levelized revenue requirements for upgrades to customers without consideration of base plan funding. AFS data table 3 reflects the allocation of upgrade costs to each request without potential base plan funding based on either the requested reservation period or the deferred

reservation period if applicable. Total upgrade levelized revenue requirements for all transmission requests after consideration of potential base plan funding is \$61 Million.

Third-party facilities must be upgraded when it is determined they are constrained in order to accommodate the requested Transmission Service. These include both first-tier neighboring facilities outside SPP and Transmission Owner facilities within SPP that are not under the SPP OATT. In this AFS, third-party facilities were identified. Total engineering and construction cost estimates for required third-party facility upgrades are indeterminate.

The Transmission Provider will tender a Letter of Intent on January 23rd, 2009. This will open a 15-day window for Customer response. To remain in the Aggregate Transmission Service Study (ATSS), the Transmission Provider must receive from the Transmission Customer (Customer) by February 7th, 2009, an executed Letter of Intent. The Letter of Intent will list options the Customer must choose to clarify their commitment to remain in the ATSS. The only action required on OASIS is to WITHDRAW the request or leave the request in STUDY mode.

At the conclusion of the ATSS, Service Agreements for each request for service will be tendered identifying the terms and conditions of the confirmed service.

If customers withdraw from the ATSS after posting of this AFS, the AFS will be re-performed to determine final cost allocation and Available Transmission Capability (ATC) in consideration of the remaining ATSS participants. All allocated revenue requirements for facility upgrades are assigned to the customer in the AFS data tables. Potential base plan funding allowable is contingent upon validation of designated resources meeting Attachment J, Section III B criteria.

2. Introduction

On January 21, 2005, the Federal Energy Regulatory Commission accepted Southwest Power Pool's proposed aggregate transmission study procedures in Docket ER05-109 to become effective February 1, 2005. In compliance with this Order, the third open season of 2007 commenced on June 1, 2007. All requests for long-term transmission service received prior to October 1, 2007 with a signed study agreement were then included in this third Aggregate Transmission Service Study (ATSS) of 2007.

Approximately 1494 MW of long-term transmission service has been restudied in this Aggregate Facility Study (AFS) with over \$41 Million in transmission upgrades being proposed. The results of the AFS are detailed in Tables 1 through 7. A highly tangible benefit of studying transmission requests aggregately under the SPP OATT Attachment Z1 is the sharing of costs among customers using the same facility. The detailed results show individual upgrade costs by study as well as potential base plan allowances as determined by Attachments J and Z1. The following URL can be used to access the SPP OATT:

(http://www.spp.org/Publications/SPP_Tariff.pdf). In order to understand the extent to which base plan upgrades may be applied to both point-to-point and network transmission services, it is necessary to highlight the definition of Designated Resource. Per Section 1.9a of the SPP OATT, a Designated Resource is "[a]ny designated generation resource owned, purchased or leased by a Transmission Customer to serve load in the SPP Region. Designated Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Transmission Customer's load on a non-interruptible basis." Therefore, not only network service, but also point-to-point service has potential for base plan funding if the conditions for classifying upgrades associated with designated resources as base plan upgrades as defined in Section III.B of Attachment J are met.

Pursuant to Attachment J, Section III B of the SPP OATT, the Transmission Customer must provide SPP information necessary to verify that the new or changed Designated Resource meets the following conditions:

- Transmission Customer's commitment to the requested new or changed
 Designated Resource must have a duration of at least five years.
- 2. During the first year the Designated Resource is planned to be used by the Transmission Customer, the accredited capacity of the Transmission Customer's existing Designated Resources plus the lesser of (a) the planned maximum net dependable capacity applicable to the Transmission Customer or (b) the requested capacity; shall not exceed 125% of the Transmission Customer's projected system peak responsibility determined pursuant to SPP Criteria 2.

According to Attachment Z1 Section VI.A, Point-to-Point customers pay the higher of the monthly transmission access charge (base rate) or the monthly revenue requirement associated with the assigned facility upgrades including any prepayments for redispatch required during construction.

Network Integration Service customers pay the total monthly transmission access charges and the monthly revenue requirement associated with the facility upgrades including any prepayments for redispatch during construction.

Transmission Customers paying for a directly assigned network upgrade shall receive credits for new transmission service using the facility as specified in Attachment Z2.

Facilities identified as limiting the requested Transmission Service have been reviewed to determine the required in-service date of each Network Upgrade. The year that each Network Upgrade is required to accommodate a request is determined by interpolating between the

applicable model years given the respective loading data. Both previously assigned facilities and the facilities assigned to this request for Transmission Service were evaluated.

In some instances due to lead times for engineering and construction, Network Upgrades may not be available when required to accommodate a request for Transmission Service. When this occurs, the ATC with available Network Upgrades will be less than the capacity requested during either a portion of or all of the requested reservation period. As a result, the lowest seasonal allocated ATC within the requested reservation period will be offered to the Transmission Customer on an applicable annual basis as listed in Table 1. The ATC may be limited by transmission owner planned projects, expansion plan projects, or customer assigned upgrades.

Some constraints identified in the AFS were not assigned to the Customer as the Transmission Provider determined that upgrades are not required due to various reasons or the Transmission Owner has construction plans pending for these upgrades. These facilities are listed by reservation in Table 3. This table also includes constrained facilities in the current planning horizon that limit the rollover rights of the Transmission Customer. Table 6 lists possible redispatch pairs to allow start of service prior to completion of assigned network upgrades. Table 7 (if applicable) lists deferment of expansion plan projects with different upgrades with the new required in service date as a result of this AFS.

A. Financial Analysis

The AFS utilizes the allocated customer E & C cost in a present worth analysis to determine the monthly levelized revenue requirement of each facility upgrade over the term of the reservation. In some cases, network upgrades cannot be completed within the requested reservation period, thus deferred reservation periods will be utilized in the present worth analysis. If the Customer chose Option 2, Redispatch, in the Letter of Intent sent coincident with the initial AFS, the present worth analysis of revenue requirements will be based on the deferred term with

redispatch in the subsequent AFS. The upgrade levelized revenue requirement includes interest, depreciation, and carrying costs.

Each request for Transmission Service is evaluated independently as the cost associated with each Network Upgrade is assigned to a request. When facilities are upgraded throughout the reservation period, the Transmission Customer shall 1) pay the total E & C costs and other annual operating costs associated with the new facilities, and 2) receive credits associated with the depreciated book value of removed usable facilities, salvage value of removed non-usable facilities, and the carrying charges, excluding depreciation, associated with all removed usable facilities based on their respective book values.

In the event that the engineering and construction of a previously assigned Network Upgrade may be expedited, with no additional upgrades, to accommodate a new request for Transmission Service, then the levelized present worth of only the incremental expenses though the reservation period of the new request, excluding depreciation, shall be assigned to the new request. These incremental expenses, excluding depreciation, include 1) the levelized difference in present worth of the engineering and construction expenses given the change in date to complete construction to account for additional interest expense and reduced engineering and construction expense due to inflation, 2) the levelized present worth of all expediting fees, and 3) the levelized present worth of the incremental annual carrying charges, excluding depreciation and interest, during the new reservation period taking into account both a) the reservation in which the project was originally assigned, and b) a reservation, if any, in which the project was previously expedited.

Achievable Base Plan Avoided Revenue Requirements in the case of a Base Plan upgrade being displaced or deferred by an earlier in service date for a Requested Upgrade shall be determined per Attachment J, Section VII.B methodology. A deferred Base Plan upgrade being defined as a different requested network upgrade needed at an earlier date that negates the need for the initial

base plan upgrade within the planning horizon. A displaced Base Plan upgrade being defined as the same network upgrade being displaced by a requested upgrade needed at an earlier date. Assumption of a 40 year service life is utilized for Base Plan funded projects unless provided otherwise by the Transmission Owner. A present worth analysis of revenue requirements on a common year basis between the Base Plan and Requested Upgrades was performed to determine avoided Base Plan revenue requirements due to the displacement or deferral of the Base Plan upgrade by the Requested Upgrade. The difference in present worth between the Base Plan and Requested Upgrades is assigned to the transmission requests impacting this upgrade based on the displacement or deferral.

B. Third Party Facilities

For third-party facilities listed in Table 3 and Table 5, the Transmission Customer is responsible for funding the necessary upgrades of these facilities per Section 21.1 of the Transmission Provider's OATT. In this AFS, third-party facilities were identified. Total engineering and construction cost estimates for required third-party facility upgrades are indeterminate. The Transmission Provider will undertake reasonable efforts to assist the Transmission Customer in making arrangements for necessary engineering, permitting, and construction of the third-party facilities. Third-party facility upgrade engineering and construction cost estimates are not utilized to determine the present worth value of levelized revenue requirements for SPP system network upgrades.

All modeled facilities within the Transmission Provider system were monitored during the development of this Study as well as certain facilities in first-tier neighboring systems. Third-party facilities must be upgraded when it is determined that they are overloaded while accommodating the requested Transmission Service. An agreement between the Customer and 3rd Party Owner detailing the mitigation of the 3rd party impact must be provided to the Transmission Provider prior to tendering of a Transmission Service Agreement. These facilities

also include those owned by members of the Transmission Provider who have not placed their facilities under the Transmission Provider's OATT. Upgrades on the Southwest Power Administration network requires prepayment of the upgrade cost prior to construction of the upgrade.

Third-party facilities are evaluated for only those requests whose load sinks within the SPP footprint. The Customer must arrange for study of 3rd party facilities for load that sinks outside the SPP footprint with the applicable Transmission Providers.

3. Study Methodology

A. Description

The system impact analysis was conducted to determine the steady-state impact of the requested service on the SPP and first tier Non - SPP control area systems. The steady-state analysis was done to ensure current SPP Criteria and NERC Reliability Standards requirements are fulfilled. The Southwest Power Pool conforms to the NERC Reliability Standards, which provide the strictest requirements, related to voltage violations and thermal overloads during normal conditions and during a contingency. It requires that all facilities be within normal operating ratings for normal system conditions and within emergency ratings after a contingency. Normal operating ratings and emergency operating ratings monitored are Rate A and B in the SPP MDWG models, respectively. The upper bound and lower bound of the normal voltage range monitored is 110% and 90%. Transmission Owner voltage monitoring criteria is used if more restrictive. The SPS Tuco 230 kV bus voltage is monitored at 92.5% due to pre-determined system stability limitations. The WERE Wolf Creek 345 kV bus voltage is monitored at 98.5% due to transmission operating procedure.

The contingency set includes all SPP control area branches and ties 69kV and above, first tier Non - SPP control area branches and ties 115 kV and above, any defined contingencies for these control areas, and generation unit outages for the control areas with SPP reserve share program redispatch. The monitor elements include all SPP control area branches, ties, and buses 69 kV and above, and all first tier Non – SPP control area branches and ties 115 kV and above. Voltage monitoring was performed for SPP control area buses 69 kV and above.

A 3 % transfer distribution factor (TDF) cutoff was applied to all SPP control area facilities. For first tier Non – SPP control area facilities, a 3 % TDF cutoff was applied to AECI, AMRN, and ENTR and a 2 % TDF cutoff was applied to MEC, NPPD, and OPPD. For voltage monitoring, a 0.02 per unit change in voltage must occur due to the transfer or modeling upgrades to be considered a valid limit to the transfer.

B. Model Development

SPP used twelve seasonal models to study the aggregate transfers of 1494 MW over a variety of requested service periods. The SPP MDWG 2008 Series Quarter 4 Cases 2008/09 Winter Peak (08WP), 2009 April (09AP), 2009 Spring Peak (09G), 2008 Summer Peak (09SP), 2009 Summer Shoulder (09SH), 2009 Fall Peak (09FA), 2009/10 Winter Peak (09WP), 2010 Summer Peak (10SP), 2010/11 Winter Peak (10WP), 2013 Summer Peak (13SP), 2013/14 Winter Peak (13WP), and 2018 Summer Peak (18SP) were used to study the impact of the requested service on the transmission system. The Spring Peak models apply to April and May, the Summer Peak models apply to June through September, the Fall Peak models apply to October and November, and the Winter Peak models apply to December through March.

The chosen base case models were modified to reflect the most current modeling information. Five groups of requests were developed from the aggregate of 1494 MW in order to minimize counter flows among requested service. Each request was included in at least two of the four groups depending on the requested path. All requests were included in group five. From the

twelve seasonal models, five system scenarios were developed. Scenario 1 includes SWPP OASIS transmission requests not already included in the SPP 2008 Series Cases flowing in a West to East direction with ERCOTN HVDC Tie South to North, ERCOTE HVDC Tie East to West, SPS exporting, and SPS importing from the Lamar HVDC Tie. Scenario 2 includes transmission requests not already included in the SPP 2008 Series Cases flowing in an East to West direction with ERCOTN HVDC tie North to South, ERCOTE HVDC tie East to West, SPS importing, and SPS exporting to the Lamar HVDC Tie. Scenario 3 includes transmission requests not already included in the SPP 2008 Series Cases flowing in a South to North direction with ERCOTN HVDC tie South to North, ERCOTE HVDC tie East to West, SPS exporting, and SPS exporting to the Lamar HVDC Tie. Scenario 4 includes transmission requests not already included in the SPP 2008 Series Cases flowing in a North to South direction with ERCOTN HVDC tie North to South, ERCOTE HVDC tie East to West, SPS importing, and SPS importing from the Lamar HVDC tie. Scenario 5 include all transmission not already included in the SPP 2008 Series Cases with ERCOTN North to South, ERCOTE East to West, SPS importing and SPS exporting to the Lamar HVDC tie. The system scenarios were developed to minimize counter flows from previously confirmed, higher priority requests not included in the MDWG Base Case.

C. <u>Transmission Request Modeling</u>

Network Integration Transmission Service requests are modeled as Generation to Load transfers in addition to Generation to Generation transfers. The Generation to Load modeling is accomplished by developing a pre-transfer case by redispatching the existing designated network resource(s) down by the new designated network resource request amount and scaling down the applicable network load by the same amount proportionally. The post-transfer case for comparison is developed by scaling the network load back to the forecasted amount and dispatching the new designated network resource being requested. Network Integration Transmission Service requests are modeled as Generation to Load transfers in addition to

Generation to Generation because the requested Network Integration Transmission Service is a request to serve network load with the new designated network resource and the impacts on transmission system are determined accordingly. If the Network Integration Transmission Service request application clearly documents that the existing designated network resource(s) is being replaced or undesignated by the new designated network resource then MW impact credits will be given to the request as is done for a redirect of existing transmission service. Point-To-Point Transmission Service requests are modeled as Generation to Generation transfers. Generation to Generation transfers are accomplished by developing a post-transfer case for comparison by dispatching the request source and redispatching the request sink.

D. Transfer Analysis

Using the selected cases both with and without the requested transfers modeled, the PSS/E Activity ACCC was run on the cases and compared to determine the facility overloads caused or impacted by the transfer. Transfer distribution factor cutoffs (SPP and 1st-Tier) and voltage threshold (0.02 change) were applied to determine the impacted facilities. The PSS/E options chosen to conduct the analysis can be found in Appendix A.

E. Curtailment and Redispatch Evaluation

During any period when SPP determines that a transmission constraint exists on the Transmission System, and such constraint may impair the reliability of the Transmission System, SPP will take whatever actions that are reasonably necessary to maintain the reliability of the Transmission System. To the extent SPP determines that the reliability of the Transmission System can be maintained by redispatching resources, SPP will evaluate interim curtailment of existing confirmed service or interim redispatch of units to provide service prior to completion of any assigned network upgrades. Any redispatch may not unduly discriminate between the Transmission Owners' use of the Transmission System on behalf of their Native Load Customers and any Transmission Customer's use of the Transmission System to serve its designated load.

Redispatch was evaluated to provide only interim service during the time frame prior to completion of any assigned network upgrades. Curtailment of existing confirmed service is evaluated to provide only interim service. Curtailment of existing confirmed service is only evaluated at the request of the transmission customer.

SPP determined potential relief pairs to relieve the incremental MW impact on limiting facilities as identified in Table 6. Using the selected cases where the limiting facilities were identified, potential incremental and decremental units were identified by determining the generation amount available for increasing and decreasing from the units generation amount, maximum generation amount, and minimum generation amount. If the incremental or decremental amount was greater than 1 MW, the unit was considered as a potential incremental or decremental unit. Generation shift factors were calculated for the potential incremental and decremental units using Managing and Utilizing System Transmission (MUST). Relief pairs from the generation shift factors for the incremental and decremental units with a greater than 3% TDF on the limiting constraint were determined from the incremental units with the lowest generation shift factors and decremental units with highest generation shift factors. If the aggregate redispatch amount for the potential relief pair was determined to be three times greater than the lower of the increment or decrement then the pair was determined not to be feasible and is not included. If transmission customer would like to see additional relief pairs beyond the relief pairs determined, the transmission customer can request SPP to provide the additional pairs. The potential relief pairs were not evaluated to determine impacts on limiting facilities in the SPP and 1st-Tier systems. The redispatch requirements would be called upon prior to implementing NERC TLR Level 5a.

4. Study Results

A. Study Analysis Results

Tables 1 through 6 contain the steady-state analysis results of the AFS. Table 1 identifies the participating long-term transmission service requests included in the AFS. This table lists deferred start and stop dates both with and without redispatch (based on customer selection of redispatch if available), the minimum annual allocated ATC without upgrades and season of first impact. Table 2 identifies total E & C cost allocated to each Transmission Customer, letter of credit requirements, third party E & C cost assignments, potential base plan E & C funding (lower of allocated E & C or Attachment J Section III B criteria), total revenue requirements for assigned upgrades without consideration of potential base plan funding, point-to-point base rate charge, total revenue requirements for assigned upgrades with consideration of potential base plan funding, and final total cost allocation to the Transmission Customer. In addition, Table 2 identifies SWPA upgrade costs which require prepayment in addition to other allocated costs. Table 3 provides additional details for each request including all assigned facility upgrades required, allocated E & C costs, allocated revenue requirements for upgrades, upgrades not assigned to customer but required for service to be confirmed, credits to be paid for previously assigned AFS or GI network upgrades, and any third party upgrades required. Table 4 lists all upgrade requirements with associated solutions needed to provide transmission service for the AFS, Minimum ATC per upgrade with season of impact, Earliest Date Upgrade is required (DUN), Estimated Date the upgrade will be completed and in service (EOC), and Estimated E & C cost. Table 5 lists identified Third-Party constrained facilities. Table 6 identifies potential redispatch pairs available to relieve the aggregate impacts on identified constraints to prevent deferral of start of service. Table 7 (if applicable) identifies deferred expansion plan projects that were replaced with requested upgrades at earlier dates.

The potential base plan funding allowable is contingent upon meeting each of the conditions for classifying upgrades associated with designated resources as base plan upgrades as defined in

Section III.B of Attachment J. If the additional capacity of the new or changed designated resource exceeds the 125% resource to load forecast for the year of start of service, the requested resource is not eligible for base plan funding of required network upgrades and the full cost of the upgrades is assignable to the customer. If the 5 year term and 125% resource to load criteria are met, the lesser of the planned maximum net dependable capacity (NDC) or the requested capacity is multiplied by \$180,000 to determine the potential base plan funding allowable. When calculating Base Plan Funding amounts that include a wind farm, the amount used is 10% of the requested amount of service, or the NDC. The Maximum Potential Base Plan Funding Allowable may be less than the potential base plan funding allowable due to the E & C Cost allocated to the customer being lower than the potential amount allowable to the customer. The customer is responsible for any assigned upgrade costs in excess of Potential Base Plan Engineering and Construction Funding Allowable.

Regarding application of base plan funding for PTP requests, if PTP base rate exceeds upgrade revenue requirements without taking into effect the reduction of revenue requirements by potential base plan funding, then the base rate revenue pays back the Transmission Owner for upgrades and no base plan funding is applicable as the access charge must be paid as it is the higher of "OR" pricing.

However, if initially the upgrade revenue requirements exceed the PTP base rate, then potential base plan funding would be applicable. The test of the higher of "OR" pricing would then be made against the remaining assignable revenue requirements versus PTP base rate. Examples are as follows:

Example A:

E & C allocated for upgrades is 74 million with revenue requirements of 140 million and PTP base rate of 101 million. Potential base plan funding is 47 million with the difference of 27

SPP AGGREGATE FACILITY STUDY (SPP-2007-AG3-AFS-6)

million E & C assignable to the customer. If the revenue requirements for the assignable portion is 54 million and the PTP base rate is 101 million, the customer will pay the higher "OR" pricing of 101 million base rate of which 54 million revenue requirements will be paid back to the Transmission Owners for the upgrades and the remaining revenue requirements of (140-54) or 86 million will be paid by base plan funding.

Example B:

E & C allocated for upgrades is 74 million with revenue requirements of 140 million and PTP base rate of 101 million. Potential base plan funding is 10 million with the difference of 64 million E & C assignable to the customer. If the revenue requirements for this assignable portion is 128 million and the PTP base rate is 101 million the customer will pay the higher "OR" pricing of 128 million revenue requirements to be paid back to the Transmission Owners and the remaining revenue requirements of (140-128) or 12 million will be paid by base plan funding.

Example C:

E & C allocated for upgrades is 25 million with revenue requirements of 50 million and PTP base rate of 101 million. Potential base plan funding is 10 million. Base plan funding is not applicable as the higher "OR" pricing of PTP base rate of 101 million must be paid and the 50 million revenue requirements will be paid from this.

The 125% resource to load determination is performed on a per request basis and is not based on a total of designated resource requests per Customer. A footnote will provide the maximum resource designation allowable for base plan funding consideration per Customer basis per year.

Base plan funding verification requires that each Transmission Customer with potential for base plan funding provide SPP attestation statements verifying that the firm capacity of the requested designated resource is committed for a minimum five year duration.

B. Study Definitions

The Date Upgrade Needed Date (DUN) is the earliest date the upgrade is required to alleviate a constraint considering all requests. End of Construction (EOC) is the estimated date the upgrade will be completed and in service. The Total Engineering and Construction Cost (E & C) is the upgrade solution cost as determined by the transmission owner. The Transmission Customer Allocation Cost is the estimated engineering and construction cost based upon the allocation of costs to all Transmission Customers in the AFS who positively impact facilities by at least 3% subsequently overloaded by the AFS. Minimum ATC is the portion of the requested capacity that can be accommodated with out upgrading facilities. Annual ATC allocated to the Transmission Customer is determined by the least amount of allocated seasonal ATC within each year of a reservation period.

5. Conclusion

The results of the AFS show that limiting constraints exist in many areas of the regional transmission system. Due to these constraints, transmission service cannot be granted unless noted in Table 3.

The Transmission Provider will tender a Letter of Intent on January 23rd, 2009. This will open a 15-day window for Customer response. To remain in the Aggregate Transmission Service Study (ATSS), the Transmission Provider must receive from the Transmission Customer (Customer) by February 7th, 2009, an executed Letter of Intent. The Letter of Intent will list options the Customer must choose to clarify their commitment to remain in the ATSS. The only action required on OASIS is to WITHDRAW the request or leave the request in STUDY mode.

The Transmission Provider must receive an unconditional and irrevocable letter of credit in the amount of the total allocated Engineering and Construction costs assigned to the Customer. This letter of credit is not required for those facilities that are base plan funded. This amount is for all assignable Network Upgrades less pre-payment requirements. The amount of the letter of credit will be adjusted down on an annual basis to reflect amortization of these costs. The Transmission Provider will issue notifications to construct facility upgrades to the constructing Transmission Owner. This date is determined by the engineering and construction lead time provided for each facility upgrade.

6. Appendix A

PSS/E CHOICES IN RUNNING LOAD FLOW PROGRAM AND ACCC

| BASE CASES: | |
|------------------------------------|--|
| Solutions - Fixed slope | decoupled Newton-Raphson solution (FDNS) |
| Tap adjustment – Stepp | ping |
| Area interchange contr | ol – Tie lines and loads |
| Var limits – Apply imr | nediately |
| Solution options - \underline{X} | Phase shift adjustment |
| | Flat start |
| _ · | Lock DC taps |
| | Lock switched shunts |
| ACCC CASES: | |
| Solutions – AC conting | gency checking (ACCC) |
| MW mismatch tolerand | ce - 0.5 |
| Contingency case ratin | g – Rate B |
| Percent of rating – 100 | |
| Output code – Summa | • |
| Min flow change in ov | |
| | ·loads form report – YES |
| Exclude interfaces from | • |
| Perform voltage limit o | |
| Elements in available of | |
| | ailable capacity table – 99999.0 |
| | chng for report -0.02 |
| Sorted output – None | |
| Newton Solution: | |
| Tap adjustment – Step | |
| _ | ol – Tie lines and loads |
| Var limits - Apply auto | • |
| - | Phase shift adjustment |
| | Flat start |
| | Lock DC taps |
| | Lock switched shunts |

Table 1 - Long-Term Transmission Service Requests Included in Aggregate Facility Study

| Customer | Study Number | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date without interim redispatch | Deferred Stop Date without interim redispatch | interim redispatch | Stop Date with interim redispatch | Minimum Allocated ATC (MW) withing reservation period | Season of Minimum Allocated ATC within reservation period |
|----------|---------------|-------------|------|------|---------------------|-------------------------|------------------------|---|--|-----------------------|---|---|---|
| AEPM | AG3-2007-015 | 1337138 | CSWS | EES | 22 | 1/1/2009 | 1/1/2010 | 6/1/2011 | 6/1/2012 | 4/1/2009 | 4/1/2010 | | 09SP |
| AEPM | AG3-2007-054 | 1352732 | CSWS | CSWS | 100 | 1/1/2010 | 1/1/2011 | 6/1/2012 | 6/1/2013 | 1/1/2010 | 1/1/2011 | 0 | 10SP |
| AEPM | AG3-2007-063 | 1352923 | CSWS | CSWS | 50 | 1/1/2009 | 1/1/2011 | 6/1/2012 | 6/1/2014 | 4/1/2009 | 4/1/2011 | 0 | 09SP |
| AEPM | AG3-2007-065 | 1352934 | CSWS | CSWS | 54 | 6/1/2010 | 6/1/2015 | 6/1/2012 | 6/1/2017 | 6/1/2010 | 6/1/2015 | 0 | 10SP |
| CMLP | AG3-2007-047 | 1352193 | GRDA | CSWS | 197 | 6/1/2008 | 6/1/2042 | 6/1/2012 | 6/1/2046 | 4/1/2009 | 4/1/2043 | 0 | 08SP |
| CRGL | AG3-2007-019 | 1340343 | OPPD | CLEC | 103 | 2/1/2008 | 2/1/2009 | 6/1/2013 | 6/1/2014 | 6/1/2013 | 6/1/2014 | 0 | 08SP |
| EDE | AG3-2007-037 | 1350960 | KCPL | EDE | 5 | 11/1/2008 | 11/1/2018 | 6/1/2012 | 6/1/2022 | 4/1/2009 | 4/1/2019 | 0 | 09SP |
| EDE | AG3-2007-046 | 1352109 | KCPL | EDE | 5 | 1/1/2010 | 1/1/2030 | 6/1/2011 | 6/1/2031 | 1/1/2010 | 1/1/2030 | 0 | 10SP |
| GRDA | AG3-2007-034 | 1350396 | OKGE | GRDA | 150 | 6/1/2008 | 6/1/2013 | 6/1/2012 | 6/1/2017 | 4/1/2009 | 4/1/2014 | | 08SP |
| KBPU | AG3-2007-017D | 1339117 | MPS | KACY | 5 | 2/1/2008 | 2/1/2009 | 11/1/2010 | 11/1/2011 | 4/1/2009 | 4/1/2010 | 0 | 08SP |
| KCPS | AG3-2007-074 | 1353013 | KCPL | KCPL | 45 | 11/1/2008 | 11/1/2018 | 6/1/2011 | 6/1/2021 | 4/1/2009 | 4/1/2019 | 0 | 09SP |
| KEPC | AG3-2007-064 | 1352933 | WR | KCPL | 15 | 6/1/2008 | 6/1/2040 | 6/1/2011 | 6/1/2043 | 4/1/2009 | 4/1/2041 | 0 | 08SP |
| KEPC | AG3-2007-066 | 1352938 | WR | WR | 68 | 6/1/2008 | 6/1/2040 | 6/1/2013 | 6/1/2045 | 6/1/2013 | 6/1/2045 | 0 | 08SP |
| KMEA | AG3-2007-104 | 1355377 | OPPD | KCPL | 20 | 1/1/2009 | 1/1/2013 | 6/1/2013 | 6/1/2017 | 6/1/2013 | 6/1/2017 | 0 | 09SP |
| KPP | AG3-2007-040 | 1351224 | WR | WR | 4 | 2/1/2008 | 2/1/2018 | 6/1/2013 | 6/1/2023 | 6/1/2011 | 6/1/2021 | | 08SP |
| MIDW | AG3-2007-082 | 1353081 | WR | WR | 5 | 6/1/2008 | 6/1/2013 | 6/1/2013 | 6/1/2018 | 6/1/2013 | 6/1/2018 | 0 | 08SP |
| MIDW | AG3-2007-082 | 1353082 | WR | WR | 4 | 6/1/2008 | 6/1/2013 | 6/1/2013 | 6/1/2018 | 6/1/2013 | 6/1/2018 | | 08SP |
| MIDW | AG3-2007-082 | 1353083 | WR | WR | 3 | 6/1/2008 | 6/1/2013 | 6/1/2013 | 6/1/2018 | 6/1/2013 | 6/1/2018 | 0 | 08SP |
| MIDW | AG3-2007-082 | 1353084 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2013 | 6/1/2018 | 6/1/2013 | 6/1/2018 | 0 | 08SP |
| MIDW | AG3-2007-082 | 1353085 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2013 | 6/1/2018 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-083 | 1353086 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2013 | 6/1/2018 | 6/1/2011 | 6/1/2016 | | 08SP |
| MIDW | AG3-2007-083 | 1353088 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2013 | 6/1/2018 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-084 | 1353090 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2013 | 6/1/2018 | 6/1/2011 | 6/1/2016 | | 08SP |
| MIDW | AG3-2007-084 | 1353091 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2013 | 6/1/2018 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-084 | 1353092 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2013 | 6/1/2018 | 6/1/2011 | 6/1/2016 | | 08SP |
| MIDW | AG3-2007-086 | 1353097 | WR | WR | 3 | 6/1/2008 | 6/1/2013 | 6/1/2013 | 6/1/2018 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-086 | 1353098 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2013 | 6/1/2018 | 6/1/2011 | 6/1/2016 | | 08SP |
| MIDW | AG3-2007-086 | 1353099 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2013 | 6/1/2018 | 6/1/2011 | 6/1/2016 | | 08SP |
| MIDW | AG3-2007-087 | 1353102 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2013 | 6/1/2018 | 6/1/2011 | 6/1/2016 | | 08SP |
| MIDW | AG3-2007-087 | 1353103 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2013 | 6/1/2018 | 6/1/2011 | 6/1/2016 | | 08SP |
| MIDW | AG3-2007-090 | 1353110 | WR | WR | 25 | 3/1/2008 | 3/1/2027 | 6/1/2013 | 6/1/2032 | 6/1/2013 | 6/1/2032 | 0 | 08SP |
| MIDW | AG3-2007-091 | 1353111 | | WR | 25 | 1/1/2009 | 1/1/2029 | 6/1/2013 | 6/1/2033 | 6/1/2013 | 6/1/2033 | | 09SP |
| OMPA | AG3-2007-035 | 1350945 | | OKGE | 23 | 5/1/2008 | 5/1/2017 | 6/1/2011 | 6/1/2020 | 4/1/2009 | 4/1/2018 | | 08SP |
| SPSM | AG3-2007-080 | 1353054 | WPEK | KCPL | 50 | 10/1/2008 | 6/1/2010 | 6/1/2011 | 2/1/2013 | 4/1/2009 | 12/1/2010 | | 09SP |
| SPSM | AG3-2007-080 | 1353055 | | KCPL | 50 | 10/1/2008 | 6/1/2010 | 6/1/2011 | 2/1/2013 | 4/1/2009 | 12/1/2010 | | 09SP |
| SPSM | AG3-2007-081 | 1353057 | | KCPL | 50 | 6/1/2010 | 1/1/2012 | 6/1/2011 | 1/1/2013 | 6/1/2010 | 1/1/2012 | | 10SP |
| SPSM | AG3-2007-081 | 1353059 | WPEK | KCPL | 50 | 6/1/2010 | 1/1/2012 | 6/1/2011 | 1/1/2013 | 6/1/2010 | 1/1/2012 | | 10SP |
| WFEC | AG3-2007-043 | 1510704 | | WFEC | 150 | 5/1/2009 | 5/1/2039 | 6/1/2011 | 6/1/2041 | 6/1/2011 | 6/1/2041 | | 09SP |
| WRGS | AG3-2007-025 | | | WR | 96 | 11/1/2008 | 11/1/2018 | 6/1/2011 | 6/1/2021 | 6/1/2011 | 6/1/2021 | | 09SP |
| WRGS | AG3-2007-026 | 1346842 | SECI | WR | 100 | 12/31/2008 | 12/31/2018 | 6/1/2011 | 6/1/2021 | 6/1/2011 | 6/1/2021 | 0 | 09SP |

1494

Note 1: Disregard Redispatch shown in Table 6 for limitations identified earlier than the start date with redispatch with the exception of limitations identified in the 2009 Summer Shoulder, and 2009 Fall Peak

Note 2: Start and Stop Dates with interim redispatch are determined based on customers choosing option to pursue redispatch to start service at Requested Start and Stop Dates or earliest date possible.

Note 3: Start dates with and without redispatch are based on the assumed completion dates of previous Aggregate Transmission Service Studies currently being conducted. Actual start dates may differ from the potential start dates upon completion of the previous studies.

 Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests

| | | , | | , | • | | | • | • | , | |
|----------|---------------|-------------|------------------|-------------------|-----------------|-------|---------------|------------------|---------------------|----------------|---------------------|
| | | | | | | | | 3 Total Revenue | | | |
| | | | | | | | | Requirements for | | | |
| | | | | | | | | | 3 5 Total Revenue | | |
| | | | Engineering and | | | | 4Additional | | Requirements for | | |
| | | | Construction | | 2Potential Base | | Engineering | | Assigned Upgrades | | 4Total Cost of |
| | | | Cost of Upgrades | : | Plan | | and | | Over Term of | Point-to-Point | Reservation |
| | | | Allocated to | | Engineering and | | Construction | | Reservation | Base Rate | Assignable to |
| | | | Customer for | 1Letter of Credit | Construction | | Cost for 3rd | | WITH | Over | Customer Contingent |
| | | | Revenue | Amount | Funding | | Party | Plan Funding | Potential Base Plan | Reservation | Upon Base Plan |
| Customer | Study Number | Reservation | Requirements | Required | Allowable | Notes | Upgrades | Allocation | Funding Allocation | Period | Funding |
| AEPM | AG3-2007-015 | 1337138 | \$ - | \$ - | \$ - | | Indeterminate | \$ - | \$ - | \$ - | Schedule 9 Charges |
| AEPM | AG3-2007-054 | 1352732 | \$ - | \$ - | \$ - | | Indeterminate | \$ - | \$ - | \$ - | Schedule 9 Charges |
| AEPM | AG3-2007-063 | 1352923 | \$ - | \$ - | \$ - | | Indeterminate | \$ - | \$ - | \$ - | Schedule 9 Charges |
| AEPM | AG3-2007-065 | 1352934 | \$ - | \$ - | \$ - | 6 | Indeterminate | \$ - | \$ - | \$ - | Schedule 9 Charges |
| CMLP | AG3-2007-047 | 1352193 | | \$ - | \$ 8,316,502 | 9 | \$ - | \$ 39,438,439 | \$ - | \$ - | Schedule 9 Charges |
| CRGL | AG3-2007-019 | 1340343 | \$ 1,870,994 | \$ 1,870,994 | \$ - | | Indeterminate | \$ 4,990,825 | \$ 4,990,825 | \$ 1,909,839 | \$ 4,990,825 |
| EDE | AG3-2007-037 | 1350960 | \$ 403,503 | \$ - | \$ 403,503 | | Indeterminate | \$ 1,059,362 | \$ - | \$ - | Schedule 9 Charges |
| EDE | AG3-2007-046 | 1352109 | \$ 403,503 | \$ - | \$ 403,503 | | Indeterminate | \$ 1,598,709 | \$ - | \$ - | Schedule 9 Charges |
| GRDA | AG3-2007-034 | 1350396 | \$ - | \$ - | \$ - | | \$ 2,000,000 | \$ - | \$ - | \$ - | Schedule 9 Charges |
| KBPU | AG3-2007-017D | 1339117 | \$ - | \$ - | \$ - | | \$ - | \$ - | \$ - | \$ 52,800 | \$ 52,800 |
| | AG3-2007-074 | 1353013 | \$ 5,153,254 | \$ - | \$ 5,153,254 | | \$ - | \$ 13,089,498 | \$ - | \$ - | Schedule 9 Charges |
| KEPC | AG3-2007-064 | 1352933 | \$ 152,559 | \$ - | \$ 152,559 | | \$ - | \$ 696,219 | \$ - | \$ - | Schedule 9 Charges |
| KEPC | AG3-2007-066 | 1352938 | \$ 435,359 | \$ - | \$ 435,359 | 9 | Indeterminate | \$ 3,045,096 | \$ - | \$ - | Schedule 9 Charges |
| KMEA | AG3-2007-104 | 1355377 | \$ 920,593 | \$ 920,593 | \$ - | | Indeterminate | \$ 2,720,671 | \$ 2,720,671 | \$ - | \$ 2,720,671 |
| KPP | AG3-2007-040 | 1351224 | \$ 85,061 | \$ - | \$ 85,061 | | \$ - | \$ 327,462 | \$ - | \$ - | Schedule 9 Charges |
| MIDW | AG3-2007-082 | 1353081 | \$ 19,217 | \$ - | \$ - | | Indeterminate | \$ 56,840 | \$ 56,840 | \$ 719,700 | \$ 719,700 |
| MIDW | AG3-2007-082 | 1353082 | \$ 15,373 | \$ - | \$ - | | Indeterminate | \$ 45,472 | \$ 45,472 | \$ 575,760 | \$ 575,760 |
| MIDW | AG3-2007-082 | 1353083 | \$ 11,530 | \$ - | \$ - | | Indeterminate | \$ 34,103 | \$ 34,103 | \$ 431,820 | \$ 431,820 |
| MIDW | AG3-2007-082 | 1353084 | \$ 7,687 | \$ - | \$ - | | Indeterminate | \$ 22,736 | \$ 22,736 | \$ 287,880 | \$ 287,880 |
| MIDW | AG3-2007-082 | 1353085 | \$ 3,844 | \$ - | \$ - | | \$ - | \$ 11,369 | \$ 11,369 | \$ 143,940 | \$ 143,940 |
| MIDW | AG3-2007-083 | 1353086 | \$ 17,347 | \$ - | \$ - | | \$ - | \$ 49,511 | \$ 49,511 | \$ 143,940 | \$ 143,940 |
| MIDW | AG3-2007-083 | 1353088 | \$ 34,696 | \$ - | \$ - | | \$ - | \$ 99,024 | \$ 99,024 | \$ 287,880 | \$ 287,880 |
| MIDW | AG3-2007-084 | 1353090 | \$ 12,327 | \$ - | \$ - | | \$ - | \$ 35,268 | \$ 35,268 | \$ 143,940 | \$ 143,940 |
| MIDW | AG3-2007-084 | 1353091 | \$ 24,652 | \$ - | \$ - | | \$ - | \$ 70,532 | \$ 70,532 | \$ 287,880 | \$ 287,880 |
| MIDW | AG3-2007-084 | 1353092 | \$ 24,652 | \$ - | \$ - | | \$ - | \$ 70,532 | \$ 70,532 | \$ 287,880 | \$ 287,880 |
| MIDW | AG3-2007-086 | 1353097 | \$ 143,983 | \$ - | \$ - | 7 | \$ - | \$ 409,393 | \$ 409,393 | \$ 431,820 | \$ 431,820 |
| MIDW | AG3-2007-086 | 1353098 | | \$ - | \$ - | 7 | \$ - | \$ 272,930 | | \$ 287,880 | \$ 287,880 |
| MIDW | AG3-2007-086 | 1353099 | \$ 47,994 | \$ - | \$ - | 7 | \$ - | \$ 136,464 | \$ 136,464 | \$ 143,940 | \$ 143,940 |
| | AG3-2007-087 | 1353102 | | \$ - | \$ - | 7 | \$ - | \$ 272,930 | | \$ 287,880 | \$ 287,880 |
| MIDW | AG3-2007-087 | 1353103 | \$ 47,994 | \$ - | \$ - | 7 | \$ - | \$ 136,464 | \$ 136,464 | \$ 143,940 | \$ 143,940 |
| MIDW | AG3-2007-090 | 1353110 | \$ 225,750 | \$ - | \$ 225,750 | | \$ - | \$ 956,008 | | \$ - | Schedule 9 Charges |
| | AG3-2007-091 | 1353111 | + -, | | \$ 225,750 | | \$ - | \$ 985,728 | * | \$ - | Schedule 9 Charges |

Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests

| | 1 | | 1 | | 1 | | | 1 | | l | 2 T | otal Revenue | l | | l | | | |
|-------------|--------------|-------------|----------|-----------|-----|----------------|------|--------------|-------|--------------|------|----------------|-------|-----------------|-----|--------------|---------|----------------|
| | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | Rec | quirements for | | | | | | |
| | | | | | | | | | | | Ass | igned | 3 5 T | otal Revenue | | | | |
| | | | Engine | ering and | | | | | | 4Additional | Upg | rades Over | Requ | irements for | | | | |
| | | | Constru | ıction | | | 2Po | tential Base | | Engineering | Terr | m of | Assig | ned Upgrades | | | 4Total | Cost of |
| | | | Cost of | Upgrades | | | Plar | ı | | and | Res | servation | Over | Term of | Poi | int-to-Point | Reserv | ation |
| | | | Allocate | ed to | | | Eng | ineering and | | Construction | WIT | HOUT | Rese | rvation | Bas | se Rate | Assigna | able to |
| | | | Custome | er for | 1Le | tter of Credit | Con | struction | | Cost for 3rd | Pote | ential Base | WITH | l | Ove | er | Custon | ner Contingent |
| | | | Revenue | ie | Amo | ount | Fun | ding | | Party | Plar | n Funding | Poter | ntial Base Plan | Res | servation | Upon E | sase Plan |
| Customer | Study Number | Reservation | Require | ements | Req | uired | Allo | wable | Notes | Upgrades | Allo | cation | Fundi | ing Allocation | Per | iod | Fundin | g |
| OMPA | AG3-2007-035 | 1350945 | \$ | 1,149 | \$ | - | \$ | 1,149 | | \$ - | \$ | 2,378 | \$ | | \$ | - | Sched | ule 9 Charges |
| SPSM | AG3-2007-080 | 1353054 | \$ | 168,750 | \$ | - | \$ | - | | \$ - | \$ | 204,785 | \$ | 204,785 | \$ | 880,000 | \$ | 880,000 |
| SPSM | AG3-2007-080 | 1353055 | \$ | 168,750 | \$ | - | \$ | - | | \$ - | \$ | 204,785 | \$ | 204,785 | \$ | 880,000 | \$ | 880,000 |
| SPSM | AG3-2007-081 | 1353057 | \$ 1 | ,748,619 | \$ | 1,618,968 | \$ | - | | \$ - | \$ | 3,405,857 | \$ | 3,405,857 | \$ | 836,000 | \$ | 3,405,857 |
| SPSM | AG3-2007-081 | 1353059 | \$ 1 | ,748,619 | \$ | 1,618,968 | \$ | - | | \$ - | \$ | 3,405,857 | \$ | 3,405,857 | \$ | 836,000 | \$ | 3,405,857 |
| WFEC | AG3-2007-043 | 1510704 | \$ | - | \$ | - | \$ | - | 8 | \$ - | \$ | - | \$ | - | \$ | - | Sched | ule 9 Charges |
| WRGS | AG3-2007-025 | 1346837 | \$ 1 | ,616,090 | \$ | - | \$ | 1,616,090 | • | \$ - | \$ | 3,934,252 | \$ | - | \$ | | Sched | ule 9 Charges |
| WRGS | AG3-2007-026 | 1346842 | \$ 17 | 7,417,601 | \$ | 15,277,413 | \$ | 1,800,000 | • | \$ - | \$ | 49,563,885 | \$ | 44,441,768 | \$ | | \$ | 44,441,768 |
| Grand Total | al | | \$ 41 | ,665,682 | | | | • | | • | \$ | 131,353,380 | \$ | 61,098,112 | | | | |

Note 1: Letter of Credit required for financial security for transmission owner for network upgrades is determined by allocated engineering and construction costsdess engineering and construction costs for upgrades when network customer is the transmission owner less the E & C allocation of expedited projects. Letter of Credit is not required for upgrades fully funded by PTP base rate or base plan funding. The Letter Of Credit Amount listed is based on meeting OATT Attachment J requirements for base plan funding.

Note 2: If potential base plan funding is applicable, this value is the lesser of the Engineering and Construction costs of assignable upgrades or the value of base plan funding calculated pursuant to Attachment J, Section III B criteria. Allocation of base plan funding is contingent upon verification of customer agreements meeting Attachment J, Section II B criteria. Not applicable if Point-to-Point base rate exceeds revenue requirements.

Note 3: Revenue Requirements (RR) are based upon deferred end dates if applicable. Deferred dates are based upon customer's choice to pursue redispatch. Achievable Base Plan Avoided RR in the case of a Base Plan upgrade being displaced or deferred by an earlier in service date for a Requested Upgrade shall be determined per Attachment J, Section VII.C methodology. Assumption of a 40 year service life is utilized for Base Plan funded projects. A present worth analysis of RR on a common year basis between the Base Plan and Requested Upgrades was performed to determine avoided Base Plan RR due to the displacement or deferral of the Base Plan upgrade by the Requested Upgrade. The incremental increase in present worth of a Requested Upgrade on a common year basis as a Base Plan upgrade is assigned to the transmission requests impacting the upgrade based on the displacement or deferral. If the displacement analysis results in lower RR due to the shorter amortization period of the requested upgrade when compared to a base plan amortization period, then no direct assignment of the upgrade cost is made due to the displacement to an earlier start date.

Note 4: For Point-to-Point requests, total cost is based on the higher of the base rate or assigned upgrade revenue requirements. For Network requests, the total cost is based on the assigned upgrade revenue requirement. Allocation of base plan funding will be determined after verification of designated resource meeting Attachment J, Section II B Criteria. Additionally E & C of 3rd Party upgrades is assignable to Customer. This includes prepayments required for any SWPA upgrades. Revenue requirements for 3rd Party facilities are not calculated. Total cost to customer is based on assumption of Revenue Requirements with confirmation of base plan funding. Customer is responsible for negotiating redispatch costs if applicable. Customer is also responsible to pay credits for previously assigned upgrades that are impacted by their request. Credits can be paid from base plan funding if applicable.

Note 5: RR with base plan funding may increase or decrease even if no base plan funding is applicable to a particular request if another request that shares the upgrade is now full base plan funded resulting in a different amortization period for the upgrade and thus different RR.

Note 6: 2010 Maximum new resources capped at 10,693MW

Note 7: Lack of resource and load forecast data provided for Base Plan Funding determination

Note 8: Per Transmission Discretion Log on OASIS

Note 9: Waiver approved to fully Base Plan Fund upgrades

Note 10: The Spearville-Knoll-Axtell 345kV Ckt 1 facility will be considered as a Balanced Portfolio project by the SPP BOD at their April 2009 meeting. If this line is approved, it will be considered a construction pending project and not assignable to 2007-AG3 customers.

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Date Without | Deferred Stop Date Without Redispatch | | Point-to-Point | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|-----|---------------------|-------------------------|------------------------|--------------|---|------|----------------|----------------------|-------------------------------|
| AEPM | 1337138 | CSWS | EES | 22 | 1/1/2009 | 1/1/2010 | 6/1/2011 | 6/1/2012 | \$ - | \$ - | \$ - | \$ - |
| | | | | | | | | | | | | 1 - |

| | | | | Earliest | Redispatch | Allocated E & C | | Total Revenue | |
|-------------|---|----------|----------|--------------|------------|-----------------|------------------|---------------|---|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | Total E & C Cost | Requirements | |
| 1337138 | BETHEL - BROKEN BOW 138KV CKT 1 #2 | 6/1/2009 | 6/1/2011 | | | \$ - | \$ - | \$ | - |
| | BETHEL - NASHOBA 138KV CKT 1 | 6/1/2009 | 6/1/2012 | | | \$ - | \$ - | \$ | - |
| | CLAYTON - NASHOBA 138KV CKT 1 | 6/1/2009 | 6/1/2012 | | | \$ - | \$ - | \$ | - |
| | CLAYTON - SARDIS 138KV CKT 1 | 6/1/2009 | 6/1/2012 | | | \$ - | \$ - | \$ | - |
| | LYDIA - WELSH 345KV CKT 1 | 6/1/2009 | 6/1/2012 | | | \$ - | \$ - | \$ | - |
| | NORTHWEST TEXARKANA - PATTERSON 138KV CKT 1 | 6/1/2009 | 6/1/2012 | | | \$ - | \$ - | \$ | - |
| | | | | | Total | \$ - | \$ - | \$ | - |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|-------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | | | Service Date | Available |
| 1337138 | SALLISAW CAP BANK | 6/1/2009 | 6/1/2009 | | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|-----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1337138 | BETHEL - BROKEN BOW 138KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | SILOAM CITY - SILOAM SPRINGS 161KV CKT 1 | 12/1/2010 | 6/1/2011 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|-----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1337138 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 4/1/2009 | 6/1/2011 | | Yes |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW | 12/1/2009 | 6/1/2010 | | Yes |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE | 12/1/2009 | 6/1/2010 | | Yes |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE #2 | 12/1/2009 | 6/1/2010 | | Yes |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 6/1/2009 | 6/1/2011 | | |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| | | | | Earliest | Redispatch |
|-------------|--------------------------------------|------------|------------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1337138 | ALUMAX TAP - BANN 138KV CKT 1 | 6/1/2008 | 6/1/2008 | | |
| | GEN2004014-1 | 12/31/2009 | 12/31/2009 | | |
| | GEN2004024-1 | 6/1/2008 | 6/1/2008 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | NORTHWEST - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |
| | WOODWARD - IODINE 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 2 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD 345/138KV TRANSFORMER CKT 1 | 1/1/2010 | 1/1/2010 | | |

| | | | | Earliest Service Start | Redispatch | Allocated E & C | |
|-------------|--|----------|----------|---------------------------|------------|-----------------|------------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost |
| 1337138 | BULL SHOALS - BULL SHOALS HES 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | No | \$ - | \$ - |
| | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 SWPA | 6/1/2009 | 6/1/2010 | | No | \$ - | \$ - |
| | | | | Total | | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Date Without | Date Without | | Point-to-Point | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|---------------------|-------------------------|------------------------|--------------|--------------|------|----------------|----------------------|-------------------------------|
| AEPM | 1352732 | CSWS | CSWS | 100 | 1/1/2010 | 1/1/2011 | 6/1/2012 | 6/1/2013 | \$ - | \$ - | \$ - | \$ - |
| | | | | | | | | | ¢. | 6 | ¢. | • |

| | | | | Earliest | Redispatch | Allocated E & C | | Total Revenue | ٦ |
|-------------|--------------|-----|-----|--------------|------------|-----------------|------|---------------|---|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Requirements | |
| 1352732 | None | | | | | \$ - | \$ - | \$ | - |
| | | | | | Total | ٠ . | \$ - | \$ | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|-----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352732 | DIANA - LONE STAR SOUTH 138KV CKT 1 | 12/1/2009 | 6/1/2012 | | Yes |
| | MOORELAND - MOREWOOD SW 138KV CKT 1 | 4/1/2009 | 6/1/2010 | | Yes |
| | RIVERSIDE STATION - TULSA POWER STATION 138KV CKT 1 | 6/1/2012 | 6/1/2012 | | |
| | SILOAM CITY - SILOAM SPRINGS 161KV CKT 1 | 12/1/2010 | 6/1/2011 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|-----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352732 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 4/1/2009 | 6/1/2011 | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW | 12/1/2009 | 6/1/2010 | | Yes |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE | 12/1/2009 | 6/1/2010 | | Yes |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE #2 | 12/1/2009 | 6/1/2010 | | Yes |

| | | | | Earliest | | | |
|-------------|--------------------------------------|----------|----------|---------------|------------|-----------------|------------------|
| | | | | Service Start | Redispatch | Allocated E & C | |
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost |
| 13527 | 32 WELLS 500/230KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | | | | | Total | • | ¢. |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Date Without | Deferred Stop Date Without Redispatch | | Point-to-Point | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|---------------------|-------------------------|------------------------|--------------|---|------|----------------|----------------------|-------------------------------|
| AEPM | 1352923 | CSWS | CSWS | 50 | 1/1/2009 | 1/1/2011 | 6/1/2012 | 6/1/2014 | \$ - | \$ - | \$ - | \$ - |
| ALI IVI | | | | | | | | | | | | |

| | | | | Earliest | Redispatch | Allocated E & C | | Total Revenue |
|---------|---|----------|-----------|--------------|------------|-----------------|------------------|---------------|
| | Upgrade Name | DUN | EOC | Service Date | Available | Cost | Total E & C Cost | Requirements |
| 1352923 | BETHEL - BROKEN BOW 138KV CKT 1 #2 | 6/1/2009 | 6/1/2011 | | Yes | \$ - | \$ - | \$ - |
| | BETHEL - NASHOBA 138KV CKT 1 | 6/1/2009 | 6/1/2012 | | Yes | \$ - | \$ - | \$ - |
| | CLAYTON - NASHOBA 138KV CKT 1 | 6/1/2009 | 6/1/2012 | | Yes | \$ - | \$ - | \$ - |
| | CLAYTON - SARDIS 138KV CKT 1 | 6/1/2009 | 6/1/2012 | | | \$ - | \$ - | \$ - |
| | LYDIA - WELSH 345KV CKT 1 | 6/1/2009 | 6/1/2012 | | Yes | \$ - | \$ - | \$ - |
| | NORTHWEST TEXARKANA - PATTERSON 138KV CKT 1 | 6/1/2009 | 6/1/2012 | | Yes | \$ - | \$ - | \$ - |
| | TEXAS EASTMAN - WHITNEY 138KV CKT 1 | 6/1/2009 | 10/1/2009 | | Yes | \$ - | \$ - | \$ - |
| | | | | | Total | \$ | \$ - | \$ |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|----------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352923 | BROWN - EXPLORER TAP 138KV CKT 1 | 6/1/2009 | 6/1/2011 | | Yes |
| | SALLISAW CAP BANK | 6/1/2009 | 6/1/2009 | | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|-----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352923 | ASHDOWN WEST - CRAIG JUNCTION 138KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | BETHEL - BROKEN BOW 138KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | DIANA - LONE STAR SOUTH 138KV CKT 1 | 12/1/2009 | 6/1/2012 | | Yes |
| | MOORELAND - MOREWOOD SW 138KV CKT 1 | 4/1/2009 | 6/1/2010 | | Yes |
| | RIVERSIDE STATION - TULSA POWER STATION 138KV CKT 1 | 6/1/2012 | 6/1/2012 | | |
| | SILOAM CITY - SILOAM SPRINGS 161KV CKT 1 | 12/1/2010 | 6/1/2011 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352923 | DANVILLE (APL) - MAGAZINE REC 161KV CKT 1 AEPW | 4/1/2009 | 6/1/2009 | | Yes |
| | DANVILLE (APL) - MAGAZINE REC 161KV CKT 1 OKGE | 4/1/2009 | 6/1/2009 | | Yes |

| | | | | Earliest | | | |
|---------|---|----------|----------|---------------|------------|-----------------|------------------|
| | | | | Service Start | Redispatch | Allocated E & C | |
| | | DUN | EOC | Date | Available | Cost | Total E & C Cost |
| 1352923 | ARKANSAS NUCLEAR ONE - RUSSELLVILLE NORTH 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | BULL SHOALS - BULL SHOALS HES 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | No | \$ - | \$ - |
| | CLARKSVILLE - DARDANELLE 161KV CKT 1 | 6/1/2013 | | | | \$ - | \$ - |
| | DANVILLE (APL) - MAGAZINE REC 161KV CKT 1 ENTR | 4/1/2009 | 6/1/2009 | | Yes | \$ - | \$ - |
| | DARDANELLE - DARDANELLE 161KV CKT 1 | 6/1/2010 | 6/1/2010 | | | \$ - | \$ - |
| | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 ENTR | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 SWPA | 6/1/2009 | 6/1/2010 | | Yes | \$ - | \$ - |
| | EVERTON - HARRISON-EAST 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | HARRISON-EAST - SUMMIT 161KV CKT 1 | 6/1/2010 | | | | \$ - | \$ - |
| | HILLTOP - ST JOE 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | RUSSELLVILLE EAST - RUSSELLVILLE NORTH 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | RUSSELLVILLE EAST - RUSSELLVILLE SOUTH 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | <u> </u> | | | | Total | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | | Date Without | Date Without | | Point-to-Point | | Total Revenue Requirements |
|----------|-------------|------|------|---------------------|-------------------------|----------|--------------|--------------|------|----------------|------|-------------------------------|
| AEPM | 1352934 | CSWS | CSWS | 54 | 4 6/1/2010 | 6/1/2015 | 6/1/2012 | 6/1/2017 | \$ - | \$ - | \$ - | \$ - |
| | | | • | • | | | | • | \$ - | \$ - | \$ - | \$ - |

| | | | | Earliest | Redispatch | Allocated E & C | | Total Revenue |
|---------|---|----------|----------|--------------|------------|-----------------|------------------|---------------|
| | Upgrade Name | DUN | EOC | Service Date | Available | Cost | Total E & C Cost | Requirements |
| 1352934 | BETHEL - BROKEN BOW 138KV CKT 1 #2 | 6/1/2009 | 6/1/2011 | | Yes | \$ - | \$ - | \$ |
| | BETHEL - NASHOBA 138KV CKT 1 | 6/1/2009 | 6/1/2012 | | Yes | \$ - | \$ - | \$ |
| | CLAYTON - NASHOBA 138KV CKT 1 | 6/1/2009 | 6/1/2012 | | Yes | \$ - | \$ - | \$ |
| | CLAYTON - SARDIS 138KV CKT 1 | 6/1/2009 | 6/1/2012 | | | \$ - | \$ - | \$ |
| | LYDIA - WELSH 345KV CKT 1 | 6/1/2009 | 6/1/2012 | | Yes | \$ - | \$ - | \$ |
| | NORTHWEST TEXARKANA - PATTERSON 138KV CKT 1 | 6/1/2009 | 6/1/2012 | | Yes | \$ - | \$ - | \$ |
| | | | | | Total | \$ - | \$ - | \$ |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352934 | ARSENAL HILL - NORTH MARKET 69KV CKT 1 | 6/1/2010 | 6/1/2011 | | Yes |
| | SALLISAW CAP BANK | 6/1/2000 | 6/1/2000 | | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|-----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352934 | 3RDST - ARKOMA 161KV CKT 1 | 6/1/2016 | 6/1/2016 | | |
| | ASHDOWN WEST - CRAIG JUNCTION 138KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | BETHEL - BROKEN BOW 138KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | DIANA - LONE STAR SOUTH 138KV CKT 1 | 12/1/2009 | 6/1/2012 | | Yes |
| | RIVERSIDE STATION - TULSA POWER STATION 138KV CKT 1 | 6/1/2012 | 6/1/2012 | | |
| | SILOAM CITY - SILOAM SPRINGS 161KV CKT 1 | 12/1/2010 | 6/1/2011 | | |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352934 | BANN - RED SPRINGS REC 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV WFEC | 7/1/2012 | 7/1/2012 | | |

| | | | | Earliest Service Start | Redispatch | Allocated E & C | |
|-------------|---|----------|----------|---------------------------|------------|-----------------|------------------|
| Reservation | Upgrade Name | DUN | | Date | Available | Cost | Total E & C Cost |
| 1352934 | ARKANSAS NUCLEAR ONE - RUSSELLVILLE NORTH 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | BULL SHOALS - BULL SHOALS HES 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | No | \$ - | \$ - |
| | CLARKSVILLE - DARDANELLE 161KV CKT 1 | 6/1/2013 | 6/1/2013 | | | \$ - | \$ - |
| | COCODRIE 230/138KV TRANSFORMER CKT 1 | 6/1/2010 | 6/1/2010 | | | \$ - | \$ - |
| | DARDANELLE - DARDANELLE 161KV CKT 1 | 6/1/2010 | 6/1/2010 | | | \$ - | \$ - |
| | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 ENTR | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 SWPA | 6/1/2009 | 6/1/2010 | | No | \$ - | \$ - |
| | EVERTON - HARRISON-EAST 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | HARRISON-EAST - SUMMIT 161KV CKT 1 | 6/1/2010 | 6/1/2010 | | | \$ - | \$ - |
| | HILLTOP - ST JOE 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | INDEPENDENCE - LS POWER OSCEOLA UNIT 500KV CKT 1 | 6/1/2012 | 6/1/2012 | | | \$ - | \$ - |
| | RUSSELLVILLE EAST - RUSSELLVILLE NORTH 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | RUSSELLVILLE EAST - RUSSELLVILLE SOUTH 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | | | | | Total | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Reservation | POR | POD | Requested Amount | | | Deferred Stop Date Without Redispatch | | Point-to-Point | Allocated E & | Total Revenue |
|----------|-------------|------|------|---------------------|----------|------------|---|-----------|----------------|---------------|---------------|
| | | | | | | redispaten | redispateri | Allowabic | Dasc Rate | 0 0031 | requirements |
| CMLP | 1352193 | GRDA | CSWS | 197 | 6/1/2008 | | 6/1/2046 | | | \$ 8,316,502 | |

| | | | | Earliest | Redispatch | Allo | cated E & C | | | Tota | al Revenue |
|-------------|---|----------|-----------|--------------|------------|------|-------------|------|---------------|------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cos | t | Tota | al E & C Cost | Req | uirements |
| 1352193 | AFTON - FAIRLAND EDE TAP 69KV CKT 1 | 6/1/2009 | 10/1/2009 | | | \$ | - | \$ | - | \$ | - |
| | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | 6/1/2016 | 6/1/2016 | | | \$ | 92,301 | \$ | 100,000 | \$ | 368,043 |
| | COFFEYVILLE FARMLAND - SOUTH COFFEYVILLE CITY 138KV CKT 1 | 6/1/2012 | 6/1/2012 | | | \$ | 2,200,000 | \$ | 2,200,000 | \$ | 10,171,482 |
| | COFFEYVILLE TAP - SOUTH COFFEYVILLE CITY 138KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ | 6,000,000 | \$ | 6,000,000 | \$ | 28,777,359 |
| | DEARING 138KV Capacitor Displacement | 6/1/2011 | 6/1/2011 | | | \$ | 24,201 | \$ | 24,201 | \$ | 121,554 |
| | | | | | Total | S | 8 316 502 | \$ | 8 324 201 | \$ | 39 438 438 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352193 | AFTON (AFTAUTO1) 161/69/13.8KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2012 | | No |
| | KERR - PENSACOLA 115KV CKT 1 | 6/1/2009 | 6/1/2012 | | No |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|-----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352193 | LOCUST GROVE - LONE STAR 115KV CKT 1 | 6/1/2014 | 6/1/2014 | | |
| | PRYOR JUNCTION (PRY-JCT1) 115/69/13.8KV TRANSFORMER CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | SILOAM CITY - SILOAM SPRINGS 161KV CKT 1 | 12/1/2010 | 6/1/2011 | | No |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 135219 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 4/1/2009 | 6/1/2011 | | No |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 6/1/2009 | 6/1/2011 | | No |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352193 | SUB 110 - ORONOGO JCT SUB 167 - RIVERTON 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | |

Customer Study Number CRGL AG3-2007-019

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|---------------------|-------------------------|------------------------|----------|---|---|----------------|----------------------|-------------------------------|
| CRGL | 1340343 | OPPD | CLEC | 103 | 3 2/1/2008 | 2/1/2009 | 6/1/2013 | 6/1/2014 | \$ - | \$ 1,909,839 | \$ 1,870,994 | \$ 4,990,825 |
| | · | • | | | | | | | • | \$ 1,909,839 | \$ 1,870,994 | \$ 4,990,825 |

| | | | | Earliest | Redispatch | Alloc | ated E & C | | | Tota | I Revenue |
|-------------|---|-----------|-----------|--------------|------------|-------|------------|------|--------------|------|-----------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Tota | I E & C Cost | Req | uirements |
| 1340343 | FINNEY SWITCHING STATION - HITCHLAND 7 345.00 345KV CKT 1 | 12/1/2010 | 12/1/2010 | | | \$ | 25,800 | \$ | 337,500 | \$ | 55,316 |
| | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2010 | 6/1/2011 | | | \$ | 1,845,194 | \$ | 8,500,000 | \$ | 4,935,509 |
| | | • | • | | Total | \$ | 1.870.994 | \$ | 8.837.500 | \$ | 4.990.825 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | Earliest | Redispatch |
|--|----------|-----------|--------------|------------|
| Reservation Upgrade Name | DUN | EOC | Service Date | Available |
| 1340343 KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | |
| Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1340343 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2009 | 6/1/2010 | | |
| | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | 6/1/2009 | 6/1/2010 | | |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1340343 | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV WFEC | 7/1/2012 | 7/1/2012 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | 1 |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cos |
|-------------|--|-----------|-----------|-----------------------------------|-------------------------|-------------------------|-----------------|
| 1340343 | 3GRENWD - HUMPHREY 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | 3GRENWD - TERREBONNE 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | 4JUDICE - MEAUX BULK 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | 4JUDICE - SCOTT 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | 4NCROWL - RICHARD 138KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ - | \$ |
| | 4NCROWL - SCOTT 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | 4SEMERE - SCOTT 138KV CKT 1 | 4/1/2009 | 4/1/2009 | | | \$ - | \$ |
| | 7PALMYRA 345.00 345/161KV TRANSFORMER CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ - | \$ |
| | ACADIA - COLONIAL ACADEMY 138KV CKT 1 | 12/1/2010 | 12/1/2010 | | | \$ - | \$ |
| | ACADIA - SCANLAN 138KV CKT 1 | 12/1/2010 | 12/1/2010 | | | \$ - | \$ |
| | ACADIANA MALL - DOC BONIN 230KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | ACADIANA MALL - FLANDERS 230KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | ADAMS CREEK - BOGALUSA 230KV CKT 2 | 4/1/2009 | 4/1/2009 | | | \$ - | \$ |
| | CECELIA - DOC BONIN 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | CECELIA - MORIL 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | COCODRIE 230/138KV TRANSFORMER CKT 1 | 6/1/2010 | 6/1/2010 | | | \$ - | \$ |
| | COLONIAL ACADEMY - RICHARD 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | DOC BONIN - LABBE 230KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | DOC BONIN - SCOTT 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | DOC BONIN 230/138KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | GIBSON - HUMPHREY 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | GIBSON - RAMOS 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | HABETZ - RICHARD 138KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ - | \$ |
| | LABBE - PONT DES MOUTON 230KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | LINE 642 TAP - LIVONIA BULK 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | LIVONIA BULK - WILBERT 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | PONT DES MOUTON - WELLS 230KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | RICHARD - SCOTT 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | SOUTHWEST BAYOU RAPIDES - TWIN BRIDGES 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | SPEARVILLE - KNOLL - AXTELL 345KV CKT 1 | 6/1/2009 | 6/1/2013 | | | \$ - | \$ |
| | WELLS - WELLS 230KV CKT 2 | 6/1/2012 | 6/1/2012 | | | \$ - | \$ |
| | WELLS 500/230KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ |
| | | | | | Total | s - | \$ |

| Customer | Reservation | | POD | Requested Amount | Requested Start Date | | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|-----|---------------------|-------------------------|-----------|--------------|--------------|--------------|----------------|----------------------|-------------------------------|
| EDE | 1350960 | KCPL | EDE | | 5 11/1/2008 | 11/1/2018 | 6/1/2012 | 6/1/2022 | \$ 403,503 | \$ - | \$ 403,503 | \$ 1,059,361 |
| | | • | • | | • | • | | • | \$ 403,503 | ٠ . | \$ 403,503 | \$ 1,059,361 |

| | | | | Earliest | Redispatch | Allocat | ted E & C | | | Total | Revenue |
|---------|---|-----------|-----------|--------------|------------|---------|-----------|-------|------------|-------|-----------|
| | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Total | E & C Cost | Requ | irements |
| 1350960 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2018 | 6/1/2018 | | | \$ | 17,838 | \$ | 2,580,000 | \$ | 36,543 |
| | AFTON - FAIRLAND EDE TAP 69KV CKT 1 | 6/1/2009 | 10/1/2009 | | | \$ | - | \$ | - | \$ | - |
| | FINNEY SWITCHING STATION - HITCHLAND 7 345.00 345KV CKT 1 | 12/1/2010 | 12/1/2010 | | | \$ | 700 | \$ | 337,500 | \$ | 1,500 |
| | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2010 | | | Yes | \$ | 376,136 | \$ | 8,500,000 | \$ | 1,002,710 |
| | NASHUA - SMITHVILLE 161KV CKT 1 | 12/1/2010 | 12/1/2010 | | | \$ | 8,829 | \$ | 180,000 | \$ | 18,608 |
| | | | | | Total | S | 403 503 | \$ | 11 597 500 | S | 1 059 361 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|----------|---|----------|----------|--------------|------------|
| Reservat | on Upgrade Name | DUN | EOC | Service Date | Available |
| 13 | 50960 AFTON (AFTAUTO1) 161/69/13.8KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2012 | | No |
| | JAMESVILLE - SUB 415 - BLACKHAWK JCT. 69KV CKT 1 EMDE | 6/1/2016 | 6/1/2016 | 6/1/2012 | |
| | KERR - PENSACOLA 115KV CKT 1 | 6/1/2009 | 6/1/2012 | | No |
| | SUB 145 - JOPLIN WEST 7TH - SUB 64 - JOPLIN 10TH ST. 69KV CKT 1 | 6/1/2017 | 6/1/2017 | 6/1/2012 | |
| | SUB 376 - MONETT CITY SOUTH 161/69/12.5KV TRANSFORMER CKT 1 | 6/1/2018 | 6/1/2018 | 6/1/2015 | |
| | SUB 383 - MONETT - SUB 376 - MONETT CITY SOUTH 161KV CKT 1 | 6/1/2018 | 6/1/2018 | 6/1/2015 | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|-----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1350960 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2009 | 6/1/2010 | | No |
| | Multi - Stateline - Joplin - Reinmiller conversion | 6/1/2017 | 6/1/2017 | | |
| | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | 6/1/2009 | 6/1/2010 | | |
| | SILOAM CITY - SILOAM SPRINGS 161KV CKT 1 | 12/1/2010 | 6/1/2011 | | No |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2010 | 6/1/2011 | | No |
| | SUB 124 - AURORA H.T SUB 152 - MONETT H.T. 69KV CKT 1 | 6/1/2009 | 6/1/2010 | 10/1/2009 | No |
| | SUB 170 - NICHOLS ST SUB 80 - SEDALIA 69KV CKT 1 | 6/1/2013 | 6/1/2013 | | |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1350960 | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | SUB 110 - ORONOGO JCT SUB 167 - RIVERTON 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |

| | | | | Earliest Service Start | Redispatch | Allocated E & C | |
|-------------|--|----------|----------|---------------------------|------------|-----------------|------------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost |
| 1350960 | BULL SHOALS - BULL SHOALS HES 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | No | \$ - | \$ - |
| | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 ENTR | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 SWPA | 6/1/2009 | 6/1/2010 | | No | \$ - | \$ - |
| | EVERTON - HARRISON-EAST 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | HARRISON-EAST - SUMMIT 161KV CKT 1 | 6/1/2010 | 6/1/2010 | | | \$ - | \$ - |
| | HILLTOP - ST JOE 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | HUBEN 345/161KV TRANSFORMER CKT 1 | 6/1/2012 | 6/1/2012 | | | \$ - | \$ - |
| | RUSSELLVILLE EAST - RUSSELLVILLE SOUTH 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | | | | | Total | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Date Without | Date Without | Potential Base Plan Funding Allowable | Point-to-Point | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|-----|---------------------|-------------------------|------------------------|--------------|--------------|---|----------------|----------------------|-------------------------------|
| EDE | 1352109 | KCPL | EDE | | 5 1/1/2010 | 1/1/2030 | 6/1/2011 | 6/1/2031 | \$ 403,503 | \$ - | \$ 403,503 | \$ 1,598,710 |
| | | • | • | • | • | • | | | \$ 403,503 | ٠ . | \$ 403,503 | \$ 1598710 |

| | | | | Earliest | Redispatch | Allocat | ted E & C | | | Total | I Revenue |
|-------------|---|-----------|-----------|--------------|------------|---------|-----------|------|---------------|-------|-----------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Tota | al E & C Cost | Requ | uirements |
| 1352109 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2018 | 6/1/2018 | | | \$ | 17,838 | \$ | 2,580,000 | \$ | 52,011 |
| | FINNEY SWITCHING STATION - HITCHLAND 7 345.00 345KV CKT 1 | 12/1/2010 | 12/1/2010 | | | \$ | 700 | \$ | 337,500 | \$ | 2,203 |
| | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2010 | 6/1/2011 | | Yes | \$ | 376,136 | \$ | 8,500,000 | \$ | 1,516,529 |
| | NASHUA - SMITHVILLE 161KV CKT 1 | 12/1/2010 | 12/1/2010 | | | \$ | 8,829 | \$ | 180,000 | \$ | 27,967 |
| | | | | | Total | \$ | 403,503 | \$ | 11,597,500 | \$ | 1,598,710 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352109 | JAMESVILLE - SUB 415 - BLACKHAWK JCT. 69KV CKT 1 EMDE | 6/1/2016 | 6/1/2016 | 6/1/2012 | |
| | SUB 145 - JOPLIN WEST 7TH - SUB 64 - JOPLIN 10TH ST. 69KV CKT 1 | 6/1/2017 | 6/1/2017 | 6/1/2012 | |
| | SUB 376 - MONETT CITY SOUTH 161/69/12.5KV TRANSFORMER CKT 1 | 6/1/2018 | 6/1/2018 | 6/1/2015 | |
| | SUB 383 - MONETT - SUB 376 - MONETT CITY SOUTH 161KV CKT 1 | 6/1/2018 | 6/1/2018 | 6/1/2015 | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | | Earliest | Redispatch |
|------|-------------|---|-----------|----------|--------------|------------|
| - (1 | Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| | 1352109 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2009 | 6/1/2010 | | |
| Π | | Multi - Stateline - Joplin - Reinmiller conversion | 6/1/2017 | 6/1/2017 | | |
| Γ | | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | 6/1/2009 | 6/1/2010 | | |
| | | SILOAM CITY - SILOAM SPRINGS 161KV CKT 1 | 12/1/2010 | 6/1/2011 | | No |
| | | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2010 | 6/1/2011 | | No |
| Γ | | SUB 124 - AURORA H.T SUB 152 - MONETT H.T. 69KV CKT 1 | 6/1/2009 | 6/1/2010 | 10/1/2009 | |
| Γ | | SUB 170 - NICHOLS ST SUB 80 - SEDALIA 69KV CKT 1 | 6/1/2013 | 6/1/2013 | | |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352109 | SUB 110 - ORONOGO JCT SUB 167 - RIVERTON 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |

| | | | | Earliest | | | |
|---------|--|----------|----------|---------------|------------|-----------------|------------------|
| | | | | Service Start | Redispatch | Allocated E & C | |
| | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost |
| 1352109 | BULL SHOALS - BULL SHOALS HES 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | No | \$ - | \$ - |
| | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 ENTR | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 SWPA | 6/1/2009 | 6/1/2010 | | No | \$ - | \$ - |
| | EVERTON - HARRISON-EAST 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | HARRISON-EAST - SUMMIT 161KV CKT 1 | 6/1/2010 | | | | \$ - | \$ - |
| | HILLTOP - ST JOE 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | HUBEN 345/161KV TRANSFORMER CKT 1 | 6/1/2012 | 6/1/2012 | | | \$ - | \$ - |
| | RUSSELLVILLE EAST - RUSSELLVILLE SOUTH 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | | | | | Total | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Date Without | Deferred Stop Date Without Redispatch | | Point-to-Point | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|---------------------|-------------------------|------------------------|--------------|---|------|----------------|----------------------|-------------------------------|
| GRDA | 1350396 | OKGE | GRDA | 150 | 6/1/2008 | 6/1/2013 | 6/1/2012 | 6/1/2017 | \$ - | \$ - | \$ - | \$ - |
| | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | | Earliest | Redispatch | Allocated E & C | | Total Revenue |
|---------------|---|----------|-----------|--------------|------------|-----------------|------------------|---------------|
| Reservation U | pgrade Name | | EOC | Service Date | Available | Cost | Total E & C Cost | Requirements |
| 1350396 A | RCADIA (ARCADIA3) 345/138/13.8KV TRANSFORMER CKT 1 #2 | 6/1/2009 | 10/1/2009 | | Yes | \$ - | \$ - | \$ |
| ·- | | | | | Total | \$ - | \$ - | \$ |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1350396 | CLAREMORE (CLRAUTO1) 161/69/13.8KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | CLAREMORE (CLRAUTO2) 161/69/13.8KV TRANSFORMER CKT 2 | 6/1/2009 | 6/1/2009 | | |
| | KERR - PENSACOLA 115KV CKT 1 | 6/1/2009 | 6/1/2012 | | Yes |
| | MAID - PRYOR FOUNDRY SOUTH 69KV CKT 1 | 6/1/2014 | 6/1/2014 | | |
| | MAID - REDDEN 69KV CKT 1 | 6/1/2014 | 6/1/2014 | | |
| | SALLISAW CAP BANK | 6/1/2009 | 6/1/2009 | | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1350396 | 3RDST - ARKOMA 161KV CKT 1 | 6/1/2016 | 6/1/2016 | | |
| | CPP TRANSF #2 - PRYOR FOUNDRY SOUTH 69KV CKT 1 | 6/1/2016 | 6/1/2016 | | |
| | MCELROY - STILLWATER 138KV CKT 1 | 6/1/2009 | 6/1/2011 | | Yes |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 13503 | 6 HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALUANT 345 KV WEEC | 7/1/2012 | 7/1/2012 | | |

| | | | | Earliest | | | |
|-------------|---|----------|----------|---------------|------------|-----------------|------------------|
| | | | | Service Start | Redispatch | Allocated E & C | |
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost |
| 135039 | 6 4LUTHER 138.00 138/69KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ 2,000,000 | \$ 2,000,000 |
| | | | | | Total | \$ 2,000,000 | \$ 2,000,000 |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number KBPU AG3-2007-017D

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested | Date Without | Date Without | | Point-to-Point | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|-----|------|---------------------|-------------------------|-----------|--------------|--------------|------|----------------|----------------------|-------------------------------|
| KBPU | 1339117 | MPS | KACY | 5 | 2/1/2008 | 2/1/2009 | 11/1/2010 | 11/1/2011 | \$ - | \$ 52,800 | \$ - | \$ - |
| | | | | | | | | | | | | |

| | | | | Earliest | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|--------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | Total E & C Cost | Requirements |
| 1339117 | None | | | | | \$ - | \$ | \$ |
| | | | | | Total | \$ - | \$ - | S |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|----------------------------------|----------|-----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 133911 | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1339117 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2009 | 6/1/2010 | | Yes |
| | Loma Vista - Montrose 161kV Tap into K.C. South | 6/1/2009 | 6/1/2011 | | |
| | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | 6/1/2009 | 6/1/2010 | | |
| | South Harper 161 kV cut-in to Stilwell-Archie JCT 161 kV line | 6/1/2009 | 6/1/2011 | 11/1/2010 | Yes |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2010 | 6/1/2011 | | |

| | | | | | Earliest | Redispatch |
|---|-------------|------------------------------------|----------|----------|--------------|------------|
| | Reservation | Upgrade Name | | EOC | Service Date | Available |
| ſ | 1330117 | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Reservation | POR | POD | Requested Amount | | | | | Point-to-Point | Allocated E & | Total Revenue |
|----------|-------------|------|------|---------------------|-----------|-----------|----------|-----------|----------------|---------------|---------------|
| | | | | | | | | Allowabic | Dasc Rate | 0 0031 | |
| KCPS | | KCPL | KCPL | 45 | 11/1/2008 | 11/1/2018 | 6/1/2021 | | | \$ 5,153,254 | |

| | | | | Earliest | Redispatch | Allo | cated E & C | | | Tota | I Revenue |
|-------------|---|-----------|-----------|--------------|------------|------|-------------|------|---------------|------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cos | t | Tota | al E & C Cost | Req | uirements |
| 1353013 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2018 | 6/1/2018 | | | \$ | 679,097 | \$ | 2,580,000 | \$ | 1,391,220 |
| | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2010 | 6/1/2011 | | Yes | \$ | 3,727,033 | \$ | 8,500,000 | \$ | 9,935,590 |
| | NASHUA - SMITHVILLE 161KV CKT 1 | 12/1/2010 | 12/1/2010 | | | \$ | 123,370 | \$ | 180,000 | \$ | 260,020 |
| | ST JOE - WOODBINE 161KV CKT 1 | 6/1/2010 | 6/1/2011 | | | \$ | 623,754 | \$ | 2,300,000 | \$ | 1,502,669 |
| | | | | | Total | \$ | 5,153,254 | \$ | 13,560,000 | \$ | 13,089,499 |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353013 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2009 | 6/1/2010 | | Yes |
| | Loma Vista - Montrose 161kV Tap into K.C. South | 6/1/2009 | 6/1/2011 | | Yes |
| | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | 6/1/2009 | 6/1/2010 | | |
| | South Harper 161 kV cut-in to Stilwell-Archie JCT 161 kV line | 6/1/2009 | 6/1/2011 | 11/1/2010 | Yes |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2010 | 6/1/2011 | | Yes |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353013 | COOK - ST JOE 161KV CKT 1 | 6/1/2010 | 6/1/2011 | | Yes |
| | REDEL - STILWELL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | Yes |

| | | | | Earliest | Redispatch |
|-------------|------------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353013 | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Date Without | Date Without | | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|-----|------|---------------------|-------------------------|------------------------|--------------|--------------|------------|-----------------------------|----------------------|-------------------------------|
| KEPC | 1352933 | WR | KCPL | | 15 6/1/20 | 08 6/1/204 | 0 6/1/2011 | 6/1/2043 | \$ 152,559 | \$ - | \$ 152,559 | \$ 696,218 |
| ILLI O | | | | | | | | | | | | |

| | | | | Earliest | Redispatch | Allocate | ed E & C | | | Total I | Revenue |
|-------------|---|-----------|-----------|--------------|------------|----------|----------|-----------|--------|---------|---------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Total E & | C Cost | Requir | rements |
| 1352933 | GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 30,600 | \$ 2 | 44,282 | \$ | 148,184 |
| | NASHUA - SMITHVILLE 161KV CKT 1 | 12/1/2010 | 12/1/2010 | | | \$ | 38,971 | \$ 1 | 80,000 | \$ | 162,316 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | | | \$ | 82,989 | \$ 1 | 50,000 | \$ | 385,718 |
| | | | | | Total | \$ | 152,559 | \$ 5 | 74,282 | \$ | 696,218 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352933 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352933 | 27TH & CROCO - TECUMSEH HILL 115KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | 27TH & CROCO JUNCTION - 41ST & CALIFORNIA 115KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2009 | 6/1/2010 | | |
| | AUBURN ROAD (AUBRN77X) 230/115/13.8KV TRANSFORMER CKT 2 | 6/1/2013 | 6/1/2013 | | |
| | LAWRENCE HILL - MOCKINGBIRD HILL SWITCHING STATION 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | Loma Vista - Montrose 161kV Tap into K.C. South | 6/1/2009 | 6/1/2011 | | Yes |
| | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | 6/1/2009 | 6/1/2010 | | |
| | SHAWNEE HEIGHTS - TECUMSEH HILL 115KV CKT 1 | 6/1/2018 | 6/1/2018 | | |
| | South Harper 161 kV cut-in to Stilwell-Archie JCT 161 kV line | 6/1/2009 | 6/1/2011 | 11/1/2010 | Yes |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352933 | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | REDEL - STILWELL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | Yes |

Planned Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|------------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352933 | HOPE 230/115 KV | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT 345/115KV TRANSFORMER CKT 1 | 6/1/2011 | 6/1/2011 | | |

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352933 | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV WFEC | 7/1/2012 | 7/1/2012 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUB 110 - ORONOGO JCT SUB 167 - RIVERTON 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |

| Customer | Reservation | POR | POD | Requested Amount | | | | Date Without | | Point-to-Point | Allocated E & | Total Revenue |
|----------|-------------|-----|-----|---------------------|------------|-----------|------------|--------------|-----------|----------------|---------------|---------------|
| Customer | Reservation | FOR | FUD | Amount | Start Date | Stop Date | Redispatch | Redispatch | Allowable | Dase Rate | CCOSI | Requirements |
| KEPC | 1352938 | WR | WR | Amount 68 | 6/1/2008 | | | | | | \$ 435,359 | |

| | | | | Earliest | Redispatch | Allocat | ted E & C | | | Tota | I Revenue |
|-------------|---|----------|----------|--------------|------------|---------|-----------|------|--------------|------|-----------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Tota | I E & C Cost | Requ | uirements |
| 1352938 | GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 57,412 | \$ | 244,282 | \$ | 376,121 |
| | MACARTHUR - OATVILLE 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 3,803 | \$ | 4,442 | \$ | 24,392 |
| | MEDICINE LODGE - PRATT 115KV CKT 1 | 4/1/2009 | 6/1/2011 | | Yes | \$ | 95,349 | \$ | 6,497,822 | \$ | 662,389 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | | \$ | 235,470 | \$ | 3,825,000 | \$ | 1,709,718 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | | | \$ | 43,325 | \$ | 150,000 | \$ | 272,478 |
| | | | | | Total | S | 435.359 | \$ | 10.721.546 | S | 3.045.098 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|-----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352938 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Nο |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352938 | AUBURN ROAD (AUBRN77X) 230/115/13.8KV TRANSFORMER CKT 2 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | No |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | No |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352938 | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | No |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | 4/1/2009 | 6/1/2011 | | Yes |

Planned Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|------------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352938 | HOPE 230/115 KV | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT 345/115KV TRANSFORMER CKT 1 | 6/1/2011 | 6/1/2011 | | |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| | | | | Earliest | Redispatch |
|-------------|---|------------|------------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1352938 | GEN2004014-1 | 12/31/2009 | 12/31/2009 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV WFEC | 7/1/2012 | 7/1/2012 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | NORTHWEST - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 2 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD 345/138KV TRANSFORMER CKT 1 | 1/1/2010 | 1/1/2010 | | |

| | | | | Earliest | | | |
|-------------|---|----------|----------|---------------|------------|-----------------|------------------|
| | | | | Service Start | Redispatch | Allocated E & C | |
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost |
| 1352938 | SPEARVILLE - KNOLL - AXTELL 345KV CKT 1 | 6/1/2009 | 6/1/2013 | | No | \$ - | \$ - |
| | | | | | Total | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Date Without | Date Without | | Point-to-Point | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|---------------------|-------------------------|------------------------|--------------|--------------|------|----------------|----------------------|-------------------------------|
| KMEA | 1355377 | OPPD | KCPL | 20 | 1/1/2009 | 1/1/2013 | 6/1/2013 | 6/1/2017 | \$ - | \$ - | \$ 920,593 | \$ 2,720,670 |
| | | | | | • | • | | | \$ - | \$ - | \$ 920.593 | \$ 2,720,670 |

| | | | | Earliest | Redispatch | Alloca | ted E & C | | | Total | I Revenue |
|-------------|------------------------------------|----------|----------|--------------|------------|--------|-----------|------|------------|-------|-----------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Tota | E & C Cost | Requ | uirements |
| 1355377 | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2010 | 6/1/2011 | | Yes | \$ | 637,724 | \$ | 8,500,000 | \$ | 1,936,618 |
| | ST JOE - WOODBINE 161KV CKT 1 | 6/1/2010 | 6/1/2011 | | | \$ | 282,869 | \$ | 2,300,000 | \$ | 784,052 |
| | | • | | | Total | S | 920 593 | \$ | 10.800.000 | S | 2.720.670 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|----------------------------------|----------|-----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1355377 | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | No |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1355377 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2009 | 6/1/2010 | | Yes |
| | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | 6/1/2009 | 6/1/2010 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2010 | 6/1/2011 | | Yes |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1355 | 77 COOK - ST JOE 161KV CKT 1 | 6/1/2010 | 6/1/2011 | | Yes |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| | | | | Earliest | Redispatch |
|-------------|------------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1355377 | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |

Third Party Limitations.

| | | | | Earliest | | | 1 | |
|-------------|---|----------|----------|---------------|------------|-----------------|------------------|--|
| | | | | Service Start | Redispatch | Allocated E & C | l | |
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | |
| 1355377 | 7PALMYRA 345.00 345/161KV TRANSFORMER CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ - | \$ - | |
| | SPEARVILLE - KNOLL - AXTELL 345KV CKT 1 | 6/1/2009 | 6/1/2013 | | No | \$ - | \$ - | |
| | | | | | Total | \$ - | \$ - | |

Customer Study Number KPP AG3-2007-040

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Date Without | Date Without | | Point-to-Point | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|-----|-----|---------------------|-------------------------|------------------------|--------------|--------------|-----------|----------------|----------------------|-------------------------------|
| KPP | 1351224 | WR | WR | 4 | 2/1/2008 | 2/1/2018 | 6/1/2011 | 6/1/2021 | \$ 85,061 | \$ - | \$ 85,061 | \$ 327,462 |
| | | | | | | | | | \$ 85,061 | • | \$ 85,061 | \$ 327,462 |

| | | | | Earliest | Redispatch | Allocate | ed E & C | | | Total | Revenue |
|-------------|---|----------|----------|--------------|------------|----------|----------|------|--------------|-------|----------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Tota | I E & C Cost | Requ | irements |
| 1351224 | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2010 | 6/1/2011 | | Yes | \$ | 85,054 | \$ | 8,500,000 | \$ | 327,441 |
| | LITCHFIELD - AQUARIUS - HUDSON JUNCTION 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 7 | \$ | 131 | \$ | 21 |
| | | | | | Total | S | 85 061 | \$ | 8 500 131 | S | 327 462 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|----------------------------------|----------|-----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1351224 | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | No |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | No |
| | Summit - NE Saline 115 kV | 6/1/2009 | 12/1/2009 | | Yes |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1351224 | AUBURN ROAD (AUBRN77X) 230/115/13.8KV TRANSFORMER CKT 2 | 6/1/2013 | 6/1/2013 | | |
| | BPU - CITY OF MCPHERSON JOHNS-MANVILLE - EAST MCPHERSON SWITCHING STATION 115KV CF | 6/1/2009 | 6/1/2011 | | Yes |
| | CHISHOLM - RIPLEY 69KV CKT 1 | 6/1/2010 | 6/1/2011 | | |
| | CHISHOLM (CHISLM1X) 138/69/13.2KV TRANSFORMER CKT 2 | 6/1/2010 | 6/1/2011 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | |
| | FORT JUNCTION SWITCHING STATION - WEST JUNCTION CITY JUNCTION 115KV CKT 1 | 6/1/2010 | 6/1/2011 | | |
| | SEVENTEENTH () 138/69/11.295KV TRANSFORMER CKT 2 | 6/1/2010 | 6/1/2011 | · · | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2010 | 6/1/2011 | | Yes |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | | Earliest | Redispatch |
|-------------|--|------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | | DUN | EOC | Service Date | Available |
| 135122 | East Manhattan to Mcdowell 230 kV Displacement | | 6/1/2009 | 6/1/2011 | | |
| | ROSE HILL (ROSEHLIX) 345/138/13 8KV TRANSFORM | MER CKT 3 Displacement | 4/1/2009 | 6/1/2011 | | Yes |

Planned Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|------------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1351224 | HOPE 230/115 KV | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT 345/115KV TRANSFORMER CKT 1 | 6/1/2011 | 6/1/2011 | | |

| | | | | Earliest | Redispatch |
|-------------|------------------------------------|------------|------------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1351224 | GEN2004014-1 | 12/31/2009 | 12/31/2009 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | | Date Without | Potential Base Plan Funding Allowable | Point-to-Point | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|-----|-----|---------------------|-------------------------|------------------------|----------|--------------|---|----------------|----------------------|-------------------------------|
| MIDW | 1353081 | WR | WR | , | 6/1/200 | 8 6/1/2013 | 6/1/2013 | 6/1/2018 | \$ - | \$ 719,700 | \$ 19,217 | \$ 56,841 |
| MIDW | 1353082 | WR | WR | 4 | 4 6/1/200 | 8 6/1/2013 | 6/1/2013 | 6/1/2018 | \$ - | \$ 575,760 | \$ 15,373 | \$ 45,472 |
| MIDW | 1353083 | WR | WR | 3 | 6/1/200 | 8 6/1/2013 | 6/1/2013 | 6/1/2018 | \$ - | \$ 431,820 | \$ 11,530 | \$ 34,104 |
| MIDW | 1353084 | WR | WR | 2 | 2 6/1/200 | 8 6/1/2013 | 6/1/2013 | | | \$ 287,880 | | \$ 22,735 |
| MIDW | 1353085 | WR | WR | , | 6/1/200 | 8 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 143,940 | \$ 3,844 | \$ 11,369 |
| | | | | | • | • | • | • | \$ - | \$ 2,159,100 | \$ 57,651 | \$ 170,521 |

| | | | | Earliest | Redispatch | | ted E & C | | | Total F | Revenue |
|---------|---|----------|----------|--------------|------------|------|-----------|------|--------------|---------|---------|
| | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Tota | I E & C Cost | Requir | ements |
| 1353081 | GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 3,807 | \$ | 244,282 | \$ | 11,54 |
| | MACARTHUR - OATVILLE 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 213 | \$ | 4,442 | \$ | 63 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | | | Yes | \$ | 11,540 | | 3,825,000 | \$ | 34,01 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | ! | | \$ | 3,657 | \$ | 150,000 | \$ | 10,64 |
| | | | | | Total | \$ | 19,217 | \$ | 4,223,724 | \$ | 56,84 |
| 1353082 | GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 3,045 | \$ | 244,282 | \$ | 9,23 |
| | MACARTHUR - OATVILLE 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 170 | \$ | 4,442 | \$ | 50 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | | | Yes | \$ | 9,232 | \$ | 3,825,000 | | 27,20 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | ! | | \$ | 2,926 | \$ | 150,000 | \$ | 8,5 |
| | | | | | Total | \$ | 15,373 | \$ | 4,223,724 | \$ | 56,84 |
| | GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 2,284 | \$ | 244,282 | \$ | 6,9 |
| | MACARTHUR - OATVILLE 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 128 | \$ | 4,442 | \$ | 3 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | Yes | \$ | 6,924 | \$ | 3,825,000 | \$ | 20,4 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | | | \$ | 2,194 | \$ | 150,000 | \$ | 6,3 |
| | | | | | Total | \$ | 11,530 | \$ | 4,223,724 | \$ | 56,8 |
| 1353084 | GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 1,523 | \$ | 244,282 | \$ | 4,6 |
| | MACARTHUR - OATVILLE 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 85 | \$ | 4,442 | \$ | 2 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | Yes | \$ | 4,616 | \$ | 3,825,000 | \$ | 13,6 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | | | \$ | 1,463 | \$ | 150,000 | \$ | 4,2 |
| | · | | | | Total | \$ | 7,687 | \$ | 4,223,724 | \$ | 56,8 |
| 1353085 | GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 761 | \$ | 244,282 | \$ | 2,3 |
| | MACARTHUR - OATVILLE 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 43 | \$ | 4,442 | \$ | 1: |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | Yes | \$ | 2,308 | \$ | 3,825,000 | \$ | 6,8 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | | | \$ | 731 | \$ | 150,000 | \$ | 2,1 |
| | · | | | | Total | S | 3.844 | \$ | 4.223.724 | \$ | 56.84 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|-----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353081 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |
| 1353082 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |
| 1353083 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |
| 1353084 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |
| 1353085 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |
| | | | | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353081 | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | No |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | No |
| | South Harper 161 kV cut-in to Stilwell-Archie JCT 161 kV line | 6/1/2009 | 6/1/2011 | 11/1/2010 | Yes |
| 1353082 | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | No |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | No |
| | South Harper 161 kV cut-in to Stilwell-Archie JCT 161 kV line | 6/1/2009 | 6/1/2011 | 11/1/2010 | Yes |
| 1353083 | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | | | No |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | No |
| | South Harper 161 kV cut-in to Stilwell-Archie JCT 161 kV line | 6/1/2009 | 6/1/2011 | 11/1/2010 | Yes |
| 1353084 | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | No |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | No |
| | South Harper 161 kV cut-in to Stilwell-Archie JCT 161 kV line | 6/1/2009 | 6/1/2011 | 11/1/2010 | Yes |
| 1353085 | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | · · | No |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | No |
| | South Harper 161 kV cut-in to Stilwell-Archie JCT 161 kV line | 6/1/2009 | 6/1/2011 | 11/1/2010 | Yes |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353081 | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | No |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | REDEL - STILWELL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | Yes |
| 1353082 | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | No |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | REDEL - STILWELL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | Yes |
| 1353083 | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | No |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | REDEL - STILWELL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | Yes |
| 1353084 | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | No |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | REDEL - STILWELL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | Yes |
| 1353085 | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | No |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | REDEL - STILWELL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | Yes |

Planned Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|------------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353081 | HOPE 230/115 KV | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT 345/115KV TRANSFORMER CKT 1 | 6/1/2011 | 6/1/2011 | | |
| 1353082 | HOPE 230/115 KV | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT 345/115KV TRANSFORMER CKT 1 | 6/1/2011 | 6/1/2011 | | |
| 1353083 | HOPE 230/115 KV | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT 345/115KV TRANSFORMER CKT 1 | 6/1/2011 | 6/1/2011 | | |
| 1353084 | HOPE 230/115 KV | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT 345/115KV TRANSFORMER CKT 1 | 6/1/2011 | 6/1/2011 | | |
| 1353085 | HOPE 230/115 KV | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT 345/115KV TRANSFORMER CKT 1 | 6/1/2011 | 6/1/2011 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| | | | | Earliest | Redispatch |
|-------------|------------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353081 | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |
| 1353082 | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |
| 1353083 | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | · · | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |

Third Party Limitations.

| | | | | F F . | | | |
|---------|---|----------|----------|---------------|------------|-----------------|------------------|
| | | | | Earliest | | | |
| | | | | Service Start | Redispatch | Allocated E & C | |
| | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost |
| 1353081 | SPEARVILLE - KNOLL - AXTELL 345KV CKT 1 | 6/1/2009 | 6/1/2013 | | No | \$ - | \$ - |
| | | | | | Total | \$ - | \$ - |
| 1353082 | SPEARVILLE - KNOLL - AXTELL 345KV CKT 1 | 6/1/2009 | 6/1/2013 | | No | \$ - | \$ - |
| | | | | | Total | \$ - | \$ - |
| 1353083 | SPEARVILLE - KNOLL - AXTELL 345KV CKT 1 | 6/1/2009 | 6/1/2013 | | No | \$ - | \$ - |
| | | | | | Total | \$ - | \$ - |
| 1353084 | SPEARVILLE - KNOLL - AXTELL 345KV CKT 1 | 6/1/2009 | 6/1/2013 | | No | \$ - | \$ - |
| | | | | | Total | \$ - | \$ - |

^{*34.5} kV System Impacts and Upgrades have yet to be determined by Midwest Energy

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Date Without | Date Without | Potential Base Plan Funding Allowable | Point-to-Point | Allocated E & C Cost | Total Revenue |
|----------|-------------|-----|-----|---------------------|-------------------------|------------------------|--------------|--------------|---|----------------|----------------------|---------------|
| MIDW | 1353086 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 143,940 | \$ 17,347 | \$ 49,511 |
| MIDW | 1353088 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 287,880 | \$ 34,696 | \$ 99,024 |
| | | • | • | | | | | • | \$ - | \$ 431.820 | \$ 52.043 | \$ 148,535 |

| | | | | Earliest | Redispatch | Allocate | ed E & C | | | Total F | tevenue |
|---------|---|----------|----------|--------------|------------|----------|----------|------|---------------|---------|---------|
| | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Tota | al E & C Cost | Requir | ements |
| 1353086 | MEDICINE LODGE - PRATT 115KV CKT 1 | 4/1/2009 | 6/1/2011 | | Yes | \$ | 12,474 | \$ | 6,497,822 | \$ | 35,175 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | Yes | \$ | 4,129 | \$ | 3,825,000 | \$ | 12,169 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | | | \$ | 744 | \$ | 150,000 | \$ | 2,167 |
| | | | | | Total | \$ | 17,347 | \$ | 10,472,822 | \$ | 49,511 |
| 1353088 | MEDICINE LODGE - PRATT 115KV CKT 1 | 4/1/2009 | 6/1/2011 | | Yes | \$ | 24,948 | \$ | 6,497,822 | \$ | 70,349 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | Yes | \$ | 8,259 | \$ | 3,825,000 | \$ | 24,341 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | | | \$ | 1,489 | \$ | 150,000 | \$ | 4,334 |
| | | | | | Total | \$ | 34,696 | \$ | 10,472,822 | \$ | 99,024 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|-----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353086 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |
| 1353088 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353086 | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | No |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | No |
| 1353088 | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | No |
| | FAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | No |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | | Earliest | Redispatch |
|------|---------|--|----------|----------|--------------|------------|
| Rese | rvation | Upgrade Name | DUN | EOC | Service Date | Available |
| | 1353086 | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | No |
| | | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | 1353088 | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | No |
| | | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |

| | | | Earliest | Redispatch |
|------------------------------------|---|--|---|--------------|
| Upgrade Name | DUN | EOC | Service Date | Available |
| GEN2004014-1 | 12/31/2009 | 12/31/2009 | | |
| LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |
| GEN2004014-1 | 12/31/2009 | 12/31/2009 | | |
| LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |
| | GEN2004014-1 LACYONE - WEST GARDNER 345KV CKT 1 RENO 345/115KV CKT 2 SUMMIT - RENO 345KV WICHITA - RENO 345KV WICHITA - RENO 345KV GEN2004014-1 LACYONE - WEST GARDNER 345KV CKT 1 RENO 345/115KV CKT 1 RENO 345/115KV CKT 1 RENO 345/115KV CKT 2 SUMMIT - RENO 345KV | GEN2004014-1 12/31/2009 LACYGNE - WEST GARDNER 345KV CKT 1 6/1/2006 RENO 345/115KV CKT 2 6/1/2016 RENO 345/115KV CKT 2 6/1/2010 WICHITA - RENO 345KV 6/1/2010 WICHITA - RENO 345KV 6/1/2010 WICHITA - RENO 345KV 6/1/2010 RENO 345KV 16/1/2010 RENO 345KV 16/1/2010 RENO 345KV 6/1/2010 RENO 345KV 6/1/2010 RENO 345KV 6/1/2010 RENO 345/115KV CKT 1 6/1/2009 RENO 345/115KV CKT 1 6/1/2009 RENO 345/115KV CKT 2 6/1/2010 SUMMIT - RENO 345KV 6/1/2010 | Upgrade Name DUN EOC GEN2004014-1 12/31/2009 12/31/2009 12/31/2006 6/1/2006 6/1/2006 6/1/2006 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2001 6/1/2010 6/1/2010 6/1/2010 6/1/2010 6/1/2010 6/1/2010 6/1/2010 6/1/2010 6/1/2010 6/1/2010 6/1/2009 6/1/2009 6/1/2009 6/1/2006 6/1/2006 6/1/2006 6/1/2006 6/1/2006 6/1/2006 6/1/2000 6/1/2010 <t< td=""><td> Upgrade Name</td></t<> | Upgrade Name |

^{*34.5} kV System Impacts and Upgrades have yet to be determined by Midwest Energy

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Date Without | Date Without Redispatch | Allowable | Point-to-Point | Allocated E & C Cost | Requirements |
|----------|-------------|-----|-----|---------------------|-------------------------|------------------------|--------------|----------------------------|-----------|----------------|----------------------|--------------|
| MIDW | 1353090 | WR | WR | 1 | 6/1/2008 | | | 6/1/2016 | | \$ 143,940 | \$ 12,327 | \$ 35,268 |
| MIDW | 1353091 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 287,880 | \$ 24,652 | \$ 70,531 |
| MIDW | 1353092 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 287,880 | \$ 24,652 | \$ 70,531 |
| , | | • | • | | | | | | \$ - | \$ 719,700 | \$ 61,631 | \$ 176,330 |

| | | | | Earliest | Redispatch | Allocate | ed E & C | | | Total Re | venue |
|-------------|---|----------|----------|--------------|------------|----------|----------|------|--------------|----------|--------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Tota | I E & C Cost | Requiren | nents |
| 1353090 | MEDICINE LODGE - PRATT 115KV CKT 1 | 4/1/2009 | 6/1/2011 | | Yes | \$ | 8,128 | \$ | 6,497,822 | \$ | 22,920 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | Yes | \$ | 3,456 | \$ | 3,825,000 | \$ | 10,186 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | | | \$ | 743 | \$ | 150,000 | \$ | 2,162 |
| | | | | | Total | \$ | 12,327 | \$ | 10,472,822 | \$ | 35,268 |
| 1353091 | MEDICINE LODGE - PRATT 115KV CKT 1 | 4/1/2009 | 6/1/2011 | | Yes | \$ | 16,255 | \$ | 6,497,822 | \$ | 45,836 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | Yes | \$ | 6,912 | \$ | 3,825,000 | \$ | 20,371 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | | | \$ | 1,485 | \$ | 150,000 | \$ | 4,324 |
| | | | | | Total | \$ | 24,652 | \$ | 10,472,822 | \$ | 70,531 |
| 1353092 | MEDICINE LODGE - PRATT 115KV CKT 1 | 4/1/2009 | 6/1/2011 | | Yes | \$ | 16,255 | \$ | 6,497,822 | \$ | 45,836 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | Yes | \$ | 6,912 | \$ | 3,825,000 | \$ | 20,371 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | | | \$ | 1,485 | \$ | 150,000 | \$ | 4,324 |
| | | | | | Total | \$ | 24,652 | \$ | 10,472,822 | \$ | 70,531 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|-----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353090 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |
| 1353091 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |
| 1353092 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353090 | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | No |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | No |
| 1353091 | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | No |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | No |
| 1353092 | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | No |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | No |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353090 | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | No |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| 1353091 | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | No |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| 1353092 | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | No |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | Earliest | Redispatch |
|-------------|------------------------------------|------------|------------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| | GEN2004014-1 | 12/31/2009 | 12/31/2009 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |
| 1353091 | GEN2004014-1 | 12/31/2009 | 12/31/2009 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |
| 1353092 | GEN2004014-1 | 12/31/2009 | 12/31/2009 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |

^{*34.5} kV System Impacts and Upgrades have yet to be determined by Midwest Energy

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Date Without | Date Without Redispatch | Allowable | Point-to-Point | | Total Revenue Requirements |
|----------|-------------|-----|-----|---------------------|-------------------------|------------------------|--------------|----------------------------|-----------|----------------|------------|-------------------------------|
| MIDW | 1353097 | WR | WR | 3 | 6/1/2008 | | | 6/1/2016 | | \$ 431,820 | \$ 143,983 | |
| MIDW | 1353098 | WR | WR | 2 | 2 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 287,880 | \$ 95,989 | \$ 272,929 |
| MIDW | 1353099 | WR | WR | 1 | 1 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 143,940 | \$ 47,994 | \$ 136,463 |
| , | | | | | • | • | | | \$ - | \$ 863,640 | \$ 287,967 | \$ 818,785 |

| | | | | Earliest | Redispatch | Allocat | ted E & C | | | Total I | Revenue |
|-------------|---|----------|----------|--------------|------------|---------|-----------|------|---------------|---------|---------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Tota | al E & C Cost | Requi | rements |
| 1353097 | MEDICINE LODGE - PRATT 115KV CKT 1 | 4/1/2009 | 6/1/2011 | | Yes | \$ | 116,788 | \$ | 6,497,822 | \$ | 329,323 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | Yes | \$ | 24,939 | \$ | 3,825,000 | \$ | 73,501 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | | | \$ | 2,256 | \$ | 150,000 | \$ | 6,569 |
| | | | | | Total | \$ | 143,983 | \$ | 10,472,822 | \$ | 409,393 |
| 1353098 | MEDICINE LODGE - PRATT 115KV CKT 1 | 4/1/2009 | 6/1/2011 | | Yes | \$ | 77,859 | \$ | 6,497,822 | \$ | 219,549 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | Yes | \$ | 16,626 | \$ | 3,825,000 | \$ | 49,001 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | | | \$ | 1,504 | \$ | 150,000 | \$ | 4,379 |
| | | | | | Total | \$ | 95,989 | \$ | 10,472,822 | \$ | 272,929 |
| 1353099 | MEDICINE LODGE - PRATT 115KV CKT 1 | 4/1/2009 | 6/1/2011 | | Yes | \$ | 38,929 | \$ | 6,497,822 | \$ | 109,773 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | Yes | \$ | 8,313 | \$ | 3,825,000 | \$ | 24,500 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | | | \$ | 752 | \$ | 150,000 | \$ | 2,190 |
| | | | | | Total | \$ | 47,994 | \$ | 10,472,822 | \$ | 136,463 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|-----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353097 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |
| 1353098 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |
| 1353099 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|---------|--|----------|----------|--------------|------------|
| | | DUN | EOC | Service Date | Available |
| 1353097 | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | No |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | No |
| | KINSLEY 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| 1353098 | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | No |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | No |
| | KINSLEY 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| 1353099 | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | No |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | No |
| | KINSLEY 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | No |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | 4/1/2009 | 6/1/2011 | | Yes |
| 1353098 | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | No |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | 4/1/2009 | 6/1/2011 | | Yes |
| 1353099 | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | No |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | 4/1/2009 | 6/1/2011 | | Yes |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | Earliest | Redispatch |
|-------------|------------------------------------|------------|------------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353097 | GEN2004014-1 | 12/31/2009 | 12/31/2009 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |
| 1353098 | GEN2004014-1 | 12/31/2009 | 12/31/2009 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |
| 1353099 | GEN2004014-1 | 12/31/2009 | 12/31/2009 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |

^{*34.5} kV System Impacts and Upgrades have yet to be determined by Midwest Energy

| | | | | Requested | Requested | Requested | Date Without | Date Without | Potential Base Plan Funding | Point-to-Point | Allocated E & | |
|----------|-------------|-----|-----|-----------|------------|-----------|--------------|--------------|--------------------------------|----------------|---------------|--------------|
| Customer | Reservation | POR | POD | Amount | Start Date | Stop Date | Redispatch | Redispatch | Allowable | Base Rate | C Cost | Requirements |
| MIDW | 1353102 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | | \$ 287,880 | \$ 95,989 | \$ 272,929 |
| MIDW | 1353103 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 143,940 | \$ 47,994 | \$ 136,463 |
| | | • | | | • | • | • | • | \$ - | \$ 431,820 | \$ 143,983 | \$ 409,392 |

| | | | | Earliest | Redispatch | Allocate | ed E & C | | | Total F | Revenue |
|---------|---|----------|----------|--------------|------------|----------|----------|------|--------------|---------|---------|
| | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Tota | I E & C Cost | Requi | rements |
| 1353102 | MEDICINE LODGE - PRATT 115KV CKT 1 | 4/1/2009 | 6/1/2011 | | Yes | \$ | 77,859 | \$ | 6,497,822 | \$ | 219,549 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | Yes | \$ | 16,626 | \$ | 3,825,000 | \$ | 49,001 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | | | \$ | 1,504 | \$ | 150,000 | \$ | 4,379 |
| | | | | | Total | \$ | 95,989 | \$ | 10,472,822 | \$ | 272,929 |
| 1353103 | MEDICINE LODGE - PRATT 115KV CKT 1 | 4/1/2009 | 6/1/2011 | | Yes | \$ | 38,929 | \$ | 6,497,822 | \$ | 109,773 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | Yes | \$ | 8,313 | \$ | 3,825,000 | \$ | 24,500 |
| | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | 6/1/2012 | 6/1/2012 | | | \$ | 752 | \$ | 150,000 | \$ | 2,190 |
| | | | | | Total | \$ | 47,994 | \$ | 10,472,822 | \$ | 136,463 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|-----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353102 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |
| 1353103 | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353102 | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | No |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | No |
| 1353103 | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | No |
| | FAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | οN |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353102 | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | No |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | 4/1/2009 | 6/1/2011 | | Yes |
| 1353103 | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | No |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | 4/1/2009 | 6/1/2011 | | Yes |

| | | | Earliest | Redispatch |
|--------------------|--|---|--|--------------------------|
| | DUN | EOC | Service Date | Available |
| | 12/31/2009 | 12/31/2009 | | |
| ARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| T1 | 6/1/2009 | 6/1/2009 | | |
| T2 | 6/1/2010 | 6/1/2010 | | |
| KV | 6/1/2010 | 6/1/2010 | | |
| KV . | 6/1/2009 | 6/1/2009 | | |
| | 12/31/2009 | 12/31/2009 | | |
| ARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| T1 | 6/1/2009 | 6/1/2009 | | |
| T2 | 6/1/2010 | 6/1/2010 | | |
| KV | 6/1/2010 | 6/1/2010 | | |
| KV | 6/1/2009 | 6/1/2009 | | |
| | ARDNER 345KV CKT 1 CT 1 TT 2 KV KV ARDNER 345KV CKT 1 CT 1 CT 2 KV | ARDNER 345KV CKT 1 6/1/2008 TT 1 6/1/2008 TT 2 6/1/2008 KV 6/1/2010 KV 6/1/2010 KV 6/1/2010 ARDNER 345KV CKT 1 6/1/2010 TT 1 6/1/2010 TT 2 6/1/2010 TT 2 6/1/2010 TT 2 6/1/2010 TT 2 6/1/2010 KV 6/1/2010 KV 6/1/2010 KV 6/1/2010 KV 6/1/2010 KV 6/1/2010 | DUN EOC 12/31/2009 12/3 | DUN EOC Service Date |

^{*34.5} kV System Impacts and Upgrades have yet to be determined by Midwest Energy

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Date Without | | Point-to-Point | | Total Revenue Requirements |
|----------|-------------|-----|-----|---------------------|-------------------------|------------------------|--------------|------------|----------------|------------|-------------------------------|
| MIDW | 1353110 | WR | WR | 25 | 3/1/2008 | | | | | \$ 225,750 | |
| | | • | • | | | • | • | \$ 225,750 | \$ - | \$ 225,750 | \$ 956,007 |

| | | | | Earliest | Redispatch | Alloca | ted E & C | | | Total | Revenue |
|-------------|---|-----------|-----------|--------------|------------|--------|-----------|------|---------------|-------|-----------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Tota | al E & C Cost | Requ | uirements |
| 1353110 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2018 | 6/1/2018 | | | \$ | 94,214 | \$ | 2,580,000 | \$ | 342,194 |
| | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | 6/1/2016 | 6/1/2016 | | | \$ | 789 | \$ | 100,000 | \$ | 2,942 |
| ı | FINNEY SWITCHING STATION - HITCHLAND 7 345.00 345KV CKT 1 | 12/1/2010 | 12/1/2010 | | | \$ | 6,132 | \$ | 337,500 | \$ | 24,625 |
| | FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 | 10/1/2009 | 6/1/2011 | | Yes | \$ | 24,665 | \$ | 2,011,826 | \$ | 112,439 |
| | FLATRDG3 138.00 - HARPER 138KV CKT 1 | 10/1/2009 | 6/1/2011 | | Yes | \$ | 54,031 | \$ | 6,035,477 | \$ | 246,309 |
| | HARPER - MILAN TAP 138KV CKT 1 | 12/1/2009 | 6/1/2010 | | | \$ | 2,619 | \$ | 337,500 | \$ | 12,519 |
| | LITCHFIELD - AQUARIUS - HUDSON JUNCTION 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 11 | \$ | 131 | \$ | 44 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | | \$ | 43,289 | \$ | 3,825,000 | \$ | 214,935 |
| | | | | | Total | \$ | 225,750 | \$ | 15,227,434 | \$ | 956,007 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|----------------------------------|----------|-----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353110 | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |
| | Summit - NE Saline 115 kV | 6/1/2009 | 12/1/2009 | | Yes |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | Earliest | Redispatch |
|---|---|--|--|--------------|
| Upgrade Name | DUN | EOC | Service Date | Available |
| AQUARIUS - HUDSON JUNCTION 69KV CKT 1 | 6/1/2018 | 6/1/2018 | | |
| AQUARIUS - LITCHFIELD 69KV CKT 1 | 6/1/2018 | 6/1/2018 | | |
| AUBURN ROAD (AUBRN77X) 230/115/13.8KV TRANSFORMER CKT 2 | 6/1/2013 | 6/1/2013 | | |
| BPU - CITY OF MCPHERSON JOHNS-MANVILLE - EAST MCPHERSON SWITCHING STATION 115KV C | 6/1/2009 | 6/1/2011 | | Yes |
| EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | |
| FORT JUNCTION SWITCHING STATION - WEST JUNCTION CITY JUNCTION 115KV CKT 1 | 6/1/2010 | 6/1/2011 | | |
| HUDSON JUNCTION - PITTSBURG 69KV CKT 1 | 6/1/2018 | 6/1/2018 | | |
| KINSLEY 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| LYONS - WHEATLAND 115KV CKT 1 MIDW | 6/1/2017 | 6/1/2017 | | |
| LYONS - WHEATLAND 115KV CKT 1 WERE | 6/1/2017 | 6/1/2017 | | |
| STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2010 | 6/1/2011 | | |
| | AQUARIUS - HUDSON JUNCTION 98KV CKT 1 AQUARIUS - LITCHFIELD 69KV CKT 1 AUBURN ROAD (AUBRN77X) 230/115/13.8KV TRANSFORMER CKT 2 BPU - CITY OF MCPHERSON JOHNS-MANVILLE - EAST MCPHERSON SWITCHING STATION 115KV CF EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 EAST MANHATTAN - NW MANHATTAN 230/115KV FORT JUNCTION SWITCHING STATION - WEST JUNCTION CITY JUNCTION 115KV CKT 1 HUDSON JUNCTION - PITTSBURG 69KV CKT 1 KINSLEY 115KV Capacitor LYONS - WHEATLAND 115KV CKT 1 MIDW | AQUARIUS - HUDSON JUNCTION 69KV CKT 1 6/1/2018 AQUARIUS - LITCHFIELD 69KV CKT 1 6/1/2018 AQUARIUS - LITCHFIELD 69KV CKT 1 6/1/2018 ADBURN ROAD (AUBRNYTX) 230/115/1/3.8KV TRANSFORMER CKT 2 6/1/2013 BPU - CITY OF MCPHERSON JOHNS-MANVILLE - EAST MCPHERSON SWITCHING STATION 115KV CF 6/1/2009 EAST MANHATTAN - JEFREY ENERGY CENTER 230KV CKT 1 6/1/2009 EAST MANHATTAN - NW MANHATTAN 230/115KV 6/1/2009 FORT JUNCTION SWITCHING STATION - WEST JUNCTION CITY JUNCTION 115KV CKT 1 6/1/2010 HUDSON JUNCTION - PUTTSBURG 69KV CKT 1 6/1/2011 KINSLEY 115KV Capacitor LYONS - WHEATLAND 115KV CKT 1 MIDW 6/1/2017 LYONS - WHEATLAND 115KV CKT 1 MERE | AQUARIUS - HUDSON JUNCTION 69KV CKT 1 6/1/2018 6/1/2018 6/1/2018 AQUARIUS - LITCHIFIELD 69KV CKT 1 6/1/2018 6/1/2018 6/1/2018 AQUARIUS - LITCHIFIELD 69KV CKT 1 6/1/2018 6/1/2 | Upgrade Name |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353110 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 4/1/2009 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | 4/1/2009 | 6/1/2011 | | Yes |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Planned Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|------------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353110 | HOPE 230/115 KV | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT 345/115KV TRANSFORMER CKT 1 | 6/1/2011 | 6/1/2011 | | |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| | | | | Earliest | Redispatch |
|-------------|----------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353110 | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |

Third Party Limitations.

| | | | | Earliest | | | |
|-------------|--|----------|----------|---------------|------------|-----------------|------------------|
| | | | | Service Start | Redispatch | Allocated E & C | |
| Reservation | n Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost |
| 135 | 1110 SPEARVILLE - KNOLL - AXTELL 345KV CKT 1 | 6/1/2009 | 6/1/2013 | | No | \$ - | \$ - |
| | | | | | Total | s - | \$ - |

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Date Without | Date Without | | Point-to-Point | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|-----|-----|---------------------|-------------------------|------------------------|--------------|--------------|------------|----------------|----------------------|-------------------------------|
| MIDW | 1353111 | WR | WR | 2 | 5 1/1/2009 | 1/1/2029 | 6/1/2013 | 6/1/2033 | \$ 225,750 | \$ - | \$ 225,750 | \$ 985,729 |
| | | | • | | - | • | | • | \$ 225,750 | e | \$ 225,750 | \$ 985,729 |

| | | | | Earliest | Redispatch | Alloca | ted E & C | | | Total | Revenue |
|---------|---|-----------|-----------|--------------|------------|--------|-----------|------|---------------|-------|----------|
| | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Tota | al E & C Cost | Requ | irements |
| 1353111 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2018 | 6/1/2018 | | | \$ | 94,214 | \$ | 2,580,000 | \$ | 351,969 |
| | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | 6/1/2016 | 6/1/2016 | | | \$ | 789 | \$ | 100,000 | \$ | 3,034 |
| | FINNEY SWITCHING STATION - HITCHLAND 7 345.00 345KV CKT 1 | 12/1/2010 | 12/1/2010 | | | \$ | 6,132 | \$ | 337,500 | \$ | 25,387 |
| | FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 | 10/1/2009 | 6/1/2011 | | Yes | \$ | 24,665 | \$ | 2,011,826 | \$ | 116,101 |
| | FLATRDG3 138.00 - HARPER 138KV CKT 1 | 10/1/2009 | 6/1/2011 | | Yes | \$ | 54,031 | \$ | 6,035,477 | \$ | 254,330 |
| | HARPER - MILAN TAP 138KV CKT 1 | 12/1/2009 | 6/1/2010 | | | \$ | 2,619 | \$ | 337,500 | \$ | 12,927 |
| | LITCHFIELD - AQUARIUS - HUDSON JUNCTION 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 11 | \$ | 131 | \$ | 46 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | | \$ | 43,289 | \$ | 3,825,000 | \$ | 221,935 |
| | | | | | Total | \$ | 225,750 | \$ | 15,227,434 | \$ | 985,729 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | | Earliest | Redispatch |
|---|-------------|----------------------------------|----------|-----------|--------------|------------|
| | Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| ſ | 1353111 | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | Yes |
| ſ | | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | Yes |
| ſ | | Summit - NE Saline 115 kV | 6/1/2009 | 12/1/2009 | | Yes |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353111 | AQUARIUS - HUDSON JUNCTION 69KV CKT 1 | 6/1/2018 | 6/1/2018 | | |
| | AQUARIUS - LITCHFIELD 69KV CKT 1 | 6/1/2018 | 6/1/2018 | | |
| | AUBURN ROAD (AUBRN77X) 230/115/13.8KV TRANSFORMER CKT 2 | 6/1/2013 | 6/1/2013 | | |
| | BPU - CITY OF MCPHERSON JOHNS-MANVILLE - EAST MCPHERSON SWITCHING STATION 115KV CH | 6/1/2009 | 6/1/2011 | | Yes |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | |
| | FORT JUNCTION SWITCHING STATION - WEST JUNCTION CITY JUNCTION 115KV CKT 1 | 6/1/2010 | 6/1/2011 | | |
| | HUDSON JUNCTION - PITTSBURG 69KV CKT 1 | 6/1/2018 | 6/1/2018 | | |
| | KINSLEY 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | LYONS - WHEATLAND 115KV CKT 1 MIDW | 6/1/2017 | 6/1/2017 | | |
| | LYONS - WHEATLAND 115KV CKT 1 WERE | 6/1/2017 | 6/1/2017 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2010 | 6/1/2011 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353111 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 4/1/2009 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | | | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | 4/1/2009 | 6/1/2011 | | Yes |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Planned Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|------------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353111 | HOPE 230/115 KV | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT 345/115KV TRANSFORMER CKT 1 | 6/1/2011 | 6/1/2011 | | |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| | | | | Earliest | Redispatch |
|-------------|----------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353111 | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |

Third Party Limitations.

| | | | | Earliest | | | |
|-----------|---|----------|----------|---------------|------------|-----------------|------------------|
| | | | | Service Start | Redispatch | Allocated E & C | 1 |
| Reservati | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost |
| 135 | 111 SPEARVILLE - KNOLL - AXTELL 345KV CKT 1 | 6/1/2009 | 6/1/2013 | | No | \$ | \$ - |
| | | | | | Total | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Reservation | | POD | Requested Amount | Requested Start Date | Requested Stop Date | | Deferred Stop Date Without Redispatch | | Point-to-Point | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|---------------------|-------------------------|------------------------|----------|---|----------|----------------|----------------------|-------------------------------|
| OMPA | 1350945 | OKGE | OKGE | 23 | 5/1/2008 | 5/1/2017 | 6/1/2011 | 6/1/2020 | \$ 1,149 | \$ - | \$ 1,149 | \$ 2,378 |
| | | | | | | | | | \$ 1,149 | \$ - | \$ 1,149 | \$ 2,378 |

| | | | | Earliest | Redispatch | Allocated E & C | | | Total Revenue |
|-------------|---|-----------|-----------|--------------|------------|-----------------|-------|---------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | Total | | Requirements |
| 1350945 | FINNEY SWITCHING STATION - HITCHLAND 7 345.00 345KV CKT 1 | 12/1/2010 | 12/1/2010 | | | \$ 1,149 | \$ | 337,500 | \$ 2,378 |
| | | | | | Total | \$ 11/0 | \$ | 337 500 | \$ 2379 |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|-----------|-----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1350945 | MCELROY - STILLWATER 138KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | RICHLAND - UDALL 69KV CKT 1 | 12/1/2013 | 12/1/2013 | 6/1/2011 | |
| | SILOAM CITY - SILOAM SPRINGS 161KV CKT 1 | 12/1/2010 | 6/1/2011 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|-----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1350945 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 4/1/2009 | 6/1/2011 | | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | RICHLAND - ROSE HILL JUNCTION 69KV CKT 1 Displacement | 12/1/2010 | 6/1/2011 | | |
| | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | 4/1/2009 | 6/1/2011 | | No |

| , | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1350945 | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV WFEC | 7/1/2012 | 7/1/2012 | | |
| | NORTHWEST - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD 345/138KV TRANSFORMER CKT 1 | 1/1/2010 | 1/1/2010 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Date Without | Date Without | Potential Base Plan Funding Allowable | Point-to-Point | | Total Revenue Requirements |
|----------|-------------|------|------|---------------------|-------------------------|------------------------|--------------|--------------|---|----------------|------------|-------------------------------|
| SPSM | 1353054 | WPEK | KCPL | 50 | 0 10/1/2008 | 6/1/2010 | 6/1/2011 | 2/1/2013 | \$ - | \$ 880,000 | \$ 168,750 | \$ 204,785 |
| SPSM | 1353055 | WPEK | KCPL | 50 | 0 10/1/2008 | 6/1/2010 | 6/1/2011 | 2/1/2013 | \$ - | \$ 880,000 | \$ 168,750 | \$ 204,785 |
| | | • | | • | • | • | • | • | \$ - | \$ 1,760,000 | \$ 337,500 | \$ 409,570 |

| | | | | Earliest | Redispatch | Allocat | ted E & C | | | Total F | Revenue |
|-------------|--|----------|----------|--------------|------------|---------|-----------|-----------|--------|---------|---------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Total E & | C Cost | Requir | rements |
| 1353054 | BUSHLAND INTERCHANGE - DEAF SMITH COUNTY INTERCHANGE 230KV CKT 1 | 4/1/2009 | 6/1/2010 | | Yes | \$ | 168,750 | \$ | 37,500 | \$ | 204,785 |
| | | | | | Total | \$ | 168,750 | \$ 3 | 37,500 | \$ | 204,785 |
| 1353055 | BUSHLAND INTERCHANGE - DEAF SMITH COUNTY INTERCHANGE 230KV CKT 1 | 4/1/2009 | 6/1/2010 | | Yes | \$ | 168,750 | \$ | 37,500 | \$ | 204,785 |
| | | | | | Total | \$ | 168.750 | \$ 3 | 37.500 | \$ | 204.785 |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353054 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2009 | 6/1/2010 | | Yes |
| | South Harper 161 kV cut-in to Stilwell-Archie JCT 161 kV line | 6/1/2009 | 6/1/2011 | 11/1/2010 | Yes |
| 1353055 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2009 | 6/1/2010 | | Yes |
| | South Harper 161 kV cut-in to Stilwell-Archie JCT 161 kV line | 6/1/2009 | 6/1/2011 | 11/1/2010 | Yes |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353054 | REDEL - STILWELL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | Yes |
| 1353055 | REDEL - STILWELL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | Yes |

| | | | | Earliest | Redispatch |
|-------------|------------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353054 | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |
| 1353055 | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |

| | | | | Requested | equested Requested R | | | | Date Without | Date Without | Potential Base Plan Funding | Point-to-Point | | Total Revenue |
|----------|-------------|------|------|-----------|----------------------|-----------|------------|------------|--------------|--------------|--------------------------------|----------------|--|---------------|
| Customer | Reservation | POR | POD | Amount | Start Date | Stop Date | Redispatch | Redispatch | Allowable | Base Rate | C Cost | Requirements | | |
| SPSM | 1353057 | WPEK | KCPL | 50 | 0 6/1/2010 | 1/1/2012 | 6/1/2011 | 1/1/2013 | | \$ 836,000 | \$ 1,748,619 | | | |
| SPSM | 1353059 | WPEK | KCPL | 50 | 0 6/1/2010 | 1/1/2012 | 6/1/2011 | 1/1/2013 | \$ - | \$ 836,000 | \$ 1,748,619 | \$ 3,405,857 | | |
| | | • | | | | | | | \$ - | \$ 1,672,000 | \$ 3,497,238 | \$ 6.811.714 | | |

| | | | | Earliest | Redispatch | Allo | cated E & C | | | Tota | l Revenue |
|-------------|---|-----------|-----------|--------------|------------|------|-------------|------|---------------|------|-----------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | t | Tota | al E & C Cost | Requ | uirements |
| 1353057 | FINNEY SWITCHING STATION - HITCHLAND 7 345.00 345KV CKT 1 | 12/1/2010 | 12/1/2010 | | | \$ | 129,651 | \$ | 337,500 | \$ | 223,094 |
| | FLATRDG3 138.00 - HARPER 138KV CKT 1 | 10/1/2009 | 6/1/2011 | | | \$ | 150,449 | \$ | 6,035,477 | \$ | 267,530 |
| | HARPER - MILAN TAP 138KV CKT 1 | 12/1/2009 | 6/1/2010 | | | \$ | 9,704 | \$ | 337,500 | \$ | 18,096 |
| | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2010 | 6/1/2011 | | Yes | \$ | 726,361 | \$ | 8,500,000 | \$ | 1,526,634 |
| | MEDICINE LODGE - PRATT 115KV CKT 1 | 4/1/2009 | 6/1/2011 | | Yes | \$ | 35,765 | \$ | 6,497,822 | \$ | 66,274 |
| | ST JOE - WOODBINE 161KV CKT 1 | 6/1/2010 | 6/1/2011 | | | \$ | 696,689 | \$ | 2,300,000 | \$ | 1,304,229 |
| | | | | | Total | \$ | 1,748,619 | \$ | 24,008,299 | \$ | 3,405,857 |
| 1353059 | FINNEY SWITCHING STATION - HITCHLAND 7 345.00 345KV CKT 1 | 12/1/2010 | 12/1/2010 | | | \$ | 129,651 | \$ | 337,500 | \$ | 223,094 |
| | FLATRDG3 138.00 - HARPER 138KV CKT 1 | 10/1/2009 | 6/1/2011 | | | \$ | 150,449 | \$ | 6,035,477 | \$ | 267,530 |
| | HARPER - MILAN TAP 138KV CKT 1 | 12/1/2009 | 6/1/2010 | | | \$ | 9,704 | \$ | 337,500 | \$ | 18,096 |
| | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2010 | 6/1/2011 | | Yes | \$ | 726,361 | \$ | 8,500,000 | \$ | 1,526,634 |
| | MEDICINE LODGE - PRATT 115KV CKT 1 | 4/1/2009 | 6/1/2011 | | Yes | \$ | 35,765 | \$ | 6,497,822 | \$ | 66,274 |
| | ST JOE - WOODBINE 161KV CKT 1 | 6/1/2010 | 6/1/2011 | | | \$ | 696,689 | \$ | 2,300,000 | \$ | 1,304,229 |
| | | | | | Total | S | 1.748.619 | \$ | 24.008.299 | S | 3.405.857 |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353057 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2009 | 6/1/2010 | | |
| | Loma Vista - Montrose 161kV Tap into K.C. South | 6/1/2009 | 6/1/2011 | | Yes |
| | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | 6/1/2009 | 6/1/2010 | | |
| | South Harper 161 kV cut-in to Stilwell-Archie JCT 161 kV line | 6/1/2009 | 6/1/2011 | 11/1/2010 | Yes |
| 1353059 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2009 | 6/1/2010 | | |
| | Loma Vista - Montrose 161kV Tap into K.C. South | 6/1/2009 | 6/1/2011 | | Yes |
| | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | 6/1/2009 | 6/1/2010 | | |
| | South Harper 161 kV cut-in to Stilwell-Archie JCT 161 kV line | 6/1/2009 | 6/1/2011 | 11/1/2010 | Yes |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1353057 | COOK - ST JOE 161KV CKT 1 | 6/1/2010 | 6/1/2011 | | Yes |
| | REDEL - STILWELL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | Yes |
| 1353059 | COOK - ST JOE 161KV CKT 1 | 6/1/2010 | 6/1/2011 | | Yes |
| | REDEL - STILWELL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | · · | Yes |

| | | | Earliest | Redispatch |
|------------------------------------|---|---|--|--|
| Upgrade Name | DUN | EOC | Service Date | Available |
| GEN2004014-1 | 12/31/2009 | 12/31/2009 | | |
| LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |
| GEN2004014-1 | 12/31/2009 | 12/31/2009 | | |
| LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |
| | GEN2004014-1 LACYONE - WEST GARDNER 345KV CKT 1 RENO 345/115KV CKT 2 SUMMIT - RENO 345KV WICHITA - RENO 345KV WICHITA - RENO 345KV GEN2004014-1 LACYONE - WEST GARDNER 345KV CKT 1 RENO 345/115KV CKT 1 RENO 345/115KV CKT 1 RENO 345/115KV CKT 2 SUMMIT - RENO 345KV SUMMIT - RENO 345KV | GEN2004014-1 12/31/2009 LACYGNE - WEST GARDNER 345KV CKT 1 6/1/2006 RENO 345/115KV CKT 2 6/1/2016 RENO 345/115KV CKT 2 6/1/2010 WICHITA - RENO 345KV 6/1/2010 WICHITA - RENO 345KV 6/1/2010 WICHITA - RENO 345KV 6/1/2010 RENO 345KV 10/1/2010 RENO 345/115KV CKT 1 6/1/2009 RENO 345/115KV CKT 1 6/1/2010 RENO 345/115KV CKT 2 6/1/2010 SUMMIT - RENO 345KV 6/1/2010 | Upgrade Name DUN EOC GEN2004014-1 1231/2009 1231/2009 LACYGNE - WEST GARDNER 345KV CKT 1 61/2006 6/1/2006 RENO 345/115KV CKT 2 61/2009 6/1/2009 SUMMIT - RENO 345KV 6/1/2010 6/1/2010 WICHITA - RENO 345KV 6/1/2010 6/1/2010 MICHITA - RENO 345KV 6/1/2010 6/1/2010 GEN2004014-1 1231/2009 12/31/2009 12/31/2009 LACYGNE - WEST GARDNER 345KV CKT 1 6/1/2006 6/1/2006 RENO 345/115KV CKT 2 6/1/2010 6/1/2010 SIMMIT - RENO 345KV 6/1/2010 6/1/2010 | Upgrade Name DUN EOC Service Date GEN2004014-1 12/31/2009 12/31/2009 12/31/2009 12/31/2009 6/1/2006 6/1/2006 6/1/2006 6/1/2006 6/1/2006 6/1/2006 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2010 6/1/2010 6/1/2010 6/1/2010 6/1/2010 6/1/2010 6/1/2010 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2009 6/1/2006 6/1/2006 6/1/2009 |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested | Date Without | Date Without | | Point-to-Point Base Rate | | Total Revenue Requirements |
|----------|-------------|------|------|---------------------|-------------------------|-----------|--------------|--------------|------|-----------------------------|------|-------------------------------|
| WFEC | 1510704 | WFEC | WFEC | 1 | 50 5/1/2009 | 5/1/2039 | 6/1/2011 | 6/1/2041 | \$ - | \$ - | \$ - | \$ - |
| | | | • | • | • | | | • | \$ - | S - | \$ - | S - |

| | | | | Earliest | Redispatch | Allocated E & C | | Total Revenue | |
|-------------|--------------|-----|-----|--------------|------------|-----------------|------------------|---------------|---|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | Total E & C Cost | Requirements | |
| 1510704 | None | | | | | \$ - | \$ - | \$ | - |
| | | | | | Total | \$ - | \$ - | \$ | - |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1510704 | CARNEGIE - FORT COBB 138KV CKT 1 | 6/1/2018 | 6/1/2018 | | |
| | CARNEGIE - HOBART JUNCTION 138KV CKT 1 | 6/1/2018 | 6/1/2018 | | |
| | ELECTRA SW 69KV CAP BANK | 6/1/2014 | 6/1/2014 | | |
| | ESQUANDALE JCT - WALTERS 69KV CKT 1 AEPW | 6/1/2011 | 6/1/2011 | | |
| | ESQUANDALE JCT - WALTERS 69KV CKT 1 WFEC | 6/1/2010 | 6/1/2011 | | |
| | FORT COBB - SOUTHWESTERN STATION 138KV CKT 1 | 6/1/2018 | 6/1/2018 | | |

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1510704 | HÜGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV WFEC | 7/1/2012 | 7/1/2012 | | |
| | KNOBHILL (KNOBHIL4) 138/69/13.2KV TRANSFORMER CKT 1 | 6/1/2006 | 6/1/2008 | | |
| | NORTHWEST - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 2 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD 245/120KV TRANSCORMED CKT 1 | 1/1/2010 | 1/1/2010 | | |

| Customer | Reservation | POR | POD | | Requested Start Date | Requested Stop Date | Date Without | Date Without | | Point-to-Point | | Total Revenue Requirements |
|----------|-------------|------|-----|----|-------------------------|------------------------|--------------|--------------|--------------|----------------|--------------|-------------------------------|
| WRGS | | SECI | WR | 96 | 11/1/2008 | | | 6/1/2021 | | | \$ 1,616,090 | |
| | | • | | | | | | | \$ 1,616,090 | \$ - | \$ 1,616,090 | \$ 3,934,252 |

| | | | | Earliest | Redispatch | Alloc | cated E & C | | | Tota | I Revenue |
|-------------|---|-----------|-----------|--------------|------------|-------|-------------|------|---------------|------|-----------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available | Cost | | Tota | al E & C Cost | Req | uirements |
| 1346837 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2018 | 6/1/2018 | | | \$ | 1,442,309 | \$ | 2,580,000 | \$ | 3,457,759 |
| | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | 6/1/2016 | 6/1/2016 | | | \$ | 3,065 | \$ | 100,000 | \$ | 7,186 |
| | FINNEY SWITCHING STATION - HITCHLAND 7 345.00 345KV CKT 1 | 12/1/2010 | 12/1/2010 | | | \$ | 13,597 | \$ | 337,500 | \$ | 34,678 |
| | FLATRDG3 138.00 - HARPER 138KV CKT 1 | 10/1/2009 | 6/1/2011 | | | \$ | 148,528 | \$ | 6,035,477 | \$ | 409,797 |
| | HARPER - MILAN TAP 138KV CKT 1 | 12/1/2009 | 6/1/2010 | | | \$ | 8,547 | \$ | 337,500 | \$ | 24,719 |
| | LITCHFIELD - AQUARIUS - HUDSON JUNCTION 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 44 | \$ | 131 | \$ | 113 |
| | | | | | Total | \$ | 1,616,090 | \$ | 9,390,608 | \$ | 3,934,252 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | | Earliest | Redispatch |
|------|---------|----------------------------------|----------|-----------|--------------|------------|
| Rese | rvation | Upgrade Name | DUN | EOC | Service Date | Available |
| | 1346837 | KELLY - SOUTH SENECA 115KV CKT 1 | 4/1/2009 | 12/1/2010 | | |
| | | Knob Hill - Steele City 115 kV | 4/1/2009 | 6/1/2010 | | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1346837 | AQUARIUS - HUDSON JUNCTION 69KV CKT 1 | 6/1/2018 | 6/1/2018 | | |
| | AQUARIUS - LITCHFIELD 69KV CKT 1 | 6/1/2018 | 6/1/2018 | | |
| | AUBURN ROAD (AUBRN77X) 230/115/13.8KV TRANSFORMER CKT 2 | 6/1/2013 | 6/1/2013 | | |
| | BPU - CITY OF MCPHERSON JOHNS-MANVILLE - EAST MCPHERSON SWITCHING STATION 115KV CF | 6/1/2009 | 6/1/2011 | | |
| | CHISHOLM (CHISLM1X) 138/69/13.2KV TRANSFORMER CKT 2 | 6/1/2010 | 6/1/2011 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | |
| | FORT JUNCTION SWITCHING STATION - WEST JUNCTION CITY JUNCTION 115KV CKT 1 | 6/1/2010 | 6/1/2011 | | |
| | GILL ENERGY CENTER WEST - WACO 138KV CKT 1 | 6/1/2010 | 6/1/2011 | | |
| | HUDSON JUNCTION - PITTSBURG 69KV CKT 1 | 6/1/2018 | 6/1/2018 | | |
| | SEVENTEENTH () 138/69/11.295KV TRANSFORMER CKT 2 | 6/1/2010 | 6/1/2011 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2010 | 6/1/2011 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|--|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1346837 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 4/1/2009 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | 4/1/2009 | 6/1/2011 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |

Planned Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|------------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1346837 | HOPE 230/115 KV | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT 345/115KV TRANSFORMER CKT 1 | 6/1/2011 | 6/1/2011 | | |

| | | | | | | | | Earliest | Redispatch |
|-------------|---------------------|----|--|--|-----|----------|----------|--------------|------------|
| Reservation | Upgrade Name | | | | DUN | | EOC | Service Date | Available |
| 1346837 | RENO 345/115KV CKT | 1 | | | | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT | 2 | | | | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | V | | | _ | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345K | .V | | | | 6/1/2009 | 6/1/2009 | | |

| | | | | Requested | Requested | | Date Without | Deferred Stop Date Without | | Point-to-Point | | |
|----------|-------------|------|-----|-----------|------------|------------|--------------|-------------------------------|--------------|----------------|---------------|---------------|
| Customer | Reservation | POR | POD | Amount | Start Date | Stop Date | Redispatch | Redispatch | Allowable | Base Rate | C Cost | Requirements |
| WRGS | 1346842 | SECI | WR | 100 | 12/31/2008 | 12/31/2018 | 6/1/2011 | 6/1/2021 | \$ 1,800,000 | \$ - | \$ 17,417,601 | \$ 49,563,886 |
| | | | | | | | | | \$ 1,800,000 | \$ - | \$ 17,417,601 | \$ 49,563,886 |

| | | | | Earliest | Redispatch | Allo | cated E & C | | | Tota | al Revenue |
|---------|---|-----------|-----------|--------------|------------|------|-------------|------|---------------|------|------------|
| | Upgrade Name | DUN | EOC | Service Date | Available | Cos | t | Tota | al E & C Cost | Req | uirements |
| 1346842 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2018 | | | | \$ | 234,489 | \$ | 2,580,000 | \$ | 562,159 |
| | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | 6/1/2016 | 6/1/2016 | 1 | | \$ | 3,056 | \$ | 100,000 | \$ | 7,165 |
| | FINNEY SWITCHING STATION - HITCHLAND 7 345.00 345KV CKT 1 | 12/1/2010 | 12/1/2010 |) | | \$ | 23,989 | \$ | 337,500 | \$ | 61,182 |
| | FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 | 10/1/2009 | 6/1/2011 | | | \$ | 1,962,496 | \$ | 2,011,826 | \$ | 5,414,634 |
| | FLATRDG3 138.00 - HARPER 138KV CKT 1 | 10/1/2009 | | | | \$ | 5,477,989 | \$ | 6,035,477 | \$ | 15,114,072 |
| | GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | 1 | | \$ | 144,851 | \$ | 244,282 | \$ | 448,226 |
| | HARPER - MILAN TAP 138KV CKT 1 | 12/1/2009 | 6/1/2010 | 1 | | \$ | 304,308 | \$ | 337,500 | \$ | 880,111 |
| | LITCHFIELD - AQUARIUS - HUDSON JUNCTION 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ | 56 | \$ | 131 | \$ | 144 |
| | MEDICINE LODGE - PRATT 115KV CKT 1 | 4/1/2009 | 6/1/2011 | | | \$ | 5,902,519 | \$ | 6,497,822 | \$ | 16,970,658 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | | \$ | 3,363,848 | \$ | 3,825,000 | \$ | 10,105,535 |
| | | | | | Total | \$ | 17,417,601 | \$ | 21,969,538 | \$ | 49,563,886 |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1346842 | AQUARIUS - HUDSON JUNCTION 69KV CKT 1 | 6/1/2018 | 6/1/2018 | | |
| | AQUARIUS - LITCHFIELD 69KV CKT 1 | 6/1/2018 | 6/1/2018 | | |
| | AUBURN ROAD (AUBRN77X) 230/115/13.8KV TRANSFORMER CKT 2 | 6/1/2013 | 6/1/2013 | | |
| | BPU - CITY OF MCPHERSON JOHNS-MANVILLE - EAST MCPHERSON SWITCHING STATION 115KV C | 6/1/2009 | 6/1/2011 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | EAST MANHATTAN - NW MANHATTAN 230/115KV | 6/1/2009 | 6/1/2011 | | |
| | FORT JUNCTION SWITCHING STATION - WEST JUNCTION CITY JUNCTION 115KV CKT 1 | 6/1/2010 | 6/1/2011 | | |
| | GILL ENERGY CENTER WEST - WACO 138KV CKT 1 | 6/1/2010 | 6/1/2011 | | |
| | HUDSON JUNCTION - PITTSBURG 69KV CKT 1 | 6/1/2018 | 6/1/2018 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2010 | 6/1/2011 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|---|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1346842 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 4/1/2009 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |

Planned Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest | Redispatch |
|-------------|------------------------------------|----------|----------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 134684 | HOPE 230/115 KV | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT 345/115KV TRANSFORMER CKT 1 | 6/1/2011 | 6/1/2011 | | |

| | | | | Earliest | Redispatch |
|-------------|------------------------------------|------------|------------|--------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Service Date | Available |
| 1346842 | GEN2004014-1 | 12/31/2009 | 12/31/2009 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | RENO 345/115KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | RENO 345/115KV CKT 2 | 6/1/2010 | 6/1/2010 | | |
| | SUMMIT - RENO 345KV | 6/1/2010 | 6/1/2010 | | |
| | WICHITA - RENO 345KV | 6/1/2009 | 6/1/2009 | | |
| | | | | | |

| Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) | Estimated Engineering & Construction Cost |
|-----------------------|--|---|--------------------------------------|--|---|
| AEPW | BETHEL - BROKEN BOW 138KV CKT 1 #2 | Interim redispatch | 6/1/2009 | 6/1/2011 | \$0.00 |
| AEPW | BETHEL - NASHOBA 138KV CKT 1 | Interim redispatch | 6/1/2009 | 6/1/2012 | \$0.00 |
| AEPW | CLAYTON - NASHOBA 138KV CKT 1 | Interim redispatch | 6/1/2009 | 6/1/2012 | \$0.00 |
| AEPW | CLAYTON - SARDIS 138KV CKT 1 | Interim redispatch | 6/1/2009 | 6/1/2012 | \$0.00 |
| AEPW | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | Replace Delaware Switches | 6/1/2016 | 6/1/2016 | \$100,000.00 |
| AEPW | COFFEYVILLE FARMLAND - SOUTH COFFEYVILLE CITY 138KV CKT 1 | Rebuild 2.20 miles of 795 ACSR with 1590 ACSR. | 6/1/2012 | 6/1/2012 | \$2,200,000.00 |
| AEPW | 00555747115 TAB 0011711 005557471115 01774 400144 01774 | Rebuild 6 miles of 556 ACSR with 1590 ACSR. | 6/1/2011 | 6/1/2011 | *** |
| AEPW | COFFEYVILLE TAP - SOUTH COFFEYVILLE CITY 138KV CKT 1 LYDIA - WELSH 345KV CKT 1 | Replace 138 kV line switch at S. Coffeyville Tap. | 6/1/2011 | 6/1/2011 | \$6,000,000.00 \$0.00 |
| AEPW | | Interim redispatch | | | |
| | NORTHWEST TEXARKANA - PATTERSON 138KV CKT 1 | Interim redispatch | 6/1/2009 | 6/1/2012 | \$0.00 |
| AEPW | TEXAS EASTMAN - WHITNEY 138KV CKT 1 | Interim redispatch | 6/1/2009 | 10/1/2009 | \$0.00 |
| GRDA KACP | AFTON - FAIRLAND EDE TAP 69KV CKT 1 IATAN - STRANGER CREEK 345KV CKT 2 | Interim redispatch Convert latan-Stranger Creek 161kV line to 345kV | 6/1/2009 6/1/2010 | 10/1/2009 6/1/2011 | \$0.00 \$8.500,000,00 |
| KACF | IATAN - STRANGER CREEK 345KV CKT 2 | Increase the normal/emergency ratings to 233/265 MVA by replacing wave trap on Nashua side with | 6/1/2010 | 6/1/2011 | \$8,300,000.00 |
| MIPU | NASHUA - SMITHVILLE 161KV CKT 1 | 1200A wavetrap | 12/1/2010 | 12/1/2010 | \$180,000.00 |
| MKEC | FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 | Rebuild 8.05 mile line | 10/1/2009 | 6/1/2011 | \$2,011,825.73 |
| MKEC | FLATRDG3 138.00 - HARPER 138KV CKT 1 | Rebuild 24.15 mile line | 10/1/2009 | 6/1/2011 | \$6,035,477,20 |
| MKEC | HARPER - MILAN TAP 138KV CKT 1 | Replace Terminal Equipment | 12/1/2009 | 6/1/2010 | \$337,500.00 |
| MKEC | MEDICINE LODGE - PRATT 115KV CKT 1 | Rebuild 26 mile line | 4/1/2009 | 6/1/2011 | \$6,497,822.00 |
| MKEC | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | Upgrade to 100/147/170MVA transformer | 6/1/2009 | 6/1/2010 | \$3,825,000.00 |
| OKGE | ARCADIA (ARCADIA3) 345/138/13.8KV TRANSFORMER CKT 1 #2 | Interim redispatch | 6/1/2009 | 10/1/2009 | \$0.00 |
| SJLP | ST JOE - WOODBINE 161KV CKT 1 | reconductor | 6/1/2010 | 6/1/2011 | \$2,300,000.00 |
| SPS | FINNEY SWITCHING STATION - HITCHLAND 7 345.00 345KV CKT 1 | Replace Terminal Equipment | 12/1/2010 | 12/1/2010 | \$337,500.00 |
| WERE | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | Rebuild 7.61 miles from 95th & Waverly-Captain Junction 115 kV line. | 6/1/2018 | 6/1/2018 | \$2,580,000.00 |
| WERE | DEARING 138KV Capacitor Displacement | Dearing 138 kV 20 MVAR Capacitor Addition | 6/1/2011 | 6/1/2011 | \$810.000.00 |
| WERE | GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1 Displacement | Rebuild 5.56-mile line, 954 ACSR | 6/1/2013 | 6/1/2013 | \$2,200,000.00 |
| WERE | LITCHFIELD - AQUARIUS - HUDSON JUNCTION 69KV CKT 1 Displacement | Replace 69 kV disconnect switches at Aquarius. | 6/1/2013 | 6/1/2013 | \$30,000.00 |
| WLILL | LITETH ILLD - AGOANIOG - HODGON JONG HON BANY CKT T Displacement | Replace the 69 kV bus and jumpers on the Oatville- | 0/1/2013 | 0/1/2013 | φ30,000.00 |
| WERE | MACARTHUR - OATVILLE 69KV CKT 1 Displacement | Mac Arthur 69 kV line. | 6/1/2013 | 6/1/2013 | \$40,000.00 |
| WERE | TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 Displacement | Uprate TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1 to 100-degree C operation and uprate terminal equipment (236/250) | 6/1/2012 | 6/1/2012 | \$1,125,000.00 |

Construction Pending Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Construction Fen | aing Projects - The requested service is contingent upon completion of the follow | ing upgrades. Cost is not assignable to the transmiss | Earliest | Estimated |
|---|---|---|-------------------|---------------------|
| | | | Date | Date of |
| Transmission | Upgrade | Solution | | Upgrade |
| Owner | Opgrade | Solution | Upgrade | |
| | | | Required (DUN) | Completion (EOC) |
| | | Rebuild 8.37 miles of 795 ACSR with 1590 ACSR & | (DUN) | (EUC) |
| AEPW | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | reset relays @ BSE | 4/1/2009 | 6/1/2011 |
| AEFW | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE TSORV CRT T | Tie Line, Reconductor 1.09 miles of 795 ACSR with | 4/1/2009 | 0/1/2011 |
| AEPW | COFFEYAN E TAB DEARING 139KA CKT 1 AFDW | , | 12/1/2000 | 6/1/2010 |
| AEPW | COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW | 1590 ACSR. | 12/1/2009 | 6/1/2010 |
| AEPW | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | Rebuild 13.11 miles of 795 ACSR with 1590 ACSR. | 6/1/2009 | 6/1/2011 |
| AEFW | COFFETVILLE TAF - NORTH BARTLESVILLE 130KV CRT 1 | Rebuild 17.96 miles of 250 Copperweld with 1272 | 6/1/2009 | 0/1/2011 |
| AEPW | DANVILLE (APL) - MAGAZINE REC 161KV CKT 1 AEPW ACSR. | | 4/1/2009 | 6/1/2009 |
| ALFV | DANVILLE (AFL) - WAGAZINE REC 101KV CKT 1 AEFW | Reconductor line with 1192 ACSS and upgrade | 4/1/2009 | 0/1/2009 |
| KACP | REDEL - STILWELL 161KV CKT 1 | terminal equipment for 2000 amps | 6/1/2009 | 6/1/2011 |
| KACF | REDEL - STILWELL TOTAL CRIT | Rebuild 17.96 miles of 250 Copperweld with 1272 | 6/1/2009 | 0/1/2011 |
| OKGE | DANVILLE (APL) - MAGAZINE REC 161KV CKT 1 OKGE | ACSR. | 4/1/2009 | 6/1/2009 |
| SJLP | COOK - ST JOE 161KV CKT 1 | Conductor, Switch, Relay | 6/1/2010 | 6/1/2009 |
| SJLP | COOK - ST JUE 161KV CKT T | Conductor, Switch, Relay | 6/1/2010 | 6/1/2011 |
| WERE | ALLEN - LEHIGH TAP 69KV CKT 1 | Tear down / Rebuild 5.69-mile line; 954 kcmil ACSR | 6/1/2011 | 6/1/2011 |
| WERE | ALLEN - LENION TAP 09KV CKT T | Teal down/ Rebuild 5.69-fille lifte, 954 kcffill ACSK | 6/1/2011 | 0/1/2011 |
| WERE | Athens to Owl Creek 69 kV | Rebuild Athens to Owl Creek (138kV/69kV Operation) | 6/1/2011 | 6/1/2011 |
| WERE | Attens to Owi Creek 69 kV | Rebuild Athens to Owi Creek (136kV/69kV Operation) | 6/1/2011 | 0/1/2011 |
| WERE | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | Rebuild 7.2 miles (138kV/69kV Operation) | 6/1/2011 | 6/1/2011 |
| WERE | BURLINGTON JUNCTION - COPPET COUNTY NO. 3 WEST PHALIA 69KV CKT 1 | Rebuild 4.1 miles (138kV/69kV Operation) | 6/1/2011 | 6/1/2011 |
| WERE | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | Rebuild 9.22 miles (138kV/69kV Operation) | 6/1/2011 | 6/1/2011 |
| WEILE | COTTET COUNTY NO. 3 WESTFTIALIA - GREEN USIKV CRT T | Tie Line, Rebuild 3.93 miles of 795 ACSR with 1590 | 0/1/2011 | 0/1/2011 |
| WERE | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE | ACSR. | 12/1/2009 | 6/1/2010 |
| WEIKE | OCT ET VIELE TAI BEARING TOUR ORT T WERE | Replace Disconnect Switches, Wavetrap, Breaker, | 12/1/2003 | 0/1/2010 |
| WERE | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE #2 | Jumpers | 12/1/2009 | 6/1/2010 |
| WEILE | COTTET VIELE TAP - DEAKING 130KV CKT T WEIKE #2 | The East Manhattan-McDowell 115 kV is built as a | 12/1/2009 | 0/1/2010 |
| | | 230 kV line, but is operated at 115 kV. Substation | | Ì |
| | | work will have to be performed in order to convert this | | Ì |
| WERE | East Manhattan to Mcdowell 230 kV Displacement | line. | 6/1/2009 | 6/1/2011 |
| WEIKE | Last Warmattan to Woodwell 200 KV Displacement | Replace Disconnect Switches, Wavetrap, Breaker, | 0/1/2003 | 0/1/2011 |
| WERE | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | Jumpers | 6/1/2010 | 6/1/2010 |
| *************************************** | EVALUE ENERGY GENTER GOOTH BUREAU BOE TOOK ON THE BIO PROGRAMME | Rebuild 7.19 miles Green to Vernon 69 kV | 0/1/2010 | 0/1/2010 |
| WERE | Green to Vernon 69 kV | (138kV/69kV Operation) | 6/1/2011 | 6/1/2011 |
| WEIKE | Orecti to venton 65 kV | Tear down / Rebuild 8.47-mile 69 kV line: 954 kcmil | 0/1/2011 | 0/1/2011 |
| WERE | LEHIGH TAP - OWL CREEK 69KV CKT 1 | ACSR | 6/1/2011 | 6/1/2011 |
| | CELITOR THE CHEEK CORK CITY | Replace bus and Jumpers at NE Parsons 138 kV | G, 1,2011 | J, 1, 2011 |
| WERE | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | substation | 6/1/2010 | 6/1/2010 |
| | | Rebuild 5.43 mile Rose Hill Junction-Richland as a | 3, 1,20.0 | 0, 1,20.0 |
| WERE | RICHLAND - ROSE HILL JUNCTION 69KV CKT 1 Displacement | 138 kV line but operate at 69 kV. | 12/1/2010 | 6/1/2011 |
| WERE | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | Add third 345-138 kV transformer at Rose Hill | 4/1/2009 | 6/1/2011 |
| | | Rebuild 5.17 miles Green to Vernon 69 kV | ., ., 2000 | J, 1,2011 |
| WERE | Vernon to Athens 69 kV | (138kV/69kV Operation) | 6/1/2011 | 6/1/2011 |
| ,_ | 1 | (oporation) | 37.720.1 | 5, 1,2011 |

Planned Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) |
|-----------------------|------------------------------------|--|--|--|
| WERE | HOPE 230/115 KV | Tap the Morris - Summit 230kV line and add a new substation "Hope"; Move 230kV/115kV transformer from Summit and Build 3.5 mile 115 kV line to TC-Hope | 6/1/2010 | 6/1/2010 |
| WERE | SUMMIT 345/115KV TRANSFORMER CKT 1 | Install new SUMMIT 345/115KV TRANSFORMER CKT 1 | 6/1/2011 | 6/1/2011 |

Expansion Plan Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) |
|---|---|---|--|--|
| AEPW ARSENAL HILL - NORTH MARKET 69KV CKT 1 | | Rebuild 2.3 miles of 666 ACSR with 1272 ACSR | 6/1/2010 | 6/1/2011 |
| EMDE | JAMESVILLE - SUB 415 - BLACKHAWK JCT. 69KV CKT 1 EMDE | Replace Jumpers to breaker #6950 at Blackhawk Jct. Replace Disconnect Switches and Leads on Breaker | 6/1/2016 | 6/1/2016 |
| EMDE | SUB 145 - JOPLIN WEST 7TH - SUB 64 - JOPLIN 10TH ST. 69KV CKT 1 | #6965 at Sub #64 and #6932 at Sub #145 | 6/1/2017 | 6/1/2017 |
| EMDE | SUB 376 - MONETT CITY SOUTH 161/69/12.5KV TRANSFORMER CKT 1 | Install 3-wind transformer from 161 kV new Sub MONETT 5 to Monett city south 69kV | 6/1/2018 | 6/1/2018 |
| EMDE | SUB 383 - MONETT - SUB 376 - MONETT CITY SOUTH 161KV CKT 1 | Install new line from Sub #383 to new Sub MONETT 5 | 6/1/2018 | 6/1/2018 |
| GRDA | AFTON (AFTAUTO1) 161/69/13.8KV TRANSFORMER CKT 1 | Add a second 50 MVA Transformer at Afton Substation. | 6/1/2009 | 6/1/2012 |
| GRDA | CLAREMORE (CLRAUTO1) 161/69/13.8KV TRANSFORMER CKT 1 | Replace existing transformer | 6/1/2009 | 6/1/2009 |
| GRDA | CLAREMORE (CLRAUTO2) 161/69/13.8KV TRANSFORMER CKT 2 | Replace existing transformer | 6/1/2009 | 6/1/2009 |
| GRDA | KERR - PENSACOLA 115KV CKT 1 | Rebuild line to accommodate 795 ACSR. | 6/1/2009 | 6/1/2012 |
| GRDA | MAID - PRYOR FOUNDRY SOUTH 69KV CKT 1 | Upgrade conductor size 795 ACSR | 6/1/2014 | 6/1/2014 |
| GRDA | MAID - REDDEN 69KV CKT 1 | Upgrade conductor size 795 ACSR | 6/1/2014 | 6/1/2014 |
| GRDA | SALLISAW CAP BANK | Install cap bank | 6/1/2009 | 6/1/2009 |
| OKGE | BROWN - EXPLORER TAP 138KV CKT 1 | Reconductor .27 miles of line to 795AS33. | 6/1/2009 | 6/1/2011 |
| WERE | CIRCLE - HUTCHINSON GAS TURBINE STATION 115KV CKT 1 | Rebuild Circle - HEC GT 115 kV line. | 6/1/2009 | 6/1/2009 |
| WERE | KELLY - SOUTH SENECA 115KV CKT 1 | Rebuild 10.28 mile line with 1192.5 kcmil ACSR and replace CTs. | 4/1/2009 | 12/1/2010 |
| WERE | Knob Hill - Steele City 115 kV | Building a new 115 kV tie with NPPD from Greenleaf to Clay Center | 4/1/2009 | 6/1/2010 |
| WERE | Summit - NE Saline 115 kV | Build 6.5-mile Summit-Southgate 115 kV, 1192.5 kcmil ACSR Tear down Northview-South Gate 115 kV | 6/1/2009 | 12/1/2009 |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| rtonasmty r rojoo | liability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission custom | | | |
|-------------------|---|---|------------------|----------------------|
| | | | Earliest Date | Estimated Date of |
| Transmission | Upgrade | Solution | Upgrade | Upgrade |
| Owner | opgrade | Solution | Required | Completion |
| | | | (DUN) | (EOC) |
| AEPW | ASHDOWN WEST - CRAIG JUNCTION 138KV CKT 1 | Rebuild 2.45 miles of 795 ACSR with 1590 ACSR | 6/1/2013 | 6/1/2013 |
| ALTW | ASTIDOWN WEST - CIVAG SONCTION 150KV CKT 1 | Rebuild 2:45 fillies of 795 ACSR With 1590 ACSR | 0/1/2013 | 0/1/2013 |
| AEPW | BETHEL - BROKEN BOW 138KV CKT 1 | Rebuild 9.19 miles of 3/0 Copperweld with 795 ACSR | 6/1/2011 | 6/1/2011 |
| 71L1 VV | DETITIES BROKEN DOW TOOK OKT T | Reconductor 11.03 miles with 795 ACSR Carnegie - | 0/1/2011 | 0/1/2011 |
| AEPW | CARNEGIE - FORT COBB 138KV CKT 1 | Fort Cobb | 6/1/2018 | 6/1/2018 |
| 71L1 VV | ONINECIE I ONI COBB ISSNY ONI I | Reconductor 26.15 miles with 795 ACSR from | 0/1/2010 | 0/1/2010 |
| AEPW | CARNEGIE - HOBART JUNCTION 138KV CKT 1 | Carnegie-Hobart Junction | | |
| | | | | |
| | | Rebuild 11.78 miles of 2-336 ACSR with 1590 ACSR | | |
| | | and replace Diana wavetrap & jumpers, Diana switch | | |
| AEPW | DIANA - LONE STAR SOUTH 138KV CKT 1 | 10387, & reset CTs @ Lone Star South & Diana | 12/1/2009 | 6/1/2012 |
| AEPW | ESQUANDALE JCT - WALTERS 69KV CKT 1 AEPW | Replace switches at Walters and reset CTs | 6/1/2011 | 6/1/2011 |
| · | | Reconductor 3.34 miles with 795 ACSR South West | | 1 |
| AEPW | FORT COBB - SOUTHWESTERN STATION 138KV CKT 1 | Station - Fort Cobb | 6/1/2018 | 6/1/2018 |
| AEPW | LOCUST GROVE - LONE STAR 115KV CKT 1 | Rebuild 2.15 miles of 266 ACSR with 795 ACSR | 6/1/2014 | 6/1/2014 |
| | | Replace (3) 600 A switches with 1200 A switches | | |
| | | replace and replace transformer 130/143 MVA | | |
| | | autotransformer also replace 500 Cu 69 kV jumpers | | |
| AEPW | PRYOR JUNCTION (PRY-JCT1) 115/69/13.8KV TRANSFORMER CKT 1 | and raise CT | 6/1/2015 | 6/1/2015 |
| AEPW | RIVERSIDE STATION - TULSA POWER STATION 138KV CKT 1 | Rebuild 5.82 miles with 1272 ACSR | 6/1/2012 | 6/1/2012 |
| | | Rebuild 2.06 miles of 2-397 ACSR with 2156 ACSR. | | |
| | | Replace wavetrap, switches, & jumpers @ AEP | | |
| AEPW | SILOAM CITY - SILOAM SPRINGS 161KV CKT 1 | Siloam Springs. | 12/1/2010 | 6/1/2011 |
| | | | | |
| | | Tear down the Riverton to Joplin 59 69 kV line, | | |
| | | rebuilding the line to 161 kV from Stateline to outside | | |
| | | Joplin 59 sub. Tear down and rebuild Joplin 59 to | | |
| | | Gateway to Pillsbury to Reinmiller, converting those 69 | | |
| EMDE | Multi - Stateline - Joplin - Reinmiller conversion | kV lines to 161 kV. Tap the 161 kV line betwe | 6/1/2017 | 6/1/2017 |
| EMDE | SUB 124 - AURORA H.T SUB 152 - MONETT H.T. 69KV CKT 1 | Change CT Ratio on breaker #6936 at Aurora #124 | 6/1/2009 | 6/1/2010 |
| LINDL | COS 121 MONOTONINI COS TOZ IMONETITIMI CONVICTO | Orange of Traile on Broater woode at Aurera #121 | 0/1/2000 | 0/1/2010 |
| | | Reconductor line from Sub #80 to Sub #170 from 1/0 | | |
| EMDE | SUB 170 - NICHOLS ST SUB 80 - SEDALIA 69KV CKT 1 | CU to 556 ACSR and replace Jumpers in Sub #80 | 6/1/2013 | 6/1/2013 |
| GRDA | CPP TRANSF #2 - PRYOR FOUNDRY SOUTH 69KV CKT 1 | Replace 600A switch with 1200A switch | 6/1/2016 | 6/1/2016 |
| MIDW | KINSLEY 115KV Capacitor | Install 10MVAR capacitors at Kinsley 115 kV | 6/1/2011 | 6/1/2011 |
| MIDW | LYONS - WHEATLAND 115KV CKT 1 MIDW | Rebuild 98.5% ownership of 19.4 miles | 6/1/2017 | 6/1/2017 |
| | | To tap the Montrose-LomaVista 161 kV Line into KC | | |
| MIPU | Loma Vista - Montrose 161kV Tap into K.C. South | South 161 kV sub. | 6/1/2009 | 6/1/2011 |
| - | | Increase the normal/emergency ratings to 233/265 | | |
| MIPU | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | MVA by replacing wave trapes | 6/1/2009 | 6/1/2010 |
| | | To tap Stilwell-Archie JCT 161 kV line into South | | 5, ., _ 5 . 0 |
| | | Harper 161 kV sub and make it two new 161 kV | | l |
| | | sections: Stilwell-South Harper and Archie JCT- South | | l |
| MIPU | South Harper 161 kV cut-in to Stilwell-Archie JCT 161 kV line | Harper . | 6/1/2009 | 6/1/2011 |
| OKGE | 3RDST - ARKOMA 161KV CKT 1 | Replace 8-1200A switches & 2-wave traps. | 6/1/2016 | 6/1/2016 |
| OKGE | MCELROY - STILLWATER 138KV CKT 1 | Reconductor 1.91 of 477AS33 to 795AS33 | 6/1/2009 | 6/1/2011 |
| | | re-set the over current relay to trip the Lake Road- | 5 2000 | 5, .,2011 |
| SJLP | ALABAMA - LAKE ROAD 161KV CKT 1 | Alabama section when flow goes above 172 MVA | 6/1/2009 | 6/1/2010 |

Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study

| | | Tear down and rebuild 2.72 mile Tecumseh Hill-27th | | |
|-------|--|---|-----------|-----------|
| WERE | 27TH & CROCO - TECUMSEH HILL 115KV CKT 1 | & Croco 115 kV line as a single circuit. | 6/1/2009 | 6/1/2011 |
| WEIKE | 27111 W ONGOO TEOOMOETTINEE TIONV ON T | a croco i ro kv iine as a single circuit. | 0/1/2003 | 0/1/2011 |
| | | Tear down and rebuild 3.43 mile 27th & Croco-41ST | | |
| WERE | 27TH & CROCO JUNCTION - 41ST & CALIFORNIA 115KV CKT 1 | & CALIFORNIA 115 kV line as a single circuit. | 6/1/2009 | 6/1/2011 |
| WERE | AQUARIUS - HUDSON JUNCTION 69KV CKT 1 | Rebuild 0.72 miles | 6/1/2018 | 6/1/2018 |
| WERE | AQUARIUS - LITCHFIELD 69KV CKT 1 | Rebuild 5.54 miles | 6/1/2018 | 6/1/2018 |
| WERE | AUBURN ROAD (AUBRN77X) 230/115/13.8KV TRANSFORMER CKT 2 | Add second Auburn 230-115 kV transformer. | 6/1/2013 | 6/1/2013 |
| WEIKE | BPU - CITY OF MCPHERSON JOHNS-MANVILLE - EAST MCPHERSON SWITCHIN | | 0/1/2010 | 0/1/2010 |
| WERE | STATION 115KV CKT 1 | Rebuild Line | 6/1/2009 | 6/1/2011 |
| WEIKE | CIATION FISING CINT I | Tear down and rebuild 2.40 Chisholm - Ripley 69 kV | 0/1/2003 | 0/1/2011 |
| WERE | CHISHOLM - RIPLEY 69KV CKT 1 | with 1192.5 ACSR | 6/1/2010 | 6/1/2011 |
| WERE | CHISHOLM (CHISLM1X) 138/69/13.2KV TRANSFORMER CKT 2 | Install Chisholm 138-69 xfmr #2 | 6/1/2010 | 6/1/2011 |
| WEIKE | OF HOLIVI (OF HOLIVITY) 100/03/13.21(V 110/140) Of WIET ON 2 | Uprate JEC- E.Manhattan 230 kV line to 100 deg C | 0/1/2010 | 0/1/2011 |
| WERE | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 | operation by raising structures | 6/1/2009 | 6/1/2011 |
| WEIKE | ENOT WINTER THAT SETTING TO ENTER 250KV OKT T | Tap the Concordia - East Manhattan 230kV line and | 0/1/2003 | 0/1/2011 |
| | | add a new substation"NW Manhattan"; Add a | | |
| | | 230kV/115kV transformer and tap the KSU - Wildcat | | |
| WERE | EAST MANHATTAN - NW MANHATTAN 230/115KV | 115kV line into NW Manhattan | 6/1/2009 | 6/1/2011 |
| WLILL | LAST WANTALTAN - NW WANTATTAN 230/113RV | Build new Ft Jct W. Jct City line that follows the path | 0/1/2009 | 0/1/2011 |
| | FORT JUNCTION SWITCHING STATION - WEST JUNCTION CITY JUNCTION | of the JEC - Summit 345kV. Remove old double | | |
| WERE | 115KV CKT 1 | circuit and WJCTYE - WJCTCTY 115 kV | 6/1/2010 | 6/1/2011 |
| WLILL | HISKV CKI I | Tear down and rebuild Gill - Waco with bundled | 0/1/2010 | 0/1/2011 |
| WERE | GILL ENERGY CENTER WEST - WACO 138KV CKT 1 | 1192.5 ACSR conductor | 6/1/2010 | 6/1/2011 |
| WERE | HUDSON JUNCTION - PITTSBURG 69KV CKT 1 | Rebuild 1.41 miles | 6/1/2018 | 6/1/2018 |
| WERE | LAWRENCE HILL - MOCKINGBIRD HILL SWITCHING STATION 115KV CKT 1 | Rebuild 5.49 mile line | 6/1/2013 | 6/1/2013 |
| WERE | LYONS - WHEATLAND 115KV CKT 1 WERE | Rebuild 1.5% ownership of 19.4 miles | 6/1/2017 | 6/1/2017 |
| WEIKE | ETONO WILEMENTON ON TWENE | Tear down / Rebuild 8.48-mile Richland-Udall 69 kV | 0/1/2017 | 0/1/2017 |
| WERE | RICHLAND - UDALL 69KV CKT 1 | line using 954 kcmil ACSR | 12/1/2013 | 12/1/2013 |
| WERE | SEVENTEENTH () 138/69/11.295KV TRANSFORMER CKT 2 | Install second 17th St. 138-69 kV transformer | 6/1/2010 | 6/1/2011 |
| WEIKE | DEVENTEENTH () 100/03/11.233/KV TRANOI ORWIEK OKT 2 | Tear down/rebuild 5.2 milse Tecumseh Hill-Shawnee | 0/1/2010 | 0/1/2011 |
| WERE | SHAWNEE HEIGHTS - TECUMSEH HILL 115KV CKT 1 | Heights 115 kV | 6/1/2018 | 6/1/2018 |
| WEIKE | OF WANTE TIESTING TEGOMOETTIME TIGHT ONLY | Rebuild 11.62-mile Jarbalo-NW Leavenworth 115 kV | 0/1/2010 | 0/1/2010 |
| WERE | STRANGER CREEK - NW LEAVENWORTH 115KV | line and tap in & out of Stranger 115 kV | 6/1/2010 | 6/1/2011 |
| | OTTO TO COLUMN TO THE COLUMN T | Add 6 Mvar capacitor at Electra 69 kV bus for a total | 3, 1,2010 | 5, 1,2011 |
| WFEC | ELECTRA SW 69KV CAP BANK | of 18 MVAR at this location | 6/1/2014 | 6/1/2014 |
| LO | ELECTION ON SORV ON DANK | Upgrade Walters to Essaquandale Jct 336.4 to | 3/1/2014 | 3/1/2014 |
| WFEC | ESQUANDALE JCT - WALTERS 69KV CKT 1 WFEC | 795ACSR | 6/1/2010 | 6/1/2011 |
| | EGGGGGGGGGGGGGGGGGGGGGGGGGGGGGGGGGGGGG | Upgrade CT's at Mooreland (Morewood Branch) to | 3, 1,2010 | 5, 1,2011 |
| WFEC | MOORELAND - MOREWOOD SW 138KV CKT 1 | 800A. | 4/1/2009 | 6/1/2010 |

Previously Assigned Aggregate Study Upgrades requiring credits to Previous Aggregate Study Customers.

| Transmission Owner | ned Aggregate Study Upgrades requiring credits to Previous Aggregate St | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) |
|-----------------------|---|---|--|--|
| | | Replace six (6) 138 kV switches, five at Bann & one at | | |
| | | Alumax Tap. Rebuild 0.67 miles of 1024 ACAR with | | |
| | | 2156 ACSR. Replace wavetrap & jumpers @ Bann. | | |
| AEPW | ALUMAX TAP - BANN 138KV CKT 1 | Replace breaker 3300 @ Bann. | 6/1/2008 | 6/1/2008 |
| AEPW | BANN - RED SPRINGS REC 138KV CKT 1 | Replace 138 kV breakers 3300 & 3310 | 7/1/2012 | 7/1/2012 |
| AEPW | GEN2004024-1 | Add one 161KV terminal for Tontitown | 6/1/2008 | 6/1/2008 |
| AEPW | HUGO POWER PLANT - VALLIANT 345 KV AEPW | Vallient 345 KV line terminal | 7/1/2012 | 7/1/2012 |
| | | Reconductor Oronogo 59467 to Riverton 59469 with | | |
| EMDE | SUB 110 - ORONOGO JCT SUB 167 - RIVERTON 161KV CKT 1 | Bundled 556 ACSR | 6/1/2011 | 6/1/2011 |
| | | KCPL Sponsored Project to Reconductor Line to be In- | | |
| KACP | LACYGNE - WEST GARDNER 345KV CKT 1 | Service by 6/1/2006 | 6/1/2006 | 6/1/2006 |
| MKEC | GEN2004014-1 | 230kv line terminal at Spearville | 12/31/2009 | 12/31/2009 |
| OKGE | KNOBHILL (KNOBHIL4) 138/69/13.2KV TRANSFORMER CKT 1 | Replace bus tie with 100MVA transformer | 6/1/2006 | 6/1/2008 |
| OKGE | NORTHWEST - WOODWARD 345KV CKT 1 | Build 120 miles of 345 kV | 1/1/2010 | 1/1/2010 |
| OKGE | WOODWARD - IODINE 138KV CKT 1 | Tap Iodine to Woodward 138 kV line | 1/1/2010 | 1/1/2010 |
| OKGE | WOODWARD - WOODWARD EHV 138KV CKT 1 | Build .5 miles of 138 kV and install terminal equipment | 1/1/2010 | 1/1/2010 |
| OKGE | WOODWARD - WOODWARD EHV 138KV CKT 2 | Build .5 miles of 138 kV and install terminal equipment | 1/1/2010 | 1/1/2010 |
| OKGE | WOODWARD 345/138KV TRANSFORMER CKT 1 | Install 345/138 kV XF | 1/1/2010 | 1/1/2010 |
| WERE | RENO 345/115KV CKT 1 | New stepdown transformer at a new substation in Reno County east northeast of Hutchinson | 6/1/2009 | 6/1/2009 |
| WERE | RENO 345/115KV CKT 2 | Install 2nd stepdown transformer at Reno County substation east northeast of Hutchinson | 6/1/2010 | 6/1/2010 |
| WERE | SUMMIT - RENO 345KV | Install new 50.55-mile 345 kV line from Reno county to Summit; 31 miles of 115 kV line between Circle and S Philips would be rebuilt as double circuit with the 345 kV line to minimize ROW impacts; Substation work required at Summit for new 345 kV terminal | 6/1/2010 | 6/1/2010 |
| | | 40 mile 345 kV transmission line from existing Wichita 345 kV substation to a new 345-115 kV substation in Reno County east northeast of Hutchinson (Wichita to | | |
| WERE | WICHITA - RENO 345KV | Reno) | 6/1/2009 | 6/1/2009 |
| WFEC | HUGO POWER PLANT - VALLIANT 345 KV WFEC | New 19 miles 345 KV | 7/1/2012 | 7/1/2012 |

Table 5 - Third Party Facility Constraints

| Transmission Owner | UpgradeName | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) | Estimated Engineering & Construction Cost |
|-----------------------|---|---|--------------------------------------|--|--|
| AECI | 4LUTHER 138.00 138/69KV TRANSFORMER CKT 1 | Replace transformer | 6/1/2009 | 6/1/2009 | \$2,000,000.00 |
| AECI | HUBEN 345/161KV TRANSFORMER CKT 1 | Install a second Huben 345/161kV transformer | 6/1/2012 | 6/1/2012 | Indeterminate |
| AMMO | 7PALMYRA 345.00 345/161KV TRANSFORMER CKT 1 | Indeterminate | 6/1/2011 | 6/1/2011 | Indeterminate |
| CELE | COCODRIE 230/138KV TRANSFORMER CKT 1 | Indeterminate | 6/1/2010 | 6/1/2010 | Indeterminate |
| CELE | PONT DES MOUTON - WELLS 230KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| CELE | SOUTHWEST BAYOU RAPIDES - TWIN BRIDGES 138KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| CELE | WELLS - WELLS 230KV CKT 2 | Weber Richard Switching Procedure | 6/1/2012 | 6/1/2012 | Indeterminate |
| EES | 3GRENWD - HUMPHREY 115KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | 3GRENWD - TERREBONNE 115KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | 4JUDICE - MEAUX BULK 138KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | 4JUDICE - SCOTT 138KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | 4NCROWL - RICHARD 138KV CKT 1 | Indeterminate | 6/1/2011 | 6/1/2011 | Indeterminate |
| EES | 4NCROWL - SCOTT 138KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | 4SEMERE - SCOTT 138KV CKT 1 | Indeterminate | 4/1/2009 | 4/1/2009 | Indeterminate |
| EES | ACADIA - COLONIAL ACADEMY 138KV CKT 1 | Indeterminate | 12/1/2010 | 12/1/2010 | Indeterminate |
| EES | ACADIA - SCANLAN 138KV CKT 1 | Indeterminate | 12/1/2010 | 12/1/2010 | Indeterminate |
| EES | ADAMS CREEK - BOGALUSA 230KV CKT 2 | Indeterminate | 4/1/2009 | 4/1/2009 | Indeterminate |
| EES | ARKANSAS NUCLEAR ONE - RUSSELLVILLE NORTH 161KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | CECELIA - DOC BONIN 138KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | CECELIA - MORIL 138KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | COLONIAL ACADEMY - RICHARD 138KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | DANVILLE (APL) - MAGAZINE REC 161KV CKT 1 ENTR | Rebuild 17.96 miles of 250 Copperweld with 1272 ACSR. | 4/1/2009 | 6/1/2009 | Indeterminate |
| EES | DARDANELLE - DARDANELLE 161KV CKT 1 | Indeterminate | 6/1/2010 | 6/1/2010 | Indeterminate |
| EES | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 ENTF | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | DOC BONIN - SCOTT 138KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | EVERTON - HARRISON-EAST 161KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | GIBSON - HUMPHREY 115KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | GIBSON - RAMOS 138KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | HABETZ - RICHARD 138KV CKT 1 | Indeterminate | 6/1/2011 | 6/1/2011 | Indeterminate |
| EES | HARRISON-EAST - SUMMIT 161KV CKT 1 | Indeterminate | 6/1/2010 | 6/1/2010 | Indeterminate |
| EES | HILLTOP - ST JOE 161KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | INDEPENDENCE - LS POWER OSCEOLA UNIT 500KV CKT 1 | Indeterminate | 6/1/2012 | 6/1/2012 | Indeterminate |
| EES | LINE 642 TAP - LIVONIA BULK 138KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | LIVONIA BULK - WILBERT 138KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | RICHARD - SCOTT 138KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | RUSSELLVILLE EAST - RUSSELLVILLE NORTH 161KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | RUSSELLVILLE EAST - RUSSELLVILLE SOUTH 161KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| EES | WELLS 500/230KV TRANSFORMER CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| LAFA | ACADIANA MALL - DOC BONIN 230KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| LAFA | ACADIANA MALL - FLANDERS 230KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| LAFA | DOC BONIN - LABBE 230KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| LAFA | DOC BONIN 230/138KV TRANSFORMER CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| LAFA | LABBE - PONT DES MOUTON 230KV CKT 1 | Indeterminate | 6/1/2009 | 6/1/2009 | Indeterminate |
| NPPD | SPEARVILLE - KNOLL - AXTELL 345KV CKT 1 | Build a new 345kV line from Spearville - Knoll - Axtell | 6/1/2009 | 6/1/2013 | Indeterminate |
| 014/54 | DULL GUALA DULL GUALAUTA (AUGUALAUTA) | Replace bus at Bull Shoals. That should increase | 0/4/000- | 0/4/004 | l |
| SWPA | BULL SHOALS - BULL SHOALS HES 161KV CKT 1 | rating to 223 MVA. | 6/1/2009 | 6/1/2011 | Indeterminate |
| SWPA | CLARKSVILLE - DARDANELLE 161KV CKT 1 | Reconductor Clarksville-Dardanelle line | 6/1/2013 | 6/1/2013 | Indeterminate |
| SWPA | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 SWPA | Replace wave trap, disconnect switches, current transformers, and breaker. Replace bus. | 6/1/2009 | 6/1/2010 | Indeterminate |