



**Feasibility Study
For
Generation Interconnection
Request
GEN-2007-039**

SPP Tariff Studies
(#GEN-2007-039)

April, 2008

Executive Summary

<OMITTED TEXT> (Customer) has requested a Feasibility Study for the purpose of interconnecting 120 MW of wind generation within the control area of Southwestern Public Service Company (SPS) located in Hansford County, Texas. The proposed interconnection point is at the existing Hansford 115 kV substation, owned by SPS. The proposed in-service date is December, 2009.

The interconnection of GEN-2007-039 will require the addition of two additional 345kV transmission lines to Oklahoma. For this study, a 345kV transmission line from GEN-2003-013 to the Mooreland / Woodward substation (\$160,000,000) and a 345kV transmission line from the Mooreland / Woodward to Northwest substation were added and the results analyzed. These lines have been assigned to GEN-2006-049. All SPS Expansion Planning projects in the area of Hitchland were included. The Hitchland – Woodward 345kV transmission line which has been assigned to GEN-2006-044 (\$120,000,000) was included. In the event, which these interconnection requests withdraw from the queue, the Customer could be responsible for the cost of these network upgrades.

Power flow analysis has indicated that for the powerflow cases studied, it is possible to interconnect the 120 MW of generation with transmission system reinforcements within the local transmission system. The need for reactive compensation for this interconnection request will be evaluated in the Impact Study based on the wind turbine manufacturer and type requested by the Customer. Dynamic Stability studies performed as part of the System Impact Study will provide additional guidance as to whether the required reactive compensation can be static or a portion must be dynamic (such as a SVC).

The requirement to interconnect the 120 MW of wind generation at the existing Hansford 115kV substation consists of adding a new 115 kV circuit-breaker and a line terminal at the existing Hansford substation. The new terminal will be constructed and maintained by SPS. The Customer did not propose a specific route for the 115 kV line extending to serve its 115/34.5 kV collection facilities. It is assumed that obtaining all necessary right-of-way for the new transmission line to serve its facilities will not be a significant expense.

The total minimum cost for building the required facilities for this 120 MW of generation is \$800,000. These costs are shown in Tables 1 and 2. This cost does not include building the 115 kV line from the Customer 115/34.5 kV collector substation into the point of interconnection. This cost also does not include the Customer's 115/34.5 kV collector substation or possible need for reactive compensation. Network constraints in the Southwestern Public Service Company (SPS) transmission systems that were identified are shown in Table 3. These Network constraints will have to be verified with a Transmission Service Request (TSR) and associated studies. Network Constraints are in the local area of the new generation when this generation is sunk throughout the SPP footprint for the Energy Resource (ER) Interconnection request. With a defined source and sink in a Transmission Service Request, this list of Network Constraints will be refined and expanded to account for all Network Upgrade requirements.

In Table 4, a value of Available Transfer Capability (ATC) associated with each overloaded facility is included. These values may be used by the Customer for future analyses including the determination of lower generation capacity levels that may be installed. When transmission service associated with this interconnection is evaluated, the loading of the facilities listed in this table may be greater due to higher priority reservations. If the loading of a facility is higher, the level of ATC will be lower.

There are several other proposed generation additions in the general area of the Customer's facility. It was assumed in this preliminary analysis that not all of these other projects within the SPP control areas will be in service. Those previously queued projects that have advanced to nearly complete phases were included in this Feasibility Study. In the event that another request for a generation interconnection with a higher priority withdraws, then this request may have to be re-evaluated to determine the local Network Constraints.

The required interconnection costs listed in Tables 1 and 2 and other upgrades associated with Network Constraints do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request through Southwest Power Pool's OASIS.

Contents

| | |
|--|----|
| Introduction | 5 |
| Interconnection Facilities | 5 |
| Interconnection Estimated Costs | 7 |
| Powerflow Analysis | 8 |
| Powerflow Analysis Methodology | 9 |
| Powerflow Results..... | 10 |
| Conclusion | 20 |
| Appendix A: Point of Interconnection Area Map..... | 21 |

Tables

| | |
|---|----|
| Table 1: Direct Assignment Facilities | 7 |
| Table 2: Required Interconnection Network Upgrade Facilities..... | 7 |
| Table 3: Network Constraints..... | 10 |
| Table 4: Network Constraints (Including Texas Panhandle-Oklahoma City 345kV line) | 12 |
| Table 5: Contingency Analysis | 13 |
| Table 6: Contingency Analysis (Including Texas Panhandle-Oklahoma City 345kV line)..... | 17 |

Figures

| | |
|---|----|
| Figure 1: Proposed Method of Interconnection..... | 6 |
| Figure 2: Point of Interconnection Area Map | 21 |

Introduction

<OMITTED TEXT> (Customer) has requested a Feasibility Study for the purpose of interconnecting 120 MW of wind generation within the control area of Southwestern Public Service Company (SPS) located in Hansford County, Texas. The proposed interconnection point is at the existing Hansford 115 kV substation, owned by SPS. The proposed in-service date is December, 2009.

Interconnection Facilities

The primary objective of this study is to identify the system problems associated with connecting the generation to the area transmission system. The Feasibility and other subsequent Interconnection Studies are designed to identify attachment facilities, Network Upgrades and other Direct Assignment Facilities needed to accept power into the grid at the interconnection receipt point.

The requirement to interconnect the 120 MW of wind generation on the existing Hansford 115 kV substation consists of adding a new 115 kV circuit-breaker and line terminal at Hansford. The line terminal will be constructed and maintained by SPS. The Customer did not propose a specific route for the 115 kV line extending to serve its 115/34.5 kV collection facilities. It is assumed that obtaining all necessary right-of-way for the new transmission line to serve its facilities will not be a significant expense.

Other Network Constraints in the Southwestern Public Service Company transmission systems that were identified are shown in Table 3. With a defined source and sink in a Transmission Service Request (TSR), this list of Network Constraints will be refined and expanded to account for all Network Upgrade requirements.

Certain other network upgrades were included in this analysis. These include two 345kV lines from the Texas panhandle to Oklahoma. If previous queued generation interconnection requests withdraw from the queue, the Customer could be expected to pay for these upgrades.

A preliminary one-line drawing of the interconnection and direct assigned facilities are shown in Figure 1.




Figure 1: Proposed Method of Interconnection

(Final design to be determined)

Interconnection Estimated Costs

The minimum cost for adding a new 115 kV circuit-breaker and line terminal serving GEN-2007-039 facilities is estimated at \$800,000. These costs are listed in Tables 1 and 2. These estimates will be refined during the development of the System Impact Study based on the final designs. This cost does not include building the Customer's 115 kV transmission line extending from the point of interconnection to serve its 115/34.5 kV collection facilities. This cost also does not include the Customer's 115/34.5 kV collector substation or the possible need for reactive compensation, all of which should be determined by the Customer. The Customer is responsible for these 115 kV – 34.5 kV facilities up to the point of interconnection.

The costs of interconnecting the facility to the SUNC transmission system are listed in Table 1 & 2.

These costs do not include any cost that might be associated with short circuit study results or dynamic stability study results. These costs will be determined when and if a System Impact Study is conducted.

Table 1: Direct Assignment Facilities

| FACILITY | ESTIMATED COST (2008 DOLLARS) |
|--|----------------------------------|
| CUSTOMER – 115/34.5 kV substation facilities. | * |
| CUSTOMER – 115 kV line between Customer substation and Hansford (SPS) 115 kV substation. | * |
| CUSTOMER – Possible reactive compensation to be determined during impact study. | * |
| CUSTOMER – Right-of-Way for all Customer facilities. | * |
| TOTAL | * |

* Estimates of cost to be determined.

Table 2: Required Interconnection Network Upgrade Facilities

| FACILITY | ESTIMATED COST (2008 DOLLARS) |
|---|----------------------------------|
| SPS – 115 kV circuit-breaker and line terminal to be built for generation request #GEN-2007-039 on the Hansford 115 kV substation. Work to include associated switches, control relaying, high speed communications, metering and related equipment and all related structures. | \$800,000 |
| TOTAL | \$800,000 |
| 345kV transmission construction (if prior queued projects withdraw) | \$160,000,000 |
| Total Including Transmission | \$160,800,000 |

* Estimates of cost to be determined.

Powerflow Analysis

A powerflow analysis was conducted for the facility using modified versions of the 2009 winter peak model, 2012 summer and winter peak models and the 2017 summer peak model. The output of the Customer's facility was offset in each model by a reduction in output of existing online SPP generation. This method allows the request to be studied as an Energy Resource (ER) Interconnection request. The proposed in-service date of the generation is December, 2009. The available seasonal models used were through the 2017 Summer Peak of which is the end of the current SPP planning horizon.

Following current practice, this analysis was conducted assuming that previous queued requests in the immediate area of this interconnect request were in service. Assuming these interconnection requests are in service, two 345kV lines from the Texas panhandle to Oklahoma were modeled as being in service. The analysis of the Customer's project indicates that, given the requested generation level of 120 MW and location, additional criteria violations will occur on the existing SPS transmission systems under steady state and contingency conditions in the peak seasons. Table 3 lists these overloaded facilities.

In Table 4, a value of Available Transfer Capability (ATC) associated with each overloaded facility is included. These values may be used by the Customer to determine lower generation capacity levels that may be installed. When transmission service associated with this interconnection is evaluated, the loading of the facilities listed in this table may be greater due to higher priority reservations. When a facility is overloaded for more than one contingency, only the highest loading on the facility for each season is included in the table.

The need for reactive compensation will be determined during the Impact Study. The need for reactive compensation will be based on the Customer's choice of wind turbine make and manufacturer. Dynamic Stability studies performed as part of the System Impact Study will provide additional guidance as to whether the reactive compensation can be static or a portion must be dynamic (such as a SVC or STATCOM). It is possible that an SVC or STATCOM device will be required at the Customer facility because of FERC Order 661A Low Voltage Ride-Through Provisions (LVRT) which went into effect January 1, 2006. FERC Order 661A orders that wind farms stay on-line for 3-phase faults at the point of interconnection even if that requires the installation of a SVC or STATCOM device.

There are several other proposed generation additions in the general area of the Customer's facility. Some of the local projects that were previously queued were assumed to be in service in this Feasibility Study. Not all local projects that were previously queued and have advanced to nearly complete phases were included in this Feasibility Study.

Powerflow Analysis Methodology

The Southwest Power Pool (SPP) criteria states that: "The transmission system of the SPP region shall be planned and constructed so that the contingencies as set forth in the Criteria will meet the applicable NERC Planning Standards for System Adequacy and Security – Transmission System Table I hereafter referred to as NERC Table I) and its applicable standards and measurements".

Using the created models and the ACCC function of PSS\E, single contingencies in portions or all of the modeled control areas of Sunflower Electric Power Corporation (SUNC), Missouri Public Service (MIPU), Westar Energy (WERE), Kansas City Power & Light (KCPL), West Plains (WEPL), Midwest Energy (MIDW), Oklahoma Gas and Electric (OKGE), American Electric Power West (AEPW), Grand River Dam Authority (GRDA), Southwestern Public Service Company (SPS), Western Farmers Electric Cooperative (WFEC) and other control areas were applied and the resulting scenarios analyzed. This satisfies the 'more probable' contingency testing criteria mandated by NERC and the SPP criteria.

Powerflow Results

Table 3: Network Constraints

| AREA | OVERLOADED ELEMENT |
|-----------|--|
| AEPW | ALTUS JCT TAP - RUSSELL 138KV CKT 1 |
| AEPW | ARSENAL HILL (ARSHILL1) 138/69/12.47KV TRANSFORMER CKT 1 |
| AEPW | ARSENAL HILL (ARSHILL2) 138/69/14.5KV TRANSFORMER CKT 2 |
| AEPW | CARNEGIE - HOBART JUNCTION 138KV CKT 1 |
| AEPW | CLINTON AIR FORCE BASE TAP - ELK CITY 138KV CKT 1 |
| AEPW | CLINTON AIR FORCE BASE TAP - HOBART JUNCTION 138KV CKT 1 |
| AEPW | CLINTON JUNCTION - ELK CITY 138KV CKT 1 |
| AEPW | ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1 |
| AEPW/SPS | ELK CITY 230KV - GRAPEVINE INTERCHANGE 230KV CKT 1 |
| MIDW | COLBY - HOXIE 115KV CKT 1 |
| OKGE | ALVA - KNOBBILL 69KV CKT 1 |
| OKGE | CIMARRON - HAYMAKER 138KV CKT 1 |
| OKGE | CLEO CORNER - GLASS MOUNTAIN 138KV CKT 1 |
| OKGE | DIVISION AVE - HAYMAKER 138KV CKT 1 |
| OKGE | EL RENO - ROMAN NOSE 138KV CKT 1 |
| OKGE | IMO TAP - SOUTH 4TH ST 138KV CKT 1 |
| OKGE | ROMAN NOSE - SOUTHHARD 138KV CKT 1 |
| OKGE | SOONER (SOONER5) 345/138/13.8KV TRANSFORMER CKT 1 |
| OKGE/WFEC | DEWEY - TALOGA 138KV CKT 1 |
| OKGE/WFEC | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| OKGE/WFEC | KNOBBILL - MOORELAND 138KV CKT 1 |
| SPS | HITCHLAND7 345.00 (HITCHLN7) 345/230/13.2KV TRANSFORMER CKT 1 |
| SPS | 2005-02 115115.00 - RIVERVIEW INTERCHANGE 115KV CKT 1 |
| SPS | CARLISLE INTERCHANGE - DOUD SUB 115KV CKT 1 |
| SPS | DOUD SUB - SOUTH PLAINS REC-YUMA 115KV CKT 1 |
| SPS | GRAPEVINE INTERCHANGE 230/115KV TRANSFORMER CKT 1 |
| SPS | HALE CO INTERCHANGE - TUOCO INTERCHANGE 115KV CKT 1 |
| SPS | HANSFORD 3 115.00 - HITCHLAND3 115.00 115KV CKT 1 |
| SPS | HANSFORD 3 115.00 - SPEARMAN INTERCHANGE 115KV CKT 1 |
| SPS | HAPPY INTERCHANGE - PALO DURO SUB 115KV CKT 1 |
| SPS | HAPPY INTERCHANGE - TULIA TAP 115KV CKT 1 |
| SPS | HARRINGTON STATION - NICHOLS STATION 230KV CKT 1 |
| SPS | HARRNG_MID6 230.00 - NICHOLS STATION 230KV CKT 2 |
| SPS | HITCHLAND6 230.00 230/115KV TRANSFORMER CKT 1 |
| SPS | KIRBY SWITCHING STATION - MCCLELLAN SUB 115KV CKT 1 |
| SPS | KRESS INTERCHANGE - TULIA TAP 115KV CKT 1 |
| SPS | LUBBOCK POWER & LIGHT-HOLLY PLANT 230/69KV TRANSFORMER CKT 1 |
| SPS | LUBBOCK POWER & LIGHT-WADSWORTH 230/69KV TRANSFORMER CKT 1 |
| SPS | PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1 |
| SPS | RANDALL COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1 |
| SPS | SHERMAN COUNTY TAP 115/0.0KV TRANSFORMER CKT 1 |
| SPS | SOUTH PLAINS REC-YUMA - WOLFFORTH INTERCHANGE 115KV CKT 1 |
| SPS | SWISHER COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1 |
| SPS | TOLK STATION EAST - TUOCO INTERCHANGE 230KV CKT 1 |
| SPS | TUOCO INTERCHANGE (TUOCO XX4) 345/230/13.2KV TRANSFORMER CKT 1 |
| SPS/AEPW | MCCLELLAN SUB - MCLEAN RURAL SUB 115KV CKT 1 |
| SPS/AEPW | MCLEAN RURAL SUB - SHAMROCK 115KV CKT 1 |
| SUNC | BEELER - DIGHTON TAP 115KV CKT 1 |
| SUNC | BEELER - NESS CITY 115KV CKT 1 |
| SUNC | DIGHTON TAP - MANNING TAP 115KV CKT 1 |
| WEPL | HARPER - MEDICINE LODGE 138KV CKT 1 |
| WEPL | MEDICINE LODGE - SUN CITY 115KV CKT 1 |
| WEPL | MEDICINE LODGE (MED-LDG4) 138/115/2.72KV TRANSFORMER CKT 1 |
| WEPL | MULLERGREN - SPEARVILLE 230KV CKT 1 |
| WEPL | SEWARD - ST JOHN 115KV CKT 1 |

| AREA | OVERLOADED ELEMENT |
|-------------|---|
| WEPL/MIDW | MULLERGREN - S HAYS6 230.00 230KV CKT 1 |
| WEPL/MIDW | ST JOHN - ST_JOHN 115KV CKT 1 |
| WEPL/SUNC | SPEARVILLE (SPEARVL) 345/230/13.8KV TRANSFORMER CKT 1 |
| WERE | CIRCLE - RENO COUNTY 115KV CKT 2 |
| WERE | DAVIS - RENO COUNTY 115KV CKT 1 |
| WFEC | CARTER JCT - LAKE CREEK 69KV CKT 1 |
| WFEC | CEDARDALE - MOORELAND 138KV CKT 1 |
| WFEC | CEDARDALE - OKEENE 138KV CKT 1 |
| WFEC | DOVER SW - OKEENE 138KV CKT 1 |
| WFEC | FPL SWITCH - WOODWARD 138KV CKT 1 |
| WFEC | MOORELAND - TALOGA 138KV CKT 1 |
| WFEC | MOORELAND 138/69KV TRANSFORMER CKT 1 |
| WFEC | MOORLND 345.00 345/138KV TRANSFORMER CKT 1 |
| AEPW | American Electric Power West |
| MIDW | Midwest Energy |
| OKGE | Oklahoma Gas and Electric |
| SPS | Southwestern Public Service Company |
| SUNC | Sunflower Electric Power Corporation |
| WEPL | West Plains |
| WFEC | Western Farmers Electric Cooperative |

Table 4: Network Constraints (Including Texas Panhandle – Oklahoma City 345kV line)

| AREA | OVERLOADED ELEMENT |
|-----------|--|
| AEPW | ARSENAL HILL (ARSHILL1) 138/69/12.47KV TRANSFORMER CKT 1 |
| AEPW | ARSENAL HILL (ARSHILL2) 138/69/14.5KV TRANSFORMER CKT 2 |
| AEPW | CLINTON JUNCTION - ELK CITY 138KV CKT 1 |
| AEPW | ELDORADO - LAKE PAULINE 69KV CKT 1 |
| AEPW | ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1 |
| AEPW/SPS | ELK CITY 230KV - GRAPEVINE INTERCHANGE 230KV CKT 1 |
| OKGE | CLEO CORNER - GLASS MOUNTAIN 138KV CKT 1 |
| OKGE/WFEC | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| SPS | CONWAY SUB - YARNELL SUB 115KV CKT 1 |
| SPS | GRAPEVINE INTERCHANGE 230/115KV TRANSFORMER CKT 1 |
| SPS | HANSFORD 3 115.00 - HITCHLAND3 115.00 115KV CKT 1 |
| SPS | HANSFORD 3 115.00 - SPEARMAN INTERCHANGE 115KV CKT 1 |
| SPS | HAPPY INTERCHANGE - PALO DURO SUB 115KV CKT 1 |
| SPS | HAPPY INTERCHANGE - TULIA TAP 115KV CKT 1 |
| SPS | HITCHLAND6 230.00 230/115KV TRANSFORMER CKT 1 |
| SPS | KIRBY SWITCHING STATION - MCCLELLAN SUB 115KV CKT 1 |
| SPS | KRESS INTERCHANGE - TULIA TAP 115KV CKT 1 |
| SPS | MCCLELLAN SUB - MCLEAN RURAL SUB 115KV CKT 1 |
| SPS | NICHOLS STATION - YARNELL SUB 115KV CKT 1 |
| SPS | PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1 |
| SPS | RANDALL COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1 |
| SPS | TEXAS COUNTY INTERCHANGE 115/69KV TRANSFORMER CKT 1 |
| SPS/AEPW | MCLEAN RURAL SUB - SHAMROCK 115KV CKT 1 |
| SUNC | DIGHTON TAP - MANNING TAP 115KV CKT 1 |
| SUNC | HOLCOMB - PLYMELL 115KV CKT 1 |
| SUNC | PIONEER TAP - PLYMELL 115KV CKT 1 |
| WEPL | MULLERGREN - SPEARVILLE 230KV CKT 1 |
| WEPL | MEDICINE LODGE - SUN CITY 115KV CKT 1 |
| WEPL/MIDW | MULLERGREN - S HAYS6 230.00 230KV CKT 1 |
| WEPL/SUNC | SPEARVILLE (SPEARVL) 345/230/13.8KV TRANSFORMER CKT 1 |
| WFEC | CEDARDALE - MOORELAND 138KV CKT 1 |
| WFEC | DOVER SW - OKEENE 138KV CKT 1 |
| WFEC | MOORLND 345.00 345/138KV TRANSFORMER CKT 1 |
| WFEC/OKGE | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| AEPW | American Electric Power West |
| MIDW | Midwest Energy |
| OKGE | Oklahoma Gas and Electric |
| SPS | Southwestern Public Service Company |
| SUNC | Sunflower Electric Power Corporation |
| WEPL | West Plains |
| WFEC | Western Farmers Electric Cooperative |

Table 5: Contingency Analysis

| SEASON | OVERLOADED ELEMENT | RATING (MVA) | LOADING (%) | ATC (MW) | CONTINGENCY |
|--------|--|--------------|-------------|----------|---|
| 09WP | CLINTON JUNCTION - ELK CITY 138KV CKT 1 | 143 | 190 | 0 | CLINTON AIR FORCE BASE TAP - ELK CITY 138KV CKT 1 |
| 09WP | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 | 124 | 169 | 0 | CEDARDALE - MOORELAND 138KV CKT 1 |
| 09WP | ELK CITY 230KV - GRAPEVINE INTERCHANGE 230KV CKT 1 | 351 | 150 | 0 | CHILDRESS - LAKE PAULINE 138KV CKT 1 |
| 09WP | ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1 | 287 | 149 | 0 | CHILDRESS - LAKE PAULINE 138KV CKT 1 |
| 09WP | DOVER SW - OKEENE 138KV CKT 1 | 122 | 148 | 0 | CLEO CORNER - MEN TAP 138KV CKT 1 |
| 09WP | GRAPEVINE INTERCHANGE 230/115KV TRANSFORMER CKT 1 | 140 | 147 | 0 | CHILDRESS - LAKE PAULINE 138KV CKT 1 |
| 09WP | ALVA - KNOBHILL 69KV CKT 1 | 48 | 144 | 0 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| 09WP | MEDICINE LODGE - SUN CITY 115KV CKT 1 | 80 | 144 | 0 | GR ISLD3 345.00 - SWEET W3 345.00 345KV CKT 1 |
| 09WP | MOORLND 345.00 345/138KV TRANSFORMER CKT 1 | 448 | 142 | 0 | CHILDRESS - LAKE PAULINE 138KV CKT 1 |
| 09WP | MULLERGREN - S HAYS6 230.00 230KV CKT 1 | 147 | 142 | 0 | CIRCLE - MULLERGREN 230KV CKT 1 |
| 09WP | KIRBY SWITCHING STATION - MCCLELLAN SUB 115KV CKT 1 | 107 | 135 | 0 | JERICHO (JERIC2WT) 115/69/14.4KV TRANSFORMER CKT 1 |
| 09WP | MCCLELLAN SUB - MCLEAN RURAL SUB 115KV CKT 1 | 107 | 134 | 0 | JERICHO (JERIC2WT) 115/69/14.4KV TRANSFORMER CKT 1 |
| 09WP | KNOBHILL - MOORELAND 138KV CKT 1 | 96 | 131 | 0 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| 09WP | CLINTON AIR FORCE BASE TAP - ELK CITY 138KV CKT 1 | 192 | 126 | 0 | CLINTON JUNCTION - ELK CITY 138KV CKT 1 |
| 09WP | CLINTON AIR FORCE BASE TAP - HOBART JUNCTION 138KV CKT 1 | 192 | 125 | 0 | CLINTON JUNCTION - ELK CITY 138KV CKT 1 |
| 09WP | SPEARVILLE (SPEARVL) 345/230/13.8KV TRANSFORMER CKT 1 | 336 | 124 | 0 | HITCHLAND3 115.00 - TEXAS COUNTY INTERCHANGE 115KV CKT 1 |
| 09WP | HARPER - MEDICINE LODGE 138KV CKT 1 | 72 | 122 | 0 | CIRCLE - MULLERGREN 230KV CKT 1 |
| 09WP | ALTUS JCT TAP - RUSSELL 138KV CKT 1 | 72 | 114 | 0 | CLINTON AIR FORCE BASE TAP - HOBART JUNCTION 138KV CKT 1 |
| 09WP | CEDARDALE - MOORELAND 138KV CKT 1 | 170 | 114 | 0 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| 09WP | CEDARDALE - OKEENE 138KV CKT 1 | 170 | 112 | 0 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| 09WP | DIGHTON TAP - MANNING TAP 115KV CKT 1 | 98 | 112 | 0 | MINGO (MINGO) 345/115/13.8KV TRANSFORMER CKT 1 |
| 09WP | CLEO CORNER - GLASS MOUNTAIN 138KV CKT 1 | 185 | 112 | 0 | CEDARDALE - MOORELAND 138KV CKT 1 |
| 09WP | DEWEY - TALOGA 138KV CKT 1 | 143 | 112 | 0 | IODINE - WOODWARD 138KV CKT 1 |
| 09WP | MOORELAND - TALOGA 138KV CKT 1 | 154 | 112 | 0 | IODINE - WOODWARD 138KV CKT 1 |
| 09WP | ST JOHN - ST_JOHN 115KV CKT 1 | 88 | 110 | 0 | CIRCLE - MULLERGREN 230KV CKT 1 |
| 09WP | BEELER - DIGHTON TAP 115KV CKT 1 | 98 | 106 | 0 | MINGO (MINGO) 345/115/13.8KV TRANSFORMER CKT 1 |
| 09WP | HITCHLAND6 230.00 230/115KV TRANSFORMER CKT 1 | 252 | 111 | 56 | SHERMAN COUNTY TAP 115/0.0KV TRANSFORMER CKT 1 |
| 09WP | DIVISION AVE - HAYMAKER 138KV CKT 1 | 308 | 101 | 60 | CIMARRON - CZECH HALL 138KV CKT 1 |
| 09WP | TUCO INTERCHANGE (TUCO XX4) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 102 | 78 | HITCHLAND7 345.00 - G05-017 345.00 345KV CKT 1 |
| 09WP | MULLERGREN - SPEARVILLE 230KV CKT 1 | 471 | 102 | 80 | GREENSBURG - SUN CITY 115KV CKT 1 |
| 09WP | IMO TAP - SOUTH 4TH ST 138KV CKT 1 | 158 | 101 | 91 | GLENWOOD - IMO TAP 138KV CKT 1 |
| 09WP | CIRCLE - RENO COUNTY 115KV CKT 2 | 92 | 100 | 115 | CIRCLE - RENO COUNTY 115KV CKT 1 |
| 12SP | CLINTON JUNCTION - ELK CITY 138KV CKT 1 | 143 | 174 | 0 | CLINTON AIR FORCE BASE TAP - ELK CITY 138KV CKT 1 |
| 12SP | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 | 124 | 170 | 0 | CEDARDALE - MOORELAND 138KV CKT 1 |
| 12SP | KIRBY SWITCHING STATION - MCCLELLAN SUB 115KV CKT 1 | 90 | 161 | 0 | JERICHO (JERIC2WT) 115/69/14.4KV TRANSFORMER CKT 1 |
| 12SP | PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1 | 99 | 153 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 12SP | HAPPY INTERCHANGE - PALO DURO SUB 115KV CKT 1 | 99 | 152 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 12SP | MCLEAN RURAL SUB - SHAMROCK 115KV CKT 1 | 90 | 146 | 0 | CLARENDRON - CLARENDRON REC 69KV CKT 1 |
| 12SP | MULLERGREN - SPEARVILLE 230KV CKT 1 | 355 | 145 | 0 | GREENSBURG - JUDSON LARGE 115KV CKT 1 |

TABLE 5: Contingency Analysis (continued)

| SEASON | OVERLOADED ELEMENT | RATING (MVA) | LOADING (%) | ATC (MW) | CONTINGENCY |
|--------|--|--------------|-------------|----------|---|
| 12SP | ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1 | 287 | 141 | 0 | KIRBY SWITCHING STATION - MCCLELLAN SUB 115KV CKT 1 |
| 12SP | DOVER SW - OKEENE 138KV CKT 1 | 122 | 140 | 0 | CLEO CORNER - MEN TAP 138KV CKT 1 |
| 12SP | KNOBHILL - MOORELAND 138KV CKT 1 | 96 | 140 | 0 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| 12SP | ELK CITY 230KV - GRAPEVINE INTERCHANGE 230KV CKT 1 | 351 | 139 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 12SP | GRAPEVINE INTERCHANGE 230/115KV TRANSFORMER CKT 1 | 129 | 138 | 0 | KIRBY SWITCHING STATION - MCCLELLAN SUB 115KV CKT 1 |
| 12SP | MEDICINE LODGE - SUN CITY 115KV CKT 1 | 80 | 137 | 0 | SEWARD - ST JOHN 115KV CKT 1 |
| 12SP | CLEO CORNER - GLASS MOUNTAIN 138KV CKT 1 | 153 | 135 | 0 | CEDARDALE - MOORELAND 138KV CKT 1 |
| 12SP | HAPPY INTERCHANGE - TULIA TAP 115KV CKT 1 | 99 | 134 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 12SP | CLINTON AIR FORCE BASE TAP - ELK CITY 138KV CKT 1 | 170 | 131 | 0 | CLINTON JUNCTION - ELK CITY 138KV CKT 1 |
| 12SP | MOORLND 345.00 345/138KV TRANSFORMER CKT 1 | 448 | 130 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 12SP | FPL SWITCH - WOODWARD 138KV CKT 1 | 153 | 130 | 0 | MOORELAND - TALOGA 138KV CKT 1 |
| 12SP | MULLERGREN - S HAYS6 230.00 230KV CKT 1 | 147 | 129 | 0 | COLBY - MINGO 115KV CKT 1 |
| 12SP | KRESS INTERCHANGE - TULIA TAP 115KV CKT 1 | 99 | 129 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 12SP | CLINTON AIR FORCE BASE TAP - HOBART JUNCTION 138KV CKT 1 | 170 | 129 | 0 | CLINTON JUNCTION - ELK CITY 138KV CKT 1 |
| 12SP | ST JOHN - ST_JOHN 115KV CKT 1 | 88 | 121 | 0 | CIRCLE - HUTCHINSON ENERGY CENTER 115KV CKT 1 |
| 12SP | MOORELAND - TALOGA 138KV CKT 1 | 154 | 117 | 0 | FPL SWITCH - WOODWARD 138KV CKT 1 |
| 12SP | CEDARDALE - MOORELAND 138KV CKT 1 | 170 | 116 | 0 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| 12SP | CEDARDALE - OKEENE 138KV CKT 1 | 170 | 113 | 0 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| 12SP | RANDALL COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1 | 259 | 112 | 0 | AMARILLO SOUTH INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| 12SP | DAVIS - RENO COUNTY 115KV CKT 1 | 194 | 111 | 0 | CIRCLE - HUTCHINSON ENERGY CENTER 115KV CKT 1 |
| 12SP | HALE CO INTERCHANGE - TUO INTERCHANGE 115KV CKT 1 | 99 | 111 | 0 | SWISHER COUNTY INTERCHANGE - TUO INTERCHANGE 230KV CKT 1 |
| 12SP | HARRINGTON STATION - NICHOLS STATION 230KV CKT 1 | 635 | 111 | 0 | HARRNG_MID6 230.00 - NICHOLS STATION 230KV CKT 2 |
| 12SP | ROMAN NOSE - SOUTHHARD 138KV CKT 1 | 153 | 111 | 0 | CLEO CORNER - MEN TAP 138KV CKT 1 |
| 12SP | DEWEY - TALOGA 138KV CKT 1 | 143 | 111 | 0 | IODINE - WOODWARD 138KV CKT 1 |
| 12SP | HARRNG_MID6 230.00 - NICHOLS STATION 230KV CKT 2 | 635 | 110 | 0 | HARRINGTON STATION - NICHOLS STATION 230KV CKT 1 |
| 12SP | MEDICINE LODGE (MED-LDG4) 138/115/2.72KV TRANSFORMER CKT 1 | 65 | 109 | 0 | MEDICINE LODGE - PRATT 115KV CKT 1 |
| 12SP | DIGHTON TAP - MANNING TAP 115KV CKT 1 | 98 | 109 | 0 | MINGO - PHEASANT RUN 115KV CKT 1 |
| 12SP | DOUD SUB - SOUTH PLAINS REC-YUMA 115KV CKT 1 | 161 | 109 | 0 | TOLK STATION EAST - TUO INTERCHANGE 230KV CKT 1 |
| 12SP | SWISHER COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1 | 150 | 108 | 0 | SWISHER COUNTY INTERCHANGE - TUO INTERCHANGE 230KV CKT 1 |
| 12SP | SOONER (SOONER5) 345/138/13.8KV TRANSFORMER CKT 1 | 448 | 107 | 0 | GEN514805 1 |
| 12SP | COLBY - HOXIE 115KV CKT 1 | 101 | 105 | 0 | MULLERGREN - S HAYS6 230.00 230KV CKT 1 |
| 12SP | CIMARRON - HAYMAKER 138KV CKT 1 | 308 | 104 | 0 | CIMARRON - CZECH HALL 138KV CKT 1 |
| 12SP | ALTUS JCT TAP - RUSSELL 138KV CKT 1 | 72 | 108 | 10 | ANADARKO - PARADISE 138KV CKT 1 |
| 12SP | 2005-02 115115.00 - RIVERVIEW INTERCHANGE 115KV CKT 1 | 161 | 109 | 11 | 2007-33T 230.00 - HARRNG_EST6 230.00 230KV CKT 1 |
| 12SP | EL RENO - ROMAN NOSE 138KV CKT 1 | 153 | 104 | 50 | CLEO CORNER - MEN TAP 138KV CKT 1 |
| 12SP | DIVISION AVE - HAYMAKER 138KV CKT 1 | 308 | 101 | 78 | CIMARRON - CZECH HALL 138KV CKT 1 |
| 12SP | HARPER - MEDICINE LODGE 138KV CKT 1 | 72 | 103 | 79 | MEDICINE LODGE - PRATT 115KV CKT 1 |
| 12SP | HANSFORD 3 115.00 - HITCHLAND3 115.00 115KV CKT 1 | 180 | 108 | 103 | HANSFORD 3 115.00 - SPEARMAN INTERCHANGE 115KV CKT 1 |
| 12SP | HITCHLAND6 230.00 230/115KV TRANSFORMER CKT 1 | 252 | 102 | 109 | SHERMAN COUNTY TAP 115/0.0KV TRANSFORMER CKT 1 |

TABLE 5: Contingency Analysis (continued)

| SEASON | OVERLOADED ELEMENT | RATING (MVA) | LOADING (%) | ATC (MW) | CONTINGENCY |
|--------|--|--------------|-------------|----------|---|
| 12SP | TOLK STATION EAST - TUO INTERCHANGE 230KV CKT 1 | 497 | 100 | 111 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 12SP | SOUTH PLAINS REC-YUMA - WOLFFORTH INTERCHANGE 115KV CKT 1 | 197 | 100 | 115 | TOLK STATION EAST - TUO INTERCHANGE 230KV CKT 1 |
| 12SP | BEELER - DIGHTON TAP 115KV CKT 1 | 98 | 100 | 118 | MINGO - PHEASANT RUN 115KV CKT 1 |
| 12WP | CLINTON JUNCTION - ELK CITY 138KV CKT 1 | 143 | 197 | 0 | CLINTON AIR FORCE BASE TAP - ELK CITY 138KV CKT 1 |
| 12WP | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 | 124 | 165 | 0 | CEDARDALE - MOORELAND 138KV CKT 1 |
| 12WP | ELK CITY 230KV - GRAPEVINE INTERCHANGE 230KV CKT 1 | 319 | 158 | 0 | BASE CASE |
| 12WP | MULLERGREN - S HAYS6 230.00 230KV CKT 1 | 147 | 151 | 0 | CIRCLE - MULLERGREN 230KV CKT 1 |
| 12WP | ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1 | 287 | 147 | 0 | GREENSBURG - JUDSON LARGE 115KV CKT 1 |
| 12WP | ALVA - KNOBHILL 69KV CKT 1 | 48 | 145 | 0 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| 12WP | GRAPEVINE INTERCHANGE 230/115KV TRANSFORMER CKT 1 | 140 | 143 | 0 | KIRBY SWITCHING STATION - MCCLELLAN SUB 115KV CKT 1 |
| 12WP | DOVER SW - OKEENE 138KV CKT 1 | 122 | 142 | 0 | CLEO CORNER - MEN TAP 138KV CKT 1 |
| 12WP | MOORLND 345.00 345/138KV TRANSFORMER CKT 1 | 448 | 141 | 0 | GEN520997 1 |
| 12WP | CLINTON AIR FORCE BASE TAP - ELK CITY 138KV CKT 1 | 192 | 134 | 0 | CLINTON JUNCTION - ELK CITY 138KV CKT 1 |
| 12WP | SPEARVILLE (SPEARVL) 345/230/13.8KV TRANSFORMER CKT 1 | 336 | 133 | 0 | GEN539670 4 |
| 12WP | CLINTON AIR FORCE BASE TAP - HOBART JUNCTION 138KV CKT 1 | 192 | 133 | 0 | CLINTON JUNCTION - ELK CITY 138KV CKT 1 |
| 12WP | MEDICINE LODGE - SUN CITY 115KV CKT 1 | 80 | 131 | 0 | SEWARD - ST JOHN 115KV CKT 1 |
| 12WP | MCLEAN RURAL SUB - SHAMROCK 115KV CKT 1 | 107 | 130 | 0 | CLARENDR REC - HEDLEY 69KV CKT 1 |
| 12WP | KNOBHILL - MOORELAND 138KV CKT 1 | 96 | 130 | 0 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| 12WP | PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1 | 118 | 129 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 12WP | HAPPY INTERCHANGE - PALO DURO SUB 115KV CKT 1 | 118 | 129 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 12WP | SEWARD - ST JOHN 115KV CKT 1 | 80 | 125 | 0 | CIRCLE - MULLERGREN 230KV CKT 1 |
| 12WP | HALE CO INTERCHANGE - TUO INTERCHANGE 115KV CKT 1 | 118 | 122 | 0 | SWISHER COUNTY INTERCHANGE - TUO INTERCHANGE 230KV CKT 1 |
| 12WP | HAPPY INTERCHANGE - TULIA TAP 115KV CKT 1 | 118 | 122 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 12WP | ALTUS JCT TAP - RUSSELL 138KV CKT 1 | 72 | 121 | 0 | CLINTON AIR FORCE BASE TAP - ELK CITY 138KV CKT 1 |
| 12WP | KRESS INTERCHANGE - TULIA TAP 115KV CKT 1 | 118 | 119 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 12WP | MEDICINE LODGE (MED-LDG4) 138/115/2.72KV TRANSFORMER CKT 1 | 65 | 114 | 0 | MEDICINE LODGE - PRATT 115KV CKT 1 |
| 12WP | CEDARDALE - MOORELAND 138KV CKT 1 | 170 | 112 | 0 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| 12WP | MOORELAND - TALOGA 138KV CKT 1 | 154 | 112 | 0 | IODINE - WOODWARD 138KV CKT 1 |
| 12WP | DIGHTON TAP - MANNING TAP 115KV CKT 1 | 98 | 112 | 0 | MINGO (MINGO) 345/115/13.8KV TRANSFORMER CKT 1 |
| 12WP | DEWEY - TALOGA 138KV CKT 1 | 143 | 111 | 0 | IODINE - WOODWARD 138KV CKT 1 |
| 12WP | CEDARDALE - OKEENE 138KV CKT 1 | 170 | 111 | 0 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| 12WP | CLEO CORNER - GLASS MOUNTAIN 138KV CKT 1 | 185 | 109 | 0 | CEDARDALE - MOORELAND 138KV CKT 1 |
| 12WP | HARPER - MEDICINE LODGE 138KV CKT 1 | 72 | 109 | 5 | CIRCLE - MULLERGREN 230KV CKT 1 |
| 12WP | BEELER - DIGHTON TAP 115KV CKT 1 | 98 | 105 | 5 | MINGO (MINGO) 345/115/13.8KV TRANSFORMER CKT 1 |
| 12WP | CARTER JCT - LAKE CREEK 69KV CKT 1 | 61 | 104 | 54 | CLINTON AIR FORCE BASE TAP - ELK CITY 138KV CKT 1 |
| 12WP | CARNEGIE - HOBART JUNCTION 138KV CKT 1 | 143 | 103 | 68 | CLINTON JUNCTION - ELK CITY 138KV CKT 1 |
| 12WP | HITCHLAND6 230.00 230/115KV TRANSFORMER CKT 1 | 252 | 106 | 82 | SHERMAN COUNTY TAP 115/0.0KV TRANSFORMER CKT 1 |

TABLE 5: Contingency Analysis (continued)

| SEASON | OVERLOADED ELEMENT | RATING (MVA) | LOADING (%) | ATC (MW) | CONTINGENCY |
|--------|--|--------------|-------------|----------|---|
| 12WP | MULLERGREN - SPEARVILLE 230KV CKT 1 | 471 | 102 | 83 | GREENSBURG - JUDSON LARGE 115KV CKT 1 |
| 12WP | ST JOHN - ST_JOHN 115KV CKT 1 | 88 | 102 | 84 | CIRCLE - MULLERGREN 230KV CKT 1 |
| 12WP | BEELER - NESS CITY 115KV CKT 1 | 98 | 101 | 89 | MINGO (MINGO) 345/115/13.8KV TRANSFORMER CKT 1 |
| | | | | | |
| 17SP | LUBBOCK POWER & LIGHT-HOLLY PLANT 230/69KV TRANSFORMER CKT 1 | 100 | 177 | 0 | LUBBOCK POWER & LIGHT-SOUTHEAST 230/69KV TRANSFORMER CKT 1 |
| 17SP | CLINTON JUNCTION - ELK CITY 138KV CKT 1 | 143 | 166 | 0 | CLINTON AIR FORCE BASE TAP - ELK CITY 138KV CKT 1 |
| 17SP | LUBBOCK POWER & LIGHT-WADSWORTH 230/69KV TRANSFORMER CKT 1 | 100 | 162 | 0 | LUBBOCK POWER & LIGHT-SOUTHEAST 230/69KV TRANSFORMER CKT 1 |
| 17SP | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 | 124 | 159 | 0 | CEDARDALE - MOORELAND 138KV CKT 1 |
| 17SP | PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1 | 99 | 154 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 17SP | HAPPY INTERCHANGE - PALO DURO SUB 115KV CKT 1 | 99 | 152 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 17SP | MCLEAN RURAL SUB - SHAMROCK 115KV CKT 1 | 90 | 144 | 0 | CLARENDRON - CLARENDRON REC 69KV CKT 1 |
| 17SP | MULLERGREN - S HAYS6 230.00 230KV CKT 1 | 147 | 144 | 0 | CIRCLE - MULLERGREN 230KV CKT 1 |
| 17SP | ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1 | 287 | 137 | 0 | KIRBY SWITCHING STATION - MCCLELLAN SUB 115KV CKT 1 |
| 17SP | ELK CITY 230KV - GRAPEVINE INTERCHANGE 230KV CKT 1 | 351 | 135 | 0 | KIRBY SWITCHING STATION - MCCLELLAN SUB 115KV CKT 1 |
| 17SP | MOORELAND 138/69KV TRANSFORMER CKT 1 | 65 | 135 | 0 | FPL SWITCH - WOODWARD 138KV CKT 1 |
| 17SP | HAPPY INTERCHANGE - TULIA TAP 115KV CKT 1 | 99 | 135 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 17SP | KNOBBILL - MOORELAND 138KV CKT 1 | 96 | 133 | 0 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| 17SP | MOORLND 345.00 345/138KV TRANSFORMER CKT 1 | 448 | 130 | 0 | GEN520997 1 |
| 17SP | KRESS INTERCHANGE - TULIA TAP 115KV CKT 1 | 99 | 129 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 17SP | DOVER SW - OKEENE 138KV CKT 1 | 122 | 128 | 0 | CLEO CORNER - MEN TAP 138KV CKT 1 |
| 17SP | MULLERGREN - SPEARVILLE 230KV CKT 1 | 355 | 127 | 0 | GREENSBURG - JUDSON LARGE 115KV CKT 1 |
| 17SP | SPEARVILLE (SPEARVL) 345/230/13.8KV TRANSFORMER CKT 1 | 336 | 126 | 0 | CIMARRON RIVER PLANT - NORTH CIMARRON 115KV CKT 1 |
| 17SP | CLEO CORNER - GLASS MOUNTAIN 138KV CKT 1 | 153 | 126 | 0 | CEDARDALE - MOORELAND 138KV CKT 1 |
| 17SP | CLINTON AIR FORCE BASE TAP - ELK CITY 138KV CKT 1 | 170 | 125 | 0 | CLINTON JUNCTION - ELK CITY 138KV CKT 1 |
| 17SP | FPL SWITCH - WOODWARD 138KV CKT 1 | 153 | 123 | 0 | MOORELAND - TALOGA 138KV CKT 1 |
| 17SP | CLINTON AIR FORCE BASE TAP - HOBART JUNCTION 138KV CKT 1 | 170 | 123 | 0 | CLINTON JUNCTION - ELK CITY 138KV CKT 1 |
| 17SP | DOUD SUB - SOUTH PLAINS REC-YUMA 115KV CKT 1 | 161 | 123 | 0 | LUBBOCK SOUTH INTERCHANGE - WOLFFORTH INTERCHANGE 230KV CKT 1 |
| 17SP | DAVIS - RENO COUNTY 115KV CKT 1 | 194 | 119 | 0 | CIRCLE - HUTCHINSON ENERGY CENTER 115KV CKT 1 |
| 17SP | RANDALL COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1 | 259 | 117 | 0 | AMARILLO SOUTH INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| 17SP | SOUTH PLAINS REC-YUMA - WOLFFORTH INTERCHANGE 115KV CKT 1 | 197 | 113 | 0 | LUBBOCK SOUTH INTERCHANGE - WOLFFORTH INTERCHANGE 230KV CKT 1 |
| 17SP | MOORELAND - TALOGA 138KV CKT 1 | 154 | 112 | 0 | FPL SWITCH - WOODWARD 138KV CKT 1 |
| 17SP | DIGHTON TAP - MANNING TAP 115KV CKT 1 | 98 | 111 | 0 | MINGO (MINGO) 345/115/13.8KV TRANSFORMER CKT 1 |
| 17SP | CEDARDALE - MOORELAND 138KV CKT 1 | 170 | 109 | 0 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| 17SP | HALE CO INTERCHANGE - TUO INTERCHANGE 115KV CKT 1 | 99 | 109 | 0 | SWISHER COUNTY INTERCHANGE - TUO INTERCHANGE 230KV CKT 1 |
| 17SP | CEDARDALE - OKEENE 138KV CKT 1 | 170 | 107 | 0 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| 17SP | CIMARRON - HAYMAKER 138KV CKT 1 | 308 | 106 | 0 | CIMARRON - CZECH HALL 138KV CKT 1 |
| 17SP | DEWEY - TALOGA 138KV CKT 1 | 143 | 106 | 0 | IODINE - WOODWARD 138KV CKT 1 |

TABLE 5: Contingency Analysis (continued)

| SEASON | OVERLOADED ELEMENT | RATING (MVA) | LOADING (%) | ATC (MW) | CONTINGENCY |
|--------|--|--------------|-------------|----------|---|
| 17SP | SHERMAN COUNTY TAP 115/0.0KV TRANSFORMER CKT 1 | 161 | 105 | 1 | MOORE COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1 |
| 17SP | ALTUS JCT TAP - RUSSELL 138KV CKT 1 | 72 | 110 | 4 | ANADARKO - PARADISE 138KV CKT 1 |
| 17SP | DIVISION AVE - HAYMAKER 138KV CKT 1 | 308 | 102 | 18 | CIMARRON - CZECH HALL 138KV CKT 1 |
| 17SP | TOLK STATION EAST - TUCO INTERCHANGE 230KV CKT 1 | 497 | 103 | 34 | SUNDOWN INTERCHANGE - WOLFFORTH INTERCHANGE 230KV CKT 1 |
| 17SP | CARLISLE INTERCHANGE - DOUD SUB 115KV CKT 1 | 161 | 102 | 56 | LUBBOCK SOUTH INTERCHANGE - WOLFFORTH INTERCHANGE 230KV CKT 1 |
| 17SP | 2005-02 115115.00 - RIVERVIEW INTERCHANGE 115KV CKT 1 | 161 | 104 | 64 | 2007-33T 230.00 - HARRNG_EST6 230.00 230KV CKT 1 |
| 17SP | ROMAN NOSE - SOUTHHARD 138KV CKT 1 | 153 | 102 | 70 | CLEO CORNER - MEN TAP 138KV CKT 1 |
| 17SP | ARSENAL HILL (ARSHILL2) 138/69/14.5KV TRANSFORMER CKT 2 | 220 | 101 | 88 | ARSENAL HILL (ARSHILL1) 138/69/12.47KV TRANSFORMER CKT 1 |
| 17SP | BEELER - DIGHTON TAP 115KV CKT 1 | 98 | 101 | 90 | MINGO (MINGO) 345/115/13.8KV TRANSFORMER CKT 1 |
| 17SP | ARSENAL HILL (ARSHILL1) 138/69/12.47KV TRANSFORMER CKT 1 | 220 | 101 | 93 | ARSENAL HILL (ARSHILL2) 138/69/14.5KV TRANSFORMER CKT 2 |
| 17SP | HANSFORD 3 115.00 - HITCHLAND3 115.00 115KV CKT 1 | 180 | 108 | 103 | HANSFORD 3 115.00 - SPEARMAN INTERCHANGE 115KV CKT 1 |
| 17SP | HANSFORD 3 115.00 - SPEARMAN INTERCHANGE 115KV CKT 1 | 180 | 101 | 117 | HANSFORD 3 115.00 - HITCHLAND3 115.00 115KV CKT 1 |
| | | | | | |

Note: When transmission service associated with this interconnection is evaluated, the loading of the facilities listed in this Table may be greater due to higher priority reservations. If the loading of a facility is higher, the level of ATC will be lower.

Table 6: Contingency Analysis (Including Texas Panhandle – Oklahoma City 345kV line)

| SEASON | OVERLOADED ELEMENT | RATING (MVA) | LOADING (%) | ATC (MW) | CONTINGENCY |
|---------------|--|---------------|----------------|------------|--|
| 09WP | ELDORADO - LAKE PAULINE 69KV CKT 1 | 20 | 255 | 0 | LAKE PAULINE - RUSSELL 138KV CKT 1 |
| 09WP | CLINTON JUNCTION - ELK CITY 138KV CKT 1 | 143 | 142 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 09WP | ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1 | 287 | 128 | 0 | CHILDRESS - LAKE PAULINE 138KV CKT 1 |
| 09WP | MEDICINE LODGE - SUN CITY 115KV CKT 1 | 80 | 125 | 0 | MULLERGREN - SPEARVILLE 230KV CKT 1 |
| 09WP | ELK CITY 230KV - GRAPEVINE INTERCHANGE 230KV CKT 1 | 351 | 123 | 0 | CHILDRESS - LAKE PAULINE 138KV CKT 1 |
| 09WP | MOORLND 345.00 - NORTHWEST 345KV CKT 1 | 1052 | 109 | 0 | MOORLND 345.00 345/138KV TRANSFORMER CKT 1 |
| 09WP | SPEARVILLE (SPEARVL) 345/230/13.8KV TRANSFORMER CKT 1 | 336 | 104 | 0 | GEN532751 1 |
| 09WP | TEXAS COUNTY INTERCHANGE 115/69KV TRANSFORMER CKT 1 | 84 | 146 | 32 | HITCHLAND3 115.00 - TEXAS COUNTY INTERCHANGE 115KV CKT 1 |
| 09WP | HITCHLAND6 230.00 230/115KV TRANSFORMER CKT 1 | 252 | 110 | 48 | SHERMAN COUNTY TAP 115/0.0KV TRANSFORMER CKT 1 |
| 09WP | MOORLND 345.00 345/138KV TRANSFORMER CKT 1 | 448 | 150 | 115 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| | | | | | |
| 12SP | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 | 124 | 152 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 12SP | MOORLND 345.00 345/138KV TRANSFORMER CKT 1 | 448 | 137 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 12SP | CLINTON JUNCTION - ELK CITY 138KV CKT 1 | 143 | 129 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 12SP | CONWAY SUB - YARNELL SUB 115KV CKT 1 | 180 | 127 | 0 | CONWAY SUB - KIRBY SWITCHING STATION 115KV CKT 1 |
| 12SP | NICHOLS STATION - YARNELL SUB 115KV CKT 1 | 180 | 126 | 0 | CONWAY SUB - KIRBY SWITCHING STATION 115KV CKT 1 |
| 12SP | SPEARVILLE (SPEARVL) 345/230/13.8KV TRANSFORMER CKT 1 | 336 | 126 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 12SP | ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1 | 287 | 125 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| SEASON | OVERLOADED ELEMENT | RATING | LOADING | ATC | CONTINGENCY |

TABLE 5: Contingency Analysis (continued)

| | | (MVA) | (%) | (MW) | |
|---------------|--|---------------|----------------|------------|---|
| 12SP | CLEO CORNER - GLASS MOUNTAIN 138KV CKT 1 | 153 | 121 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 12SP | MULLERGREN - SPEARVILLE 230KV CKT 1 | 355 | 120 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 12SP | ELK CITY 230KV - GRAPEVINE INTERCHANGE 230KV CKT 1 | 351 | 119 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 12SP | MEDICINE LODGE - SUN CITY 115KV CKT 1 | 80 | 115 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 12SP | DOVER SW - OKEENE 138KV CKT 1 | 122 | 114 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 12SP | MULLERGREN - S HAYS6 230.00 230KV CKT 1 | 147 | 106 | 0 | CIRCLE - MULLERGREN 230KV CKT 1 |
| 12SP | RANDALL COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1 | 259 | 102 | 9 | AMARILLO SOUTH INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| 12SP | HITCHLAND6 230.00 230/115KV TRANSFORMER CKT 1 | 252 | 106 | 84 | SHERMAN COUNTY TAP 115/0.0KV TRANSFORMER CKT 1 |
| 12SP | HANSFORD 3 115.00 - HITCHLAND3 115.00 115KV CKT 1 | 180 | 108 | 99 | HANSFORD 3 115.00 - SPEARMAN INTERCHANGE 115KV CKT 1 |
| 12SP | CEDARDALE - MOORELAND 138KV CKT 1 | 170 | 100 | 111 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 12SP | HANSFORD 3 115.00 - SPEARMAN INTERCHANGE 115KV CKT 1 | 180 | 102 | 116 | HANSFORD 3 115.00 - HITCHLAND3 115.00 115KV CKT 1 |
| 12WP | GRAPEVINE INTERCHANGE 230/115KV TRANSFORMER CKT 1 | 140 | 138 | 0 | CHILDRESS - LAKE PAULINE 138KV CKT 1 |
| 12WP | ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1 | 287 | 135 | 0 | CHILDRESS - LAKE PAULINE 138KV CKT 1 |
| 12WP | ELK CITY 230KV - GRAPEVINE INTERCHANGE 230KV CKT 1 | 319 | 132 | 0 | BASE CASE |
| 12WP | CLINTON JUNCTION - ELK CITY 138KV CKT 1 | 143 | 132 | 0 | CLINTON AIR FORCE BASE TAP - ELK CITY 138KV CKT 1 |
| 12WP | KIRBY SWITCHING STATION - MCCLELLAN SUB 115KV CKT 1 | 107 | 125 | 0 | JERICHO (JERIC2WT) 115/69/14.4KV TRANSFORMER CKT 1 |
| 12WP | MCCLELLAN SUB - MCLEAN RURAL SUB 115KV CKT 1 | 107 | 124 | 0 | JERICHO (JERIC2WT) 115/69/14.4KV TRANSFORMER CKT 1 |
| 12WP | MEDICINE LODGE - SUN CITY 115KV CKT 1 | 80 | 118 | 0 | MULLERGREN - SPEARVILLE 230KV CKT 1 |
| 12WP | MCLEAN RURAL SUB - SHAMROCK 115KV CKT 1 | 107 | 117 | 0 | JERICHO (JERIC2WT) 115/69/14.4KV TRANSFORMER CKT 1 |
| 12WP | MOORLND 345.00 - NORTHWEST 345KV CKT 1 | 1052 | 110 | 0 | MOORLND 345.00 345/138KV TRANSFORMER CKT 1 |
| 12WP | PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1 | 118 | 110 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 12WP | HAPPY INTERCHANGE - PALO DURO SUB 115KV CKT 1 | 118 | 109 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 12WP | CONWAY SUB - YARNELL SUB 115KV CKT 1 | 218 | 108 | 0 | GRAPEVINE INTERCHANGE 230/115KV TRANSFORMER CKT 1 |
| 12WP | NICHOLS STATION - YARNELL SUB 115KV CKT 1 | 218 | 108 | 0 | GRAPEVINE INTERCHANGE 230/115KV TRANSFORMER CKT 1 |
| 12WP | SPEARVILLE (SPEARVL) 345/230/13.8KV TRANSFORMER CKT 1 | 336 | 103 | 0 | GEN539670 4 |
| 12WP | HAPPY INTERCHANGE - TULIA TAP 115KV CKT 1 | 118 | 103 | 61 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 12WP | HITCHLAND6 230.00 230/115KV TRANSFORMER CKT 1 | 252 | 105 | 84 | SHERMAN COUNTY TAP 115/0.0KV TRANSFORMER CKT 1 |
| 17SP | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 | 124 | 142 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 17SP | CONWAY SUB - YARNELL SUB 115KV CKT 1 | 180 | 137 | 0 | GRAPEVINE INTERCHANGE - KIRBY SWITCHING STATION 115KV CKT 1 |
| 17SP | NICHOLS STATION - YARNELL SUB 115KV CKT 1 | 180 | 137 | 0 | GRAPEVINE INTERCHANGE - KIRBY SWITCHING STATION 115KV CKT 1 |
| 17SP | PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1 | 99 | 132 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 17SP | MOORLND 345.00 345/138KV TRANSFORMER CKT 1 | 448 | 131 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 17SP | HAPPY INTERCHANGE - PALO DURO SUB 115KV CKT 1 | 99 | 130 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 17SP | CLINTON JUNCTION - ELK CITY 138KV CKT 1 | 143 | 125 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 17SP | HOLCOMB - PLYMELL 115KV CKT 1 | 143 | 125 | 0 | FLETCHER - HOLCOMB 115KV CKT 1 |
| 17SP | ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1 | 287 | 123 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 17SP | PIONEER TAP - PLYMELL 115KV CKT 1 | 143 | 121 | 0 | FLETCHER - HOLCOMB 115KV CKT 1 |
| SEASON | OVERLOADED ELEMENT | RATING | LOADING | ATC | CONTINGENCY |

TABLE 5: Contingency Analysis (continued)

| | | (MVA) | (%) | (MW) | |
|------|--|-------|-----|------|---|
| 17SP | ELK CITY 230KV - GRAPEVINE INTERCHANGE 230KV CKT 1 | 351 | 118 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 17SP | SPEARVILLE (SPEARVL) 345/230/13.8KV TRANSFORMER CKT 1 | 336 | 117 | 0 | HOLCOMB - SETAB 345KV CKT 1 |
| 17SP | HAPPY INTERCHANGE - TULIA TAP 115KV CKT 1 | 99 | 113 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 17SP | CLEO CORNER - GLASS MOUNTAIN 138KV CKT 1 | 153 | 112 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 17SP | RANDALL COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1 | 259 | 110 | 0 | AMARILLO SOUTH INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| 17SP | KRESS INTERCHANGE - TULIA TAP 115KV CKT 1 | 99 | 108 | 0 | AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY INTERCHANGE 230KV CKT 1 |
| 17SP | MULLERGREN - SPEARVILLE 230KV CKT 1 | 355 | 107 | 0 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 17SP | MULLERGREN - S HAYS6 230.00 230KV CKT 1 | 147 | 106 | 0 | MINGO - SETAB 345KV CKT 1 |
| 17SP | DOVER SW - OKEENE 138KV CKT 1 | 122 | 104 | 27 | MOORLND 345.00 - NORTHWEST 345KV CKT 1 |
| 17SP | DIGHTON TAP - MANNING TAP 115KV CKT 1 | 98 | 103 | 50 | MINGO - SETAB 345KV CKT 1 |
| 17SP | ARSENAL HILL (ARSHILL2) 138/69/14.5KV TRANSFORMER CKT 2 | 220 | 101 | 89 | ARSENAL HILL (ARSHILL1) 138/69/12.47KV TRANSFORMER CKT 1 |
| 17SP | ARSENAL HILL (ARSHILL1) 138/69/12.47KV TRANSFORMER CKT 1 | 220 | 101 | 93 | ARSENAL HILL (ARSHILL2) 138/69/14.5KV TRANSFORMER CKT 2 |
| 17SP | HANSFORD 3 115.00 - HITCHLAND3 115.00 115KV CKT 1 | 180 | 108 | 98 | HANSFORD 3 115.00 - SPEARMAN INTERCHANGE 115KV CKT 1 |
| 17SP | HITCHLAND6 230.00 230/115KV TRANSFORMER CKT 1 | 252 | 103 | 105 | SHERMAN COUNTY TAP 115/0.0KV TRANSFORMER CKT 1 |
| 17SP | HANSFORD 3 115.00 - SPEARMAN INTERCHANGE 115KV CKT 1 | 180 | 102 | 116 | HANSFORD 3 115.00 - HITCHLAND3 115.00 115KV CKT 1 |
| 17SP | TEXAS COUNTY INTERCHANGE 115/69KV TRANSFORMER CKT 1 | 84 | 101 | 116 | HITCHLAND3 115.00 - TEXAS COUNTY INTERCHANGE 115KV CKT 1 |

Note: When transmission service associated with this interconnection is evaluated, the loading of the facilities listed in this Table may be greater due to higher priority reservations. If the loading of a facility is higher, the level of ATC will be lower.

Conclusion

The minimum cost of interconnecting the Customer's interconnection request is estimated at \$800,000 for Direct Assignment Facilities and Network Upgrades. At this time, the cost estimates for other Direct Assignment facilities including those in Tables 1 and 2 have not been defined by the Customer. In addition to the Customer's proposed interconnection facilities, the Customer may be responsible for installing reactive compensation in the Customer's substation for reactive support. As stated earlier, some but not all of the local projects that were previously queued are assumed to be in service in this Feasibility Study. These costs exclude upgrades of other transmission facilities that were listed in Table 3 of which are Network Constraints.

In Table 4, a value of Available Transfer Capability (ATC) associated with each overloaded facility is included. These values may be used by the Customer to determine lower generation capacity levels that may be installed. When transmission service associated with this interconnection is evaluated, the loading of the facilities listed in this table may be greater due to higher priority reservations. When a facility is overloaded for more than one contingency, only the highest loading on the facility for each season is included in the table.

These interconnection costs do not include any cost that may be associated with short circuit or transient stability analysis. These studies will be performed if the Customer signs a System Impact Study Agreement. At the time of the System Impact Study, a better determination of the interconnection facilities may be available.

The required interconnection costs listed in Tables 1 and 2 and other upgrades associated with Network Constraints do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request through Southwest Power Pool's OASIS.

Appendix A: Point of Interconnection Area Map




Figure 2: Point of Interconnection Area Map