



***Facility Study
For
Generation Interconnection
Request
GEN-2008-021***

SPP Tariff Studies

(#GEN-2008-021)

June 2010

Summary

The customer has requested a Facility Study under the Southwest Power Pool Open Access Transmission Tariff for the purpose of a 42MW increase in the capacity of an existing generating facility in Coffey County, Kansas within the transmission system of Westar Energy (WERE).

Pursuant to the tariff, Westar Energy was asked to perform a detailed Facility Study of the generation interconnection request to satisfy the Facility Study Agreement executed by the requesting customer and SPP.

Westar has determined that no circuit breakers will have their short circuit duty ratings exceeded due to the addition of the incremental generation. Westar has also determined that no new interconnection facilities are required for the addition of the incremental generation. The total cost of the interconnection facilities for this interconnection request is approximately \$0.