

Feasibility Cluster Study for Generation Interconnection Requests

Southwest Power Pool
Engineering Dept.
Tariff Studies – Generation Interconnection

(FCS-2010-002)
June 2010



Feasibility Study for Generation Interconnection Requests

Southwest Power Pool
Engineering Department
Tariff Studies – Generation Interconnection

(FCS-2010-002 Study)
June 2010

Date	Rev.	Comment
June 25, 2010	0	Report Issued

Executive Summary

Generation Interconnection customers have requested a Feasibility Study under the Large Generation Interconnection Procedures (LGIP) in the Southwest Power Pool Open Access Transmission Tariff (OATT). The Interconnection Customers' requests have been clustered together for the following Feasibility Cluster Study. This Feasibility Cluster Study analyzes the interconnecting of multiple generation interconnection requests associated with new generation totaling approximately 1,886 MW of new generation which would be located within the transmission systems of American Electric Power West (AEPW), Southwestern Public Service (SPS) Nebraska Public Power District (NPPD), Missouri Public Service (MIPU), Sunflower Electric Power Corporation (SUNC), Empire District Electric (EDE) and Western Farmers Electric Cooperative (WFEC). The various generation interconnection requests have differing proposed in-service dates¹. The generation interconnection requests included in this Feasibility Cluster Study are listed in Appendix A by their queue number, amount, area, requested interconnection point, proposed interconnection point, and the requested in-service date.

Power flow analysis has indicated that for the powerflow cases studied, 1,886 MW of nameplate generation may be interconnected with transmission system reinforcements within the SPP transmission system. The need for reactive compensation in accordance with Order No. 661-A for wind farm interconnection requests will be evaluated in the Interconnection System Impact Study based on the wind turbine manufacturer and type requested by the Customer. Dynamic stability studies performed as part of the System Impact Cluster Study will provide additional guidance as to whether the required reactive compensation can be static or a portion must be dynamic (such as a SVC).

The total estimated minimum cost for interconnecting the studied generation interconnection request is \$186,600,000. These costs are shown in Appendix E and F. These costs do not include the Interconnection Customer Interconnection Facilities as defined by the SPP Open Access Transmission Tariff (OATT). This cost does not include the possible need for reactive compensation or additional network constraints in the SPP transmission system that were identified are shown in Appendix H.

Network Constraints listed in Appendix G are in the local area of the new generation when this generation is injected throughout the SPP footprint for the Energy Resource (ER) Interconnection Request. Additional Network constraints will have to be verified with a Transmission Service Request (TSR) and associated studies. With a defined source and sink in a TSR, this list of Network Constraints will be refined and expanded to account for all Network Upgrade requirements.

The required interconnection costs listed in Appendix E and F do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP OATT.

Based on the SPP Tariff Attachment O, transmission facilities that are part of the SPP Transmission Expansion Plan (STEP) including Sponsored Economic Upgrades or the Balanced Portfolio that may be approved by the SPP Board of Directors will receive notifications to construct. These projects will

¹ The generation interconnection requests in-service dates will need to be deferred based on the required lead time for the Network Upgrades necessary. The Interconnection Customer's that proceed to the Facility Study will be provided a new in-service date based on the competition of the Facility Study.

then be considered construction pending projects and would not be assignable to the Feasibility Cluster Study Generation Interconnection Requests. The network Upgrades identified in the Base Case Upgrades will not be assigned to the Feasibility Cluster Study for Generation Interconnection Requests.

Table of Contents

Introduction.....	6
Model Development	6
Interconnection Requests Included in the Cluster	6
Electrically Isolated Interconnection Requests	6
Previous Queued Projects	6
Development of Base Cases	6
Base Case Upgrades.....	7
Potential Upgrades Not in the Base Case	8
Regional Groupings	8
Identification of Network Constraints	8
Determination of Cost Allocated Network Upgrades	9
Credits for Amounts Advanced for Network Upgrades.....	10
Interconnection Facilities	10
Powerflow Analysis Methodology	10
Powerflow Analysis.....	11
Conclusion.....	13
Appendix	14
A: Generation Interconnection Requests Considered for Feasibility Study.....	A-1
B: Prior Queued Interconnection Requests	B-1
C: Study Groupings	C-1
D: Proposed Point of Interconnection One line Diagrams	D-1
E: Cost Allocation per Interconnection Request.....	E-1
F: Cost Allocation per Proposed Network Upgradel.....	F-1
G: FCITC Analysis (No Upgrades)	G-1
H: FCITC Analysis (No Threshold)	H-1

Introduction

Generation Interconnection customers have requested a Feasibility Study under the Large Generation Interconnection Procedures (LGIP) in the Southwest Power Pool Open Access Transmission Tariff (OATT). The Interconnection Customers' requests have been clustered together for the following Feasibility Cluster Study. This Feasibility Cluster Study analyzes the interconnecting of multiple generation interconnection requests associated with new generation totaling approximately 1,886 MW of new generation which would be located within the transmission systems of American Electric Power West (AEPW), Southwestern Public Service (SPS) Nebraska Public Power District (NPPD), Missouri Public Service (MIPU), Sunflower Electric Power Corporation (SUNC), Empire District Electric (EDE) and Western Farmers Electric Cooperative (WFEC). The various generation interconnection requests have differing proposed in-service dates². The generation interconnection requests included in this Feasibility Cluster Study are listed in Appendix A by their queue number, amount, area, requested interconnection point, proposed interconnection point, and the requested in-service date.

The primary objective of this Feasibility Cluster Study is to identify the system constraints associated with connecting the generation to the area transmission system. The Feasibility and other subsequent Interconnection Studies are designed to identify attachment facilities, Network Upgrades and other Direct Assignment Facilities needed to accept power into the grid at each specific interconnection receipt point.

Model Development

Interconnection Requests Included in the Cluster – SPP has included the interconnection requests listed in Appendix A to be analyzed in this cluster study. These interconnection requests represent requests with an executed Feasibility Study Agreement signed by 3/31/2010.

Electrically Isolated Interconnection Requests – Electrically isolated requests are discussed in the “Regional Groupings” section.

Previous Queued Projects – The previous queued projects included in this study are listed in Appendix B. In addition to the Base Case Upgrades, the previous queued projects were assumed to be in-service and added to the Base Case models. These projects were dispatched as Energy Resources with equal distribution across the SPP footprint.

Development of Base Cases – The 2009 series Transmission Service Request (TSR) Models 2010 spring and 2014 summer and winter scenario 0 peak cases were used for this study. After the 2010 spring and the 2014 summer and winter peak cases were developed, each of the control areas' resources were then redispatched using current dispatch orders.

² The generation interconnection requests in-service dates will need to be deferred based on the required lead time for the Network Upgrades necessary. The Interconnection Customer's that proceed to the Facility Study will be provided a new in-service date based on the competition of the Facility Study.

Base Case Upgrades -The following facilities are part of the SPP Transmission Expansion Plan or the Balanced Portfolio. These facilities have been approved or are in the construction stages and were assumed to be in-service at the time of dispatch and added to the base case models. The FCS-200-002 Customers have no potential cost for the below listed projects. However, the FCS-2010-002 Customer Generation Facilities in service dated may need to be delayed until the completion of the following upgrades. If for some reason, construction on these projects is discontinued, additional restudies will be needed to determine the interconnection needs of the FCS-2010-002 customers.

- Woodward – Northwest 345kV line and associated projects to be built by OKGE placed in service in 2010.
- Hitchland 345/230/115kV upgrades to be built by SPS for 2010/2011 in-service³.
 - Hitchland – Pringle 230kV line
 - Hitchland – Moore County 230kV line
 - Hitchland – Perryton 230kV line
 - Hitchland – Texas County 115kV line
 - Hitchland – Hansford County 115kV line
 - Hitchland – Sherman County Tap 115kV line
- Valliant – Hugo – Sunnyside 345kV – assigned to Aggregate Study AG3-2006 Customers for 2012 in-service
- Wichita – Reno County – Summit 345kV to be built by WERE for 2011 in-service⁴.
- Rose Hill – Sooner 345kV to be built by WERE/OKGE for 2012 in-service.
- Balanced Portfolio Projects:
 - Anadarko 345/138/13.2kV Autotransformer
 - Woodward– TUCO 345kV line
 - Sooner– Cleveland 345kV line
 - Iatan– Nashua 345kV line
 - Muskogee– Seminole 345kV line
 - Knoll– Axtell 345kV line
 - Spearville– Knoll 345kV line
 - Tap Stillwell – Swissvale 345kV line at West Gardner

Contingent Upgrades

The following facilities do not yet have approval. These facilities have been assigned to higher queued interconnection customers. These facilities have been included in the models for the FCS-2010-002 study and are assumed to be in service. The FCS-2010-002 Customers at this time do not have responsibility for these facilities but may later be assigned the cost of these facilities if higher queued customers terminate their LGIA or withdraw from the interconnection queue. The FCS-2010-002 Customer Generation Facilities in service dates may need to be delayed until the completion of the following upgrades.

- Finney – Holcomb 345kV ckt #2 line assigned to GEN-2006-044 interconnection customer. This customer is currently in suspension⁵.

³ Approved 230kV upgrades are based on SPP 2007 STEP. Upgrades may need to be re-evaluated in the system impact study.

⁴ Approved based on an order of the Kansas Corporation Commission issued in Docket no. 07-WSEE-715-MIS

⁵ Based on Facility Study Posting November 2008

- Hitchland – Woodward 345kV line assigned to GEN-2006-049 interconnection customer for in service date yet to be determined
- Stevens County – Gray County 345kV line assigned to 1st Cluster Interconnection Customers
- Central Plains – Setab 115kV transmission line assigned to GEN-2007-013 interconnection customer.
- Spearville – Comanche 345kV line assigned to 1st Cluster Interconnection Customers
- Comanche – Wichita 345kV line assigned to 1st Cluster Interconnection Customers
- Comanche – Woodward 345kV line assigned to 1st Cluster Interconnection Customers
- Grassland 230/115kV autotransformer #2 assigned to 1st Cluster Interconnection Customers (100% to GEN-2008-016)

Potential Upgrades Not in the Base Case – Any potential upgrades that do not have a Notification to Construct (NTC) to construct have not been included in the base case. These upgrades include any identified in the SPP Extra-High Voltage (EHV) overlay plan, or any other SPP planning study other than the upgrades listed above in the previous section.

Regional Groupings – The interconnection requests listed in Appendix A were grouped together in six different regional groups based on geographical and electrical impacts. These groupings are shown in Appendix C. Two other interconnection requests not in close proximity to any other requests were grouped by themselves.

To determine interconnection impacts, six different dispatch variations of the spring base case models were developed to accommodate the regional groupings.

For each group, the various wind generating plants were modeled at 80% nameplate of maximum generation. The wind generating plants in the other areas were modeled at 20% nameplate of maximum generation. This process created six different scenarios with each group being studied at 80% nameplate rating. These projects were dispatched as Energy Resources with equal distribution across the SPP footprint. This method allowed for the identification of network constraints that were common to the regional groupings that could then in turn have the mitigating upgrade cost allocated throughout the entire cluster. Additionally, each wind interconnection request was studied as a stand alone project at 100% nameplate assuming no other projects in the cluster.

Peaking units were not dispatched in the 2010 spring model. To study peaking units' impacts, the 2014 summer peak model was chosen and peaking units were modeled at 100% of the nameplate rating and wind generating facilities were modeled at 10% of the nameplate rating.

Identification of Network Constraints

The initial set of network constraints were found by using PTI MUST First Contingency Incremental Transfer Capability (FCITC) analysis on the entire cluster grouping dispatched at the various levels mentioned above. These constraints were then screened to determine if any of the generation interconnection requests had at least a 20% Distribution Factor (DF) upon the constraint. Constraints that measured at least a 20% DF from at least one interconnection request were considered for mitigation.

Identification of Electrically Isolated Groups and Requests – From the FCITC analysis, it was determined that some of the regional groups had no common impacts with the other groups. However, this determination may change as the Interconnection Customers depending upon the time at which the interconnection customers enter either the Preliminary Interconnection System Impact Study (PESIS) or the Definitive Interconnection System Impact Study (DISIS)

Determination of Cost Allocated Network Upgrades

Cost Allocated Network Upgrades of wind generation interconnection requests were determined using the 2010 spring model. Cost Allocated Network Upgrades of peaking units was determined using the 2014 summer peak model. Once a determination of the required Network Upgrades was made, a powerflow model of the 2010 spring case was developed with all cost allocated Network Upgrades in-service. A MUST FCITC analysis was performed to determine the Power Transfer Distribution Factors (PTDF), a distribution factor with no contingency that each generation interconnection request had on each new upgrade. The impact each generation interconnection request had on each upgrade project was weighted by the size of each request. Finally the costs due by each request for a particular project were then determined by allocating the portion of each request's impact over the impact of all affecting requests.

For example, assume that there are three Generation Interconnection requests, X, Y, and Z that are responsible for the costs of Upgrade Project '1'. Given that their respective PTDF for the project have been determined, the cost allocation for Generation Interconnection request 'X' for Upgrade Project 1 is found by the following set of steps and formulas:

- Determine an Impact Factor on a given project for all responsible GI requests:

$$\text{Request X Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(X) * \text{MW}(X) = X_1$$

$$\text{Request Y Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(Y) * \text{MW}(Y) = Y_1$$

$$\text{Request Z Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(Z) * \text{MW}(Z) = Z_1$$

- Determine each request's Allocation of Cost for that particular project:

$$\text{Request X's Project 1 Cost Allocation (\$)} = \frac{\text{Network Upgrade Project 1 Cost}(\$) * X_1}{X_1 + Y_1 + Z_1}$$

- Repeat previous for each responsible GI request for each Project

The cost allocation of each needed Network Upgrade is determined by the size of each request and its impact on the given project. This allows for the most efficient and reasonable mechanism for sharing the costs of upgrades.

Credits for Amounts Advanced for Network Upgrades – Interconnection Customer shall be entitled to credits in accordance with Attachment Z1 of the SPP Tariff for any Network Upgrades including any tax gross-up or any other tax-related payments associated with the Network Upgrades, and not refunded to the Interconnection Customer.

Interconnection Facilities

The requirement to interconnect the 1,886 MW of generation into the existing and proposed transmission systems in the affected areas of the SPP transmission footprint consist of the necessary cost allocated shared facilities listed in Appendix F. Interconnection Facilities specific to each generation interconnection request are listed in Appendix E.

Other Network Constraints in the AEPW, MIDW, OKGE, SPS, MIPU, NPPD, SUNC, SWPA, MKEC, WERE, and WFEC transmission systems that were identified that may be needed to deliver to load are not listed in Appendix H. With a defined source and sink in a TSR, a list of Network Constraints will be refined and expanded to account for all Network Upgrade requirements.

A preliminary one-line drawing for each generation interconnection request are listed in Appendix D. Figure 1 depicts the major transmission line Network Upgrades needed to support the interconnection of the generation amounts requested in this study.

Powerflow Analysis Methodology

The Southwest Power Pool (SPP) Criteria states that:

“The transmission system of the SPP region shall be planned and constructed so that the contingencies as set forth in the Criteria will meet the applicable *NERC Reliability Standards* for transmission planning. All MDWG power flow models shall be tested to verify compliance with the System Performance Standards from NERC Table 1 – Category A.”

The FCITC function of MUST was used to simulate single contingencies in portions or all of the modeled control areas of AEPW, EMDE, Grand River Dam Authority (GRDA), Kansas City Power & Light (KCPL), MIDW, MIPU, NPPD, OKGE, SPS, SUNC, WERE, WFEC and other control areas were applied and the resulting scenarios analyzed. This satisfies the “more probable” contingency testing criteria mandated by NERC and the SPP criteria.

Powerflow Analysis

A powerflow analysis was conducted for each Interconnection Customer's facility using modified versions of the 2010 spring peak and the 2014 summer peak and winter peak models. The output of the Interconnection Customer's facility was offset in each model by a reduction in output of existing online SPP generation. This method allows the request to be studied as an Energy Resource (ER) Interconnection Request. The available seasonal models used were through the 2014 Summer Peak.

This analysis was conducted assuming that previous queued requests in the immediate area of these interconnect requests were in-service. The analysis of the each Customer's project indicates that additional criteria violations will occur on the AEPW, MIDW, MIPU, NPPD, OKGE, SPS, SUNC, SWPA, MKEC, WERE, and WFEC transmission systems under steady state and contingency conditions in the peak seasons.

The need for reactive compensation will be determined during the Interconnection System Impact Study. The need for reactive compensation will be based on the Interconnection Customer's choice of wind turbine make and manufacturer. Dynamic Stability studies performed as part of the System Impact Cluster Study will provide additional guidance as to whether the reactive compensation can be static or a portion must be dynamic (such as a SVC or STATCOM). It is possible that an SVC or STATCOM device will be required at the Customer facility because of FERC Order 661A Low Voltage Ride-Through Provisions (LVRT) which went into effect January 1, 2006. FERC Order 661A orders that wind farms stay on-line for 3-phase faults at the point of interconnection even if that requires the installation of a SVC or STATCOM device

Woodward Area – The Woodward area contained one interconnection request of 99 MW. The interconnection request was at the WFEC Iodine 138kV bus. There were constraints identified at Fort Supply and the underlying 69kV system served out of Fort Supply. To mitigate these constraints a new 138kV transmission circuit from WFEC Iodine – Woodward will be required.

Hitchland Area – This study area contained 400 MW of interconnection requests. With previously allocated network upgrades to higher queued customers in the models, no new constraints were found in this area. The withdrawal of higher queued projects will change the requirements for interconnection

Spearville Area – This study area contained 900 MW of interconnection requests. . With previously allocated network upgrades to higher queued customers in the models, no new constraints were found in this area. The withdrawal of higher queued projects will change the requirements for interconnection

New Mexico/West Texas Area – This group had 40 MW of requested generation. All of this generation was solar based generation. No new constraints were found in this area.

Southwestern Oklahoma – This group had 153 MW of interconnection requested in the area. One interconnection request was at the WFEC Eric 138kV bus. Due to higher queued customers, the 138kV transmission loop from Elk City to Moorewood will need to be rebuilt. In addition, terminal equipment at Carter Jct will need to be replaced.

Northeast Nebraska – This group had 99 MW of interconnection requested in the area. No new constraints were found in this area.

North Nebraska – This group had 100 MW of interconnection requested in the area. The major constraints in the area were on the Mission – St. Francis 115kV line, the Harmony – Valentine 115kV line, and the GEN-2010-024 – Harmony 115kV line. In order to mitigate the constraints in the area a Stuart – O’Neill 115kV line and a Valentine – GEN-2010-024 were modeled.

Northwest Arkansas – This group had 20 MW of interconnection requested in the area. No new constraints were found in this area.

Northwest Missouri – This group had 75 MW of interconnection requested in the area. No new constraints were found in this area.

Conclusion

The minimum cost of interconnecting all of the interconnection requests included in the Feasibility Cluster Study is estimated at \$186,600,000 for the Allocated Network Upgrades and Transmission Owner Interconnection Facilities are listed in Appendix E and F. These costs do not include the cost of upgrades of other transmission facilities listed in Appendix H which are Network Constraints.

These interconnection costs do not include any cost of Network Upgrades determined to be required by AC powerflow, short circuit or transient stability analysis. These studies will be performed if the Interconnection Customer executes the appropriate Interconnection System Impact Study Agreement and provides the required data along with demonstration of Site Control and the appropriate deposit. At the time of the System Impact Cluster Study, a better determination of the interconnection facilities may be available.

The required interconnection costs listed in Appendices E, and F, and other upgrades associated with Network Constraints do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request (TSR) through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP Open Access Transmission Tariff (OATT).

Appendix

A: Generation Interconnection Requests Considered for Feasibility Study

Request	Amount	Area	Requested Point of Interconnection	Proposed Point of Interconnection	Requested In-Service Date
GEN-2009-069	400	SPS	Tap Hitchland - Woodward 345kV	Tap Hitchland - Woodward 345kV	12/31/2014
GEN-2010-018	100.8	WFEC	Erick 138kV	Erick 138kV	12/31/2011
GEN-2010-019	52.2	WFEC	Carter Junction 69kV	Carter Junction 69kV	12/31/2011
GEN-2010-020	20	SPS	Roswell 69kV	Roswell 69kV	3/1/2011
GEN-2010-021	20	SPS	Atoka 69kV	Atoka 69kV	3/1/2011
GEN-2010-022	75	MIPU	Archie 161kV	Archie 161kV	12/3/2012
GEN-2010-023	99	WFEC	Iodine 138kV	Iodine 138kV	1/0/1900
GEN-2010-024	100	NPPD	Tap Valentine - Mission 115kV	Tap Valentine - Mission 115kV	12/31/2011
GEN-2010-025	20	EMDE	Decatur South 161kV	Decatur South 161kV	9/16/2010
GEN-2010-026	99	NPPD	Hoskins 230kV	Hoskins 230kV	10/1/2012
GEN-2010-027	900	SUNC	Spearville 345kV	Spearville 345kV	12/31/2012
Grouped Total	1,886				

* Planned Facility

^ Proposed Facility

** Alternate requests - counted as one request for study purpose

*** Electrically Remote Interconnection Requests

****Portions of this request are alternates for other interconnection requests listed as prior queued generators

B: Prior Queued Interconnection Requests

Request	Amount	Area	Requested/Proposed Point of Interconnection	Status or In-Service Date
GEN-2001-014	96	WFEC	Fort Supply 138kV	On-Line
GEN-2001-026	74	WFEC	Washita 138kV	On-Line
GEN-2001-033	180	SPS	San Juan Mesa Tap 230kV	On-Line
GEN-2001-036	80	SPS	NORTON 115kV	On-Line
GEN-2001-037	100	OKGE	Windfarm Switching 138kV	On-Line
GEN-2001-039A	105	WPEK	Greensburg - Judson-Large 115kV	On Schedule for 2011 in service
GEN-2001-039M	100	SUNC	Central Plains Tap 115kV	On-Line
GEN-2002-004	200	WERE	Latham 345kV	On-Line (150 MW)
GEN-2002-005	120	WFEC	RED HILLS TAP 138kV	On-Line
GEN-2002-006	150	SPS	Texas County 115kV	On Schedule for 12/31/2010
GEN-2002-008	240	SPS	*Hitchland 345kV	On-Line (120MW)
GEN-2002-009	80	SPS	Hansford County 115kV	On-Line
GEN-2002-022	240	SPS	Bushland 230kV	On-Line (160MW)
GEN-2002-025A	150	WPEK	Spearville 230kV	On-Line (100.5 MW)
GEN-2003-005	100	WFEC	Tap Anadarko - Paradise 138kV	On-Line
GEN-2003-006A	200	MKEC	Elm Creek 230kV	On-Line
GEN-2003-013**	198	SPS	Tap Finney - *Hitchland 345kV	On Schedule for 2012
GEN-2003-019	250	MIDW	Smoky Hills 230kV	On-Line
GEN-2003-020	160	SPS	MARTIN 115kV	On-Line (80MW)
GEN-2003-021N	75	NPPD	Ainsworth Wind Tap 115kV	On-Line (60MW)
GEN-2003-022	120	AEPW	Washita 138kV	On-Line
GEN-2004-005N	30	NPPD	St. Francis 115kV	IA Pending
GEN-2004-010	300	WERE	Latham 345kV	On Suspension
GEN-2004-014	155	MIDW	Spearville 230kV	On Schedule for 2010
GEN-2004-020	27	AEPW	Washita 138kV	On-Line
GEN-2005-005	18	OKGE	Windfarm Switching 138kV	IA Pending
GEN-2005-008	120	OKGE	Woodward 138kV	On-Line
GEN-2005-010	160	SPS	Tap Roosevelt County North - Tolk West 230kV	On Suspension
GEN-2005-012	250	WPEK	Spearville 345kV	On Suspension
GEN-2005-013	201	WERE	Tap Latham-Neosho 345kV	On Schedule for 2012
GEN-2005-015	150	SPS	TUCO - Oklaunion 345kV	On Suspension
GEN-2005-016	150	WERE	Tap Latham-Neosho 345kV	On Schedule for 2012
GEN-2005-017	340	SPS	Tap *Hitchland - Potter County 345kV	On Suspension
GEN-2005-021	86	SPS	Kirby 115kV	On Suspension

Appendix B: Prior Queued Interconnection Requests



Request	Amount	Area	Requested/Proposed Point of Interconnection	Status or In-Service Date
GEN-2006-002	150	AEPW	Grapevine - Elk City 230kV	On Suspension
GEN-2006-006	206	MKEC	Spearville 230kV	Under Study (ICS-2008-001)
GEN-2006-014	300	MIPU	Tap Maryville-Clarinda and tie to Midway (WFARMS) 161kV	On Suspension
GEN-2006-017	300	MIPU	Tap Maryville-Clarinda and tie to Midway (WFARMS) 161kV	On Suspension
GEN-2006-018	170	SPS	Tuco 230kV	
GEN-2006-020S	18.9	SPS	*DWS FRISCO TAP 115kV	On Schedule for 12/31/2010
GEN-2006-020N	42	NPPD	BloomField 115kV	1/1/2009
GEN-2006-021	101	WPEK	Flat Ridge Wind Farm Tap 138kV	On-Line (100MW)
GEN-2006-022	150	WEPL	Ninnescah Tap 115kV	On Suspension
GEN-2006-024S	20	WFEC	SOUTH BUFFALO TAP 69kV	On-Line
GEN-2006-031	75	MIDW	Knoll 115kV	On-Line
GEN-2006-032	200	MIDW	South Hays 230kV	On Suspension
GEN-2006-034	81	SUNC	Kanarado - Sharon Springs 115kV	On Suspension
GEN-2006-035	225	AEPW	Grapevine - Elk City 230kV	10/1/2010
GEN-2006-037N1	75	NPPD	Broken Bow 115kV	Under Study (DISIS-2009-001)
GEN-2006-038	750	WFEC	Hugo 345kV	On Suspension
GEN-2006-038N005	80	NPPD	Broken Bow 115kV	IA Pending
GEN-2006-038N019	80	NPPD	Petersburg 115kV	5/1/2011
GEN-2006-039	400	SPS	Tap and Tie both Potter County - Plant X 230kV and Bushland - Deaf Smith 230kV	On Suspension
GEN-2006-040	108	SUNC	Mingo 115kV	6/30/2010
GEN-2006-043	99	AEPW	Grapevine - Elk City 230kV	On Line
GEN-2006-044	370	SPS	*Hitchland 345kV	On Suspension
GEN-2006-044N	40.5	NPPD	Tap Neligh-Petersburg 115kV	Under Study (DISIS-2009-001)
GEN-2006-044N02	100.5	NPPD	GEN-2008-086N02 230kV	Under Study (DISIS-2010-001)
GEN-2006-045	240	SPS	Tap and Tie both Potter County - Plant X 230kV and Bushland - Deaf Smith 230kV	On Suspension
GEN-2006-046	131	OKGE	Dewey 138kV	On Schedule for 12/31/2010
GEN-2006-047	240	SPS	TAP & TIE POTTER-PLANT X & BUSHLAND-DEAF SMITH (GEN-2006-039 TAP & TIE)	12/31/2013
GEN-2006-049	400	SPS	Tap Finney - *Hitchland 345kV	IA Pending
GEN-2007-002	160	SPS	Grapevine 115kV	On Suspension
GEN-2007-005	200	SPS	Pringle 115kV	Under Study (ICS-2008-001)
GEN-2007-006	160	OKGE	Roman Nose 138kV	On Suspension
GEN-2007-011	135	SUNC	Syracuse 115kV	12/31/2010
GEN-2007-011N06	75	NPPD	Tap Neligh-Petersburg 115kV	Under Study (DISIS-2009-001)
GEN-2007-011N08	81	NPPD	Bloomfield 115kV	On-Line

Appendix B: Prior Queued Interconnection Requests



Request	Amount	Area	Requested/Proposed Point of Interconnection	Status or In-Service Date
GEN-2007-011N09	75	NPPD	Bloomfield 115kV	Under Study (DISIS-2009-001)
GEN-2007-013	99	SUNC	Selkirk 115kV	On Schedule for 2011
GEN-2007-015	135	WERE	Tap Humboldt - Kelly 161kV	On Schedule for 2011
GEN-2007-017	101	MIPU	Tap Maryville-Clarinda and tie to Midway (WFARMS) 161kV	On Schedule for 2012
GEN-2007-021	201	OKGE	TATONGA EHV 345kV	Under Study (ICS-2008-001)
GEN-2007-025	300	WERE	Wichita – Woodring 345kV	Under Study (ICS-2008-001)
GEN-2007-032	150	WFEC	Tap Clinton Junction - Clinton 138kV	Under Study (ICS-2008-001)
GEN-2007-034	150	SPS	Tap Tolk - Eddy County 345kV	Under Study (ICS-2008-001)
GEN-2007-038	200	SUNC	Spearville 345kV	Under Study (ICS-2008-001)
GEN-2007-040	200	SUNC	Tap Holcomb - Spearville 345kV	Under Study (DISIS-2009-001)
GEN-2007-043	300	AEPW	Lawton Eastside - Cimarron 345kV	Under Study (ICS-2008-001)
GEN-2007-044	300	OKGE	^TATONGA EHV 345kV	Under Study (ICS-2008-001)
GEN-2007-046	200	SPS	TAP & TIE TEXAS COUNTY-HITCHLAND & DWS FRISCO TAP-HITCHLAND 115kV	Under Study (ICS-2008-001)
GEN-2007-048	400	SPS	Amarillo South - Swisher County 230kV	Under Study (ICS-2008-001)
GEN-2007-050	170	OKGE	Woodward EHV 138kV	Under Study (ICS-2008-001)
GEN-2007-051	200	WFEC	Mooreland 138kV	Under Study (ICS-2008-001)
GEN-2007-052	150	WFEC	Anadarko 138kV	Under Study (ICS-2008-001)
GEN-2007-053***	110	MIPU	Maryville 161kV	Under Study (ICS-2008-001)
GEN-2007-057	35	SPS	MOORE EAST 115kV	Under Study (ICS-2008-001)
GEN-2007-062**	765	OKGE	*Woodward EHV 345kV	Under Study (ICS-2008-001)
GEN-2008-003	101	OKGE	Woodward 138kV	Under Study (ICS-2008-001)
GEN-2008-008	60	SPS	Graham 115kV	Under Study (ICS-2008-001)
GEN-2008-009	60	SPS	San Juan Mesa 230kV	Under Study (ICS-2008-001)
GEN-2008-013	300	OKGE	Wichita - Woodring 345kV	Under Study (ICS-2008-001)
GEN-2008-014	150	SPS	Tap TUZO - Oklaunion 345kV	Under Study (ICS-2008-001)
GEN-2008-016	248	SPS	Grassland 230kV	Under Study (ICS-2008-001)
GEN-2008-017	300	SUNC	Setab 345kV	Under Study (ICS-2008-001)
GEN-2008-018	405	SUNC	FINNEY 345kV	Under Study (ICS-2008-001)
GEN-2008-019**	300	OKGE	TATONGA EHV 345kV	Under Study (ICS-2008-001)
GEN-2008-021	42	WERE	Wolf Creek 25kV	Under Study (DISIS-2009-001)
GEN-2008-022	300	SPS	Tap Eddy – GEN-2007-034 345kV	Under Study (DISIS-2010-001)

Appendix B: Prior Queued Interconnection Requests



Request	Amount	Area	Requested/Proposed Point of Interconnection	Status or In-Service Date
GEN-2008-023	150	AEPW	Hobart Junction 138kV	Under Study (DISIS-2009-001)
GEN-2008-025	101.2	SUNC	Ruleton 115kV	Under Study (DISIS-2009-001)
GEN-2008-028	360	SPS	Hitchland 345kV	Under Study (DISIS-2010-001)
GEN-2008-029	205.5	OKGE	Woodward EHV 138kV	Under Study (DISIS-2009-001)
GEN-2008-037	100.8	WFEC	Tap Washita – Blue Canyon 138kV	Under Study (DISIS-2010-001)
GEN-2008-038	144	AEPW	Tap Shidler-West Pawhuska 138kV	Under Study (DISIS-2009-001)
GEN-2008-044	197.8	OKGE	Tatonga 345kV	Under Study (DISIS-2010-001)
GEN-2008-046	200	OKGE	Sunnyside 345kV	Under Study (DISIS-2010-001)
GEN-2008-047	300	SPS	Tap Hitchland – Woodward 345kV	Under Study (DISIS-2010-001)
GEN-2008-051	322	SPS	Potter 345kV	Under Study (DISIS-2009-001)
GEN-2008-071	76.8	OKGE	Newkirk 138kV	Under Study (DISIS-2010-001)
GEN-2008-079	100.5	MKEC	TAP JUDSON LARGE-CUDAHY 115kV	Under Study (DISIS-2009-001)
GEN-2008-086N02	99	NPPD	TAP FT RANDALL-COLUMBUS 230kV	Under Study (DISIS-2009-001)
GEN-2008-088	50.6	SPS	Vega 69kV	Under Study (DISIS-2010-001)
GEN-2008-092	201	MIDW	KNOLL 115kV	Under Study (DISIS-2009-001)
GEN-2008-098	100.8	WERE	Tap Wolf Creek – LaCygne 345kV	Under Study (DISIS-2010-001)
GEN-2008-110	299.2	SPS	Hitchland 345kV	Under Study (DISIS-2010-001)
GEN-2008-119O	60	OPPD	TAP HUMBOLDT-KELLY (NORTH OF GEN-2007-015) 161kV	Under Study (DISIS-2009-001)
GEN-2008-123N	89.7	NPPD	Tap Guide – Pauline 115kV	Under Study (DISIS-2010-001)
GEN-2008-124	200.1	MKEC	SPEARVILLE 230kV	Under Study (DISIS-2009-001)
GEN-2008-127	200.1	WERE	TAP SOONER-ROSE HILL 345kV	Under Study (DISIS-2009-001)
GEN-2008-129	46S/80W	MIPU	PLEASANT HILL 161kV	Under Study (DISIS-2009-001)
GEN-2009-008	200	SUNC	South Hays 230kV	Under Study (DISIS-2010-001)
GEN-2009-011	50	MKEC	TAP PLAINVILLE-PHILLIPSBURG 115kV	Under Study (DISIS-2009-001)
GEN-2009-016	140.3	AEPW	FALCON ROAD 138kV	Under Study (DISIS-2009-001)
GEN-2009-017	60	SPS	TAP PEMBROOK-STILES 138kV	Under Study (DISIS-2009-001)
GEN-2009-020	48.6	MIDW	Tap Bazine – Nekoma 69kV	Under Study (DISIS-2010-001)
GEN-2009-025	60	OKGE	Tap Deer Creek – Sinclair 69kV	Under Study (DISIS-2009-001)
GEN-2009-030	100.8	WFEC	Weatherford 138kV	Under Study (DISIS-2010-001)
GEN-2009-032S	6.4	OKGE	Foster 138kV	Under Study (DISIS-2010-001)
GEN-2009-040	73.8	WERE	Tap Smittyville – Knob Hill 115kV	Under Study (DISIS-2010-001)

Appendix B: Prior Queued Interconnection Requests



Request	Amount	Area	Requested/Proposed Point of Interconnection	Status or In-Service Date
GEN-2009-059	100.5	SUNC	Tap GEN-2008-079 – Cudahy 115kV	Under Study (DISIS-2010-001)
GEN-2009-060	84	WFEC	Gotebo 69kV	Under Study (DISIS-2010-001)
GEN-2009-062	115	SUNC	Hugoton 115kV	Under Study (DISIS-2010-001)
GEN-2009-067S	20	SPS	7 Rivers 69kV	Under Study (DISIS-2010-001)
GEN-2010-003	100.8	WERE	GEN-2008-098 345kV	Under Study (DISIS-2010-001)
GEN-2010-005	300	MKEC	GEN-2007-025 345kV	Under Study (DISIS-2010-001)
GEN-2010-006	205	SPS	Jones 230kV	Under Study (DISIS-2010-001)
GEN-2010-007	73.8	SPS	Tap Pringle – Riverview 115kV	Under Study (DISIS-2010-001)
GEN-2010-008	64.4	WFEC	Tap Woodward - Fargo Junction 69kV	Under Study (DISIS-2010-001)
GEN-2010-009	165.6	SUNC	Gray County 345kV	Under Study (DISIS-2010-001)
GEN-2010-010	100.5	NPPD	Tap GEN-2008-086N02 – Columbus 230kV	Under Study (DISIS-2010-001)
GEN-2010-011	29.7	OKGE	GEN-2008-044 345kV	Under Study (DISIS-2010-001)
GEN-2010-013	50.4	WERE	GEN-2005-013 345kV	Under Study (DISIS-2010-001)
GEN-2010-014	358.8	SPS	Hitchland 345kV	Under Study (DISIS-2010-001)
GEN-2010-015	200.1	SUNC	Spearville 345kV	Under Study (DISIS-2010-001)
GEN-2010-016	199.8	SUNC	Tap Spearville – Knoll 345kV	Under Study (DISIS-2010-001)
ASGI-2010-003	300	AECI	Maryville 161kV	AECI queue Affected Study
ASGI-2010-004	50	AECI	Tap Queen City – Lancaster 69kV	AECI queue Affected Study
ASGI-2010-005	99	AECI	Lathrop 161kV	AECI queue Affected Study
ASGI-2010-006	150	AECI	Tap Fairfax – Fairfax Tap 138kV	AECI queue Affected Study
ASGI-2010-007	150	AECI	Tap Fairfax – Fairfax Tap 138kV	AECI queue Affected Study
ASGI-2010-008	100	AECI	Maryville 161kV	AECI queue Affected Study
ASGI-2010-009	201	AECI	Osborn 161kV	AECI queue Affected Study
ASGI-2010-010	42	SPS	Lovington 115kV	LCED Affected Study
Genoa	4	NPPD	Genoa 115kV	On-Line
Ord	13.9	NPPD	Bloomfield 115kV	On-Line
Stuart	2.1	NPPD	Petersburg 115kV	On-Line
Llanoest	80	SPS	Llano Wind Farm Tap 115kV	On-Line
SPSDISTR	90	SPS	Dumas_19ST 115kV	On-Line
			Etter 115kV	On-Line
			Sherman 115kV	On-Line
			Spearman 115kV	On-Line
			Texas County 115kV	On-Line

Appendix B: Prior Queued Interconnection Requests



Request	Amount	Area	Requested/Proposed Point of Interconnection	Status or In-Service Date
BLUCAN2	151.2	WFEC	Washita 138kV (GEN-2003-004)	On-Line
			Washita 138kV (GEN-2004-023)	On-Line
			Washita 138kV (GEN-2005-003)	On-Line
Monte	110	MKEC	Haggard 115kV	On-Line
GROUPED TOTAL	27,386.6			

* Planned Facility

^ Proposed Facility

** Alternate requests - counted as one request for study purpose

*** Electrically Remote Interconnection Requests

C: Study Groupings

Cluster	Request	Amount	Area	Proposed Point of Interconnection
Prior Queued	GEN-2001-014	96	WFEC	Fort Supply 138kV
	GEN-2001-037	100	OKGE	Windfarm Switching 138kV
	GEN-2002-005	120	WFEC	Morewood - Elk City 138kV
	GEN-2005-005	18	OKGE	Windfarm Switching 138kV
	GEN-2005-008	120	OKGE	Woodward 138kV
	GEN-2006-024	20	WFEC	South Buffalo Tap 69kV
	GEN-2006-046	131	OKGE	Dewey 138kV
	GEN-2007-006	160	OKGE	Roman Nose 138kV
	GEN-2007-021	201	OKGE	*Tatonga 345kV
	GEN-2007-044	300	OKGE	*Tatonga 345kV
	GEN-2007-050	170	OKGE	*Woodward 345kV
	GEN-2007-051	200	WFEC	Mooreland 138kV
	GEN-2007-062**	765	OKGE	*Woodward 345kV
	GEN-2008-003	101	OKGE	*Woodward EHV 138kV
	GEN-2008-019**	300	OKGE	*Tatonga 345kV
	GEN-2008-029	250.5	OKGE	Woodward 345kV
	GEN-2008-044	197.8	OKGE	Tatonga 345kV
	GEN-2010-008	64.4	WFEC	Tap Woodward - Fargo Junction 69kV
	GEN-2010-011	29.7	OKGE	GEN-2008-044 345kV
PRIOR QUEUED SUBTOTAL		3,344.4		
Cluster	Request	Amount	Area	Proposed Point of Interconnection
Woodward	GEN-2010-023	99	OKGE	WFEC Iodine 138kV
WOODWARD SUBTOTAL		99		
AREA SUBTOTAL		3,443.4		

Appendix C: Study Groupings



Cluster	Request	Amount	Area	Proposed Point of Interconnection
Prior Queued	SPS Distribution	90	SPS	Various
	GEN-2002-006	150	SPS	Texas County 115kV
	GEN-2002-008	240	SPS	Hitchland 345kV
	GEN-2002-009	80	SPS	Hansford County 115kV
	GEN-2003-013	198	SPS	Hitchland - Finney 345kV
	GEN-2003-020	160	SPS	Carson County 115kV
	GEN-2005-017	340	SPS	Hitchland - Potter County 345kV
	GEN-2006-020	18.9	SPS	Hitchland - Sherman County Tap 115kV
	GEN-2006-044	370	SPS	Hitchland 345kV
	GEN-2006-049	400	SPS	Hitchland - Finney 345kV
	GEN-2007-005	200	SPS	Pringle 115kV
	GEN-2007-046	200	SPS	TAP & TIE TEXAS COUNTY-HITCHLAND & DWS FRISCO TAP-HITCHLAND 115kV
	GEN-2007-057	35	SPS	Moore County East 115kV
	GEN-2008-028	360	SPS	Hitchland 345kV
	GEN-2008-047	300	SPS	Tap Hitchland – Woodward 345kV
	GEN-2008-110	299.2	SPS	Hitchland 345kV
	GEN-2010-007	73.8	SPS	Tap Pringle – Riverview 115kV
	GEN-2010-014	358.8	SPS	Hitchland 345kV
PRIOR QUEUED SUBTOTAL		3,873.7		
Cluster	Request	Amount	Area	Proposed Point of Interconnection
Hitchland	GEN-2009-069	400	SPS	Hitchland – Woodward 345kV
HITCHLAND SUBTOTAL		400		
AREA SUBTOTAL		4,273.7		

Cluster	Request	Amount	Area	Proposed Point of Interconnection
Prior Queued	Montezuma	110	MKEC	Haggard 115kV
	GEN-2001-039A	105	WPEK	Greensburg - Judson-Large 115kV
	GEN-2002-025A	150	WPEK	Spearville 230kV
	GEN-2004-014	155	MIDW	Spearville 230kV
	GEN-2005-012	250	WPEK	Spearville 345kV
	GEN-2006-006	206	MKEC	Spearville 230kV
	GEN-2006-021	101	WPEK	Flat Ridge Tap 138kV
	GEN-2006-022	150	WPEK	Ninnescah Tap 115kV
	GEN-2007-038	200	SUNC	Spearville 345kV
	GEN-2007-040	200	SUNC	Tap Holcomb – Spearville 345kV
	GEN-2008-018	405	SUNC	Finney 345kV
	GEN-2008-079	100.5	MKEC	Tap Judson Large – Cudahy 115kV
	GEN-2008-124	200.1	MKEK	Spearville 230kV
	GEN-2009-059	100.5	SUNC	Tap GEN-2008-079 – Cudahy 115kV
	GEN-2009-062	115	SUNC	Hugoton 115kV
	GEN-2010-009	165.6	SUNC	Gray County 345kV
	GEN-2010-015	200.1	SUNC	Spearville 345kV
	GEN-2010-016	199.8	SUNC	Tap Spearville – Knoll 345kV
PRIOR QUEUED SUBTOTAL		3,113.6		
Cluster	Request	Amount	Area	Proposed Point of Interconnection
Spearville	GEN-2010-027	900	SUNC	Spearville 345kV
SPEARVILLE SUBTOTAL		900		
AREA SUBTOTAL		4,013.6		

Appendix C: Study Groupings



Cluster	Request	Amount	Area	Proposed Point of Interconnection
Prior Queued	GEN-2001-039M	100	SUNC	Tap Leoti - City Services 115kV
	GEN-2006-034	81	SUNC	Tap Kanarado - Sharon Springs 115kV
	GEN-2006-040	108	SUNC	Mingo 115kV
	GEN-2007-011	135	SUNC	Syracuse 115kV
	GEN-2007-013	99	SUNC	Selkirk 115kV
	GEN-2008-017	300	SUNC	Setab 345kV
	GEN-2008-025	101.2	SUNC	Ruleton 115kV
PRIOR QUEUED SUBTOTAL		924.2		
MINGO/NW KANSAS SUBTOTAL		924.2		

Cluster	Request	Amount	Area	Proposed Point of Interconnection
Prior Queued	Llano Estacado	80	SPS	Llano Estacado Tap 115kV
	GEN-2002-022	240	SPS	Bushland 230kV
	GEN-2005-021	86	SPS	Kirby 115kV
	GEN-2006-039	400	SPS	Tap and Tie both Potter County - Plant X 230kV and Bushland - Deaf Smith 230kV
	GEN-2006-045	240	SPS	Tap and Tie both Potter County - Plant X 230kV and Bushland - Deaf Smith 230kV
	GEN-2006-047	240	SPS	Tap and Tie both Potter County - Plant X 230kV and Bushland - Deaf Smith 230kV
	GEN-2007-002	160	SPS	Grapevine 115kV
	GEN-2007-048	400	SPS	Tap Amarillo South – Swisher 230kV
	GEN-2008-051	322	SPS	Potter 345kV
	GEN-2008-088	50.6	SPS	Vega 69kV
PRIOR QUEUED SUBTOTAL		2,218.6		
AMARILLO SUBTOTAL		2,218.6		

Cluster	Request	Amount	Area	Proposed Point of Interconnection
Prior Queued	GEN-2001-033	180	SPS	San Juan Mesa Tap 230kV
	GEN-2001-036	80	SPS	Caprock Tap 115kV
	GEN-2005-010	160	SPS	Roosevelt County - Tolk West 230kV (Single Ckt Tap)
	GEN-2005-015	150	SPS	Tuco - Oklaunion 345kV
	GEN-2006-018	170	SPS	Tuco 230kV
	GEN-2007-034	150	SPS	Tolk - Eddy County 345kV
	GEN-2008-008	60	SPS	Graham 115kV
	GEN-2008-009	60	SPS	San Juan Mesa 230kV
	GEN-2008-014	150	SPS	Tuco - Oklaunion 345kV
	GEN-2008-016	248	SPS	Grassland 230kV
	GEN-2008-022	300	SPS	Tap Eddy – GEN-2007-034 345kV
	GEN-2009-017	60	SPS	Pembrook – Stiles 138kV
	GEN-2009-067S	20	SPS	7 Rivers 69kV
	GEN-2010-006	205	SPS	Jones 345kV
	ASGI-2010-010	42	SPS	Lovington 115kV
PRIOR QUEUED SUBTOTAL		2,035		
Cluster	Request	Amount	Area	Proposed Point of Interconnection
New Mexico & West Texas	GEN-2010-020	20	SPS	Roswell 69kV
	GEN-2010-021	20	SPS	Atoka 69kV
	NM & WEST TEXAS AREA SUBTOTAL		40	
AREA SUBTOTAL		2,075		

Appendix C: Study Groupings




Cluster	Request	Amount	Area	Proposed Point of Interconnection
Prior Queued	GEN-2001-026	74	WFEC	Washita 138kV
	GEN-2003-004	101	WFEC	Washita 138kV
	GEN-2003-005	100	WFEC	Tap Anadarko - Paradise 138kV
	GEN-2003-022	120	AEPW	Washita 138kV
	GEN-2004-020	27	AEPW	Washita 138kV
	GEN-2004-023	21	WFEC	Washita 138kV
	GEN-2005-003	31	WFEC	Washita 138kV
	GEN-2006-002	150	AEPW	Tap Grapevine - Elk City 230kV
	GEN-2006-035	225	AEPW	Tap Grapevine - Elk City 230kV
	GEN-2006-043	99	AEPW	Tap Grapevine - Elk City 230kV
	GEN-2007-032	150	WFEC	Tap Clinton Junction - Clinton 138kV
	GEN-2007-043	300	AEPW	Tap Lawton Eastside - Cimarron 345kV
	GEN-2007-052	150	WFEC	Anadarko 138kV
	GEN-2008-023	150	AEPW	Hobart Junction 138kV
	GEN-2008-037	100.8	WFEC	Tap Washita – Blue Canyon 138kV
	GEN-2009-016	140.3	AEPW	Falcon Road 138kV
	GEN-2009-030	100.8	WFEC	Weatherford 138kV
	GEN-2009-060	84	WFEC	Gotebo 69kV
PRIOR QUEUED SUBTOTAL		2,123.9		
Cluster	Request	Amount	Area	Proposed Point of Interconnection
SW Oklahoma	GEN-2010-018	100.8	WFEC	Erick 138kV
	GEN-2010-019	52.2	WFEC	Carter Junction 69kV
SW OKLAHOMA SUBTOTAL		153		
AREA SUBTOTAL		2,276.9		
Cluster	Request	Amount	Area	Proposed Point of Interconnection
North Oklahoma	ASGI-2010-006	150	AECI	Tap Fairfax – Fairfax Tap 138kV
	ASGI-2010-007	150	AECI	Tap Fairfax – Fairfax Tap 138kV
	GEN-2002-004	200	WERE	Latham 345kV
	GEN-2004-010	300	WERE	Latham 345kV
	GEN-2005-013	201	WERE	Tap Latham - Neosho
	GEN-2005-016	150	WERE	Tap Latham - Neosho
	GEN-2007-025	300	WERE	Tap Woodring – Wichita 345kV
	GEN-2008-013	300	OKGE	Tap Woodring – Wichita 345kV
	GEN-2008-021	42	WERE	Wolf Creek 25kV
	GEN-2008-038	144	AEPW	Tap Shidler – West Pawhuska 138kV
	GEN-2008-071	76.8	OKGE	Newkirk 138kV
	GEN-2008-098	100.8	WERE	Tap Wolf Creek – LaCygne 345kV
	GEN-2008-127	200.1	WERE	Tap Sooner – Rose Hill 345kV
	GEN-2009-025	60	OKGE	Tap Deer Creek – Sinclair 69kV
	GEN-2010-003	100.8	WERE	GEN-2008-098 345kV
	GEN-2010-005	300	MKEC	GEN-2007-025 345kV
	GEN-2010-013	50.4	WERE	GEN-2005-013 345kV
PRIOR QUEUED SUBTOTAL		2,825.9		
NORTH OKLAHOMA SUBTOTAL		2,825.9		


Cluster	Request	Amount	Area	Proposed Point of Interconnection
---------	---------	--------	------	-----------------------------------

D: Proposed Point of Interconnection One line Diagrams


GEN-2009-069




GEN-2010-018



GEN-2010-019




GEN-2010-020




* Planned

^ Proposed


GEN-2010-021




GEN-2010-022



GEN-2010-023




GEN-2010-024




GEN-2010-025


**Decatur South (EMDE) 161 kV
switching station**



GEN-2010-026



GEN-2010-027



E: Cost Allocation per Interconnection Request

Appendix E. - Cost Allocation Per Request

(Including Previously Allocated Network Upgrades*)

Interconnection Request	Upgrade Type	Allocated Costs	E + C Costs
GEN-2009-069			
GEN-2009-069 Interconnection Costs	Current Study Allocation	\$2,000,000.00	\$2,000,000.00
Hitchland - Woodward 345kV CKT 1 via GEN-2008-047 Tap	Previously Assigned		\$168,000,000.00
Comanche - Woodward 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$80,000,000.00
Medicine Lodge - Wichita 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$90,000,000.00
Comanche - Medicine Lodge 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$60,000,000.00
Stevens County - Gray County 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$58,200,000.00
Hitchland - Woodward 345kv CKT 2	DISIS-2010-001 Allocation		\$168,000,000.00
Finney Switching Station - Holcomb 345KV CKT 2 Per GEN-2006-044 Facility Study	Previously Allocated		\$6,299,839.00
Spearville (SPEARVL6-2) 230/115/13.8KV Transformer CKT 1	Previously Assigned		\$3,000,000.00
Spearville (SPEARVL2) 345/230/13.8KV Transformer CKT 1	Previously Assigned		\$6,000,000.00
Current Study Total		\$2,000,000.00	
GEN-2010-018			
GEN-2010-018 Interconnection Costs	Current Study Allocation	\$1,500,000.00	\$1,500,000.00
Elk City - Clinton Junction 138kv Rebuild	Current Study Allocation	\$13,847,351.38	\$19,200,000.00
Brantley - Sweetwater 138kv Rebuild	Current Study Allocation	\$44,000,000.00	\$44,000,000.00
Replace Carter Junction - Lake Creek 69kv Terminal Equipment	Current Study Allocation	\$11,008.30	\$50,000.00
Comanche - Woodward 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$80,000,000.00
Medicine Lodge - Wichita 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$90,000,000.00
Comanche - Medicine Lodge 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$60,000,000.00
Hitchland - Woodward 345kV CKT 1 via GEN-2008-047 Tap	Previously Assigned		\$168,000,000.00
Current Study Total		\$59,358,359.68	
GEN-2010-019			

* Current Study Requests' Costs of Previously Allocated Network Upgrades will be determined by a restudy, if necessary.

Interconnection Request	Upgrade Type	Allocated Costs	E + C Costs
GEN-2010-019 Interconnection Costs	Current Study Allocation	\$850,000.00	\$850,000.00
Replace Carter Junction - Lake Creek 69kv Terminal Equipment	Current Study Allocation	\$38,991.70	\$50,000.00
Elk City - Clinton Junction 138kv Rebuild	Current Study Allocation	\$5,352,648.62	\$19,200,000.00
Comanche - Woodward 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$80,000,000.00
Comanche - Medicine Lodge 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$60,000,000.00
Medicine Lodge - Wichita 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$90,000,000.00
Current Study Total		\$6,241,640.32	
GEN-2010-020			
GEN-2010-020 Interconnection Costs	Current Study Allocation	\$850,000.00	\$850,000.00
Midpoint(Wheeler) - TUCO Interchange 345KV CKT 1 Total E & C Cost for TUCO - Woodward Project	Previously Allocated		\$229,000,000.00
Midpoint(Wheeler) - Woodward 345KV CKT 1 Total E & C Cost for TUCO - Woodward Project	Previously Allocated		\$229,000,000.00
Comanche - Woodward 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$80,000,000.00
Hitchland - Woodward 345kV CKT 1 via GEN-2008-047 Tap	Previously Assigned		\$168,000,000.00
Medicine Lodge - Wichita 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$90,000,000.00
Comanche - Medicine Lodge 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$60,000,000.00
Finney Switching Station - Holcomb 345KV CKT 2 Per GEN-2006-044 Facility Study	Previously Allocated		\$6,299,839.00
Current Study Total		\$850,000.00	
GEN-2010-021			
GEN-2010-021 Interconnection Costs	Current Study Allocation	\$850,000.00	\$850,000.00
Midpoint(Wheeler) - TUCO Interchange 345KV CKT 1 Total E & C Cost for TUCO - Woodward Project	Previously Allocated		\$229,000,000.00
Midpoint(Wheeler) - Woodward 345KV CKT 1 Total E & C Cost for TUCO - Woodward Project	Previously Allocated		\$229,000,000.00
Comanche - Woodward 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$80,000,000.00
Hitchland - Woodward 345kV CKT 1 via GEN-2008-047 Tap	Previously Assigned		\$168,000,000.00
Comanche - Medicine Lodge 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$60,000,000.00

* Current Study Requests' Costs of Previously Allocated Network Upgrades will be determined by a restudy, if necessary.

Interconnection Request	Upgrade Type	Allocated Costs	E + C Costs
Medicine Lodge - Wichita 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$90,000,000.00
Finney Switching Station - Holcomb 345KV CKT 2 Per GEN-2006-044 Facility Study	Previously Allocated		\$6,299,839.00
Current Study Total			\$850,000.00
GEN-2010-022			
GEN-2010-022 Interconnection Costs	Current Study Allocation	\$3,500,000.00	\$3,500,000.00
Current Study Total			\$3,500,000.00
GEN-2010-023			
GEN-2010-023 Interconnection Costs	Current Study Allocation	\$2,500,000.00	\$2,500,000.00
Iodine - Woodward 138kv CKT 1	Current Study Allocation	\$19,800,000.00	\$19,800,000.00
Comanche - Woodward 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$80,000,000.00
Medicine Lodge - Wichita 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$90,000,000.00
Comanche - Medicine Lodge 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$60,000,000.00
Midpoint(Wheeler) - Woodward 345KV CKT 1 Total E & C Cost for TU CO - Woodward Project	Previously Allocated		\$229,000,000.00
Midpoint(Wheeler) - TU CO Interchange 345KV CKT 1 Total E & C Cost for TU CO - Woodward Project	Previously Allocated		\$229,000,000.00
Spearville (SPEARVL6-2) 230/115/13.8KV Transformer CKT 1	Previously Assigned		\$3,000,000.00
Current Study Total			\$22,300,000.00
GEN-2010-024			
GEN-2010-024 Interconnection Costs	Current Study Allocation	\$4,000,000.00	\$4,000,000.00
Valentine - GEN-2010-024 115kv CKT 1	Current Study Allocation	\$50,000,000.00	\$50,000,000.00
Stuart - Oneill 115kv	Current Study Allocation	\$28,000,000.00	\$28,000,000.00
Spearville - Comanche 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$50,000,000.00
Current Study Total			\$82,000,000.00
GEN-2010-025			
GEN-2010-025 Interconnection Costs	Current Study Allocation	\$2,000,000.00	\$2,000,000.00
Current Study Total			\$2,000,000.00
GEN-2010-026			

* Current Study Requests' Costs of Previously Allocated Network Upgrades will be determined by a restudy, if necessary.

Interconnection Request	Upgrade Type	Allocated Costs	E + C Costs
GEN-2010-026 Interconnection Costs	Current Study Allocation	\$1,500,000.00	\$1,500,000.00
Spearville - Comanche 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$50,000,000.00
Current Study Total		\$1,500,000.00	
GEN-2010-027			
GEN-2010-027 Interconnection Costs	Current Study Allocation	\$6,000,000.00	\$6,000,000.00
Spearville - Comanche 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$50,000,000.00
Comanche - Woodward 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$80,000,000.00
Comanche - Medicine Lodge 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$60,000,000.00
Medicine Lodge - Wichita 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$90,000,000.00
Stevens County - Gray County 345KV CKT 1 Per Cluster I Impact Restudy	Previously Allocated		\$58,200,000.00
Midpoint(Wheeler) - Woodward 345KV CKT 1 Total E & C Cost for TU CO - Woodward Project	Previously Allocated		\$229,000,000.00
Midpoint(Wheeler) - TU CO Interchange 345KV CKT 1 Total E & C Cost for TU CO - Woodward Project	Previously Allocated		\$229,000,000.00
Current Study Total		\$6,000,000.00	

* Current Study Requests' Costs of Previously Allocated Network Upgrades will be determined by a restudy, if necessary.

F: Cost Allocation per Network Upgrade

Appendix F. - Cost Allocation Per Upgrade Facility

Upgrade Facility	Allocated Costs	E + C Costs
Brantley - Sweetwater 138kv Rebuild	\$44,000,000.00	
GEN-2010-018	\$44,000,000.00	
Total	\$44,000,000.00	
Elk City - Clinton Junction 138kv Rebuild		\$19,200,000.00
GEN-2010-018	\$13,847,351.38	
GEN-2010-019	\$5,352,648.62	
Total	\$19,200,000.00	
GEN-2009-069 Interconnection Costs		\$2,000,000.00
GEN-2009-069	\$2,000,000.00	
Total	\$2,000,000.00	
GEN-2010-018 Interconnection Costs		\$1,500,000.00
GEN-2010-018	\$1,500,000.00	
Total	\$1,500,000.00	
GEN-2010-019 Interconnection Costs		\$850,000.00
GEN-2010-019	\$850,000.00	
Total	\$850,000.00	
GEN-2010-020 Interconnection Costs		\$850,000.00
GEN-2010-020	\$850,000.00	
Total	\$850,000.00	
GEN-2010-021 Interconnection Costs		\$850,000.00
GEN-2010-021	\$850,000.00	
Total	\$850,000.00	
GEN-2010-022 Interconnection Costs		\$3,500,000.00
GEN-2010-022	\$3,500,000.00	
Total	\$3,500,000.00	
GEN-2010-023 Interconnection Costs		\$2,500,000.00
GEN-2010-023	\$2,500,000.00	

Upgrade Facility	Allocated Costs	E + C Costs
	Total	\$2,500,000.00
GEN-2010-024 Interconnection Costs		\$4,000,000.00
GEN-2010-024	\$4,000,000.00	
	Total	\$4,000,000.00
GEN-2010-025 Interconnection Costs		\$2,000,000.00
GEN-2010-025	\$2,000,000.00	
	Total	\$2,000,000.00
GEN-2010-026 Interconnection Costs		\$1,500,000.00
GEN-2010-026	\$1,500,000.00	
	Total	\$1,500,000.00
GEN-2010-027 Interconnection Costs		\$6,000,000.00
GEN-2010-027	\$6,000,000.00	
	Total	\$6,000,000.00
Iodine - Woodward 138kv CKT 1		\$19,800,000.00
GEN-2010-023	\$19,800,000.00	
	Total	\$19,800,000.00
Replace Carter Junction - Lake Creek 69kv Terminal Equipment		\$50,000.00
GEN-2010-018	\$11,008.30	
GEN-2010-019	\$38,991.70	
	Total	\$50,000.00
Stuart - Oneill 115kv		\$28,000,000.00
GEN-2010-024	\$28,000,000.00	
	Total	\$28,000,000.00
Valentine - GEN-2010-024 115kv CKT 1		\$50,000,000.00
GEN-2010-024	\$50,000,000.00	
	Total	\$50,000,000.00
Current Study Upgrades Total		\$186,600,000.00

G: FCITC Analysis (Interconnection Constraints)

H: FCITC Analysis

SOURCE	GROUP DISPATCH	SEASON	SINK	ELEMENT	DIRECTION	TDF	RATING	LOADING	CONTNAME
G10_027	3	10G	FOOTPRINT	'FPL SWITCH - WOODWARD 138KV CKT 1'	TO->FROM	0.04912	280	102.7751	'TATONGA EHV 345.00 - WWRDEHV7 345.00 345KV CKT 1'
G10_027	3	10G	FOOTPRINT	'FPL SWITCH - WOODWARD 138KV CKT 1'	TO->FROM	0.04912	280	107.7529	'TATONGA EHV 345.00 - WWRDEHV7 345.00 345KV CKT 1'
G10_027	3	10G	FOOTPRINT	'CIRCLE - MULLERGREN 230KV CKT 1'	TO->FROM	0.06195	313.2	101.1031	'SMOKYHLLS 230.00 - SUMMIT 230KV CKT 1'
G10_027	3	10G	FOOTPRINT	'MULLERGREN - SPEARVILLE 230KV CKT 1'	TO->FROM	0.11532	351.7	124.916	'G10-016TAP 345.00 - KNOLL345 345.00 345KV CKT 1'
G10_027	3	10G	FOOTPRINT	'MULLERGREN - SPEARVILLE 230KV CKT 1'	TO->FROM	0.11532	351.7	130.079	'G10-016TAP 345.00 - KNOLL345 345.00 345KV CKT 1'
G10_027	3	10G	FOOTPRINT	'MULLERGREN - SPEARVILLE 230KV CKT 1'	TO->FROM	0.11682	351.7	113.3677	'G10-016TAP 345.00 - SPEARVILLE 345KV CKT 1'
G10_027	3	10G	FOOTPRINT	'MULLERGREN - SPEARVILLE 230KV CKT 1'	TO->FROM	0.11682	351.7	118.5209	'G10-016TAP 345.00 - SPEARVILLE 345KV CKT 1'