



# Aggregate Facility Study SPP-2011-AG3-AFS-9

7/15/2013

SPP Engineering, SPP Transmission Service Studies



---

# Table of Contents

---

<b>Table of Contents .....</b>	<b>1</b>
<b>Executive Summary .....</b>	<b>2</b>
<b>Introduction.....</b>	<b>3</b>
<b>Financial Analysis .....</b>	<b>5</b>
<b>Third-Party Facilities .....</b>	<b>6</b>
<b>Study Methodology .....</b>	<b>6</b>
Description .....	6
Model Development.....	7
Transmission Request Modeling.....	8
Transfer Analysis .....	8
Curtailement and Redispatch Evaluation.....	8
<b>Study Results .....</b>	<b>9</b>
Study Analysis Results .....	9
Example A:.....	10
Example B:.....	10
Example C:.....	11
Study Definitions .....	11
<b>Conclusion .....</b>	<b>12</b>
<b>Appendix A .....</b>	<b>13</b>
BASE CASE SETTINGS: .....	13
ACCC CASE SETTINGS:.....	13

## Executive Summary

---

Pursuant to Attachment Z1 of the Southwest Power Pool, Inc. (SPP) Open Access Transmission Tariff (OATT), 1769 MW of long-term transmission service requests have been studied in this Aggregate Facility Study (AFS). The principal objective of the AFS is to identify system problems and potential modifications necessary to facilitate these transfers while maintaining or improving system reliability, as well as summarizing the operating limits and determination of the financial characteristics associated with facility upgrades. A highly tangible benefit of studying transmission requests aggregately under the SPP OATT Attachment Z1 is the sharing of costs among Transmission Customers using the same facility. Facility upgrade costs are allocated on a prorated basis to all requests positively impacting any individual overloaded facility.

Attachment Z2 further provides for facility upgrade cost recovery by stating: “Transmission Customers paying Directly Assigned Upgrade Costs for Service Upgrades or that are in excess of the Safe Harbor Cost Limit for Network Upgrades associated with new or changed Designated Resources and Project Sponsors paying Directly Assigned Upgrade Costs for Sponsored Upgrades shall receive revenue credits in accordance with Attachment Z2. Generation Interconnection Customers paying for Network Upgrades shall receive credits for new transmission service using the facility as specified in Attachment Z1.”

- The AFS determined that the total assigned facility upgrade Engineering and Construction (E&C) cost is \$292 million. Additionally, there are no E&C cost for third party facility upgrades assignable to the customer.
- Total upgrade levelized revenue requirements for all transmission requests after consideration of potential base plan funding is \$510 million.

To accommodate the requested SPP Transmission Service, third-party facilities must be upgraded when the third-party transmission provider determines that they are constrained. Third-party facilities include both first-tier neighboring facilities outside SPP and Transmission Owner facilities within SPP that are not under the SPP OATT. In this AFS, no third-party facilities were identified. Total E&C cost estimates for required third-party facility upgrades are applicable.

SPP will tender a Letter of Intent on July 15, 2013. This will open a 15-day window for Customer response. To remain in the Aggregate Transmission Service Study (ATSS), SPP must receive from the Customer by July 30, 2013, an executed Letter of Intent. The Letter of Intent will list options the Customer must choose to clarify their commitment to remain in the ATSS. The only action required on OASIS is to withdraw the request or leave the request in study mode.

At the conclusion of the ATSS, Service Agreements for each request for service will be tendered identifying the terms and conditions of the confirmed service.

If Customers withdraw from the ATSS after posting of this AFS, the AFS will be re-performed to determine final cost allocation and Available Transmission Capability (ATC) in consideration of the remaining ATSS participants. All allocated revenue requirements for facility upgrades are assigned

to the Customer in the AFS data tables. Potential base plan funding allowable is contingent upon validation of designated resources meeting Attachment J, Section III B criteria.

---

## Introduction

---

Important milestones and dates in SPP's Aggregate Transmission Study process:

- In 2005, the Federal Energy Regulatory Commission (FERC) accepted SPP's proposed Aggregate Transmission Study procedures in Docket ER05-109.
- In 2008, in Docket ER08-1379-000 SPP filed with FERC to pair open seasons closing during January 2010 with an effective date of August 9, 2008.
- In January 2010, in Docket ER10-659-000 SPP filed with FERC to extend its current practice of pairing open seasons through January 31, 2011, with an effective date of January 28, 2010.
- In March 2010, in Docket ER10-659-000 FERC issued a letter order accepting SPP's proposal to continue to pair open seasons through January 31, 2011, effective January 28, 2010.
- All requests for long-term transmission service with a signed study agreement received before October 1, 2011 for 2011-AG3 have been included in this third Aggregate Transmission Service Study (ATSS) of 2011.

Approximately 1769 MW of long-term Transmission Service was studied in this Aggregate Facility Study (AFS), and over \$510 million in transmission upgrades is proposed. The results of the AFS are detailed in Tables 1 through 6. Detailed results depict individual upgrade costs by study and potential base plan allowances determined by Attachments J and Z1. The [OATT](#) may be accessed at SPP's website by going to [SPP.org>Org Groups>Governing Documents](#).

To understand the extent to which Base Plan Upgrades may be applied to both Point-to-Point (PTP) and Network Transmission Services, it is necessary to highlight the definition of Designated Resource. Per Section 1.9a of the SPP OATT, a Designated Resource is:

“[a]ny designated generation resource owned, purchased or leased by a Transmission Customer to serve load in the SPP Region. Designated Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Transmission Customer's load on a non-interruptible basis.”

Network and PTP service has potential for base plan funding if the conditions for classifying upgrades associated with designated resources as Base Plan Upgrades as defined in Section III.B of Attachment J are met.

Pursuant to Attachment J, Section III B of the SPP OATT, the Transmission Customer must provide SPP information necessary to verify that the new or changed Designated Resource meets the following conditions:

1. Transmission Customer's commitment to the requested new or changed Designated Resource must have a duration of at least five years.
2. During the first year the Designated Resource is planned to be used by the Transmission Customer, the accredited capacity of the Transmission Customer's existing Designated Resources plus the lesser of:
  - a. The planned maximum net dependable capacity applicable to the Transmission Customer or
  - b. The requested capacity; shall not exceed 125% of the Transmission Customer's projected system peak responsibility determined pursuant to SPP Criteria 2.

According to Attachment Z1 Section VI.A, PTP customers pay the higher of the monthly transmission access charge (base rate) or the monthly revenue requirement associated with the assigned facility upgrades, including any prepayments for redispatch required during construction.

Network Integration Service Customers pay the total monthly transmission access charges and the monthly revenue requirement associated with the facility upgrades, including any prepayments for redispatch during construction.

Transmission Customers paying for a directly assigned Network Upgrade shall receive credits for new transmission service using the facility as specified in Attachment Z2.

Facilities identified as limiting the requested Transmission Service have been reviewed to determine the required in-service date of each Network Upgrade. The year that each Network Upgrade is required to accommodate a request is determined by interpolating between the applicable model years given the respective loading data. Both previously assigned facilities and the facilities assigned to this request for Transmission Service were evaluated.

In some instances, due to lead times for engineering and construction, Network Upgrades may not be available when required to accommodate a request for Transmission Service. When this occurs, the ATC with available Network Upgrades will be less than the capacity requested during either a portion of or all of the requested reservation period. As a result, the lowest seasonal allocated ATC within the requested reservation period will be offered to the Transmission Customer on an applicable annual basis as listed in Table 1. The ATC may be limited by transmission owner planned projects, expansion plan projects, or Customer assigned upgrades.

Some constraints identified in the AFS were not assigned to the Customer because SPP, the Transmission Provider, determined that upgrades are not required due to various reasons or the Transmission Owner has construction plans pending for these upgrades. These facilities are listed by reservation in Table 3. This table also includes constrained facilities in the current planning horizon that limit the rollover rights of the Transmission Customer. Table 6 lists possible redispatch pairs to allow start of service prior to completion of assigned Network Upgrades. Table 7 (if applicable) lists

deferment of expansion plan projects with different upgrades with the new required in service date as a result of this AFS.

---

## Financial Analysis

---

The AFS utilizes the allocated Customer's E&C cost in a present worth analysis to determine the monthly levelized revenue requirement of each facility upgrade over the term of the reservation. In some cases, Network Upgrades cannot be completed within the requested reservation period, thus deferred reservation periods will be utilized in the present worth analysis. If the Customer chose Option 2, Redispatch, in the Letter of Intent sent coincident with the initial AFS, the present worth analysis of revenue requirements will be based on the deferred term with redispatch in the subsequent AFS. The upgrade levelized revenue requirement includes interest, depreciation, and carrying costs.

Each request for Transmission Service is evaluated independently as the cost associated with each Network Upgrade is assigned to a request. When facilities are upgraded throughout the reservation period, the Transmission Customer shall 1) pay the total E&C costs and other annual operating costs associated with the new facilities, and 2) receive credits associated with the depreciated book value of removed usable facilities; salvage value of removed non-usable facilities; and the carrying charges, excluding depreciation, associated with all removed usable facilities based on their respective book values.

In the event that the engineering and construction of a previously assigned Network Upgrade may be accelerated, with no additional upgrades, to accommodate a new request for Transmission Service, the levelized present worth of only the incremental expenses though the reservation period of the new request, excluding depreciation, shall be assigned to the new request. These incremental expenses, excluding depreciation, include:

1. The levelized difference in present worth of the engineering and construction expenses given the change in date to complete construction to account for additional interest expense and reduced engineering and construction expense due to inflation,
2. The levelized present worth of all expediting fees, and
3. The levelized present worth of the incremental annual carrying charges, excluding depreciation and interest, during the new reservation period taking into account both:
  - a. The reservation in which the project was originally assigned, and
  - b. A reservation, if any, in which the project was previously accelerated.

In the case of a Base Plan Upgrade being displaced or deferred by an earlier in service date for a requested upgrade, achievable base plan avoided revenue requirements shall be determined per Attachment J, Section VII.B methodology. A deferred Base Plan Upgrade is defined as a different requested Network Upgrade needed at an earlier date that negates the need for the initial Base Plan

Upgrade within the planning horizon. A displaced Base Plan Upgrade is defined as the same Network Upgrade being displaced by a requested upgrade needed at an earlier date.

A 40-year service life assumption is utilized for Base Plan funded projects, unless another assumption is provided by the Transmission Owner. A present worth analysis of revenue requirements on a common year basis between the Base Plan and Requested Upgrades was performed to determine avoided Base Plan revenue requirements due to the displacement or deferral of the Base Plan Upgrade by the Requested Upgrade. The difference in present worth between the Base Plan and Requested Upgrades is assigned to the transmission requests impacting this upgrade based on the displacement or deferral.

---

## Third-Party Facilities

---

For third-party facilities listed in Table 3 and Table 5, the Transmission Customer is responsible for funding the necessary upgrades of these facilities per Section 21.1 of the Transmission Provider's OATT. In this AFS, third-party facilities were not identified. Total E&C cost estimates for required third-party facility upgrades are not applicable. The Transmission Provider will undertake reasonable efforts to assist the Transmission Customer in making arrangements for necessary engineering, permitting, and construction of the third-party facilities. Third-party facility upgrade E&C cost estimates are not utilized to determine the present worth value of levelized revenue requirements for SPP system Network Upgrades.

All modeled facilities within the Transmission Provider system were monitored during the development of this study, as well as certain facilities in first-tier neighboring systems. Third-party facilities must be upgraded when it is determined that they are overloaded while accommodating the requested Transmission Service. An agreement between the Customer and third party owner detailing the mitigation of the third party impact must be provided to the Transmission Provider prior to tendering of a Transmission Service Agreement. These facilities also include those owned by members of the Transmission Provider who have not placed their facilities under the Transmission Provider's OATT. Upgrades on the Southwest Power Administration network requires prepayment of the upgrade cost prior to construction of the upgrade.

Third-party facilities are evaluated for only those requests whose load sinks within the SPP footprint. The Customer must arrange for study of third party facilities for load that sinks outside the SPP footprint with the applicable Transmission Providers.

---

## Study Methodology

---

### **Description**

The facility study analysis was conducted to determine the steady-state impact of the requested service on the SPP and first tier non-SPP control area systems. The steady-state analysis was performed to ensure current SPP Criteria and NERC Reliability Standards requirements are fulfilled.

SPP conforms to NERC Reliability Standards, which provide strict requirements related to voltage violations and thermal overloads during normal conditions and during a contingency. NERC Standards require all facilities to be within normal operating ratings for normal system conditions and within emergency ratings after a contingency.

Normal operating ratings and emergency operating ratings monitored are Rate A and B in the SPP Model Development Working Group (MDWG) models, respectively. The upper bound and lower bound of the normal voltage range monitored is 105% and 95%. The upper bound and lower bound of the emergency voltage range monitored is 105% and 90%. Transmission Owner voltage monitoring criteria is used if more restrictive. The SPS Tuco 230 kV bus voltage is monitored at 92.5% due to pre-determined system stability limitations. The WERE Wolf Creek 345 kV bus voltage is monitored at 103.5% and 98.5% due to transmission operating procedure.

The contingency set includes all SPP control area branches and ties 69 kV and above; first tier non-SPP control area branches and ties 115 kV and above; any defined contingencies for these control areas; and generation unit outages for the control areas with SPP reserve share program redispatch. The monitor elements include all SPP control area branches, ties, and buses 69 kV and above, and all first tier non-SPP control area branches and ties 115 kV and above. Voltage monitoring was performed for SPP control area buses 69 kV and above.

A 3 % transfer distribution factor (TDF) cutoff was applied to all SPP control area facilities. For first tier non-SPP control area facilities, a 3 % TDF cutoff was applied to AECI, AMRN (Ameren), and ENTR (Entergy) control areas. A 2 % TDF cutoff was applied to WAPA. For voltage monitoring, a 0.02 per unit change in voltage must occur due to the transfer or modeling upgrades to be considered a valid limit to the transfer.

## **Model Development**

SPP used eight seasonal models to study the aggregate transfers of 1769 MW over a variety of requested service periods. The following SPP Transmission Expansion Plan 2012 Build 1 Cases were used to study the impact of the requested service on the transmission system:

- 2013 Summer Peak (13SP)
- 2013/14 Winter Peak (13WP)
- 2014 Summer Peak (14SP)
- 2014/15 Winter Peak (14WP)
- 2018 Summer Peak (18SP)
- 2018/19 Winter Peak (18WP)
- 2023 Summer Peak (23SP)
- 2023/24 Winter Peak (23WP)

The Summer Peak models apply to June through September and the Winter Peak models apply to December through March.

The chosen base case models were modified to reflect the current modeling information. One group of requests was developed from the aggregate of 1769 MW to model the requested service. From the eight seasonal models, two system scenarios were developed. Scenario 0 includes projected usage of transmission included in the SPP 2012 Series Cases. Scenario 5 includes transmission service not already included in the SPP 2012 Series Cases.



## **Transmission Request Modeling**

Network Integration Transmission Service requests are modeled as Generation to Load transfers in addition to Generation to Generation transfers. Network Integration Transmission Service requests are modeled as Generation to Load transfers in addition to Generation to Generation because the requested Network Integration Transmission Service is a request to serve network load with the new designated network resource, and the impacts on Transmission System are determined accordingly. Point-To-Point Transmission Service requests are modeled as Generation to Generation transfers. Generation to Generation transfers are accomplished by developing a post-transfer case for comparison by dispatching the request source and redispatching the request sink.

## **Transfer Analysis**

Using the selected cases both with and without the requested transfers modeled, the PSS/E Activity ACCC was run on the cases and compared to determine the facility overloads caused or impacted by the transfer. Transfer distribution factor cutoffs (SPP and 1<sup>st</sup>-Tier) and voltage threshold (0.02 change) were applied to determine the impacted facilities. The PSS/E options chosen to conduct the analysis can be found in Appendix A.

## **Curtailed and Redispatch Evaluation**

During any period in which SPP determines that a transmission constraint exists on and may impair Transmission System reliability, SPP will take whatever actions are reasonably necessary to maintain reliability. If SPP determines Transmission System reliability can be maintained by redispatching resources, it will evaluate the interim curtailment of existing confirmed service or interim redispatch of units to provide service prior to completion of any assigned Network Upgrades. Any redispatch may not unduly discriminate between the Transmission Owners' use of the Transmission System on behalf of their Native Load Customers and any Transmission Customer's use of the Transmission System to serve its designated load. Redispatch was evaluated to provide only interim service during the time frame prior to completion of any assigned Network Upgrades. Curtailment of existing confirmed service is evaluated to provide only interim service. Curtailment of existing confirmed service is only evaluated at the request of the transmission Customer.

SPP determined potential relief pairs to relieve the incremental MW impact on limiting facilities as identified in Table 6. Using the selected cases where the limiting facilities were identified, potential incremental and decremental units were identified by determining the generation amount available for increasing and decreasing from the units generation amount, maximum generation amount, and minimum generation amount. If the incremental or decremental amount was greater than 1 MW, the unit was considered as a potential incremental or decremental unit.

Generation shift factors were calculated for the potential incremental and decremental units using Managing and Utilizing System Transmission (MUST). Relief pairs from the generation shift factors for the incremental and decremental units with a greater than 3% TDF on the limiting constraint were determined from the incremental units with the lowest generation shift factors and decremental units with highest generation shift factors. If the aggregate redispatch amount for the potential relief pair was determined to be three times greater than the lower of the increment or decrement, then the

pair was determined not to be feasible and is not included. Transmission Customers can request SPP to provide additional relief pairs beyond those determined. The potential relief pairs were not evaluated to determine impacts on limiting facilities in the SPP and first tier systems. The SPP Reliability Coordinator would call upon the redispatch requirements before implementing NERC TLR Level 5a.

---

## Study Results

---

### **Study Analysis Results**

Tables 1 through 6 contain the AFS steady-state analysis results. Table 1 identifies the participating long-term Transmission Service requests included in the AFS. This table lists deferred start and stop dates both with and without redispatch (based on Customer selection of redispatch if available) and the minimum annual allocated ATC without upgrades and season of first impact.

Table 2 identifies total E&C cost allocated to each Transmission Customer, letter of credit requirements, third party E&C cost assignments, potential base plan E&C funding (lower of allocated E&C or Attachment J Section III B criteria), total revenue requirements for assigned upgrades without consideration of potential base plan funding, point-to-point base rate charge, total revenue requirements for assigned upgrades with consideration of potential base plan funding, and final total cost allocation to the Transmission Customer. In addition, Table 2 identifies SWPA upgrade costs which require prepayment in addition to other allocated costs.

Table 3 provides additional details for each request including all assigned facility upgrades required, allocated E&C costs, allocated revenue requirements for upgrades, upgrades not assigned to the Customer but required for service to be confirmed, credits to be paid for previously assigned AFS or Generation Interconnection Network Upgrades, and any required third party upgrades.

Table 4 lists all upgrade requirements with associated solutions needed to provide Transmission Service for the AFS, minimum ATC per upgrade with season of impact, earliest date upgrade is required (DUN), estimated date the upgrade will be completed, in service (EOC), and estimated E&C cost.

Table 5 lists identified third-party constrained facilities.

Table 6 identifies potential redispatch pairs available to relieve the aggregate impacts on identified constraints to prevent deferral of start of service.

Table 7 (if applicable) identifies deferred expansion plan projects that were replaced with requested upgrades at earlier dates.

The potential base plan funding allowable is contingent on meeting each of the conditions for classifying upgrades associated with designated resources as Base Plan Upgrades as defined in Section III.B of Attachment J. If the additional capacity of the new or changed Designated Resource exceeds the 125% resource to load forecast for the year of start of service, the requested resource is not eligible for base plan funding of required Network Upgrades and the full cost of the upgrades is assignable to the Customer.

If the request is for wind generation, the total requested capacity of wind generation plus existing wind generation capacity shall not exceed 20% of the customer's projected system peak responsibility in the first year the Designated Resource is planned to be used by the customer. If the five-year term and 125% resource to load criteria are met, (as well as the 20% wind resource to load criteria for wind generation requests) the requested capacity is multiplied by \$180,000 to determine the potential base plan funding allowable. The maximum potential base plan funding allowable may be less than the potential base plan funding allowable, due to the E&C cost allocated to the customer being lower than the potential amount allowable to the Customer. The Customer is responsible for any assigned upgrade costs in excess of potential base plan E&C funding allowable. Network Upgrades required for wind generation requests located in a zone other than the Customer POD shall be allocated as 67% base plan region-wide charge and 33% directly assigned to the Customer.

Regarding application of base plan funding for PTP requests, if PTP base rate exceeds upgrade revenue requirements without taking into effect the reduction of revenue requirements by potential base plan funding, then the base rate revenue pays back the Transmission Owner for upgrades and no base plan funding is applicable as the access charge must be paid as it is the higher of "OR" pricing.

However, if initially the upgrade revenue requirements exceed the PTP base rate, then potential base plan funding would be applicable. The test of the higher of "OR" pricing would then be made against the remaining assignable revenue requirements versus PTP base rate. Examples are as follows:

**Example A:**

E&C allocated for upgrades is \$74 million with revenue requirements of \$140 million and PTP base rate of \$101 million. Potential base plan funding is \$47 million, with the difference of \$27 million E&C assignable to the Customer. If the revenue requirements for the assignable portion is \$54 million and the PTP base rate is \$101 million, the Customer will pay the higher amount (so-called "or pricing") of \$101 million base rate of which \$54 million revenue requirements will be paid back to the Transmission Owners for the upgrades, and the remaining revenue requirements of \$86 million (\$140 million less \$54 million) will be paid by base plan funding.

**Example B:**

E&C allocated for upgrades is \$74 million with revenue requirements of \$140 million and PTP base rate of \$101 million. Potential base plan funding is \$10 million with the difference of \$64 million E&C assignable to the Customer. If the revenue requirements for this assignable portion is \$128 million and the PTP base rate is \$101 million, the Customer will pay the higher amount of \$128 million revenue requirements to be paid back to the Transmission Owners, and the remaining revenue requirements of \$12 million (\$140 million less \$128 million) will be paid by base plan funding.

### **Example C:**

E&C allocated for upgrades is \$25 million with revenue requirements of \$50 million and PTP base rate of \$101 million. Potential base plan funding is \$10 million. Base plan funding is not applicable as the higher amount of PTP base rate of \$101 million must be paid and the \$50 million revenue requirements will be paid from this.

The 125% resource to load determination is performed on a per request basis and is not based on a total of Designated Resource requests per Customer. A footnote will provide the maximum resource designation allowable for base plan funding consideration per Customer basis per year.

Base plan funding verification requires that each Transmission Customer with potential for base plan funding provide SPP attestation statements verifying that the firm capacity of the requested Designated Resource is committed for a minimum five year duration.

### **Study Definitions**

- The date upgrade needed date (DUN) is the earliest date the upgrade is required to alleviate a constraint considering all requests.
- End of construction (EOC) is the estimated date the upgrade will be completed and in service.
- Total engineering and construction cost (E&C) is the upgrade solution cost as determined by the Transmission Owner.
- The Transmission Customer's allocation of the E&C cost is based on the request (1) having an impact of at least 3% on the limiting element, and (2) having a positive impact on the upgraded facility.
- Minimum ATC is the portion of the requested capacity that can be accommodated without upgrading facilities.
- Annual ATC allocated to the Transmission Customer is determined by the least amount of allocated seasonal ATC within each year of a reservation period.

---

## Conclusion

---

The results of the AFS show that limiting constraints exist in many areas of the regional Transmission System. Due to these constraints, Transmission Service cannot be granted unless noted in Table 3.

The Transmission Provider will tender a Letter of Intent on July 15, 2013. This will open a 15-day window for Customer response. To remain in the Aggregate Transmission Service Study (ATSS), the Transmission Provider must receive from the Transmission Customer) by July 30, 2013, an executed Letter of Intent. The Letter of Intent will list options the Customer must choose to clarify their commitment to remain in the ATSS. The only action required on OASIS is to WITHDRAW the request or leave the request in STUDY mode.

The Transmission Provider must receive an unconditional and irrevocable letter of credit in the amount of the total allocated E&C costs assigned to the Customer. This letter of credit is not required for those facilities that are fully base plan funded. The amount of the letter of credit will be adjusted down on an annual basis to reflect cost recovery based on revenue allocation. The Transmission Provider will issue notifications to construct Network Upgrades to the constructing Transmission Owner after filing of necessary service agreements at FERC.

---

## Appendix A

---

### PSS/E CHOICES IN RUNNING LOAD FLOW PROGRAM AND ACCC

#### BASE CASE SETTINGS:

- Solutions: Fixed slope decoupled Newton-Raphson solution (FDNS)
- Tap adjustment: Stepping
- Area Interchange Control: Tie lines and loads
- Var limits: Apply immediately
- Solution Options:
  - Phase shift adjustment
  - Flat start
  - Lock DC taps
  - Lock switched shunts

#### ACCC CASE SETTINGS:

- Solutions: AC contingency checking (ACCC)
- MW mismatch tolerance: 0.5
- System intact rating: Rate A
- Contingency case rating: Rate B
- Percent of rating: 100
- Output code: Summary
- Min flow change in overload report: 3mw
- Excl'd cases w/ no overloads from report: YES
- Exclude interfaces from report: NO
- Perform voltage limit check: YES
- Elements in available capacity table: 60000
- Cutoff threshold for available capacity table: 99999.0
- Min. contng. Case Vltg chng for report: 0.02
- Sorted output: None
- Newton Solution:
- Tap adjustment: Stepping
- Area interchange control: Tie lines and loads (Disabled for generator outages)
- Var limits: Apply immediately
- Solution options:
  - Phase shift adjustment
  - Flat start
  - Lock DC taps
  - Lock switched shunts

Table 1 - Long-Term Transmission Service Requests Included in Aggregate Facility Study

Customer	Study Number	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date without interim redispach	Deferred Stop Date without interim redispach	Start Date with interim redispach	Stop Date with interim redispach	Minimum Allocated ATC (MW) within reservation period	Season of Minimum Allocated ATC within reservation period
AEPM	AG3-2011-088	76213445	WR	CSWS	31	12/1/2012	12/1/2032	12/31/2018	12/31/2038	12/1/2013	12/1/2033	0	13SP
BPAE	AG3-2011-043	76216638	WR	EES	100	12/1/2013	12/1/2018	6/1/2018	6/1/2023	12/1/2013	12/1/2018	0	14SP
BPAE	AG3-2011-044	76216640	WR	EES	50	12/1/2013	12/1/2018	6/1/2018	6/1/2023	12/1/2013	12/1/2018	0	14SP
BPAE	AG3-2011-045	76216631	WR	EES	124	12/1/2013	12/1/2018	6/1/2018	6/1/2023	12/1/2013	12/1/2018	0	14SP
CRGL	AG3-2011-053	76216558	SPS	EES	50	1/1/2013	1/1/2023	6/1/2018	6/1/2028	12/1/2013	12/1/2023	0	13SP
CRGL	AG3-2011-054	76216556	SPS	EES	100	1/1/2013	1/1/2023	6/1/2018	6/1/2028	12/1/2013	12/1/2023	0	13SP
CRGL	AG3-2011-055	76216551	SPS	EES	100	1/1/2013	1/1/2023	6/1/2018	6/1/2028	12/1/2013	12/1/2023	0	13SP
FPLP	AG3-2011-005	76143887	WR	EES	100	12/31/2012	12/31/2032	12/31/2018	12/31/2038	12/1/2013	12/1/2033	0	13SP
FPLP	AG3-2011-006	76143889	WR	EES	100	12/31/2012	12/31/2032	12/31/2018	12/31/2038	12/1/2013	12/1/2033	0	13SP
FPLP	AG3-2011-047	76216533	CSWS	EES	100	1/1/2013	1/1/2033	12/31/2018	12/31/2038	12/1/2013	12/1/2033	0	13SP
GSECGS	AG3-2011-031	76214890	OKGE	SPS	101	8/1/2012	1/1/2033	12/31/2018	5/31/2039	12/1/2013	5/1/2034	0	13SP
GSECGS	AG3-2011-032	76214894	SPS	SPS	175	12/1/2012	1/1/2043	6/1/2015	7/1/2045	12/1/2013	1/1/2044	0	13SP
KBPU	AG3-2011-019	76210042	MPS	KACY	100	1/1/2013	1/1/2043	6/1/2016	6/1/2046	12/1/2013	12/1/2043	0	13SP
KCPS	AG3-2011-026	76216053	SECI	KCPL	32	4/1/2012	4/1/2032	12/31/2018	4/1/2032	12/1/2013	4/1/2032	0	12SP
KCPS	AG3-2011-027	76216066	WPEK	KCPL	50	4/1/2012	4/1/2032	12/31/2018	4/1/2032	12/1/2013	4/1/2032	0	12SP
NMEC	AG3-2011-003	75350825	NPPD	WR	1	10/1/2014	10/1/2024	10/1/2014	10/1/2024	10/1/2014	10/1/2024	0	18SP
OMPA	AG3-2011-093	76216657	OKGE	OKGE	51	1/1/2013	1/1/2038	6/1/2015	6/1/2040	12/1/2013	12/1/2038	0	13SP
SECI	AG3-2011-089	76177839	SECI	SECI	24	7/1/2012	7/1/2032	6/1/2017	6/1/2037	12/1/2013	12/1/2033	0	13SP
SECI	AG3-2011-090	76192515	SPRM	SECI	50	1/1/2013	1/1/2019	6/1/2017	6/1/2023	Note 4	Note 4	0	13SP
SECI	AG3-2011-091	76192531	SECI	SECI	55	1/1/2014	1/1/2044	1/1/2018	1/1/2048	1/1/2014	1/1/2044	0	14SP
SECI	AG3-2011-092	76209412	KCPL	SECI	50	1/1/2013	1/1/2043	6/1/2017	6/1/2047	12/1/2013	12/1/2043	0	13SP
SPSM	AG3-2011-041	76213597	SPS	SPS	100	6/1/2013	6/1/2014	Note 3	Note 3	12/1/2013	6/1/2014	0	13SP
SPSM	AG3-2011-042	76213598	SPS	SPS	25	6/1/2014	6/1/2015	6/1/2014	6/1/2015	6/1/2014	6/1/2015	0	14SP
UCU	AG3-2011-022	76216331	WPEK	MPS	100	4/1/2012	4/1/2032	12/31/2018	4/1/2032	12/1/2013	4/1/2032	0	12SP

1769

**Note 1:** Start and Stop Dates with interim redispach are determined based on customers choosing option to pursue redispach to start service at Requested Start and Stop Dates or earliest date possible.

**Note 2:** Start dates with and without redispach are based on the assumed completion dates of previous Aggregate Transmission Service Studies currently being conducted. Actual start dates may differ from the potential start dates upon completion of the previous studies.

**Note 3:** Request is unable to be deferred due to fixed stop dates.

**Note 4:** Transmission customer did not select "remain in the study using interim redispach" option.

Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests

Customer	Study Number	Reservation	Engineering and Construction Cost of Upgrades Allocated to Customer for Revenue Requirements	<sup>1</sup> Letter of Credit Amount Required	<sup>2</sup> Potential Base Plan Engineering and Construction Funding Allowable	Notes	<sup>4</sup> Additional Engineering and Construction Cost for 3rd Party Upgrades	<sup>3,5</sup> Total Revenue Requirements for Assigned Upgrades Over Term of Reservation WITH Potential Base Plan Funding Allocation	Point-to-Point Base Rate Over Reservation Period	<sup>4</sup> Total Cost of Reservation Assignable to Customer Contingent Upon Base Plan Funding
AEPM	AG3-2011-088	76213445	\$ 3,309,053	\$ 16,223	\$ 3,292,831		\$ -	\$ 50,963	\$ -	\$ 50,963
BPAE	AG3-2011-043	76216638	\$ 4,929,156	\$ 4,929,156	\$ -		\$ -	\$ 9,037,643	\$ 7,680,000	\$ 9,037,643
BPAE	AG3-2011-044	76216640	\$ 2,464,577	\$ 2,464,577	\$ -		\$ -	\$ 4,518,820	\$ 3,840,000	\$ 4,518,820
BPAE	AG3-2011-045	76216631	\$ 5,506,873	\$ 5,506,873	\$ -		\$ -	\$ 10,100,040	\$ 9,523,200	\$ 10,100,040
CRGL	AG3-2011-053	76216558	\$ 1,721,663	\$ 1,721,663	\$ -		\$ -	\$ 3,733,747	\$ 7,680,000	\$ 7,680,000
CRGL	AG3-2011-054	76216556	\$ 3,443,325	\$ 3,443,325	\$ -		\$ -	\$ 7,467,492	\$ 15,360,000	\$ 15,360,000
CRGL	AG3-2011-055	76216551	\$ 3,443,325	\$ 3,443,325	\$ -		\$ -	\$ 7,467,492	\$ 15,360,000	\$ 15,360,000
FPLP	AG3-2011-005	76143887	\$ 15,633,159	\$ 15,633,160	\$ -		\$ -	\$ 39,195,890	\$ 30,720,000	\$ 39,195,890
FPLP	AG3-2011-006	76143889	\$ 15,633,159	\$ 15,633,160	\$ -		\$ -	\$ 39,195,890	\$ 30,720,000	\$ 39,195,890
FPLP	AG3-2011-047	76216533	\$ 10,582,511	\$ 10,582,510	\$ -		\$ -	\$ 33,062,300	\$ 30,720,000	\$ 33,062,300
GSECGS	AG3-2011-031	76214890	\$ 124,224,092	\$ 106,044,100	\$ 18,180,000		\$ -	\$ 244,965,960	\$ -	\$ 244,965,960
GSECGS	AG3-2011-032	76214894	\$ 18,954,173	\$ -	\$ 18,954,173		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
KBPU	AG3-2011-019	76210042	\$ 732,486	\$ 732,486	\$ -		\$ -	\$ 2,396,814	\$ 31,572,000	\$ 31,572,000
KCPS	AG3-2011-026	76216053	\$ 7,485,983	\$ 1,725,983	\$ 5,760,000		\$ -	\$ 4,295,761	\$ -	\$ 4,295,761
KCPS	AG3-2011-027	76216066	\$ 9,197,749	\$ 197,749	\$ 9,000,000		\$ -	\$ 516,702	\$ -	\$ 516,702
NMEC	AG3-2011-003	75350825	\$ 8,827,145	\$ 8,647,145	\$ 180,000		\$ -	\$ 13,518,627	\$ -	\$ 13,518,627
OMPA	AG3-2011-093	76216657	\$ 1,720,000	\$ -	\$ 1,720,000		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
SECI	AG3-2011-089	76177839	\$ 3,355,984	\$ 1,483	\$ 3,354,501		\$ -	\$ 4,100	\$ -	\$ 4,100
SECI	AG3-2011-090	76192515	\$ 3,615,621	\$ 3,615,621	\$ -		\$ -	\$ 10,885,150	\$ 15,966,120	\$ 15,966,120
SECI	AG3-2011-091	76192531	\$ 6,830	\$ -	\$ 6,830		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
SECI	AG3-2011-092	76209412	\$ 4,269,411	\$ -	\$ 4,269,411		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
SPSM	AG3-2011-041	76213597	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
SPSM	AG3-2011-042	76213598	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
UCU	AG3-2011-022	76216331	\$ 43,074,365	\$ 25,074,365	\$ 18,000,000		\$ -	\$ 79,193,452	\$ -	\$ 79,193,452
<b>Grand Total</b>			<b>\$ 292,130,640</b>		<b>\$ 82,717,746</b>			<b>\$ 509,606,842</b>		



Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests

<p><b>Note 1:</b> Letter of Credit required for financial security for transmission owner for network upgrades is determined by allocated engineering and construction costs less engineering and construction costs for upgrades when network customer is the transmission owner less the E &amp; C allocation of expedited projects. Letter of Credit is required for upgrades assigned to PTP requests. The amount of the letter of credit will be adjusted down on an annual basis to reflect cost recovery based on revenue allocation. This letter of credit is not required for those facilities that are fully base plan funded. The Letter Of Credit Amount listed is based on meeting OATT Attachment J requirements for base plan funding.</p>
<p><b>Note 2:</b> If potential base plan funding is applicable, this value is the lesser of the Engineering and Construction costs of assignable upgrades or the value of base plan funding calculated pursuant to Attachment J, Section III B criteria. Allocation of base plan funding is contingent upon verification of customer agreements meeting Attachment J, Section II B criteria. Not applicable if Point-to-Point base rate exceeds revenue requirements.</p>
<p><b>Note 3:</b> Revenue Requirements (RR) are based upon deferred end dates if applicable. Deferred dates are based upon customer's choice to pursue redispatch. Achievable Base Plan Avoided RR in the case of a Base Plan upgrade being displaced or deferred by an earlier in service date for a Requested Upgrade shall be determined per Attachment J, Section VII.C methodology. Assumption of a 40 year service life is utilized for Base Plan funded projects. A present worth analysis of RR on a common year basis between the Base Plan and Requested Upgrades was performed to determine avoided Base Plan RR due to the displacement or deferral of the Base Plan upgrade by the Requested Upgrade. The incremental increase in present worth of a Requested Upgrade on a common year basis as a Base Plan upgrade is assigned to the transmission requests impacting the upgrade based on the displacement or deferral. If the displacement analysis results in lower RR due to the shorter amortization period of the requested upgrade when compared to a base plan amortization period, then no direct assignment of the upgrade cost is made due to the displacement to an earlier start date.</p>
<p><b>Note 4:</b> For Point-to-Point requests, total cost is based on the higher of the base rate or assigned upgrade revenue requirements. For Network requests, the total cost is based on the assigned upgrade revenue requirement. Allocation of base plan funding will be determined after verification of designated resource meeting Attachment J, Section II B Criteria. Additionally E &amp; C of 3rd Party upgrades is assignable to Customer. This includes prepayments required for any SWPA upgrades. Revenue requirements for 3rd Party facilities are not calculated. Total cost to customer is based on assumption of Revenue Requirements with confirmation of base plan funding. Customer is responsible for negotiating redispatch costs if applicable. Customer is also responsible to pay credits for previously assigned upgrades that are impacted by their request. Credits can be paid from base plan funding if applicable.</p>
<p><b>Note 5:</b> RR with base plan funding may increase or decrease even if no base plan funding is applicable to a particular request if another request that shares the upgrade is now full base plan funded resulting in a different amortization period for the upgrade and thus different RR.</p>



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 BPAE AG3-2011-043

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
BPAE	76216638	WR	EES	100	12/1/2013	12/1/2018	6/1/2018	6/1/2023	\$ -	\$ 7,680,000	\$ 4,929,156	\$ 9,037,643
									\$ -	\$ 7,680,000	\$ 4,929,156	\$ 9,037,643

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76216638	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015			\$ 136,255	\$ 827,424	\$ 269,562
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes	\$ 4,792,901	\$ 49,623,119	\$ 8,768,081
Total						\$ 4,929,156	\$ 50,450,543	\$ 9,037,643

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216638	IATAN - NASHUA 345KV CKT 1	12/1/2013	6/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216638	Cherry Co - Gentleman 345 kV Ckt1	12/1/2013	1/1/2018		
	Cherry Co - Holt Co 345 kV Ckt1	12/1/2013	1/1/2018		
	Cherry Co 345 kV Terminal Upgrades	12/1/2013	1/1/2018		
	Multi - Centerton - Osage Creek 345 kV	6/1/2014	6/1/2016		Yes
	Multi - Flint Creek - Centerton 345 kV and Centerton - East Centerton 161 kV	6/1/2014	6/1/2014		
	Viola - Clearwater 138KV Ckt1	10/1/2014	6/1/2018		Yes
	Viola - Gill 138KV Ckt1	10/1/2014	6/1/2018		Yes
	Viola 345/138KV Transformer Ckt 1	10/1/2014	6/1/2018		Yes

Planned Projects

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216638	GOODYEAR JUNCTION - MCVICAR3 115kV	6/1/2014	6/1/2014		
	MCVICAR3 - 17TH & FAIRLAWN 115kV	12/1/2013	12/1/2014		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216638	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 BPAE AG3-2011-044

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
BPAE	76216640	WR	EES	50	12/1/2013	12/1/2018	6/1/2018	6/1/2023	\$ -	\$ 3,840,000	\$ 2,464,577	\$ 4,518,819
									\$ -	\$ 3,840,000	\$ 2,464,577	\$ 4,518,819

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76216640	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015			\$ 68,127	\$ 827,424	\$ 134,780
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes	\$ 2,396,450	\$ 49,623,119	\$ 4,384,039
Total						\$ 2,464,577	\$ 50,450,543	\$ 4,518,819

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216640	IATAN - NASHUA 345KV CKT 1	12/1/2013	6/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216640	Cherry Co - Gentleman 345 kV Ckt1	12/1/2013	1/1/2018		
	Cherry Co - Holt Co 345 kV Ckt1	12/1/2013	1/1/2018		
	Cherry Co 345 kV Terminal Upgrades	12/1/2013	1/1/2018		
	Multi - Centerton - Osage Creek 345 kV	6/1/2014	6/1/2016		
	Multi - Flint Creek - Centerton 345 kV and Centerton - East Centerton 161 kV	6/1/2014	6/1/2014		
	Viola - Clearwater 138KV Ckt1	10/1/2014	6/1/2018		Yes
	Viola - Gill 138KV Ckt1	10/1/2014	6/1/2018		Yes
	Viola 345/138KV Transformer Ckt 1	10/1/2014	6/1/2018		Yes

Planned Projects

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216640	GOODYEAR JUNCTION - MCVICAR3 115kV	6/1/2014	6/1/2014		
	MCVICAR3 - 17TH & FAIRLAWN 115kV	12/1/2013	12/1/2014		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216640	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 BPAE AG3-2011-045

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
BPAE	76216631	WR	EES	124	12/1/2013	12/1/2018	6/1/2018	6/1/2023	\$ -	\$ 9,523,200	\$ 5,506,873	\$ 10,100,042
									\$ -	\$ 9,523,200	\$ 5,506,873	\$ 10,100,042

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76216631	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015			\$ 173,376	\$ 827,424	\$ 343,001
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes	\$ 5,333,497	\$ 49,623,119	\$ 9,757,041
Total						\$ 5,506,873	\$ 50,450,543	\$ 10,100,042

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216631	IATAN - NASHUA 345KV CKT 1	12/1/2013	6/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216631	Cherry Co - Gentleman 345 kV Ckt1	12/1/2013	1/1/2018		
	Cherry Co - Holt Co 345 kV Ckt1	12/1/2013	1/1/2018		
	Cherry Co 345 kV Terminal Upgrades	12/1/2013	1/1/2018		
	Multi - Centerton - Osage Creek 345 kV	6/1/2014	6/1/2016		Yes
	Multi - Flint Creek - Centerton 345 kV and Centerton - East Centerton 161 kV	6/1/2014	6/1/2014		
	Viola - Clearwater 138KV Ckt1	10/1/2014	6/1/2018		Yes
	Viola - Gill 138KV Ckt1	10/1/2014	6/1/2018		Yes
	Viola 345/138KV Transformer Ckt 1	10/1/2014	6/1/2018		Yes

Planned Projects

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216631	GOODYEAR JUNCTION - MCVICAR3 115kV	6/1/2014	6/1/2014		
	MCVICAR3 - 17TH & FAIRLAWN 115kV	12/1/2013	12/1/2014		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216631	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
CRGL AG3-2011-053

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CRGL	76216558	SPS	EES	50	1/1/2013	1/1/2023	6/1/2018	6/1/2028	\$ -	\$ 7,680,000	\$ 1,721,663	\$ 3,733,747
									\$ -	\$ 7,680,000	\$ 1,721,663	\$ 3,733,747

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76216558	GLASS MOUNTAIN - MOORELAND 138KV CKT 1	12/1/2013	6/1/2015		Yes	\$ 4,871	\$ 40,500	\$ 9,121
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes	\$ 1,716,792	\$ 49,623,119	\$ 3,724,626
Total						\$ 1,721,663	\$ 49,663,619	\$ 3,733,747

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216558	IATAN - NASHUA 345KV CKT 1	12/1/2013	6/1/2015		Yes
	Line - Clark County - Thistle 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt OKGE	12/1/2013	7/1/2014		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt SPS	12/1/2013	7/1/2014		Yes
	Line - Spearville - Clark County 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt WERE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt OKGE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Tuco - Woodward 345 kv line OKGE	12/1/2013	6/1/2014		Yes
	Line - Tuco - Woodward 345 kv line SPS	12/1/2013	6/1/2014		Yes
	XFR - Thistle 345/138 kv	12/1/2013	1/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216558	Cherry Co - Gentleman 345 kv Ckt1	12/1/2013	1/1/2018		
	Cherry Co - Holt Co 345 kv Ckt1	12/1/2013	1/1/2018		
	Cherry Co 345 kv Terminal Upgrades	12/1/2013	1/1/2018		
	Multi - Centerton - Osage Creek 345 kv	6/1/2014	6/1/2016		
	Multi - Flint Creek - Centerton 345 kv and Centerton - East Centerton 161 kv	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216558	NORTHWEST 345/138/13.8KV TRANSFORMER CKT 3 Accelerated	12/1/2013	6/1/2015		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216558	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - IODINE 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - WOODWARD EHV 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD 345/138KV TRANSFORMER CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
CRGL AG3-2011-054

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CRGL	76216556	SPS	EES	100	1/1/2013	1/1/2023	6/1/2018	6/1/2028	\$ -	\$ 15,360,000	\$ 3,443,325	\$ 7,467,492
									\$ -	\$ 15,360,000	\$ 3,443,325	\$ 7,467,492

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
76216556	GLASS MOUNTAIN - MOORELAND 138KV CKT 1	12/1/2013	6/1/2015		Yes	\$ 9,742	\$ 40,500	\$ 18,242	
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes	\$ 3,433,583	\$ 49,623,119	\$ 7,449,250	
						Total	\$ 3,443,325	\$ 49,663,619	\$ 7,467,492

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216556	IATAN - NASHUA 345KV CKT 1	12/1/2013	6/1/2015		Yes
	Line - Clark County - Thistle 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt OKGE	12/1/2013	7/1/2014		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt SPS	12/1/2013	7/1/2014		Yes
	Line - Spearville - Clark County 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt WERE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt OKGE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Tuco - Woodward 345 kv line OKGE	12/1/2013	6/1/2014		Yes
	Line - Tuco - Woodward 345 kv line SPS	12/1/2013	6/1/2014		Yes
	XFR - Thistle 345/138 kv	12/1/2013	1/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216556	Cherry Co - Gentleman 345 kv Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co - Holt Co 345 kv Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co 345 kv Terminal Upgrades	12/1/2013	1/1/2018		Yes
	Multi - Centerton - Osage Creek 345 kv	6/1/2014	6/1/2016		Yes
	Multi - Flint Creek - Centerton 345 kv and Centerton - East Centerton 161 kv	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216556	NORTHWEST 345/138/13.8KV TRANSFORMER CKT 3 Accelerated	12/1/2013	6/1/2015		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216556	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - IODINE 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - WOODWARD EHV 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD 345/138KV TRANSFORMER CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
CRGL AG3-2011-055

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CRGL	76216551	SPS	EES	100	1/1/2013	1/1/2023	6/1/2018	6/1/2028	\$ -	\$ 15,360,000	\$ 3,443,325	\$ 7,467,492
									\$ -	\$ 15,360,000	\$ 3,443,325	\$ 7,467,492

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
76216551	GLASS MOUNTAIN - MOORELAND 138KV CKT 1	12/1/2013	6/1/2015		Yes	\$ 9,742	\$ 40,500	\$ 18,242	
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes	\$ 3,433,583	\$ 49,623,119	\$ 7,449,250	
						Total	\$ 3,443,325	\$ 49,663,619	\$ 7,467,492

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216551	NATAN - NASHUA 345KV CKT 1	12/1/2013	6/1/2015		Yes
	Line - Clark County - Thistle 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt OKGE	12/1/2013	7/1/2014		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt SPS	12/1/2013	7/1/2014		Yes
	Line - Spearville - Clark County 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt WERE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt OKGE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Tuco - Woodward 345 kv line OKGE	12/1/2013	6/1/2014		Yes
	Line - Tuco - Woodward 345 kv line SPS	12/1/2013	6/1/2014		Yes
	XFR - Thistle 345/138 kv	12/1/2013	1/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216551	Cherry Co - Gentleman 345 kv Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co - Holt Co 345 kv Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co 345 kv Terminal Upgrades	12/1/2013	1/1/2018		Yes
	Multi - Centerton - Osage Creek 345 kv	6/1/2014	6/1/2016		Yes
	Multi - Flint Creek - Centerton 345 kv and Centerton - East Centerton 161 kv	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216551	NORTHWEST 345/138/13.8KV TRANSFORMER CKT 3 Accelerated	12/1/2013	6/1/2015		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216551	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - IODINE 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - WOODWARD EHV 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD 345/138KV TRANSFORMER CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
FPLP AG3-2011-005

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
FPLP	76143887	WR	EES	100	12/31/2012	12/31/2032	12/31/2018	12/31/2038	\$ -	\$ 30,720,000	\$ 15,633,159	\$ 39,195,888
									\$ -	\$ 30,720,000	\$ 15,633,159	\$ 39,195,888

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76143887	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015			\$ 109,602	\$ 827,424	\$ 344,317
	HAYS PLANT - VINE STREET 115KV CKT 1 #1	6/1/2014	6/1/2015		Yes	\$ 14,844	\$ 35,000	\$ 44,635
	HAYS PLANT - VINE STREET 115KV CKT 1 #2	6/1/2014	6/1/2016		Yes	\$ 54,870	\$ 129,375	\$ 148,053
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes	\$ 5,314,125	\$ 49,623,119	\$ 15,437,318
	Potter to Tolk 345 kV (Please see upgrade description note in Table 4)	12/1/2013	12/31/2018		Yes	\$ 10,139,718	\$ 168,852,765	\$ 23,221,565
Total						\$ 15,633,159	\$ 219,467,683	\$ 39,195,888

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76143887	HARPER - MILAN TAP 138KV CKT 1 #1	12/1/2013	12/1/2014		Yes
	HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2	12/1/2013	6/1/2015		Yes
	Line - Clark County - Thistle 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt OKGE	12/1/2013	7/1/2014		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt SP5	12/1/2013	7/1/2014		Yes
	Line - Spearville - Clark County 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt WERE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt OKGE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Tuco - Woodward 345 kv line OKGE	12/1/2013	6/1/2014		Yes
	Line - Tuco - Woodward 345 kv line SP5	12/1/2013	6/1/2014		Yes
	MOUNDRIDGE 138/115KV TRANSFORMER CKT 2	12/1/2013	12/1/2014		Yes
	XFR - Thistle 345/138 kv	12/1/2013	1/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76143887	Cherry Co - Gentleman 345 kv Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co - Holt Co 345 kv Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co 345 kv Terminal Upgrades	12/1/2013	1/1/2018		Yes
	Viola - Clearwater 138kv Ckt1	10/1/2014	6/1/2018		Yes
	Viola - Gill 138kv Ckt1	10/1/2014	6/1/2018		Yes
	Viola 345/138kv Transformer Ckt 1	10/1/2014	6/1/2018		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76143887	CLEARWATER - MILAN TAP 138KV CKT 1 MKEC Accelerate	12/1/2013	6/1/2017		Yes
	CLEARWATER - MILAN TAP 138KV CKT 1 WERE Accelerate	12/1/2013	6/1/2017		Yes
	HARPER - MILAN TAP 138KV CKT 1 #2 Accelerate	12/1/2013	6/1/2017		Yes

Planned Projects

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76143887	GOODYEAR JUNCTION - MCVICAR3 115KV	6/1/2014	6/1/2014		
	MCVICAR3 - 17TH & FAIRLAWN 115KV	12/1/2013	12/1/2014		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment 22 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76143887	BARBER (BARBER 4) 138/115/2.72KV TRANSFORMER CKT 1	12/1/2009	6/1/2013		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1	12/1/2009	6/1/2013		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
FPLP AG3-2011-006

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
FPLP	76143889	WR	EES	100	12/31/2012	12/31/2032	12/31/2018	12/31/2038	\$ -	\$ 30,720,000	\$ 15,633,159	\$ 39,195,888
									\$ -	\$ 30,720,000	\$ 15,633,159	\$ 39,195,888

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76143889	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015			\$ 109,602	\$ 827,424	\$ 344,317
	HAYS PLANT - VINE STREET 115KV CKT 1 #1	6/1/2014	6/1/2015		Yes	\$ 14,844	\$ 35,000	\$ 44,635
	HAYS PLANT - VINE STREET 115KV CKT 1 #2	6/1/2014	6/1/2016		Yes	\$ 54,870	\$ 129,375	\$ 148,053
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes	\$ 5,314,125	\$ 49,623,119	\$ 15,437,318
	Potter to Tolk 345 kV (Please see upgrade description note in Table 4)	12/1/2013	12/31/2018		Yes	\$ 10,139,718	\$ 168,852,765	\$ 23,221,565
Total						\$ 15,633,159	\$ 219,467,683	\$ 39,195,888

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76143889	HARPER - MILAN TAP 138KV CKT 1 #1	12/1/2013	12/1/2014		Yes
	HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2	12/1/2013	6/1/2015		Yes
	Line - Clark County - Thistle 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt OKGE	12/1/2013	7/1/2014		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt SP5	12/1/2013	7/1/2014		Yes
	Line - Spearville - Clark County 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt WERE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt OKGE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Tuco - Woodward 345 kv line OKGE	12/1/2013	6/1/2014		Yes
	Line - Tuco - Woodward 345 kv line SP5	12/1/2013	6/1/2014		Yes
	MOUNDRIDGE 138/115KV TRANSFORMER CKT 2	12/1/2013	12/1/2014		Yes
	XFR - Thistle 345/138 kv	12/1/2013	1/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76143889	Cherry Co - Gentleman 345 kv Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co - Holt Co 345 kv Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co 345 kv Terminal Upgrades	12/1/2013	1/1/2018		Yes
	Viola - Clearwater 138kv Ckt1	10/1/2014	6/1/2018		Yes
	Viola - Gill 138kv Ckt1	10/1/2014	6/1/2018		Yes
	Viola 345/138kv Transformer Ckt 1	10/1/2014	6/1/2018		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76143889	CLEARWATER - MILAN TAP 138KV CKT 1 MKEC Accelerate	12/1/2013	6/1/2017		Yes
	CLEARWATER - MILAN TAP 138KV CKT 1 WERE Accelerate	12/1/2013	6/1/2017		Yes
	HARPER - MILAN TAP 138KV CKT 1 #2 Accelerate	12/1/2013	6/1/2017		Yes

Planned Projects

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76143889	GOODYEAR JUNCTION - MCVICAR3 115KV	6/1/2014	6/1/2014		
	MCVICAR3 - 17TH & FAIRLAWN 115KV	12/1/2013	12/1/2014		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment 22 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76143889	BARBER (BARBER 4) 138/115/2.72KV TRANSFORMER CKT 1	12/1/2009	6/1/2013		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1	12/1/2009	6/1/2013		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
FPLP AG3-2011-047

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
FPLP	76216533	CSWS	EES	100	1/1/2013	1/1/2033	12/31/2018	12/31/2038	\$ -	\$ 30,720,000	\$ 10,582,511	\$ 33,062,298
									\$ -	\$ 30,720,000	\$ 10,582,511	\$ 33,062,298

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76216533	CORNVILLE - NORGE ROAD 138KV CKT 1	6/1/2019	6/1/2019			\$ 6,357,000	\$ 6,357,000	\$ 19,858,946
	GLASS MOUNTAIN - MOORELAND 138KV CKT 1	12/1/2013	6/1/2015		Yes	\$ 16,145	\$ 40,500	\$ 36,396
	HOBART - HOBART JUNCTION 69KV CKT 1 Accelerate	12/1/2013	6/1/2017		Yes	\$ 230,370	\$ 230,370	\$ 797,557
	HOBART - ROOSEVELT TAP 69KV CKT 1 Accelerate	6/1/2014	6/1/2017		Yes	\$ 606,238	\$ 606,238	\$ 2,098,837
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes	\$ 2,524,025	\$ 49,623,119	\$ 7,332,190
	ROOSEVELT TAP - SNYDER 69KV CKT 1 Accelerate	12/1/2013	6/1/2017		Yes	\$ 848,733	\$ 848,733	\$ 2,938,371
Total						\$ 10,582,511	\$ 57,705,960	\$ 33,062,298

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216533	Grapevine 230/115kV Transformer Ckt 1	6/1/2014	6/1/2014		
	Line - Clark County - Thistle 345 kV dbI Ckt	12/1/2013	1/1/2015		Yes
	Line - Hitchland - Woodward 345 kV dbI Ckt OKGE	12/1/2013	7/1/2014		Yes
	Line - Hitchland - Woodward 345 kV dbI Ckt SPS	12/1/2013	7/1/2014		Yes
	Line - Spearville - Clark County 345 kV dbI Ckt	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kV dbI Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kV dbI Ckt WERE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kV dbI Ckt OKGE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kV dbI Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Tuco - Woodward 345 kV line OKGE	12/1/2013	6/1/2014		Yes
	Line - Tuco - Woodward 345 kV line SPS	12/1/2013	6/1/2014		Yes
	XFR - Thistle 345/138 kV	12/1/2013	1/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216533	Cherry Co - Gentleman 345 kV Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co - Holt Co 345 kV Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co 345 kV Terminal Upgrades	12/1/2013	1/1/2018		Yes
	Multi - Centerton - Osage Creek 345 kV	6/1/2014	6/1/2016		Yes
	Multi - Flint Creek - Centerton 345 kV and Centerton - East Centerton 161 kV	6/1/2014	6/1/2014		Yes
	NORGE ROAD - SOUTHWESTERN STATION 138KV CKT 1	6/1/2019	6/1/2019		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216533	BLUE CANYON - PARADISE 138KV CKT 1	6/1/2010	6/1/2013		
	CHERRY6 230.00 - Harrington Station East Bus 230KV CKT 1	6/1/2015	6/1/2015		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 OKGE	1/1/2012	1/1/2012		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 WFEC	1/1/2012	1/1/2012		
	HUGO POWER PLANT - VALLIANT 345 kV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - WOODWARD EHV 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD 345/138KV TRANSFORMER CKT 1	1/1/2010	1/1/2010		

Potential reservation deferral and redispatch requirement on the following upgrades due to positive MW Impact on limitations that require upgrade. No cost assignment due to negative MW impact on defined upgrade.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216533	ELK CITY - RED HILLS WIND 138KV CKT 1	6/1/2015	6/1/2016		Yes
	Potter to Tolk 345 kV (Please see upgrade description note in Table 4)	12/1/2013	12/31/2018		Yes

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
GSECGS AG3-2011-031

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
GSECGS	76214890	OKGE	SPS	101	8/1/2012	1/1/2033	12/31/2018	5/31/2039	\$ 18,180,000	\$ -	\$ 124,224,092	\$ 286,962,464
									\$ 18,180,000	\$ -	\$ 124,224,092	\$ 286,962,464

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76214890	Potter to Tolk 345 kV (Please see upgrade description note in Table 4)	12/1/2013	12/31/2018		Yes	\$ 18,180,000	\$ 106,044,092	\$ 124,224,092	\$ 168,852,765	\$ 286,962,464
					Total	\$ 18,180,000	\$ 106,044,092	\$ 124,224,092	\$ 168,852,765	\$ 286,962,464

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76214890	BAILEY COUNTY INTERCHANGE - CURRY COUNTY INTERCHANGE 115KV CKT 1	12/1/2013	6/1/2015		Yes
	Cox Interchange - Kiser 115 kV Ckt 1 #2	12/1/2013	2/28/2014		Yes
	DEAF SMITH COUNTY INTERCHANGE (I) 230/115/13.8KV TRANSFORMER CKT 1	6/1/2014	3/1/2015		Yes
	DEAF SMITH COUNTY INTERCHANGE (J) 230/115/13.8KV TRANSFORMER CKT 2	6/1/2014	3/1/2015		Yes
	Grapevine 230/115KV Transformer Ckt 1	6/1/2014	6/1/2014		
	Kiser Substation 115/69 kV Ckt 1	12/1/2013	2/28/2014		Yes
	Kress Interchange - Kiser 115 kV Ckt 1	12/1/2013	11/30/2014		Yes
	Line - Clark County - Thistle 345 kV dbI Ckt	12/1/2013	1/1/2015		Yes
	Line - Hitchland - Woodward 345 kV dbI Ckt OKGE	12/1/2013	7/1/2014		Yes
	Line - Hitchland - Woodward 345 kV dbI Ckt SPS	12/1/2013	7/1/2014		Yes
	Line - Spearville - Clark County 345 kV dbI Ckt	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kV dbI Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kV dbI Ckt WERE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kV dbI Ckt OKGE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kV dbI Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Tuco - Woodward 345 kV line OKGE	12/1/2013	6/1/2014		Yes
	Line - Tuco - Woodward 345 kV line SPS	12/1/2013	6/1/2014		Yes
	NEWHART INTERCHANGE PROJECT	6/1/2014	4/30/2015		Yes
	Renfrow - Grant County 138 kV line	12/1/2013	11/1/2014		Yes
	Renfrow 345/138 kV Transformer Ckt 1	12/1/2013	11/1/2014		Yes
	Renfrow Substation	6/1/2014	11/1/2014		Yes
	XFR - Thistle 345/138 kV	12/1/2013	1/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76214890	Hitchland 230/115/13.2 kV Transformer Ckt 2	6/1/2019	6/1/2019		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76214890	Jones Station Bus#2 - Lubbock South Interchange 230 kV CKT 2 terminal upgrade	6/1/2014	12/30/2014		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76214890	CHERRY6 230.00 - Harrington Station East Bus 230KV CKT 1	6/1/2015	6/1/2015		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 OKGE	1/1/2012	1/1/2012		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 WFEC	1/1/2012	1/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - IODINE 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - WOODWARD EHV 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD 345/138KV TRANSFORMER CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 GSECGS AG3-2011-032

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
GSECGS	76214894	SPS	SPS	175	12/1/2012	1/1/2043	6/1/2015	7/1/2045	\$ 18,954,173	\$ -	\$ 18,954,173	\$ 64,450,467
									\$ 18,954,173	\$ -	\$ 18,954,173	\$ 64,450,467

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76214894	Mustang to Shell CO2 115 kv	6/1/2015	12/31/2016			\$ 15,196,916	\$ 15,196,916	\$ 52,863,316
	YOAKUM COUNTY INTERCHANGE () 230/115/13.2KV TRANSFORMER CKT 1	6/1/2019	6/1/2019			\$ 3,757,257	\$ 3,757,257	\$ 11,587,150
<b>Total</b>						\$ 18,954,173	\$ 18,954,173	\$ 64,450,467

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76214894	BAILEY COUNTY INTERCHANGE - CURRY COUNTY INTERCHANGE 115KV CKT 1	12/1/2013	6/1/2015		Yes
	DEAF SMITH COUNTY INTERCHANGE () 230/115/13.8KV TRANSFORMER CKT 1	6/1/2014	3/1/2015		Yes
	DEAF SMITH COUNTY INTERCHANGE () 230/115/13.8KV TRANSFORMER CKT 2	6/1/2014	3/1/2015		Yes
	Line - Clark County - Thistle 345 kv dbi Ckt	12/1/2013	1/1/2015		
	Line - Hitchland - Woodward 345 kv dbi Ckt OKGE	12/1/2013	7/1/2014		
	Line - Hitchland - Woodward 345 kv dbi Ckt SPS	12/1/2013	7/1/2014		
	Line - Spearville - Clark County 345 kv dbi Ckt	12/1/2013	1/1/2015		
	Line - Thistle - Wichita 345 kv dbi Ckt PW	12/1/2013	1/1/2015		
	Line - Thistle - Wichita 345 kv dbi Ckt WERE	12/1/2013	1/1/2015		
	Line - Thistle - Woodward 345 kv dbi Ckt OKGE	12/1/2013	1/1/2015		
	Line - Thistle - Woodward 345 kv dbi Ckt PW	12/1/2013	1/1/2015		
	Line - Tuco - Woodward 345 kv line OKGE	12/1/2013	6/1/2014		
	Line - Tuco - Woodward 345 kv line SPS	12/1/2013	6/1/2014		
	NEWHART INTERCHANGE PROJECT	6/1/2014	4/30/2015		Yes
	XFR - Thistle 345/138 kv	12/1/2013	1/1/2015		

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76214894	Hitchland 230/115/13.2 kv Transformer Ckt 2	6/1/2019	6/1/2019		
	YOAKUM COUNTY INTERCHANGE () 230/115/13.2KV TRANSFORMER CKT 2	6/1/2019	6/1/2019		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76214894	CHERRY6 230.00 - Harrington Station East Bus 230KV CKT 1	6/1/2015	6/1/2015		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
KBPU AG3-2011-019

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KBPU	76210042	MPS	KACY	100	1/1/2013	1/1/2043	6/1/2016	6/1/2046	\$ -	\$ 31,572,000	\$ 732,486	\$ 2,396,814
									\$ -	\$ 31,572,000	\$ 732,486	\$ 2,396,814

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76210042	BLUE SPRING SOUTH - BLUE SPRINGS EAST 161KV CKT 1 #2 Accelerate	6/1/2014	6/1/2016		Yes	\$ 172,914	\$ 282,780	\$ 632,674
	KAW WEST 5 161/69KV TRANSFORMER CKT 1	6/1/2014	6/1/2014			\$ -	\$ -	\$ -
	LONGVIEW - WESTERN ELECTRIC 161KV CKT 1 #2	6/1/2019	6/1/2019			\$ 559,572	\$ 2,559,827	\$ 1,764,140
Total						\$ 732,486	\$ 2,842,607	\$ 2,396,814

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76210042	IATAN - NASHUA 345KV CKT 1	12/1/2013	6/1/2015		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76210042	BLUE SPRING SOUTH - BLUE SPRINGS EAST 161KV CKT 1 #1 Accelerate	6/1/2014	6/1/2015		Yes
	BLUE SPRING SOUTH - PRAIRIE LEE 161KV CKT 1 #2 Accelerate	6/1/2014	6/1/2016		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76210042	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 KCPS AG3-2011-026

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KCPS	76216053	SECI	KCPL	32	4/1/2012	4/1/2032	12/31/2018	4/1/2032	\$ 5,760,000	-	\$ 7,485,983	\$ 18,606,832
									\$ 5,760,000	\$ -	\$ 7,485,983	\$ 18,606,832

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76216053	BLUE SPRING SOUTH - BLUE SPRINGS EAST 161KV CKT 1 #2 Accelerate	6/1/2014	6/1/2016			\$ 4,125	\$ 3,862	\$ 7,987	\$ 282,780	\$ 21,980
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015			\$ 16,014	\$ 14,996	\$ 31,010	\$ 827,424	\$ 97,419
	HAYS PLANT - VINE STREET 115KV CKT 1 #1	6/1/2014	6/1/2015		Yes	\$ 28	\$ 26	\$ 54	\$ 35,000	\$ 162
	HAYS PLANT - VINE STREET 115KV CKT 1 #2	6/1/2014	6/1/2016		Yes	\$ 102	\$ 96	\$ 198	\$ 129,375	\$ 534
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes	\$ 1,795,956	\$ 534,120	\$ 2,330,076	\$ 49,623,119	\$ 6,768,776
	Potter to Tolk 345 kV (Please see upgrade description note in Table 4)	12/1/2013	12/31/2018		Yes	\$ 3,943,775	\$ 1,172,883	\$ 5,116,658	\$ 168,852,765	\$ 11,717,960
					Total	\$ 5,760,000	\$ 1,725,983	\$ 7,485,983	\$ 219,750,463	\$ 18,606,832

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216053	HARPER - MILAN TAP 138KV CKT 1 #1	12/1/2013	12/1/2014		Yes
	HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2	12/1/2013	6/1/2015		Yes
	IATAN - NASHUA 345KV CKT 1	12/1/2013	6/1/2015		Yes
	Line - Clark County - Thistle 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt OKGE	12/1/2013	7/1/2014		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt SPS	12/1/2013	7/1/2014		Yes
	Line - Spearville - Clark County 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt WERE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt OKGE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Tuco - Woodward 345 kv line OKGE	12/1/2013	6/1/2014		Yes
	Line - Tuco - Woodward 345 kv line SPS	12/1/2013	6/1/2014		Yes
	MOUNDRIDGE 138/115KV TRANSFORMER CKT 2	12/1/2013	12/1/2014		Yes
	XFR - Thistle 345/138 kv	12/1/2013	1/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216053	Cherry Co - Gentleman 345 kv Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co - Holt Co 345 kv Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co 345 kv Terminal Upgrades	12/1/2013	1/1/2018		Yes
	Viola - Clearwater 138kv Ckt1	10/1/2014	6/1/2018		
	Viola - Gill 138kv Ckt1	10/1/2014	6/1/2018		
	Viola 345/138kv Transformer Ckt 1	10/1/2014	6/1/2018		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216053	BLUE SPRING SOUTH - BLUE SPRINGS EAST 161KV CKT 1 #1 Accelerate	6/1/2014	6/1/2015		
	BLUE SPRING SOUTH - PRAIRIE LEE 161KV CKT 1 #2 Accelerate	6/1/2014	6/1/2016		
	CLEARWATER - MILAN TAP 138KV CKT 1 MKEC Accelerate	12/1/2013	6/1/2017		Yes
	CLEARWATER - MILAN TAP 138KV CKT 1 WERE Accelerate	12/1/2013	6/1/2017		Yes
	HARPER - MILAN TAP 138KV CKT 1 #2 Accelerate	12/1/2013	6/1/2017		Yes
	MEDICINE LODGE - PRATT 115KV CKT 1	12/1/2013	6/15/2014		Yes

Planned Projects

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216053	GOODYEAR JUNCTION - MCVICAR3 115kv	6/1/2014	6/1/2014		
	MCVICAR3 - 17TH & FAIRLAWN 115KV	12/1/2013	12/1/2014		Yes

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216053	BARBER - MEDICINE LODGE 115KV CKT 1	12/1/2009	6/1/2013		
	BARBER (BARBER 4) 138/115/2.72KV TRANSFORMER CKT 1	12/1/2009	6/1/2013		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1	12/1/2009	6/1/2013		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - WOODWARD EHV 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD 345/138KV TRANSFORMER CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 KCPS AG3-2011-027

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KCPS	76216066	WPEK	KCPL	50	4/1/2012	4/1/2032	12/31/2018	4/1/2032	\$ 9,000,000	-	\$ 9,197,749	\$ 23,512,054
									\$ 9,000,000	\$ -	\$ 9,197,749	\$ 23,512,054

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76216066	BLUE SPRING SOUTH - BLUE SPRINGS EAST 161KV CKT 1 #2 Accelerate	6/1/2014	6/1/2016			\$ 8,338	\$ 4,348	\$ 12,686	\$ 282,780	\$ 34,912
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015			\$ 35,359	\$ 18,441	\$ 53,800	\$ 827,424	\$ 169,014
	HAYS PLANT - VINE STREET 115KV CKT 1 #1	6/1/2014	6/1/2015		Yes	\$ 423	\$ 221	\$ 644	\$ 35,000	\$ 1,936
	HAYS PLANT - VINE STREET 115KV CKT 1 #2	6/1/2014	6/1/2016		Yes	\$ 1,564	\$ 815	\$ 2,379	\$ 129,375	\$ 6,419
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes	\$ 3,820,794	\$ 74,213	\$ 3,895,007	\$ 49,623,119	\$ 11,314,837
	Potter to Tolk 345 kv (Please see upgrade description note in Table 4)	12/1/2013	12/31/2018		Yes	\$ 5,133,522	\$ 99,711	\$ 5,233,233	\$ 168,852,765	\$ 11,984,935
					Total	\$ 9,000,000	\$ 197,749	\$ 9,197,749	\$ 219,750,463	\$ 23,512,054

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216066	HARPER - MILAN TAP 138KV CKT 1 #1	12/1/2013	12/1/2014		Yes
	HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2	12/1/2013	6/1/2015		Yes
	IATAN - NASHUA 345KV CKT 1	12/1/2013	6/1/2015		Yes
	Line - Clark County - Thistle 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt OKGE	12/1/2013	7/1/2014		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt SPS	12/1/2013	7/1/2014		Yes
	Line - Spearville - Clark County 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt WERE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt OKGE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Tuco - Woodward 345 kv line OKGE	12/1/2013	6/1/2014		Yes
	Line - Tuco - Woodward 345 kv line SPS	12/1/2013	6/1/2014		Yes
	MOUNDRIDGE 138/115KV TRANSFORMER CKT 2	12/1/2013	12/1/2014		Yes
	XFR - Thistle 345/138 kv	12/1/2013	1/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216066	Cherry Co - Gentleman 345 kv Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co - Holt Co 345 kv Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co 345 kv Terminal Upgrades	12/1/2013	1/1/2018		Yes
	Viola - Clearwater 138kv Ckt1	10/1/2014	6/1/2018		Yes
	Viola - Gill 138kv Ckt1	10/1/2014	6/1/2018		Yes
	Viola 345/138kv Transformer Ckt 1	10/1/2014	6/1/2018		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216066	BLUE SPRING SOUTH - BLUE SPRINGS EAST 161KV CKT 1 #1 Accelerate	6/1/2014	6/1/2015		
	BLUE SPRING SOUTH - PRAIRIE LEE 161KV CKT 1 #2 Accelerate	6/1/2014	6/1/2016		
	CLEARWATER - MILAN TAP 138KV CKT 1 MKEC Accelerate	12/1/2013	6/1/2017		Yes
	CLEARWATER - MILAN TAP 138KV CKT 1 WERE Accelerate	12/1/2013	6/1/2017		Yes
	HARPER - MILAN TAP 138KV CKT 1 #2 Accelerate	12/1/2013	6/1/2017		Yes
	MEDICINE LODGE - PRATT 115KV CKT 1	12/1/2013	6/15/2014		Yes

Planned Projects

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216066	GOODYEAR JUNCTION - MCVICAR3 115kv	6/1/2014	6/1/2014		
	MCVICAR3 - 17TH & FAIRLAWN 115kv	12/1/2013	12/1/2014		Yes

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216066	BARBER - MEDICINE LODGE 115KV CKT 1	12/1/2009	6/1/2013		
	BARBER (BARBER 4) 138/115/2.72KV TRANSFORMER CKT 1	12/1/2009	6/1/2013		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1	12/1/2009	6/1/2013		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	Spearville 345/115/13.8kv Transformer CKT 3	10/1/2013	6/1/2015		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
NMEC AG3-2011-003

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
NMEC	75350825	NPPD	WR	1	10/1/2014	10/1/2024			\$ 180,000	\$ -	\$ 8,827,145	\$ 13,800,032
									\$ 180,000	\$ -	\$ 8,827,145	\$ 13,800,032

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
75350825	GOODYEAR JUNCTION - NORTHLAND 115KV CKT 1	6/1/2019	6/1/2019			\$ 6,641,120	\$ 6,641,120	\$ 10,374,333
	HOYT - HOYTJS 3 115.00 115KV CKT 1	6/1/2019	6/1/2019			\$ 2,172,216	\$ 2,172,216	\$ 3,393,875
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018			\$ 13,809	\$ 49,623,119	\$ 31,824
	<b>Total</b>					\$ 8,827,145	\$ 58,436,455	\$ 13,800,032

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
75350825	HARPER - MILAN TAP 138KV CKT 1 #1	12/1/2013	12/1/2014		
	Line - Clark County - Thistle 345 kv dbi Ckt	12/1/2013	1/1/2015		
	Line - Hitchland - Woodward 345 kv dbi Ckt OKGE	12/1/2013	7/1/2014		
	Line - Hitchland - Woodward 345 kv dbi Ckt SPS	12/1/2013	7/1/2014		
	Line - Spearville - Clark County 345 kv dbi Ckt	12/1/2013	1/1/2015		
	Line - Thistle - Wichita 345 kv dbi Ckt PW	12/1/2013	1/1/2015		
	Line - Thistle - Wichita 345 kv dbi Ckt WERE	12/1/2013	1/1/2015		
	Line - Thistle - Woodward 345 kv dbi Ckt OKGE	12/1/2013	1/1/2015		
	Line - Thistle - Woodward 345 kv dbi Ckt PW	12/1/2013	1/1/2015		
	Line - Tuco - Woodward 345 kv line OKGE	12/1/2013	6/1/2014		
	Line - Tuco - Woodward 345 kv line SPS	12/1/2013	6/1/2014		
	XFR - Thistle 345/138 kv	12/1/2013	1/1/2015		

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
75350825	Cherry Co - Gentleman 345 kv Ckt1	12/1/2013	1/1/2018		
	Cherry Co - Holt Co 345 kv Ckt1	12/1/2013	1/1/2018		
	Cherry Co 345 kv Terminal Upgrades	12/1/2013	1/1/2018		
	Viola - Clearwater 138kv Ckt1	10/1/2014	6/1/2018		
	Viola - Gill 138kv Ckt1	10/1/2014	6/1/2018		
	Viola 345/138kv Transformer Ckt 1	10/1/2014	6/1/2018		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
75350825	CLEARWATER - MILAN TAP 138KV CKT 1 MKEC Accelerate	12/1/2013	6/1/2017		
	CLEARWATER - MILAN TAP 138KV CKT 1 WERE Accelerate	12/1/2013	6/1/2017		
	HARPER - MILAN TAP 138KV CKT 1 #2 Accelerate	12/1/2013	6/1/2017		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
75350825	ALBION - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		
	CIRCLE - RICE_CO 230KV CKT 1	10/1/2012	11/15/2012		
	CLIFTON - GREENLEAF 115KV CKT 1	6/1/2011	6/1/2013		
	GREENLEAF - KNOB HILL 115KV CKT 1 MKEC	6/1/2013	6/1/2013		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	LYONS - RICE_CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	NELIGH - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		
	RICE_CO 230/115KV TRANSFORMER CKT 1	10/1/2012	11/15/2012		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 OMPA AG3-2011-093

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
OMPA	76216657	OKGE	OKGE	51	1/1/2013	1/1/2038	6/1/2015	6/1/2040	\$ 1,720,000	\$ -	\$ 1,720,000	\$ 5,666,302
									\$ 1,720,000	\$ -	\$ 1,720,000	\$ 5,666,302

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76216657	DIVISION AVE - LAKESIDE 138KV CKT 1	6/1/2019	6/1/2019			\$ 1,720,000	\$ -	\$ 1,720,000	\$ 1,720,000	\$ 5,666,302
					Total	\$ 1,720,000	\$ -	\$ 1,720,000	\$ 1,720,000	\$ 5,666,302

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216657	Renfrow - Grant County 138 kV line	12/1/2013	11/1/2014		Yes
	Renfrow 345/138 kV Transformer Ckt 1	12/1/2013	11/1/2014		Yes
	Renfrow Substation	6/1/2014	11/1/2014		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216657	NORTHWEST 345/138/13.8KV TRANSFORMER CKT 3 Accelerated	12/1/2013	6/1/2015		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216657	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
SECI AG3-2011-089

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
SECI	76177839	SECI	SECI	24	7/1/2012	7/1/2032	6/1/2017	6/1/2037	\$ 3,354,501	\$ -	\$ 3,355,984	\$ 12,253,947
									\$ 3,354,501	\$ -	\$ 3,355,984	\$ 12,253,947

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76177839	CIMARRON RIVER PLANT - CIMARRON RIVER TAP 115KV CKT 1	12/1/2013	6/1/2017		Yes	\$ 616,119	\$ -	\$ 616,119	\$ 6,120,760	\$ 2,250,413
	CIMARRON RIVER TAP - KISMET 3 115.00 115KV CKT 1	12/1/2013	6/1/2017		Yes	\$ 432,274	\$ -	\$ 432,274	\$ 4,129,240	\$ 1,578,908
	CUDAHY - KISMET 3 115.00 115KV CKT 1	12/1/2013	6/1/2017		Yes	\$ 2,303,096	\$ -	\$ 2,303,096	\$ 22,000,000	\$ 8,412,202
	HAYS PLANT - VINE STREET 115KV CKT 1 #1	6/1/2014	6/1/2015		Yes	\$ 641	\$ 316	\$ 957	\$ 35,000	\$ 2,878
	HAYS PLANT - VINE STREET 115KV CKT 1 #2	6/1/2014	6/1/2016		Yes	\$ 2,370	\$ 1,168	\$ 3,538	\$ 129,375	\$ 9,546
					Total	\$ 3,354,501	\$ 1,483	\$ 3,355,984	\$ 32,414,375	\$ 12,253,947

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76177839	HARPER - MILAN TAP 138KV CKT 1 #1	12/1/2013	12/1/2014		Yes
	HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2	12/1/2013	6/1/2015		Yes
	Line - Clark County - Thistle 345 kv dbl Ckt	12/1/2013	1/1/2015		Yes
	Line - Hitchland - Woodward 345 kv dbl Ckt OKGE	12/1/2013	7/1/2014		Yes
	Line - Hitchland - Woodward 345 kv dbl Ckt SPS	12/1/2013	7/1/2014		Yes
	Line - Spearville - Clark County 345 kv dbl Ckt	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbl Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbl Ckt WERE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbl Ckt OKGE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbl Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Tuco - Woodward 345 kv line OKGE	12/1/2013	6/1/2014		Yes
	Line - Tuco - Woodward 345 kv line SPS	12/1/2013	6/1/2014		Yes
	XFR - Thistle 345/138 kv	12/1/2013	1/1/2015		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76177839	CLEARWATER - MILAN TAP 138KV CKT 1 MKEC Accelerate	12/1/2013	6/1/2017		Yes
	CLEARWATER - MILAN TAP 138KV CKT 1 WERE Accelerate	12/1/2013	6/1/2017		Yes
	HARPER - MILAN TAP 138KV CKT 1 #2 Accelerate	12/1/2013	6/1/2017		Yes
	Judson Large - North Judson Large 115KV CKT 2	12/1/2013	6/1/2015		Yes
	MEDICINE LODGE - PRATT 115KV CKT 1	12/1/2013	6/15/2014		Yes
	North Judson Large - Spearville 115KV CKT 2	12/1/2013	6/1/2015		Yes
	Spearville 345/115/13.8kv Transformer CKT 3	12/1/2013	6/1/2015		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76177839	ALEXANDER - PRATT 115KV CKT 1	12/1/2009	6/1/2013		
	BARBER - MEDICINE LODGE 115KV CKT 1	12/1/2009	6/1/2013		
	BARBER - SAWYER 115KV CKT 1	12/1/2009	6/1/2013		
	BARBER (BARBER 4) 138/115/2.72KV TRANSFORMER CKT 1	12/1/2009	6/1/2013		
	CLIFTON - GREENLEAF 115KV CKT 1	6/1/2011	6/1/2013		
	FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1	12/1/2009	6/1/2013		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	Judson Large - North Judson Large 115KV CKT 2	10/1/2013	6/1/2015		
	North Judson Large - Spearville 115KV CKT 2	10/1/2013	6/1/2015		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	Spearville 345/115/13.8kv Transformer CKT 3	10/1/2013	6/1/2015		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
SECI AG3-2011-090

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
SECI	76192515	SPRM	SECI	50	1/1/2013	1/1/2019	6/1/2017	6/1/2023	\$ -	\$ 15,966,120	\$ 3,615,621	\$ 10,885,151
									\$ -	\$ 15,966,120	\$ 3,615,621	\$ 10,885,151

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76192515	CIMARRON RIVER PLANT - CIMARRON RIVER TAP 115KV CKT 1	12/1/2013	6/1/2017			\$ 696,348	\$ 6,120,760	\$ 2,096,418
	CIMARRON RIVER TAP - KISMET 3 115.00 115KV CKT 1	12/1/2013	6/1/2017			\$ 461,337	\$ 4,129,240	\$ 1,388,896
	CUDAHY - KISMET 3 115.00 115KV CKT 1	12/1/2013	6/1/2017			\$ 2,457,936	\$ 22,000,000	\$ 7,399,836
Total						\$ 3,615,621	\$ 32,250,000	\$ 10,885,151

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76192515	Arcadia 345 kV Terminal Upgrades	12/1/2013	12/1/2013		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76192515	Judson Large - North Judson Large 115KV CKT 2	12/1/2013	6/1/2015		
	North Judson Large - Spearville 115KV CKT 2	12/1/2013	6/1/2015		
	Spearville 345/115/13.8kV Transformer CKT 3	12/1/2013	6/1/2015		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76192515	BARBER - MEDICINE LODGE 115KV CKT 1	12/1/2009	6/1/2013		
	BARBER (BARBER 4) 138/115/2.72KV TRANSFORMER CKT 1	12/1/2009	6/1/2013		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	CLIFTON - GREENLEAF 115KV CKT 1	6/1/2011	6/1/2013		
	FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1	12/1/2009	6/1/2013		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	Judson Large - North Judson Large 115KV CKT 2	10/1/2013	6/1/2015		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	North Judson Large - Spearville 115KV CKT 2	10/1/2013	6/1/2015		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	Spearville 345/115/13.8kV Transformer CKT 3	10/1/2013	6/1/2015		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - WOODWARD EHV 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD 345/138KV TRANSFORMER CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
SECI AG3-2011-091

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
SECI	76192531	SECI	SECI	55	1/1/2014	1/1/2044	1/1/2018	1/1/2048	\$ 6,830	\$ -	\$ 6,830	\$ 24,628
									\$ 6,830	\$ -	\$ 6,830	\$ 24,628

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
76192531	HAYS PLANT - VINE STREET 115KV CKT 1 #1	6/1/2014	6/1/2015		Yes	\$ 1,454	\$ 35,000	\$ 5,704	
	HAYS PLANT - VINE STREET 115KV CKT 1 #2	6/1/2014	6/1/2016		Yes	\$ 5,376	\$ 129,375	\$ 18,924	
						Total	\$ 6,830	\$ 164,375	\$ 24,628

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76192531	HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2	12/1/2013	6/1/2015		Yes
	Line - Clark County - Thistle 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt OKGE	12/1/2013	7/1/2014		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt SPS	12/1/2013	7/1/2014		Yes
	Line - Spearville - Clark County 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt WERE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt OKGE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Tuco - Woodward 345 kv line OKGE	12/1/2013	6/1/2014		
	Line - Tuco - Woodward 345 kv line SPS	12/1/2013	6/1/2014		
	XFR - Thistle 345/138 kv	12/1/2013	1/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76192531	Cherry Co - Gentleman 345 kv Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co - Holt Co 345 kv Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co 345 kv Terminal Upgrades	12/1/2013	1/1/2018		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76192531	Judson Large - North Judson Large 115KV CKT 2	12/1/2013	6/1/2015		
	MEDICINE LODGE - PRATT 115KV CKT 1	12/1/2013	6/15/2014		
	North Judson Large - Spearville 115KV CKT 2	12/1/2013	6/1/2015		
	Spearville 345/115/13.8kv Transformer CKT 3	12/1/2013	6/1/2015		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76192531	BARBER - MEDICINE LODGE 115KV CKT 1	12/1/2009	6/1/2013		
	CLIFTON - GREENLEAF 115KV CKT 1	6/1/2011	6/1/2013		
	Judson Large - North Judson Large 115KV CKT 2	10/1/2013	6/1/2015		
	North Judson Large - Spearville 115KV CKT 2	10/1/2013	6/1/2015		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	Spearville 345/115/13.8kv Transformer CKT 3	10/1/2013	6/1/2015		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
SECI AG3-2011-092

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
SECI	76209412	KCPL	SECI	50	1/1/2013	1/1/2043	6/1/2017	6/1/2047	\$ 4,269,411	\$ -	\$ 4,269,411	\$ 20,513,227
									\$ 4,269,411	\$ -	\$ 4,269,411	\$ 20,513,227

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76209412	BLUE SPRING SOUTH - BLUE SPRINGS EAST 161KV CKT 1 #2 Accelerate	6/1/2014	6/1/2016	6/1/2016	Yes	\$ 80,229	\$ 282,780	\$ 293,549
	CIMARRON RIVER PLANT - CIMARRON RIVER TAP 115KV CKT 1	12/1/2013	6/1/2017	6/1/2017	Yes	\$ 697,985	\$ 6,120,760	\$ 3,441,736
	CIMARRON RIVER TAP - KISMET 3 115.00 115KV CKT 1	12/1/2013	6/1/2017	6/1/2017	Yes	\$ 512,603	\$ 4,129,240	\$ 2,527,625
	CUDAHY - KISMET 3 115.00 115KV CKT 1	12/1/2013	6/1/2017	6/1/2017	Yes	\$ 2,731,076	\$ 22,000,000	\$ 13,466,825
	HAYS PLANT - VINE STREET 115KV CKT 1 #1	6/1/2014	6/1/2015	6/1/2015	Yes	\$ 1,560	\$ 35,000	\$ 6,081
	HAYS PLANT - VINE STREET 115KV CKT 1 #2	6/1/2014	6/1/2016	6/1/2016	Yes	\$ 5,767	\$ 129,375	\$ 20,171
	LONGVIEW - WESTERN ELECTRIC 161KV CKT 1 #2	6/1/2019	6/1/2019	6/1/2019	Yes	\$ 240,191	\$ 2,559,827	\$ 757,241
					Total	\$ 4,269,411	\$ 35,256,982	\$ 20,513,227

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76209412	Arcadia 345 kV Terminal Upgrades	12/1/2013	12/1/2013		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2	12/1/2013	6/1/2015		Yes
	IATAN - NASHUA 345KV CKT 1	12/1/2013	6/1/2015		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76209412	BLUE SPRING SOUTH - BLUE SPRINGS EAST 161KV CKT 1 #1 Accelerate	6/1/2014	6/1/2015	6/1/2015	Yes
	BLUE SPRING SOUTH - PRAIRIE LEE 161KV CKT 1 #2 Accelerate	6/1/2014	6/1/2016	6/1/2016	Yes
	Judson Large - North Judson Large 115KV CKT 2	12/1/2013	6/1/2015	6/1/2015	Yes
	North Judson Large - Spearville 115KV CKT 2	12/1/2013	6/1/2015	6/1/2015	Yes
	Spearville 345/115/13.8kV Transformer CKT 3	12/1/2013	6/1/2015	6/1/2015	Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76209412	BARBER - MEDICINE LODGE 115KV CKT 1	12/1/2009	6/1/2013		
	BARBER (BARBER 4) 138/115/2.72KV TRANSFORMER CKT 1	12/1/2009	6/1/2013		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	CLIFTON - GREENLEAF 115KV CKT 1	6/1/2011	6/1/2013		
	FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1	12/1/2009	6/1/2013		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	Judson Large - North Judson Large 115KV CKT 2	10/1/2013	6/1/2015		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	North Judson Large - Spearville 115KV CKT 2	10/1/2013	6/1/2015		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	Spearville 345/115/13.8kV Transformer CKT 3	10/1/2013	6/1/2015		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
SPSM AG3-2011-041

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
SPSM	76213597	SPS	SPS	100	6/1/2013	6/1/2014	6/1/2015	6/1/2016	\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76213597	None					\$ -	\$ -	\$ -
Total						\$ -	\$ -	\$ -

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76213597	BAILEY COUNTY INTERCHANGE - CURRY COUNTY INTERCHANGE 115KV CKT 1	12/1/2013	6/1/2015		Yes
	Cox Interchange - Kiser 115 kV Ckt 1 #2	12/1/2013	2/28/2014		Yes
	Kiser Substation 115/69 kV Ckt 1	12/1/2013	2/28/2014		Yes
	Kress Interchange - Kiser 115 kV Ckt 1	12/1/2013	11/30/2014		Yes
	Line - Clark County - Thistle 345 kV dbI Ckt	12/1/2013	1/1/2015		Yes
	Line - Hitchland - Woodward 345 kV dbI Ckt OKGE	12/1/2013	7/1/2014		Yes
	Line - Hitchland - Woodward 345 kV dbI Ckt SPS	12/1/2013	7/1/2014		Yes
	Line - Spearville - Clark County 345 kV dbI Ckt	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kV dbI Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kV dbI Ckt WERE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kV dbI Ckt OKGE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kV dbI Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Tuco - Woodward 345 kV line OKGE	12/1/2013	6/1/2014		Yes
	Line - Tuco - Woodward 345 kV line SPS	12/1/2013	6/1/2014		Yes
	NEWHART INTERCHANGE PROJECT	6/1/2014	4/30/2015		Yes
	XFR - Thistle 345/138 kV	12/1/2013	1/1/2015		Yes

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
SPSM AG3-2011-042

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
SPSM	76213598	SPS	SPS	25	6/1/2014	6/1/2015			\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76213598	None					\$ -	\$ -	\$ -
Total						\$ -	\$ -	\$ -

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76213598	BAILEY COUNTY INTERCHANGE - CURRY COUNTY INTERCHANGE 115KV CKT 1	12/1/2013	6/1/2015		
	NEWHART INTERCHANGE PROJECT	6/1/2014	4/30/2015		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
UCU AG3-2011-022

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
UCU	76216331	WPEK	MPS	100	4/1/2012	4/1/2032	12/31/2018	12/31/2038	\$ 18,000,000	\$ -	\$ 43,074,365	\$ 132,920,876
									\$ 18,000,000	\$ -	\$ 43,074,365	\$ 132,920,876

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76216331	BLUE SPRING SOUTH - BLUE SPRINGS EAST 161KV CKT 1 #2 Accelerate	6/1/2014	6/1/2016		Yes	\$ 3,053	\$ 5,911	\$ 8,964	\$ 282,780	\$ 24,669
	CIMARRON RIVER PLANT - CIMARRON RIVER TAP 115KV CKT 1	12/1/2013	6/1/2017		Yes	\$ 1,399,693	\$ 2,710,615	\$ 4,110,308	\$ 6,120,760	\$ 15,013,157
	CIMARRON RIVER TAP - KISMET 3 115.00 115KV CKT 1	12/1/2013	6/1/2017		Yes	\$ 927,278	\$ 1,795,748	\$ 2,723,026	\$ 4,129,240	\$ 9,946,023
	CUDAHY - KISMET 3 115.00 115KV CKT 1	12/1/2013	6/1/2017		Yes	\$ 4,940,406	\$ 9,567,485	\$ 14,507,891	\$ 22,000,000	\$ 52,990,979
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015		Yes	\$ 32,859	\$ 63,635	\$ 96,494	\$ 827,424	\$ 303,138
	HAYS PLANT - VINE STREET 115KV CKT 1 #1	6/1/2014	6/1/2015		Yes	\$ 219	\$ 424	\$ 643	\$ 35,000	\$ 1,933
	HAYS PLANT - VINE STREET 115KV CKT 1 #2	6/1/2014	6/1/2016		Yes	\$ 810	\$ 1,568	\$ 2,378	\$ 129,375	\$ 6,416
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes	\$ 4,107,023	\$ 3,973,577	\$ 8,080,600	\$ 49,623,119	\$ 23,473,816
	LONGVIEW - WESTERN ELECTRIC 161KV CKT 1 #2	6/1/2019	6/1/2019		Yes	\$ 599,359	\$ 1,160,705	\$ 1,760,064	\$ 2,559,827	\$ 4,173,519
	Potter to Talk 345 kv (Please see upgrade description note in Table 4)	12/1/2013	12/31/2018		Yes	\$ 5,989,301	\$ 5,794,696	\$ 11,783,997	\$ 168,852,765	\$ 26,987,225
					Total	\$ 18,000,000	\$ 25,074,365	\$ 43,074,365	\$ 254,560,290	\$ 132,920,876

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216331	HARPER - MILAN TAP 138KV CKT 1 #1	12/1/2013	12/1/2014		Yes
	HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2	12/1/2013	6/1/2015		Yes
	IATAN - NASHUA 345KV CKT 1	12/1/2013	6/1/2015		Yes
	Line - Clark County - Thistle 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt OKGE	12/1/2013	7/1/2014		Yes
	Line - Hitchland - Woodward 345 kv dbi Ckt SPS	12/1/2013	7/1/2014		Yes
	Line - Spearville - Clark County 345 kv dbi Ckt	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Thistle - Wichita 345 kv dbi Ckt WERE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt OKGE	12/1/2013	1/1/2015		Yes
	Line - Thistle - Woodward 345 kv dbi Ckt PW	12/1/2013	1/1/2015		Yes
	Line - Tuco - Woodward 345 kv line OKGE	12/1/2013	6/1/2014		Yes
	Line - Tuco - Woodward 345 kv line SPS	12/1/2013	6/1/2014		Yes
	MOUNDRIDGE 138/115KV TRANSFORMER CKT 2	12/1/2013	12/1/2014		Yes
	XFR - Thistle 345/138 kv	12/1/2013	1/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216331	Cherry Co - Gentleman 345 kv Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co - Holt Co 345 kv Ckt1	12/1/2013	1/1/2018		Yes
	Cherry Co 345 kv Terminal Upgrades	12/1/2013	1/1/2018		Yes
	Viola - Clearwater 138kv Ckt1	10/1/2014	6/1/2018		Yes
	Viola - Gill 138kv Ckt1	10/1/2014	6/1/2018		Yes
	Viola 345/138kv Transformer Ckt 1	10/1/2014	6/1/2018		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216331	BLUE SPRING SOUTH - BLUE SPRINGS EAST 161KV CKT 1 #1 Accelerate	6/1/2014	6/1/2015		Yes
	BLUE SPRING SOUTH - PRAIRIE LEE 161KV CKT 1 #2 Accelerate	6/1/2014	6/1/2016		Yes
	CLEARWATER - MILAN TAP 138KV CKT 1 MKEC Accelerate	12/1/2013	6/1/2017		Yes
	CLEARWATER - MILAN TAP 138KV CKT 1 WERE Accelerate	12/1/2013	6/1/2017		Yes
	HARPER - MILAN TAP 138KV CKT 1 #2 Accelerate	12/1/2013	6/1/2017		Yes
	Judson Large - North Judson Large 115KV CKT 2	12/1/2013	6/1/2015		Yes
	MEDICINE LODGE - PRATT 115KV CKT 1	12/1/2013	6/15/2014		Yes
	North Judson Large - Spearville 115KV CKT 2	12/1/2013	6/1/2015		Yes
	Spearville 345/115/13.8kv Transformer CKT 3	12/1/2013	6/1/2015		Yes

Planned Projects

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216331	GOODYEAR JUNCTION - MCVICAR3 115KV	6/1/2014	6/1/2014		
	MCVICAR3 - 17TH & FAIRLAWN 115KV	12/1/2013	12/1/2014		Yes

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76216331	ALEXANDER - PRATT 115KV CKT 1	12/1/2009	6/1/2013		
	BARBER - MEDICINE LODGE 115KV CKT 1	12/1/2009	6/1/2013		
	BARBER - SAWYER 115KV CKT 1	12/1/2009	6/1/2013		
	BARBER (BARBER 4) 138/115/2.72KV TRANSFORMER CKT 1	12/1/2009	6/1/2013		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1	12/1/2009	6/1/2013		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	Judson Large - North Judson Large 115KV CKT 2	10/1/2013	6/1/2015		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	North Judson Large - Spearville 115KV CKT 2	10/1/2013	6/1/2015		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	Spearville 345/115/13.8kV Transformer CKT 3	10/1/2013	6/1/2015		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)	Estimated Engineering & Construction Cost
AEPW	CORNVILLE - NORGE ROAD 138KV CKT 1	Rebuild 4.89 miles	6/1/2019	6/1/2019	\$6,357,000.00
AEPW	HOBART - HOBART JUNCTION 69KV CKT 1 Accelerate	Rebuild 1.86 miles with 1233 & ACSR/TW.	12/1/2013	6/1/2017	\$230,370.00
AEPW	HOBART - ROOSEVELT TAP 69KV CKT 1 Accelerate	Rebuild 10 miles to 1272 ACSR 45/7	6/1/2014	6/1/2017	\$606,238.00
AEPW	ROOSEVELT TAP - SNYDER 69KV CKT 1 Accelerate	Rebuild 14 miles to 1272 ACSR 45/7	12/1/2013	6/1/2017	\$848,733.00
KACY	KAW WEST 5 161/69KV TRANSFORMER CKT 1	Indeterminate	6/1/2014	6/1/2014	\$0.00
MIDW	HAYS PLANT - VINE STREET 115KV CKT 1 #1	Replace Wavetrap	6/1/2014	6/1/2015	\$35,000.00
MIDW	HAYS PLANT - VINE STREET 115KV CKT 1 #2	Rebuild 0.23 miles	6/1/2014	6/1/2016	\$129,375.00
MIPU	BLUE SPRING SOUTH - BLUE SPRINGS EAST 161KV CKT 1 #2 Accelerate	Reconductor 2.5 mile from Blue Springs South - Blue Springs East 161 KV to 795 ACS.	6/1/2014	6/1/2016	\$282,780.00
MIPU	LONGVIEW - WESTERN ELECTRIC 161KV CKT 1 #2	Rebuild 3.5 miles	6/1/2019	6/1/2019	\$2,559,827.33
MKEC	CIMARRON RIVER PLANT - CIMARRON RIVER TAP 115KV CKT 1	Rebuild 4 miles and Substation work	12/1/2013	6/1/2017	\$6,120,760.00
MKEC	CIMARRON RIVER TAP - KISMET 3 115.00 115KV CKT 1	Rebuild 3.37 miles and Substation work	12/1/2013	6/1/2017	\$4,129,240.00
MKEC	CUDAHTY - KISMET 3 115.00 115KV CKT 1	Rebuild 32 miles and Substation work	12/1/2013	6/1/2017	\$22,000,000.00
OKGE	DIVISION AVE - LAKESIDE 138KV CKT 1	Rebuild 3.58 mile line with 1590A552 Conductor	6/1/2019	6/1/2019	\$1,720,000.00
SPS	Mustang to Shell CO2 115 KV	Build 6.3 mile 115 kv line from Mustang to Shell CO2 Build a new 6.9 mile 115KV line between the Mustang and Shell CO2 substations.	6/1/2015	12/31/2016	\$15,196,916.00
SPS	Potter to Talk 345 KV	Build 111 mile 345 kv line from Potter to Talk. Further study analysis will be performed with regard to the SPS North-South Stability Limit to determine whether its rating may be increased based on approved SPP Expansion Plan Network Upgrades scheduled to be placed in service. Pending this analysis, the Potter - Talk 345 kv Service Upgrade requirement will be re-evaluated.	12/1/2013	12/31/2018	\$168,852,765.00
SPS	YOKUM COUNTY INTERCHANGE (I 230/115/13.2KV TRANSFORMER CKT 1	Upgrade transformer to 250 MVA.	6/1/2019	6/1/2019	\$3,757,257.00
WERE	EVANS ENERGY CENTER NORTH - MAZE 138KV CKT 1 #1	Upgrade disconnect switches, wavetrap, breaker, jumpers	6/1/2015	6/1/2015	\$827,424.00
WERE	GOODYEAR JUNCTION - NORTHLAND 115KV CKT 1	Rebuild 3.44 miles and replace buses and jumper to at least 187 MVA Summer Rate B	6/1/2019	6/1/2019	\$6,641,120.00
WERE	HOYT - HOYTJS 3 115.00 115KV CKT 1	Rebuild 1 mile	6/1/2019	6/1/2019	\$2,172,216.00
WERE	HOYT - JEFFREY EMERGY CENTER 345KV CKT 1	Rebuild the JEC - Hoyt 345KV line as a single circuit with new conductor, poles, and shield wire and substation work	6/1/2015	6/1/2018	\$49,623,119.00
WFEC	GLASS MOUNTAIN - MOORELAND 138KV CKT 1	Reset CT	12/1/2013	6/1/2015	\$40,500.00

Construction Pending Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
MIPU	BLUE SPRING SOUTH - BLUE SPRINGS EAST 161KV CKT 1 #1 Accelerate	Upgrade wave trap.	6/1/2014	6/1/2015
MIPU	BLUE SPRING SOUTH - PRAIRIE LEE 161KV CKT 1 #2 Accelerate	Reconductor 3.21 miles from Blue Springs South to Prairie Lee 161 KV to 954 ACS.	6/1/2014	6/1/2016
MKEC	CLEARWATER - MILAN TAP 138KV CKT 1 MKEC Accelerate	Rebuild MKEC portion of the 5.6 mile Clearwater-Milan Tap 115 kv with bundled 1192.5 kcmil ACSR conductor (Bunting)	12/1/2013	6/1/2017
MKEC	HARPER - MILAN TAP 138KV CKT 1 #2 Accelerate	Reconductor 22.1 mile Harper to Milan Tap 138 kv line.	12/1/2013	6/1/2017
MKEC	Judson Large - North Judson Large 115KV CKT 2	Construct approximately 1 mile of new 115KV for 2nd circuit	12/1/2013	6/1/2015
MKEC	MEDICINE LODGE - PRATT 115KV CKT 1	Rebuild 26 mile line	12/1/2013	6/15/2014
MKEC	North Judson Large - Spearville 115KV CKT 2	Construct approximately 15 miles of new 115KV for 2nd circuit	12/1/2013	6/1/2015
MKEC	Spearville 345/115/13.8KV Transformer CKT 3	Install 345/115/13.8KV Transformer CKT 3 at Spearville	12/1/2013	6/1/2015
OKGE	NORTHWEST 345/138/13.8KV TRANSFORMER CKT 3 Accelerated	Install third 345/138 KV Bus Tie in Northwest Sub	12/1/2013	6/1/2015
SPS	Jones Station Bus#2 - Lubbock South Interchange 230 KV CKT 2 terminal upgrade	Upgrade line trap at both Jones Bus #2 and Lubbock South Interchange.	6/1/2014	12/30/2014
WERE	CLEARWATER - MILAN TAP 138KV CKT 1 WERE Accelerate	Rebuild Westar portion of the Clearwater-Milan tap 115 kv with bundled 1192.5 kcmil ACSR conductor (Bunting)	12/1/2013	6/1/2017

Planned Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
WERE	GOODYEAR JUNCTION - MCVICAR3 115KV	Build 3.25 miles of 115KV from Goodyear to MacVicar. 223 MVA Rate A. 245 MVA Rate B.	12/1/2013	12/1/2013
WERE	MCVICAR3 - 17TH & FAIRLAWN 115KV	Build 3.6 miles of 115KV from MacVicar to 17th & Fairlawn. 223 MVA Rate A. 245 MVA Rate B.	12/1/2013	12/1/2014

Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study

Expansion Plan Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
ITCGP	Line - Clark County - Thistle 345 kv dbl Ckt	Build a new 86 mile double circuit 345 kv line with at least 3000 A capacity from the Thistle 345 kv substation to the new Clark County substation. Build a new 345 kv substation at Thistle with a ring bus and necessary terminal equipment.	12/1/2013	1/1/2015
ITCGP	Line - Spearville - Clark County 345 kv dbl Ckt	Build a new 36 mile double circuit 345 kv line with at least 3000 A capacity from the Spearville substation to the new Clark County substation. Build the Clark County 345 kv substation with a ring bus and necessary terminal equipment.	12/1/2013	1/1/2015
ITCGP	XFR - Thistle 345/138 kv	Install a 400 MVA 345/138 kv transformer at the new 345 kv Thistle substation.	12/1/2013	1/1/2015
KACP	IATAN - NASHUA 345KV CKT 1	Tap Nashua 345kv bus in Hawthorn - St. Joseph 345 kv line. Build new 345 kv line from Iatan to Nashua. Add Nashua 345/165 kv	12/1/2013	6/1/2015
MIDW	HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2	Tear down and rebuild of existing South Hays - Hays Plant 115 kv line. Tentative plans include rebuilding on existing right-of-way with the possibility of re-routing a portion of the line to new right-of-way as necessary.	12/1/2013	6/1/2015
MKEC	HARPER - MILAN TAP 138KV CKT 1 #1	Replace Wave Trap at Harper Substation	12/1/2013	12/1/2014
OKGE	Arcadia 345 kv Terminal Upgrades	Upgrade 345 kv 2000 amp breakers and associated switches to 3000 amp at Arcadia Sub.	12/1/2013	12/1/2013
OKGE	Line - Hitchland - Woodward 345 kv dbl Ckt OKGE	Build a new 92 mile double circuit 345 kv line with at least 3000 A capacity from the Woodward District EHV substation to the SPS interception from the Hitchland substation. Upgrade the Woodward District EHV substation with the necessary breakers and term	12/1/2013	7/1/2014
OKGE	Line - Thistle - Woodward 345 kv dbl Ckt OKGE	Build a new 79 mile double circuit 345 kv line with at least 3000 A capacity from the Woodward District EHV substation to the Kansas/Oklahoma state border towards the Thistle substation. Upgrade the Woodward District EHV substation with the necessary lines	12/1/2013	1/1/2015
OKGE	Line - Tuco - Woodward 345 kv line OKGE	Build new 345 kv line from Woodward EHV to Border - Project costs now include Border reactor substation	12/1/2013	6/1/2014
OKGE	Renfrow - Grant County 138 kv line	Build 138 kv line from Renfrow to Grant County substation.	12/1/2013	11/1/2014
OKGE	Renfrow 345/138 kv Transformer Ckt 1	Build 400 MVA 345/138 kv bus tie transformer at Renfrow.	12/1/2013	11/1/2014
OKGE	Renfrow Substation	Build substation at Renfrow and tap Woodring-Wichita 345 kv line.	6/1/2014	11/1/2014
PW	Line - Thistle - Wichita 345 kv dbl Ckt PW	Build a new 78 mile double circuit 345 kv line with at least 3000 A capacity from the Wichita substation to the new Thistle 345 kv substation.	12/1/2013	1/1/2015
PW	Line - Thistle - Woodward 345 kv dbl Ckt PW	Build a new 30 mile double circuit 345 kv line with at least 3000 A capacity from the Thistle substation to the Kansas/Oklahoma state border towards the Woodward District EHV substation.	12/1/2013	1/1/2015
SPS	BAILEY COUNTY INTERCHANGE - CURRY COUNTY INTERCHANGE 115KV CKT 1	40 miles 115 kv between Bailey and Curry.	12/1/2013	6/1/2015
SPS	Cox Interchange - Kiser 115 kv Ckt 1 #2	Build new 8.7-mile 115 kv line from Cox to new Kiser substation.	12/1/2013	2/28/2014
SPS	DEAF SMITH COUNTY INTERCHANGE (I) 230/115/13.8KV TRANSFORMER CKT 1	Upgrade Deaf Smith Interchange 230/115 kv transformer ckt 1 to 250 MVA	6/1/2014	3/1/2015
SPS	DEAF SMITH COUNTY INTERCHANGE (I) 230/115/13.8KV TRANSFORMER CKT 2	Upgrade Deaf Smith Interchange 230/115 kv transformer ckt 2 to 250 MVA	6/1/2014	3/1/2015
SPS	Grapevine 230/115kv Transformer Ckt 1	All elements and conductor must have at least an emergency rating of 250 MVA.	6/1/2014	6/1/2014
SPS	Kiser Substation 115/69 kv Ckt 1	Build new substation at Kiser and install a 115/69 kv transformer and 69 kv terminal equipment to connect to the local 69 kv system.	12/1/2013	2/28/2014
SPS	Kress Interchange - Kiser 115 kv Ckt 1	Build new 22-mile 115 kv line from Kress Interchange to new Kiser substation.	12/1/2013	11/30/2014
SPS	Line - Hitchland - Woodward 345 kv dbl Ckt SPS	Build 30 mile double circuit 345 kv line with at least 3000 A capacity from the Hitchland substation to the OGE interception point from the Woodward District EHV substation. Upgrade the Hitchland substation with the necessary breakers and terminal equipment.	12/1/2013	7/1/2014
SPS	Line - Tuco - Woodward 345 kv line SPS	Build new 345 kv line from Tuco to OGE Border station near TX/OK Stateline. Install line reactor outside Border station and line reactors at Tuco.	12/1/2013	6/1/2014
SPS	NEWHART INTERCHANGE PROJECT	Tap the Potter Interchange - Plant X Station 230 kv line for new Newhart Substation and install 230/115 kv, 150/173 MVA transformer. New 15 mile Lampton Interchange - Hart Industrial Substation 115 kv line. New 19 mile Swisher County Interchange - Newhart	6/1/2014	4/30/2015
WERE	Line - Thistle - Wichita 345 kv dbl Ckt WERE	Upgrade the Wichita substation with the necessary breakers and terminal equipment to accommodate two new 345 kv circuits from the new Thistle 345 kv substation	12/1/2013	1/1/2015
WERE	MOUNDRIDGE 138/115KV TRANSFORMER CKT 2	Install second 138/115 kv transformer at Moundridge. Operate both 138/115 kv transformers normally closed.	12/1/2013	12/1/2014

Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
AEPW	Multi - Centerton - Osage Creek 345 kV	Install new 345/161 kV transformer at Kings River (Previous name Osage Creek); Install 9 miles of 345 kV line from Shipe Road to East Rogers; Install 32 miles of 345 kV line from East Rogers to Kings River (previous Osage Creek).	6/1/2014	6/1/2016
AEPW	Multi - Flint Creek - Centerton 345 kV and Centerton- East Centerton 161 kV	Install 9 miles of 161 kV from new Shipe Road Substation to East Centerton Substation; Install 345/161 kV transformer at Shipe Road; Install 1.8 miles of new 345 kV, 2-954 ACSR line.	6/1/2014	6/1/2014
AEPW	NORGE ROAD - SOUTHWESTERN STATION 138KV CKT 1	Rebuild 22.35 miles to 1533.3 ACSR/TW and replace switches.	6/1/2019	6/1/2019
NPPD	Cherry Co - Gentleman 345 kV Ckt1	Build new 345 kV Transmission Line from GGS 345 kV Substation to a new Cherry County 345 kV Substation (76 miles).	12/1/2013	1/1/2018
NPPD	Cherry Co - Holt Co 345 kV Ckt1	Build new 345 kV Transmission Line from new Cherry County 345 kV Substation to new 345 kV Holt County Substation. (Estimated 146 miles).	12/1/2013	1/1/2018
NPPD	Cherry Co 345 kV Terminal Upgrades	Build new Cherry County 345 kV Substation.	12/1/2013	1/1/2018
SPS	Hitchland 230/115/13.2 kV Transformer Ckt 2	Build a second 230/115/13.2 kV transformer at Hitchland.	6/1/2019	6/1/2019
SPS	YOAKUM COUNTY INTERCHANGE (I 230/115/13.2KV TRANSFORMER CKT 2	Upgrade transformer to 250 MVA.	6/1/2019	6/1/2019
WERE	Viola - Clearwater 138kV Ckt1	Build new 138kV line between new Viola substation 345/138 kV transformer and existing Clearwater 138 kV substation.	10/1/2014	6/1/2018
WERE	Viola - Gill 138kV Ckt1	Build new 138kV line between new Viola substation 345/138 kV transformer and existing Gill 138 kV substation.	10/1/2014	6/1/2018
WERE	Viola 345/138kV Transformer Ckt 1	Install new 345/138 kV transformer at Viola substation	10/1/2014	6/1/2018

Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study

Network Upgrades requiring credits per Attachment 22 of the SPP OATT.				
Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
AEPW	BANN - RED SPRINGS REC 138KV CKT 1	Replace 138 kv breakers 3300 & 3310	7/1/2012	7/1/2012
AEPW	EXPLORER GLENPOOL TAP - RIVERSIDE STATION 138KV CKT 1 AEPW	Reconductor 1.82 miles with ACCC. Replace wave trap jumpers at Riverside.	6/1/2009	6/1/2009
AEPW	HUGO POWER PLANT - VALLIANT 345 KV AEPW	Valliant 345 kv line terminal	7/1/2012	7/1/2012
KACP	LACYGNE - WEST GARDNER 345KV CKT 1	KCP Sponsored Project to Reconductor Line to be In-Service by 6/1/2006	6/1/2006	6/1/2006
MIDW	OKCLE - RICE CO 230KV CKT 1	Convert from 115KV to 230KV operation	10/1/2012	11/15/2012
MIDW	LYDONS - RICE CO 115KV CKT 1	Rebuild 11.7 mile line	10/1/2012	4/1/2013
MIDW	RICE CO 230/115KV TRANSFORMER CKT 1	Add 230/115KV Transformer	10/1/2012	11/15/2012
MKEC	ALEXANDER - PRATT 115KV CKT 1	Rebuild line	12/1/2009	6/1/2013
MKEC	BARBER - MEDICINE LODGE 115KV CKT 1	Rebuild line	12/1/2009	6/1/2013
MKEC	BARBER - SAWYER 115KV CKT 1	Rebuild line	12/1/2009	6/1/2013
MKEC	BARBER (BARBER 4) 138/115/2.72KV TRANSFORMER CKT 1	Upgrade transformer	12/1/2009	6/1/2013
MKEC	CLIFTON - GREENLEAF 115KV CKT 1	Rebuild 14.4 miles	6/1/2011	6/1/2013
MKEC	FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1	Rebuild 8.05 mile line	12/1/2009	6/1/2013
MKEC	FLATRDG3 138.00 - HARPER 138KV CKT 1	Rebuild 24.15 mile line	12/1/2009	6/1/2013
MKEC	GREENLEAF - KNOB HILL 115KV CKT 1 MKEC	Rebuild 43.5% Ownership of 20.9 miles	6/1/2013	6/1/2013
MKEC	Judson Large - North Judson Large 115KV CKT 2	Construct approximately 1 mile of new 115KV for 2nd circuit	10/1/2013	6/1/2015
MKEC	North Judson Large - Spearville 115KV CKT 2	Construct approximately 15 miles of new 115KV for 2nd circuit	10/1/2013	6/1/2015
MKEC	Spearville 345/115/13.8KV Transformer CKT 3	Install 345/115/13.8KV Transformer CKT 3 at Spearville	10/1/2013	6/1/2015
NPPD	ALBION - PETERSBURG 115KV CKT 1	Replace Breaker Switch 1106-D and jumpers at Albion. Replace main bus at Petersburg. Upgrade and replace transmission structures on 115 kv lineto facilitate 100 degrees Centigrade line operation.	1/1/2013	1/1/2013
NPPD	NELIGH - PETERSBURG 115KV CKT 1	Replace Breaker 1106, jumpers, and 115 kv Switch 1106-02 at Neligh. Replace main bus at Petersburg. Upgrade and replace transmission structures on 115 kv lineto facilitate 100 degrees Centigrade line operation.	1/1/2013	1/1/2013
OKGE	BEELINE - EXPLORER GLENPOOL TAP 138KV CKT 1	Reconductor .92miles of line with Drake ACCC/TW.	6/1/2009	6/1/2009
OKGE	CIMARRON - DRAPER LAKE 345KV CKT 1	Increase capacity of Draper Lake CT and Cimarron wave trap	10/1/2014	6/1/2016
OKGE	EXPLORER GLENPOOL TAP - RIVERSIDE STATION 138KV CKT 1 OKGE	Reconductor 1.82 miles line with Drake ACCC/TW.	6/1/2009	6/1/2009
OKGE	GRACMNT4 138.00 - WASHITA 138KV CKT 2 OKGE	Build 138KV Terminal.	1/1/2012	1/1/2012
OKGE	NORTHWEST - TATONGA 345KV CKT 1	Build 345 kv line	1/1/2010	1/1/2010
OKGE	TATONGA - WOODWARD 345KV CKT 1	Build 345 kv line	1/1/2010	1/1/2010
OKGE	WOODWARD - IODINE 138KV CKT 1	Tap Iodine to Woodward 138 kv line	1/1/2010	1/1/2010
OKGE	WOODWARD - WOODWARD EHV 138KV CKT 1	Build .5 miles of 138 kv and install terminal equipment	1/1/2010	1/1/2010
OKGE	WOODWARD 345/138KV TRANSFORMER CKT 1	Install 345/138 kv xf	1/1/2010	1/1/2010
SPS	CHERRY6 230.00 - Harrington Station East Bus 230KV CKT 1	Replace wavetrap at Harrington East	6/1/2015	6/1/2015
WERE	LYONS - WHEATLAND 115KV CKT 1 #1	Replace CTS	10/1/2012	7/15/2013
WERE	LYONS - WHEATLAND 115KV CKT 1 #2	Rerate circuit to 1000 amps	10/1/2012	7/15/2013
WFEC	BLUE CANYON - PARADISE 138KV CKT 1	Upgrade Paradise to Blue Canyon to 1113	6/1/2010	6/1/2013
WFEC	GRACMNT4 138.00 - WASHITA 138KV CKT 2 WFEC	Build approximately 6 miles of 138kv.	1/1/2012	1/1/2012
WFEC	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	New 19 miles 345 kv	7/1/2012	7/1/2012



Table 5 - Third Party Facility Constraints

Transmission Owner	UpgradeName	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)	Estimated Engineering & Construction Cost
None					