Aggregate Facility Study SPP-2011-AGP1-AFS-9

10/30/2012

SPP Engineering, SPP Transmission Service Studies



Table of Contents

| Table of Contents | 1 |
|---------------------------------------|----|
| Executive Summary | 2 |
| Introduction | 3 |
| Financial Analysis | 5 |
| Third-Party Facilities | 6 |
| Study Methodology | 7 |
| Description | 7 |
| Model Development | 7 |
| Transmission Request Modeling | 8 |
| Transfer Analysis | 8 |
| Curtailment and Redispatch Evaluation | 8 |
| Study Results | 9 |
| Study Analysis Results | 9 |
| Example A: | 10 |
| Example B: | 10 |
| Example C: | 11 |
| Study Definitions | 11 |
| Conclusion | 12 |
| Appendix A | 13 |
| BASE CASE SETTINGS: | 13 |
| ACCC CASE SETTINGS: | 13 |

Executive Summary

Pursuant to Attachment Z1 of the Southwest Power Pool, Inc. (SPP) Open Access Transmission Tariff (OATT), 3959 MW of long-term transmission service requests have been studied in this Aggregate Facility Study (AFS). The principal objective of the AFS is to identify system problems and potential modifications necessary to facilitate these transfers while maintaining or improving system reliability, as well as summarizing the operating limits and determination of the financial characteristics associated with facility upgrades. A highly tangible benefit of studying transmission requests aggregately under the SPP OATT Attachment Z1 is the sharing of costs among Transmission Customers using the same facility. Facility upgrade costs are allocated on a prorated basis to all requests positively impacting any individual overloaded facility.

Attachment Z2 further provides for facility upgrade cost recovery by stating: "Transmission Customers paying Directly Assigned Upgrade Costs for Service Upgrades or that are in excess of the Safe Harbor Cost Limit for Network Upgrades associated with new or changed Designated Resources and Project Sponsors paying Directly Assigned Upgrade Costs for Sponsored Upgrades shall receive revenue credits in accordance with Attachment Z2. Generation Interconnection Customers paying for Network Upgrades shall receive credits for new transmission service using the facility as specified in Attachment Z1."

- The AFS determined that the total assigned facility upgrade Engineering and Construction (E&C) cost is \$8 Million. Additionally, \$4 Million of assigned E&C cost for third party facility upgrades are assignable to the customer.
- Total upgrade levelized revenue requirements for all transmission requests after consideration of potential base plan funding is \$7 Million.

To accommodate the requested SPP Transmission Service, third-party facilities must be upgraded when the third-party transmission provider determines that they are constrained. Third-party facilities include both first-tier neighboring facilities outside SPP and Transmission Owner facilities within SPP that are not under the SPP OATT. In this AFS, third-party facilities were identified. Total E&C cost estimates for required third-party facility upgrades are applicable.

SPP will tender a Letter of Intent on October 30, 2012. This will open a 15-day window for Customer response. To remain in the Aggregate Transmission Service Study (ATSS), SPP must receive from the Customer by November 14, 2012, an executed Letter of Intent. The Letter of Intent will list options the Customer must choose to clarify their commitment to remain in the ATSS. The only action required on OASIS is to withdraw the request or leave the request in study mode.

At the conclusion of the ATSS, Service Agreements for each request for service will be tendered identifying the terms and conditions of the confirmed service.

If Customers withdraw from the ATSS after posting of this AFS, the AFS will be re-performed to determine final cost allocation and Available Transmission Capability (ATC) in consideration of the

remaining ATSS participants. All allocated revenue requirements for facility upgrades are assigned to the Customer in the AFS data tables. Potential base plan funding allowable is contingent upon validation of designated resources meeting Attachment J, Section III B criteria.

Introduction

Important milestones and dates in SPP's Aggregate Transmission Study process:

- In 2005, the Federal Energy Regulatory Commission (FERC) accepted SPP's proposed Aggregate Transmission Study procedures in Docket ER05-109.
- In 2008, in Docket ER08-1379-000 SPP filed with FERC to pair open seasons closing during January 2010 with an effective date of August 9, 2008.
- In January 2010, in Docket ER10-659-000 SPP filed with FERC to extend its current practice of pairing open seasons through January 31, 2011, with an effective date of January 28, 2010.
- In March 2010, in Docket ER10-659-000 FERC issued a letter order accepting SPP's proposal to continue to pair open seasons through January 31, 2011, effective January 28, 2010.
- The 2010-AG3 open season commenced June 1, 2010 and closed September 30, 2010.
- The 2011-AG1 open season commenced October 1, 2010 and closed January 31, 2011.
- All requests for long-term transmission service with a signed study agreement received before October 1, 2010 for 2010-AG3 and February 1, 2011 for 2011-AG1 have been included in the first paired Aggregate Transmission Service Study (ATSS) of 2011.

Approximately 4005 MW of long-term Transmission Service was studied in this Aggregate Facility Study (AFS), and over \$8 Million in transmission upgrades is proposed. The results of the AFS are detailed in Tables 1 through 6. Detailed results depict individual upgrade costs by study and potential base plan allowances determined by Attachments J and Z1. The OATT may be accessed at SPP's website by going to SPP.org>Org Groups>Governing Documents.

To understand the extent to which Base Plan Upgrades may be applied to both Point-to-Point (PTP) and Network Transmission Services, it is necessary to highlight the definition of Designated Resource. Per Section 1.9a of the SPP OATT, a Designated Resource is:

"[a]ny designated generation resource owned, purchased or leased by a Transmission Customer to serve load in the SPP Region. Designated Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Transmission Customer's load on a non-interruptible basis."

Southwest Power Pool, Inc.

Network and PTP service has potential for base plan funding if the conditions for classifying upgrades associated with designated resources as Base Plan Upgrades as defined in Section III.B of Attachment J are met.

Pursuant to Attachment J, Section III B of the SPP OATT, the Transmission Customer must provide SPP information necessary to verify that the new or changed Designated Resource meets the following conditions:

- 1. Transmission Customer's commitment to the requested new or changed Designated Resource must have a duration of at least five years.
- 2. During the first year the Designated Resource is planned to be used by the Transmission Customer, the accredited capacity of the Transmission Customer's existing Designated Resources plus the lesser of:
 - a. The planned maximum net dependable capacity applicable to the Transmission Customer or
 - b. The requested capacity; shall not exceed 125% of the Transmission Customer's projected system peak responsibility determined pursuant to SPP Criteria 2.

According to Attachment Z1 Section VI.A, PTP customers pay the higher of the monthly transmission access charge (base rate) or the monthly revenue requirement associated with the assigned facility upgrades, including any prepayments for redispatch required during construction.

Network Integration Service Customers pay the total monthly transmission access charges and the monthly revenue requirement associated with the facility upgrades, including any prepayments for redispatch during construction.

Transmission Customers paying for a directly assigned Network Upgrade shall receive credits for new transmission service using the facility as specified in Attachment Z2.

Facilities identified as limiting the requested Transmission Service have been reviewed to determine the required in-service date of each Network Upgrade. The year that each Network Upgrade is required to accommodate a request is determined by interpolating between the applicable model years given the respective loading data. Both previously assigned facilities and the facilities assigned to this request for Transmission Service were evaluated.

In some instances, due to lead times for engineering and construction, Network Upgrades may not be available when required to accommodate a request for Transmission Service. When this occurs, the ATC with available Network Upgrades will be less than the capacity requested during either a portion of or all of the requested reservation period. As a result, the lowest seasonal allocated ATC within the requested reservation period will be offered to the Transmission Customer on an applicable annual basis as listed in Table 1. The ATC may be limited by transmission owner planned projects, expansion plan projects, or Customer assigned upgrades.

Some constraints identified in the AFS were not assigned to the Customer because SPP, the Transmission Provider, determined that upgrades are not required due to various reasons or the

Transmission Owner has construction plans pending for these upgrades. These facilities are listed by reservation in Table 3. This table also includes constrained facilities in the current planning horizon that limit the rollover rights of the Transmission Customer. Table 6 lists possible redispatch pairs to allow start of service prior to completion of assigned Network Upgrades. Table 7 (if applicable) lists deferment of expansion plan projects with different upgrades with the new required in service date as a result of this AFS.

Financial Analysis

The AFS utilizes the allocated Customer's E&C cost in a present worth analysis to determine the monthly levelized revenue requirement of each facility upgrade over the term of the reservation. In some cases, Network Upgrades cannot be completed within the requested reservation period, thus deferred reservation periods will be utilized in the present worth analysis. If the Customer chose Option 2, Redispatch, in the Letter of Intent sent coincident with the initial AFS, the present worth analysis of revenue requirements will be based on the deferred term with redispatch in the subsequent AFS. The upgrade levelized revenue requirement includes interest, depreciation, and carrying costs.

Each request for Transmission Service is evaluated independently as the cost associated with each Network Upgrade is assigned to a request. When facilities are upgraded throughout the reservation period, the Transmission Customer shall 1) pay the total E&C costs and other annual operating costs associated with the new facilities, and 2) receive credits associated with the depreciated book value of removed usable facilities; salvage value of removed non-usable facilities; and the carrying charges, excluding depreciation, associated with all removed usable facilities based on their respective book values.

In the event that the engineering and construction of a previously assigned Network Upgrade may be accelerated, with no additional upgrades, to accommodate a new request for Transmission Service, the levelized present worth of only the incremental expenses though the reservation period of the new request, excluding depreciation, shall be assigned to the new request. These incremental expenses, excluding depreciation, include:

- 1. The levelized difference in present worth of the engineering and construction expenses given the change in date to complete construction to account for additional interest expense and reduced engineering and construction expense due to inflation,
- 2. The levelized present worth of all expediting fees, and
- 3. The levelized present worth of the incremental annual carrying charges, excluding depreciation and interest, during the new reservation period taking into account both:
 - a. The reservation in which the project was originally assigned, and
 - b. A reservation, if any, in which the project was previously accelerated.

In the case of a Base Plan Upgrade being displaced or deferred by an earlier in service date for a requested upgrade, achievable base plan avoided revenue requirements shall be determined per Attachment J, Section VII.B methodology. A deferred Base Plan Upgrade is defined as a different requested Network Upgrade needed at an earlier date that negates the need for the initial Base Plan Upgrade within the planning horizon. A displaced Base Plan Upgrade is defined as the same Network Upgrade being displaced by a requested upgrade needed at an earlier date.

A 40-year service life assumption is utilized for Base Plan funded projects, unless another assumption is provided by the Transmission Owner. A present worth analysis of revenue requirements on a common year basis between the Base Plan and Requested Upgrades was performed to determine avoided Base Plan revenue requirements due to the displacement or deferral of the Base Plan Upgrade by the Requested Upgrade. The difference in present worth between the Base Plan and Requested Upgrades is assigned to the transmission requests impacting this upgrade based on the displacement or deferral.

Third-Party Facilities

For third-party facilities listed in Table 3 and Table 5, the Transmission Customer is responsible for funding the necessary upgrades of these facilities per Section 21.1 of the Transmission Provider's OATT. In this AFS, third-party facilities were identified. Total E&C cost estimates for required third-party facility upgrades are applicable. The Transmission Provider will undertake reasonable efforts to assist the Transmission Customer in making arrangements for necessary engineering, permitting, and construction of the third-party facilities. Third-party facility upgrade E&C cost estimates are not utilized to determine the present worth value of levelized revenue requirements for SPP system Network Upgrades.

All modeled facilities within the Transmission Provider system were monitored during the development of this study, as well as certain facilities in first-tier neighboring systems. Third-party facilities must be upgraded when it is determined that they are overloaded while accommodating the requested Transmission Service. An agreement between the Customer and third party owner detailing the mitigation of the third party impact must be provided to the Transmission Provider prior to tendering of a Transmission Service Agreement. These facilities also include those owned by members of the Transmission Provider who have not placed their facilities under the Transmission Provider's OATT. Upgrades on the Southwest Power Administration network requires prepayment of the upgrade cost prior to construction of the upgrade.

Third-party facilities are evaluated for only those requests whose load sinks within the SPP footprint. The Customer must arrange for study of third party facilities for load that sinks outside the SPP footprint with the applicable Transmission Providers.

Study Methodology

Description

The facility study analysis was conducted to determine the steady-state impact of the requested service on the SPP and first tier non-SPP control area systems. The steady-state analysis was performed to ensure current SPP Criteria and NERC Reliability Standards requirements are fulfilled. SPP conforms to NERC Reliability Standards, which provide strict requirements related to voltage violations and thermal overloads during normal conditions and during a contingency. NERC Standards require all facilities to be within normal operating ratings for normal system conditions and within emergency ratings after a contingency.

Normal operating ratings and emergency operating ratings monitored are Rate A and B in the SPP Model Development Working Group (MDWG) models, respectively. The upper bound and lower bound of the normal voltage range monitored is 105% and 95%. The upper bound and lower bound of the emergency voltage range monitored is 105% and 90%. Transmission Owner voltage monitoring criteria is used if more restrictive. The SPS Tuco 230 kV bus voltage is monitored at 92.5% due to pre-determined system stability limitations. The WERE Wolf Creek 345 kV bus voltage is monitored at 103.5% and 98.5% due to transmission operating procedure.

The contingency set includes all SPP control area branches and ties 69 kV and above; first tier non-SPP control area branches and ties 115 kV and above; any defined contingencies for these control areas; and generation unit outages for the control areas with SPP reserve share program redispatch. The monitor elements include all SPP control area branches, ties, and buses 69 kV and above, and all first tier non-SPP control area branches and ties 115 kV and above. Voltage monitoring was performed for SPP control area buses 69 kV and above.

A 3 % transfer distribution factor (TDF) cutoff was applied to all SPP control area facilities. For first tier non-SPP control area facilities, a 3 % TDF cutoff was applied to AECI, AMRN (Ameren), and ENTR (Entergy) control areas. A 2 % TDF cutoff was applied to WAPA. For voltage monitoring, a 0.02 per unit change in voltage must occur due to the transfer or modeling upgrades to be considered a valid limit to the transfer

Model Development

SPP used six seasonal models to study the aggregate transfers of 3959 MW over a variety of requested service periods. The following SPP Transmission Expansion Plan 2011 Build 2 Cases were used to study the impact of the requested service on the transmission system:

2012/13 Winter Peak (12WP)

2013 Summer Peak (13SP)

2013/14 Winter Peak (13WP)

2017 Summer Peak (17SP)

2017/18 Winter Peak (17WP)

2022 Summer Peak (22SP)

The Summer Peak models apply to June through September and the Winter Peak models apply to December through March.

The chosen base case models were modified to reflect the current modeling information. One group of requests was developed from the aggregate of 3959 MW to model the requested service. From the six seasonal models, two system scenarios were developed. Scenario 0 includes projected usage of transmission included in the SPP 2011 Series Cases. Scenario 5 includes transmission service not already included in the SPP 2011 Series Cases.

Transmission Request Modeling

Network Integration Transmission Service requests are modeled as Generation to Load transfers in addition to Generation to Generation transfers. Network Integration Transmission Service requests are modeled as Generation to Load transfers in addition to Generation to Generation because the requested Network Integration Transmission Service is a request to serve network load with the new designated network resource, and the impacts on Transmission System are determined accordingly. Point-To-Point Transmission Service requests are modeled as Generation to Generation transfers. Generation to Generation transfers are accomplished by developing a post-transfer case for comparison by dispatching the request source and redispatching the request sink.

Transfer Analysis

Using the selected cases both with and without the requested transfers modeled, the PSS/E Activity ACCC was run on the cases and compared to determine the facility overloads caused or impacted by the transfer. Transfer distribution factor cutoffs (SPP and 1st-Tier) and voltage threshold (0.02 change) were applied to determine the impacted facilities. The PSS/E options chosen to conduct the analysis can be found in Appendix A.

Curtailment and Redispatch Evaluation

During any period in which SPP determines that a transmission constraint exists on and may impair Transmission System reliability, SPP will take whatever actions are reasonably necessary to maintain reliability. If SPP determines Transmission System reliability can be maintained by redispatching resources, it will evaluate the interim curtailment of existing confirmed service or interim redispatch of units to provide service prior to completion of any assigned Network Upgrades. Any redispatch may not unduly discriminate between the Transmission Owners' use of the Transmission System on behalf of their Native Load Customers and any Transmission Customer's use of the Transmission System to serve its designated load. Redispatch was evaluated to provide only interim service during the time frame prior to completion of any assigned Network Upgrades. Curtailment of existing confirmed service is evaluated to provide only interim service. Curtailment of existing confirmed service is only evaluated at the request of the transmission Customer.

SPP determined potential relief pairs to relieve the incremental MW impact on limiting facilities as identified in Table 6. Using the selected cases where the limiting facilities were identified, potential incremental and decremental units were identified by determining the generation amount available for increasing and decreasing from the units generation amount, maximum generation amount, and minimum generation amount. If the incremental or decremental amount was greater than 1 MW, the unit was considered as a potential incremental or decremental unit.

Southwest Power Pool, Inc.

Generation shift factors were calculated for the potential incremental and decremental units using Managing and Utilizing System Transmission (MUST). Relief pairs from the generation shift factors for the incremental and decremental units with a greater than 3% TDF on the limiting constraint were determined from the incremental units with the lowest generation shift factors and decremental units with highest generation shift factors. If the aggregate redispatch amount for the potential relief pair was determined to be three times greater than the lower of the increment or decrement, then the pair was determined not to be feasible and is not included. Transmission Customers can request SPP to provide additional relief pairs beyond those determined. The potential relief pairs were not evaluated to determine impacts on limiting facilities in the SPP and first tier systems. The SPP Reliability Coordinator would call upon the redispatch requirements before implementing NERC TLR Level 5a.

Study Results

Study Analysis Results

Tables 1 through 6 contain the AFS steady-state analysis results. Table 1 identifies the participating long-term Transmission Service requests included in the AFS. This table lists deferred start and stop dates both with and without redispatch (based on Customer selection of redispatch if available) and the minimum annual allocated ATC without upgrades and season of first impact.

Table 2 identifies total E&C cost allocated to each Transmission Customer, letter of credit requirements, third party E&C cost assignments, potential base plan E&C funding (lower of allocated E&C or Attachment J Section III B criteria), total revenue requirements for assigned upgrades without consideration of potential base plan funding, point-to-point base rate charge, total revenue requirements for assigned upgrades with consideration of potential base plan funding, and final total cost allocation to the Transmission Customer. In addition, Table 2 identifies SWPA upgrade costs which require prepayment in addition to other allocated costs.

Table 3 provides additional details for each request including all assigned facility upgrades required, allocated E&C costs, allocated revenue requirements for upgrades, upgrades not assigned to the Customer but required for service to be confirmed, credits to be paid for previously assigned AFS or Generation Interconnection Network Upgrades, and any required third party upgrades.

Table 4 lists all upgrade requirements with associated solutions needed to provide Transmission Service for the AFS, minimum ATC per upgrade with season of impact, earliest date upgrade is required (DUN), estimated date the upgrade will be completed, in service (EOC), and estimated E&C cost.

Table 5 lists identified third-party constrained facilities.

Table 6 identifies potential redispatch pairs available to relieve the aggregate impacts on identified constraints to prevent deferral of start of service.

Table 7 (if applicable) identifies deferred expansion plan projects that were replaced with requested upgrades at earlier dates.

The potential base plan funding allowable is contingent on meeting each of the conditions for classifying upgrades associated with designated resources as Base Plan Upgrades as defined in Section III.B of Attachment J. If the additional capacity of the new or changed Designated Resource exceeds the 125% resource to load forecast for the year of start of service, the requested resource is not eligible for base plan funding of required Network Upgrades and the full cost of the upgrades is assignable to the Customer.

If the request is for wind generation, the total requested capacity of wind generation plus existing wind generation capacity shall not exceed 20% of the customer's projected system peak responsibility in the first year the Designated Resource is planned to be used by the customer. If the five-year term and 125% resource to load criteria are met, (as well as the 20% wind resource to load criteria for wind generation requests) the requested capacity is multiplied by \$180,000 to determine the potential base plan funding allowable. The maximum potential base plan funding allowable may be less than the potential base plan funding allowable, due to the E&C cost allocated to the customer being lower than the potential amount allowable to the Customer. The Customer is responsible for any assigned upgrade costs in excess of potential base plan E&C funding allowable. Network Upgrades required for wind generation requests located in a zone other than the Customer POD shall be allocated as 67% base plan region-wide charge and 33% directly assigned to the Customer.

Regarding application of base plan funding for PTP requests, if PTP base rate exceeds upgrade revenue requirements without taking into effect the reduction of revenue requirements by potential base plan funding, then the base rate revenue pays back the Transmission Owner for upgrades and no base plan funding is applicable as the access charge must be paid as it is the higher of "OR" pricing.

However, if initially the upgrade revenue requirements exceed the PTP base rate, then potential base plan funding would be applicable. The test of the higher of "OR" pricing would then be made against the remaining assignable revenue requirements versus PTP base rate. Examples are as follows:

Example A:

E&C allocated for upgrades is \$74 million with revenue requirements of \$140 million and PTP base rate of \$101 million. Potential base plan funding is \$47 million, with the difference of \$27 million E&C assignable to the Customer. If the revenue requirements for the assignable portion is \$54 million and the PTP base rate is \$101 million, the Customer will pay the higher amount (so-called "or pricing") of \$101 million base rate of which \$54 million revenue requirements will be paid back to the Transmission Owners for the upgrades, and the remaining revenue requirements of \$86 million (\$140 million less \$54 million) will be paid by base plan funding.

Example B:

E&C allocated for upgrades is \$74 million with revenue requirements of \$140 million and PTP base rate of \$101 million. Potential base plan funding is \$10 million with the difference of \$64 million

Southwest Power Pool, Inc.

E&C assignable to the Customer. If the revenue requirements for this assignable portion is \$128 million and the PTP base rate is \$101 million, the Customer will pay the higher amount of \$128 million revenue requirements to be paid back to the Transmission Owners, and the remaining revenue requirements of \$12 million (\$140 million less \$128 million) will be paid by base plan funding.

Example C:

E&C allocated for upgrades is \$25 million with revenue requirements of \$50 million and PTP base rate of \$101 million. Potential base plan funding is \$10 million. Base plan funding is not applicable as the higher amount of PTP base rate of \$101 million must be paid and the \$50 million revenue requirements will be paid from this.

The 125% resource to load determination is performed on a per request basis and is not based on a total of Designated Resource requests per Customer. A footnote will provide the maximum resource designation allowable for base plan funding consideration per Customer basis per year.

Base plan funding verification requires that each Transmission Customer with potential for base plan funding provide SPP attestation statements verifying that the firm capacity of the requested Designated Resource is committed for a minimum five year duration.

Study Definitions

- The date upgrade needed date (DUN) is the earliest date the upgrade is required to alleviate a constraint considering all requests.
- End of construction (EOC) is the estimated date the upgrade will be completed and in service.
- Total engineering and construction cost (E&C) is the upgrade solution cost as determined by the Transmission Owner.
- The Transmission Customer's allocation of the E&C cost is based on the request (1) having an impact of at least 3% on the limiting element, and (2) having a positive impact on the upgraded facility.
- Minimum ATC is the portion of the requested capacity that can be accommodated without upgrading facilities.
- Annual ATC allocated to the Transmission Customer is determined by the least amount of allocated seasonal ATC within each year of a reservation period.

Conclusion

The results of the AFS show that limiting constraints exist in many areas of the regional Transmission System. Due to these constraints, Transmission Service cannot be granted unless noted in Table 3.

The Transmission Provider will tender a Letter of Intent on October 30, 2012. This will open a 15-day window for Customer response. To remain in the Aggregate Transmission Service Study (ATSS), the Transmission Provider must receive from the Transmission Customer) by November 14, 2012, an executed Letter of Intent. The Letter of Intent will list options the Customer must choose to clarify their commitment to remain in the ATSS. The only action required on OASIS is to WITHDRAW the request or leave the request in STUDY mode.

The Transmission Provider must receive an unconditional and irrevocable letter of credit in the amount of the total allocated E&C costs assigned to the Customer. This letter of credit is not required for those facilities that are fully base plan funded. The amount of the letter of credit will be adjusted down on an annual basis to reflect cost recovery based on revenue allocation. The Transmission Provider will issue notifications to construct Network Upgrades to the constructing Transmission Owner after filing of necessary service agreements at FERC.

Appendix A

PSS/E CHOICES IN RUNNING LOAD FLOW PROGRAM AND ACCC

| R | Δ | F | CI | 7 CE | SET | ГТІ | N | CS. |
|----|-----|---|----------|------|---------|-----|---|---------------|
| L) | л.: | L | L | IJĿ | .) ; | | | (1.) . |

• Solutions: Fixed slope decoupled Newton-Raphson solution

(FDNS)

• Tap adjustment: Stepping

Area Interchange Control: Tie lines and loads
 Var limits: Apply immediately

• Solution Options:

X Phase shift adjustment

Flat start

_ Lock DC taps

_ Lock switched shunts

ACCC CASE SETTINGS:

• Solutions: AC contingency checking (ACCC)

MW mismatch tolerance: 0.5
 System intact rating: Rate A

Contingency case rating: Rate B
Percent of rating: 100

• Output code: Summary

• Min flow change in overload report: 3mw

Excld cases w/ no overloads from report: YES
 Exclude interfaces from report: NO

Perform voltage limit check:
 YES

Elements in available capacity table: 60000
Cutoff threshold for available capacity 99999.0

table:

Min. contng. Case Vltg chng for report: 0.02
 Sorted output: None

• Newton Solution:

• Tap adjustment: Stepping

• Area interchange control: Tie lines and loads (Disabled for generator

outages)

• Var limits: Apply immediately

• Solution options: \underline{X} Phase shift adjustment

_ Flat start

_ Lock DC taps

_ Lock switched shunts

Southwest Power Pool, Inc.

Table 1 - Long-Term Transmission Service Requests Included in Aggregate Facility Study

| Customer | Study Number | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date without interim redispatch | Deferred Stop Date without interim redispatch | Start Date with interim redispatch | Stop Date with interim redispatch | Minimum Allocated ATC (MW) within reservation period | Season of Minimum Allocated ATC within reservation period |
|----------|--------------|-------------|------|--------|---------------------|-------------------------|------------------------|---|--|--|---|---|---|
| AECC | AG1-2011-032 | 75197033 | OKGE | OKGE | 238 | 7/1/2015 | 7/1/2020 | 7/1/2015 | 7/1/2020 | Note 4 | Note 4 | 0 | 22SP |
| AECC | AG1-2011-036 | 75197522 | SPA | OKGE | 89 | 7/1/2015 | 7/1/2020 | 7/1/2015 | 7/1/2020 | Note 4 | Note 4 | 0 | 22SP |
| AECC | AG1-2011-038 | 75197570 | CSWS | OKGE | 710 | 7/1/2015 | 7/1/2020 | 7/1/2015 | 7/1/2020 | Note 4 | Note 4 | 0 | 22SP |
| AECC | AG1-2011-039 | 75197442 | CSWS | CSWS | 170 | 6/1/2015 | 6/1/2020 | 6/1/2016 | 6/1/2021 | Note 4 | Note 4 | 0 | 22SP |
| AECC | AG1-2011-040 | 75197472 | CSWS | OKGE | 170 | 7/1/2015 | 6/1/2020 | 7/1/2015 | 6/1/2020 | Note 4 | Note 4 | 0 | 22SP |
| AECC | AG1-2011-041 | 75197551 | EES | OKGE | 320 | 7/1/2015 | 7/1/2020 | 7/1/2015 | 7/1/2020 | Note 4 | Note 4 | 0 | 22SP |
| BPAE | AG1-2011-018 | 75181762 | WR | AECI | 50 | 11/1/2012 | 11/1/2017 | 6/1/2019 | 6/1/2024 | 2/1/2013 | 2/1/2018 | 0 | 13SP |
| BPAE | AG1-2011-019 | 75181747 | WR | AECI | 150 | 11/1/2012 | 11/1/2017 | 6/1/2019 | 6/1/2024 | 2/1/2013 | 2/1/2018 | 0 | 13SP |
| CRGL | AG1-2011-073 | 75199999 | SECI | EES | 500 | 7/1/2014 | 7/1/2019 | 1/1/2018 | 1/1/2023 | 1/1/2015 | 1/1/2020 | 0 | 22SP |
| CRGL | AG1-2011-079 | 75199802 | OKGE | EES | 98 | 12/1/2012 | 12/1/2032 | 2/1/2013 | 2/1/2033 | 2/1/2013 | 2/1/2033 | 0 | 13SP |
| CRGL | AG1-2011-081 | 75199815 | NPPD | EES | 200 | 12/1/2012 | 12/1/2032 | 2/1/2013 | 2/1/2033 | 2/1/2013 | 2/1/2033 | 200 | 13SP |
| HZN | AG1-2011-055 | 75181743 | WFEC | EES | 100 | 1/1/2012 | 1/1/2017 | 2/1/2013 | 2/1/2018 | Note 4 | Note 4 | 92 | 12SP |
| KCPS | AG1-2011-011 | 75181547 | NPPD | KCPL | 20 | 1/1/2014 | 1/1/2024 | 1/1/2018 | 1/1/2028 | 1/1/2014 | 1/1/2024 | 0 | 17SP |
| KCPS | AG1-2011-012 | 75181564 | NPPD | KCPL | 20 | 1/1/2014 | 1/1/2024 | 6/1/2015 | 6/1/2025 | 1/1/2014 | 1/1/2024 | 0 | 17SP |
| KCPS | AG1-2011-013 | 75181568 | NPPD | KCPL | 22 | 1/1/2014 | 1/1/2024 | 6/1/2015 | 6/1/2025 | 1/1/2014 | 1/1/2024 | 0 | 17SP |
| KCPS | AG1-2011-057 | 75199886 | SECI | KCPL | 50 | 8/1/2011 | 9/1/2013 | 4/1/2012 | 9/1/2013 | 4/1/2012 | 9/1/2013 | 0 | 12SP |
| KCPS | AG1-2011-061 | 75199893 | SECI | KCPL | 50 | 8/1/2011 | 9/1/2013 | 4/1/2012 | 9/1/2013 | 4/1/2012 | 9/1/2013 | 0 | 12SP |
| KMEA | AG1-2011-094 | 75200249 | SPA | SECI | 1 | 11/1/2013 | 12/31/2018 | 11/1/2013 | 12/1/2018 | 11/1/2013 | 12/1/2018 | 0 | 17SP |
| KMEA | AG1-2011-095 | 75199561 | OPPD | WR | 6 | 2/1/2012 | 2/1/2017 | 2/1/2013 | 2/1/2018 | 2/1/2013 | 2/1/2018 | 0 | 12SP |
| KMEA | AG1-2011-096 | 75200582 | SECI | SECI | 23 | 1/1/2012 | 6/1/2026 | 1/1/2018 | 6/1/2032 | 2/1/2013 | 7/1/2027 | 0 | 12SP |
| LESM | AG1-2011-006 | 75134451 | NPPD | LES | 10 | 10/1/2012 | 10/1/2017 | 2/1/2013 | 2/1/2018 | 2/1/2013 | 2/1/2018 | 7 | 13SP |
| MEAN | AG1-2011-044 | 75179416 | NPPD | MEC | 1 | 7/1/2011 | 7/1/2016 | 2/1/2013 | 2/1/2018 | 2/1/2013 | 2/1/2018 | 1 | 12SP |
| MEAN | AG1-2011-045 | 75179412 | NPPD | MEC | 2 | 7/1/2011 | 7/1/2016 | 2/1/2013 | 2/1/2018 | 2/1/2013 | 2/1/2018 | 2 | 12SP |
| MIDW | AG1-2011-084 | 75200166 | WR | WR | 15 | 6/1/2012 | 6/1/2017 | 6/1/2016 | 6/1/2021 | 2/1/2013 | 2/1/2018 | 7 | 12SP |
| MIDW | AG1-2011-085 | 75200168 | WR | WR | 5 | 6/1/2012 | 6/1/2017 | 6/1/2016 | 6/1/2021 | 2/1/2013 | 2/1/2018 | 2 | 12SP |
| MIDW | AG1-2011-086 | 75200171 | WR | WR | 5 | 6/1/2012 | 6/1/2017 | 6/1/2016 | 6/1/2021 | 2/1/2013 | 2/1/2018 | 2 | 12SP |
| MIDW | AG1-2011-087 | 75200180 | WR | WR | 5 | 6/1/2013 | 6/1/2018 | 6/1/2016 | 6/1/2021 | 6/1/2013 | 6/1/2018 | 2 | 13SP |
| MIDW | AG1-2011-088 | 75200183 | WR | WR | 5 | 6/1/2013 | 6/1/2018 | 6/1/2016 | 6/1/2021 | 6/1/2013 | 6/1/2018 | 2 | 13SP |
| NPPM | AG1-2011-066 | 75200206 | NPPD | NPPD | 1 | 12/1/2012 | 12/1/2017 | 2/1/2013 | 2/1/2018 | 2/1/2013 | 2/1/2018 | 0 | 13SP |
| OMPA | AG1-2011-049 | 75180762 | CSWS | CSWS | 50 | 6/1/2014 | 9/30/2018 | 6/1/2014 | 9/30/2018 | 6/1/2014 | 9/30/2018 | 0 | 17SP |
| OMPA | AG1-2011-050 | 75196276 | | OKGE | 3 | | 12/31/2027 | 2/1/2013 | 12/1/2028 | 2/1/2013 | 12/1/2028 | | 12SP |
| OPPM | AG1-2011-026 | 75180047 | | OPPD | 18 | | 12/1/2017 | 2/1/2013 | 2/1/2018 | 2/1/2013 | 2/1/2018 | | 13SP |
| SECI | AG1-2011-108 | 75173900 | | SECI | 80 | , , , | 7/1/2032 | 6/1/2016 | 6/1/2036 | 2/1/2013 | 2/1/2033 | | 13SP |
| SPSM | AG1-2011-064 | 75197996 | | SPS | 42 | -,,- | 6/1/2045 | 6/1/2015 | 6/1/2048 | 6/1/2035 | 2/1/2046 | | 12SP |
| SPSM | AG1-2011-065 | 75197998 | | SPS | 29 | | 6/1/2032 | 6/1/2015 | | 2/1/2013 | 2/1/2033 | | 12SP |
| TNSK | AG1-2011-029 | 75108845 | | ERCOTE | 44 | -7 , - | 6/1/2014 | Note 3 | Note 3 | 2/1/2013 | 6/1/2014 | | 12SP |
| TNSK | AG1-2011-030 | 75108838 | | ERCOTE | 6 | 8/1/2011 | 6/1/2014 | 2/1/2013 | 6/1/2014 | 2/1/2013 | 6/1/2014 | | 12SP |
| WFEC | AG1-2011-097 | 75179329 | CSWS | WFEC | 150 | 1/1/2012 | 1/1/2037 | 1/1/2015 | 1/1/2040 | 2/1/2013 | 2/1/2038 | 0 | 12SP |

 Table 1 - Long-Term Transmission Service Requests Included in Aggregate Facility Study

| Customer | Study Number | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date without interim redispatch | Deferred Stop Date without interim redispatch | Start Date with interim redispatch | Stop Date with interim redispatch | Minimum Allocated ATC (MW) within reservation period | Season of Minimum Allocated ATC within reservation period |
|----------|--------------|-------------|------|-----|---------------------|-------------------------|------------------------|---|--|--|---|---|---|
| WRGS | AG1-2011-002 | 74977737 | OKGE | WR | 300 | 1/1/2016 | 6/1/2027 | 1/1/2016 | 6/1/2027 | 1/1/2016 | 6/1/2027 | 300 | 22SP |
| WRGS | AG1-2011-003 | 75021167 | WR | WR | 201 | 10/1/2012 | 1/1/2032 | 12/1/2014 | 3/1/2034 | 2/1/2013 | 5/1/2032 | 0 | 13SP |

Note 1: Start and Stop Dates with interim redispatch are determined based on customers choosing option to pursue redispatch to start service at Requested Start and Stop Dates or earliest date possible.

Note 2: Start dates with and without redispatch are based on the assumed completion dates of previous Aggregate Transmission Service Studies currently being conducted. Actual start dates may differ from the potential start dates upon completion of the previous studies.

Note 3: Request is unable to be deferred due to fixed stop dates.

Note 4: Transmission customer did not select "remain in the study using interim redispatch" option.

Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests

| Customer | Study Number | Reservation | Engineering and Construction Cost of Upgrades Allocated to Customer for Revenue Requirements | ¹ Letter of Credit Amount Required | ² Potential Base Plan Engineering and Construction Funding Allowable | Notes | ⁴ Additional Engineering and Construction Cost for 3rd Party Upgrades | ³⁵ Total Revenue Requirements for Assigned Upgrades Over Term of Reservation WITH Potential Base Plan Funding Allocation | Point-to-Point Base Rate Over Reservation Period | ⁴ Total Cost of Reservation Assignable to Customer Contingent Upon Base Plan Funding |
|----------|--------------|-------------|--|--|--|-------|--|--|--|--|
| AECC | AG1-2011-032 | 75197033 | \$. | \$. | \$ | | \$. | \$. | \$ - | Schedule 9 & 11 Charges |
| AECC | AG1-2011-036 | 75197522 | \$. | \$. | \$ | | \$. | \$. | \$ - | Schedule 9 & 11 Charges |
| AECC | AG1-2011-038 | 75197570 | \$. | \$. | \$ | | \$. | \$. | \$ - | Schedule 9 & 11 Charges |
| AECC | AG1-2011-039 | 75197442 | \$ 205,780 | \$. | \$ 205,780 | | \$. | \$. | \$ - | Schedule 9 & 11 Charges |
| AECC | AG1-2011-040 | 75197472 | \$. | \$. | \$ | | \$. | \$. | \$ - | Schedule 9 & 11 Charges |
| AECC | AG1-2011-041 | 75197551 | \$ - | \$. | \$ | | \$. | \$. | \$ - | Schedule 9 & 11 Charges |
| BPAE | AG1-2011-018 | 75181762 | \$ 396,134 | \$ 396,134 | \$ | | \$ 454,238 | \$ 732,139 | \$ 2,634,000 | \$ 2,634,000 |
| BPAE | AG1-2011-019 | 75181747 | \$ 1,188,401 | \$ 1,188,401 | \$ | | \$ 1,362,714 | \$ 2,196,416 | \$ 7,902,000 | \$ 7,902,000 |
| CRGL | AG1-2011-073 | 75199999 | \$ 51,340 | \$ 51,340 | \$ | | \$. | \$ 123,282 | \$ 38,400,000 | \$ 38,400,000 |
| CRGL | AG1-2011-079 | 75199802 | \$ 686,150 | \$ 686,150 | \$ | | \$ 1,075,174 | \$ 2,300,682 | \$ 30,105,600 | \$ 30,105,600 |
| CRGL | AG1-2011-081 | 75199815 | \$. | \$ - | \$ | | \$ - | \$. | \$ 61,440,000 | \$ 61,440,000 |
| HZN | AG1-2011-055 | 75181743 | \$ 845,582 | \$ 845,582 | \$ | | \$ 1,108,434 | \$ 1,613,337 | \$ 7,680,000 | \$ 7,680,000 |
| KCPS | AG1-2011-011 | 75181547 | \$. | \$ - | \$ | | \$ - | \$. | \$ - | Schedule 9 & 11 Charges |
| KCPS | AG1-2011-012 | 75181564 | \$. | \$ - | \$ | | \$ - | \$. | \$ - | Schedule 9 & 11 Charges |
| KCPS | AG1-2011-013 | 75181568 | \$. | \$. | \$ | | \$. | \$. | \$ - | Schedule 9 & 11 Charges |
| KCPS | AG1-2011-057 | 75199886 | \$. | \$. | \$ | | \$. | \$. | \$ 746,300 | \$ 746,300 |
| KCPS | AG1-2011-061 | 75199893 | \$. | \$. | \$ | | \$. | \$. | \$ 746,300 | \$ 746,300 |
| KMEA | AG1-2011-094 | 75200249 | \$ 4,621 | \$. | \$ 4,623 | | \$. | \$. | \$ - | Schedule 9 & 11 Charges |
| KMEA | AG1-2011-095 | 75199561 | \$. | \$. | \$ | - 6 | \$. | \$. | \$ - | Schedule 9 & 11 Charges |
| KMEA | AG1-2011-096 | 75200582 | \$ 203,965 | \$. | \$ 203,965 | | \$ 129,440 | \$. | \$ - | Schedule 9 & 11 Charges |
| LESM | AG1-2011-006 | 75134451 | \$. | \$. | \$ | | \$. | \$. | \$ - | Schedule 9 & 11 Charges |
| MEAN | AG1-2011-044 | 75179416 | \$. | \$. | \$ | | \$. | \$. | \$ 65,400 | \$ 65,400 |
| MEAN | AG1-2011-045 | 75179412 | \$. | \$. | \$ | | \$. | \$. | \$ 130,800 | \$ 130,800 |
| MIDW | AG1-2011-084 | 75200166 | \$ 1,682,303 | \$. | \$ 1,682,303 | | \$. | \$. | \$ - | Schedule 9 & 11 Charges |
| MIDW | AG1-2011-085 | 75200168 | \$ 560,768 | \$. | \$ 560,768 | 3 | \$. | \$ | \$ - | Schedule 9 & 11 Charges |
| MIDW | AG1-2011-086 | 75200171 | \$ 560,768 | \$. | \$ 560,768 | | \$. | \$. | \$ - | Schedule 9 & 11 Charges |
| MIDW | AG1-2011-087 | 75200180 | \$ 560,768 | \$. | \$ 560,768 | | \$. | \$. | \$ - | Schedule 9 & 11 Charges |
| MIDW | AG1-2011-088 | 75200183 | \$ 560,768 | \$. | \$ 560,768 | | \$. | \$. | \$ - | Schedule 9 & 11 Charges |
| NPPM | AG1-2011-066 | 75200206 | \$ | \$. | \$ | | \$. | \$. | \$ 110,239 | \$ 110,239 |
| OMPA | AG1-2011-049 | 75180762 | \$. | \$. | \$ | | \$. | \$. | \$ - | Schedule 9 & 11 Charges |
| OMPA | AG1-2011-050 | 75196276 | \$ - | \$ - | \$ | | \$ - | \$. | \$ - | Schedule 9 & 11 Charges |
| OPPM | AG1-2011-026 | 75180047 | \$. | \$. | \$ | | \$ - | \$ - | \$ - | Schedule 9 & 11 Charges |
| SECI | AG1-2011-108 | 75173900 | \$ 694,301 | \$ 225,275 | \$ 469,026 | | \$ - | \$ 527,561 | \$ - | \$ 527,561 |
| SPSM | AG1-2011-064 | 75197996 | \$. | \$ - | \$ | | \$ - | \$ - | \$ - | \$ |
| SPSM | AG1-2011-065 | 75197998 | \$. | \$ - | \$ | | \$ - | \$. | | Schedule 9 & 11 Charges |
| TNSK | AG1-2011-029 | 75108845 | \$ | \$. | \$ | | \$. | \$. | \$ 1,071,565 | , |
| TNSK | AG1-2011-030 | 75108838 | \$ | \$. | \$ | | \$. | \$. | \$ 146,123 | \$ 146,123 |
| WFEC | AG1-2011-097 | 75179329 | \$. | \$. | \$ | | \$. | \$. | \$ - | Schedule 9 & 11 Charges |

Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests

| Customer | Study Number | Reservation | Engineering and Construction Cost of Upgrades Allocated to Customer for Revenue Requirements | ¹ Letter of Credit Amount Required | ² Potential Base Plan Engineering and Construction Funding Allowable | Notes | ⁴ Additional Engineering and Construction Cost for 3rd Party Upgrades | ^{3 S} Total Revenue Requirements for Assigned Upgrades Over Term of Reservation WITH Potential Base Plan Funding Allocation | Base Rate Over Reservation Period | ⁴ Total Cost of Reservation Assignable to Customer Contingent Upon Base Plan Funding |
|--------------------|--------------|-------------|--|--|--|-------|--|---|-----------------------------------|--|
| WRGS | AG1-2011-002 | 74977737 | \$ | \$. | \$. | | \$. | \$ | \$ - | Schedule 9 & 11 Charges |
| WRGS | AG1-2011-003 | 75021167 | \$. | \$. | \$. | | \$. | \$ | \$ - | Schedule 9 & 11 Charges |
| Grand Total | | | \$ 8,201,649 | | \$ 4,808,767 | | | \$ 7,493,417 | | |

Note 1: Letter of Credit required for financial security for transmission owner for network upgrades is determined by allocated engineering and construction costs less engineering and construction costs for upgrades when network customer is the transmission owner less the E & C allocation of expedited projects. Letter of Credit is required for upgrades assigned to PTP requests. The amount of the letter of credit will be adjusted down on an annual basis to reflect cost recovery based on revenue allocation. This letter of credit is not required for those facilities that are fully base plan funded. The Letter Of Credit Amount listed is based on meeting OATT Attachment J requirements for base plan funding.

Note 2: If potential base plan funding is applicable, this value is the lesser of the Engineering and Construction costs of assignable upgrades or the value of base plan funding calculated pursuant to Attachment J, Section III B criteria.

Note 3: Revenue Requirements (RR) are based upon deferred end dates if applicable. Deferred dates are based upon customer's choice to pursue redispatch. Achievable Base Plan Avoided RR in the case of a Base Plan upgrade being displaced or deferred by an earlier in service date for a Requested Upgrade shall be determined per Attachment J. Section VII.C methodology. Assumption of a 40 year service life is utilized for Base Plan funded projects. A present worth analysis of RR on a common year basis between the Base Plan and Requested Upgrades was performed to determine avoided Base Plan RR due to the displacement or deferral of the Base Plan upgrade by the Requested Upgrade. The incremental increase in present worth of a Requested Upgrade on a common year basis as a Base Plan upgrade is assigned to the transmission requests impacting the upgrade based on the displacement or deferral. If the displacement analysis results in lower RR due to the shorter amortization period of the requested upgrade when compared to a base plan amortization period, then no direct assignment of the upgrade cost is made due to the displacement to an earlier Note 4: For Point-to-Point requests, total cost is based on the higher of the base rate or assigned upgrade revenue requirements. For Network requests, the total cost is based on the assigned upgrade revenue requirements. For Network requests, the total cost is based on the assigned upgrade revenue requirements. For Network requests, the total cost is based on the assigned upgrade revenue requirements. For Network requests, the total cost is based on the assigned upgrade revenue requirements. For Network requests, the total cost is assignable to Customer. This includes prepayments required for any SWPA upgrades. Revenue requirements for 3rd Party facilities are not calculated. Total cost to customer is based on assumption of Revenue Requirements with confirmation of base plan funding. Customer is responsible for negotiating redispatch costs if applicable. Customer is also responsible

Note 5: RR with base plan funding may increase or decrease even if no base plan funding is applicable to a particular request if another request that shares the upgrade is now full base plan funded resulting in a different amortization period for the upgrade and thus different RR.

Note 6: The estimated engineering and construction cost for the Pawnee to Larned 115 kV line has a 2009 year effective date. This estimate will be updated with a 2012 year effective date.

Allocation of base plan funding is contingent upon verification of customer agreements meeting Attachment J, Section II B criteria. Not applicable if Point-to-Point base rate exceeds revenue requirements.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|------|-----------|-------------|--------|---------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested S | art Re | equested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | D | ate | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| AECC | 75197033 | OKGE | OKGE | | 238 7/1/ | 2015 | 7/1/2020 | | | \$ - | \$ - | \$ - | \$ - |
| | | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue | |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|---|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements | |
| 75197033 | None | | | | | \$ - | \$ - | \$ - | |
| • | | | | | Total | \$ - | \$ - | \$ - | 1 |

^{*}Credits may be required for applicable generation interconnection network upgrades.

AG1-2011-081

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|-----|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| AECC | 75197522 | SPA | OKGE | 89 | 7/1/2015 | 7/1/2020 | | | \$ - | \$ - | \$ - | \$ - |
| | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75197522 | None | | | | | \$ - | \$ - | \$ - |
| | | | | | Total | Ś - | \$ - | \$. |

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75197522 | BEELINE - EXPLORER GLENPOOL 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | EXPLORER GLENPOOL - RIVERSIDE STATION 138KV CKT 1 AEPW | 6/1/2009 | 6/1/2009 | | |
| | EXPLORER GLENPOOL - RIVERSIDE STATION 138KV CKT 1 OKGE | 6/1/2009 | 6/1/2009 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC | 7/1/2012 | 7/1/2012 | | |
| | KNOBHILL (KNOBHIL4) 138/69/13.2KV TRANSFORMER CKT 1 | 6/1/2006 | 6/1/2008 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | MCNAB REC - TURK 115KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| SPSM | WOODWARD - IODINE 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 2 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD 345/138KV TRANSFORMER CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

 Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| AECC | 75197570 | CSWS | OKGE | 710 | 7/1/2015 | 7/1/2020 | | | \$ - | \$ - | \$ - | - \$ - |
| - | | | | | | | | | \$ - | \$ - | \$ - | - \$ - |

| | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|--------------------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75197570 None | | | | | \$ - | \$ - | \$ - |
| | | | | Total | \$ - | \$ - | \$ - |

| | | | Earliest Start | Redispatch |
|--|-----------|-----------|----------------|------------|
| Upgrade Name | DUN | EOC | Date | Available |
| ALBION - PETERSBURG 115KV CKT 1 | 1/1/2013 | | | |
| ALEXANDER - PRATT 115KV CKT 1 | 12/1/2009 | | | |
| ALEXANDER - SAWYER 3 115.00 115KV CKT 1 | 12/1/2009 | | | |
| ALUMAX TAP - BANN 138KV CKT 1 | 6/1/2008 | | | |
| BEELINE - EXPLORER GLENPOOL 138KV CKT 1 | 6/1/2009 | | | |
| CANTON - TALOGA 69KV CKT 1 | 6/1/2011 | | | |
| CHERRY6 230.00 - Harrington Station East Bus 230KV CKT 1 | 6/1/2015 | | | |
| CLIFTON - GREENLEAF 115KV CKT 1 | 6/1/2011 | | | |
| EXPLORER GLENPOOL - RIVERSIDE STATION 138KV CKT 1 AEPW | 6/1/2009 | 6/1/2009 | | |
| EXPLORER GLENPOOL - RIVERSIDE STATION 138KV CKT 1 OKGE | 6/1/2009 | 6/1/2009 | | |
| FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2009 | | | |
| FLATRDG3 138.00 - HARPER 138KV CKT 1 | 12/1/2009 | 6/15/2013 | | |
| FT RANDAL - MADISONCO 230.00 230KV CKT 1 | 10/1/2013 | 11/1/2014 | | |
| G03-05T 138.00 - PARADISE 138KV CKT 1 | 6/1/2010 | | | |
| GREENLEAF - KNOB HILL 115KV CKT 1 MKEC | 6/1/2013 | 6/1/2013 | | |
| HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC | 7/1/2012 | 7/1/2012 | | |
| HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1 | 7/1/2012 | 7/1/2012 | | |
| KELLY - MADISONCO 230.00 230KV CKT 1 | 10/1/2013 | 11/1/2014 | | |
| KNOBHILL (KNOBHIL4) 138/69/13.2KV TRANSFORMER CKT 1 | 6/1/2006 | 6/1/2008 | | |
| MCNAB REC - TURK 115KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| MEDICINE LODGE - SAWYER 115KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 Displacement | 12/1/2009 | 6/1/2013 | | |
| NELIGH - PETERSBURG 115KV CKT 1 | 1/1/2013 | 1/1/2013 | | |
| NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| OKAY - TURK 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| SE TEXARKANA - TURK 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| SUB 110 - ORONOGO JCT SUB 167 - RIVERTON 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| SUGAR HILL - TURK 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| TALOGA (TALOGA) 138/69/13.8KV TRANSFORMER CKT 1 | 10/1/2010 | 6/1/2013 | | |
| TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| WOODWARD - IODINE 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| WOODWARD - WOODWARD EHV 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| WOODWARD - WOODWARD EHV 138KV CKT 2 | 1/1/2010 | 1/1/2010 | | |
| WOODWARD 345/138KV TRANSFORMER CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| AECC | 75197442 | CSWS | CSWS | 170 | 6/1/2015 | 6/1/2020 | 6/1/2016 | 6/1/2021 | \$ 205,780 | \$ - | \$ 205,780 | \$ 383,365 |
| | | | | | | | | | \$ 205,780 | \$ - | \$ 205,780 | \$ 383,365 |

| | | | | Earliest Start | Redispatch | Allocate | d E & C | | Total Revenue |
|-------------|---|----------|----------|----------------|------------|----------|---------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | | Total E & C Cost | Requirements |
| 75197442 | 5 TRIBES - PECAN CREEK 161KV CKT 1 Accelerate | 6/1/2014 | 6/1/2016 | | | \$ | 205,780 | \$ 343,986 | \$ 383,365 |
| • | | | | | Total | Ś | 205.780 | \$ 343,986 | \$ 383,365 |

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75197442 | ASHDOWN REC (MILLWOOD) - OKAY 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | ASHDOWN REC (MILLWOOD) - PATTERSON 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | BANN - RED SPRINGS REC 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC | 7/1/2012 | 7/1/2012 | | |
| | MCNAB REC - TURK 115KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | OKAY - TURK 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | SE TEXARKANA - TURK 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | SUGAR HILL - TURK 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

 Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| AECC | 75197472 | CSWS | OKGE | 170 | 7/1/2015 | 6/1/2020 | | | \$ - | \$ - | \$ - | - \$ - |
| | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75197472 | None | | | | | \$ - | \$ - | \$ |
| | | | | | Total | Ś - | \$ - | Ś |

| | | | | Earliest Start | Redispatch |
|-------------|---|-----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75197472 | ALUMAX TAP - BANN 138KV CKT 1 | 6/1/2008 | 6/1/2008 | | |
| | BANN - RED SPRINGS REC 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | BEELINE - EXPLORER GLENPOOL 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | CLIFTON - GREENLEAF 115KV CKT 1 | 6/1/2011 | 6/1/2013 | | |
| | EXPLORER GLENPOOL - RIVERSIDE STATION 138KV CKT 1 AEPW | 6/1/2009 | 6/1/2009 | | |
| | EXPLORER GLENPOOL - RIVERSIDE STATION 138KV CKT 1 OKGE | 6/1/2009 | 6/1/2009 | | |
| | FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | GREENLEAF - KNOB HILL 115KV CKT 1 MKEC | 6/1/2013 | 6/1/2013 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC | 7/1/2012 | 7/1/2012 | | |
| | KNOBHILL (KNOBHIL4) 138/69/13.2KV TRANSFORMER CKT 1 | 6/1/2006 | 6/1/2008 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 Displacement | 12/1/2009 | 6/1/2013 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - IODINE 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 2 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD 345/138KV TRANSFORMER CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

 Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|-----|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| AECC | 75197551 | EES | OKGE | 320 | 7/1/2015 | 7/1/2020 | | | \$ - | \$ - | \$ - | \$ - |
| | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75197551 | None | | | | | \$ - | \$ - | \$ |
| • | | | | | Total | Ś - | Ś - | Ś |

| | | | | Earliest Start | Redispatch |
|-------------|--|-----------|-----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75197551 | ALEXANDER - PRATT 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| | ALEXANDER - SAWYER 3 115.00 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| | ALUMAX TAP - BANN 138KV CKT 1 | 6/1/2008 | 6/1/2008 | | |
| | BANN - RED SPRINGS REC 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | BEELINE - EXPLORER GLENPOOL 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | |
| | CHERRY6 230.00 - Harrington Station East Bus 230KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | CLIFTON - GREENLEAF 115KV CKT 1 | 6/1/2011 | 6/1/2013 | | |
| | EXPLORER GLENPOOL - RIVERSIDE STATION 138KV CKT 1 AEPW | 6/1/2009 | 6/1/2009 | | |
| | EXPLORER GLENPOOL - RIVERSIDE STATION 138KV CKT 1 OKGE | 6/1/2009 | 6/1/2009 | | |
| | FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | FT RANDAL - MADISONCO 230.00 230KV CKT 1 | 10/1/2013 | 11/1/2014 | | |
| | GREENLEAF - KNOB HILL 115KV CKT 1 MKEC | 6/1/2013 | 6/1/2013 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC | 7/1/2012 | 7/1/2012 | | |
| | KELLY - MADISONCO 230.00 230KV CKT 1 | 10/1/2013 | 11/1/2014 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | MCNAB REC - TURK 115KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | MEDICINE LODGE - SAWYER 115KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 Displacement | 12/1/2009 | 6/1/2013 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | SUB 110 - ORONOGO JCT SUB 167 - RIVERTON 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | SUGAR HILL - TURK 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - IODINE 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 2 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD 345/138KV TRANSFORMER CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|-----|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| BPAE | 75181762 | WR | AECI | 50 | 11/1/2012 | 11/1/2017 | 6/1/2019 | 6/1/2024 | \$ - | \$ 2,634,000 | \$ 396,134 | \$ 732,139 |
| | | | | | | | | | \$ - | \$ 2,634,000 | \$ 396,134 | \$ 732,139 |

| | | | | Earliest Start | Redispatch | Allocat | ed E & C | | Total Revenue |
|-------------|--|----------|----------|----------------|------------|---------|----------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | | Total E & C Cost | Requirements |
| 75181762 | BEAVER - EUREKA SPRINGS 161KV CKT 1 AEPW | 6/1/2013 | 6/1/2016 | | | \$ | 289,884 | \$ 2,635,666 | \$ 583,194 |
| | MIDWAY - ST JOE 161KV CKT 1 Reactor | 6/1/2014 | 6/1/2015 | | Yes | \$ | 106,250 | \$ 425,000 | \$ 148,945 |
| | | | • | • | Total | Ś | 396.134 | \$ 3,060,666 | \$ 732,139 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|----------------------------|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75181762 | IATAN - NASHUA 345KV CKT 1 | 2/1/2013 | 6/1/2015 | | Yes |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75181762 | BLUE SPRING SOUTH - PRAIRIE LEE 161KV CKT 1 #1 | 6/1/2014 | 6/1/2015 | | |
| | Brookline – Compton Ridge 345 kV EMDE | 6/1/2013 | 6/1/2019 | | Yes |
| | Brookline – Compton Ridge 345 kV SPRM | 6/1/2013 | 6/1/2019 | | Yes |
| | Compton Ridge 345/161 kV Transformer | 6/1/2013 | 6/1/2019 | | Yes |

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75181762 | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC | 7/1/2012 | 7/1/2012 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |

Third Party Limitations.

| | | | | Earliest Start | Redispatch | *Alloca | ated E & C | | |
|-------------|--|----------|----------|----------------|------------|---------|------------|----------|-----------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | | *Total E | & C Cost |
| 75181762 | BEAVER - EUREKA SPRINGS 161KV CKT 1 SWPA | 6/1/2013 | 6/1/2016 | | | \$ | 454,238 | \$ | 4,130,000 |
| | | | | | Total | \$ | 454,238 | \$ | 4,130,000 |

^{*}Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|-----|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| BPAE | 75181747 | WR | AECI | 150 | 11/1/2012 | 11/1/201 | 6/1/2019 | 6/1/2024 | \$ - | \$ 7,902,000 | \$ 1,188,401 | \$ 2,196,416 |
| | | | | | | | | | \$ - | \$ 7,902,000 | \$ 1,188,401 | \$ 2,196,416 |

| | | | | Earliest Start | Redispatch | Alloca | ted E & C | | Total Revenue |
|-------------|--|----------|----------|----------------|------------|--------|-----------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | | Total E & C Cost | Requirements |
| 75181747 | BEAVER - EUREKA SPRINGS 161KV CKT 1 AEPW | 6/1/2013 | 6/1/2016 | | | \$ | 869,651 | \$ 2,635,666 | \$ 1,749,580 |
| | MIDWAY - ST JOE 161KV CKT 1 Reactor | 6/1/2014 | 6/1/2015 | | Yes | \$ | 318,750 | \$ 425,000 | \$ 446,836 |
| | | • | | | Total | Ś | 1.188.401 | \$ 3,060,666 | \$ 2,196,416 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|----------------------------|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 7518174 | IATAN - NASHUA 345KV CKT 1 | 2/1/2013 | 6/1/2015 | | Yes |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | | Earliest Start | Redispatch |
|------|----------|--|----------|----------|----------------|------------|
| Rese | rvation | Upgrade Name | DUN | EOC | Date | Available |
| | 75181747 | BLUE SPRING SOUTH - PRAIRIE LEE 161KV CKT 1 #1 | 6/1/2014 | 6/1/2015 | | Yes |
| | | Brookline – Compton Ridge 345 kV EMDE | 6/1/2013 | 6/1/2019 | | Yes |
| | | Brookline – Compton Ridge 345 kV SPRM | 6/1/2013 | 6/1/2019 | | Yes |
| | | Compton Ridge 345/161 kV Transformer | 6/1/2013 | 6/1/2019 | | Yes |

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75181747 | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC | 7/1/2012 | 7/1/2012 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |

Third Party Limitations.

| | | | | Earliest Start | Redispatch | *Allor | cated E & C | | |
|-------------|--|----------|----------|----------------|------------|--------|-------------|----------|-----------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | | *Total E | & C Cost |
| 75181747 | BEAVER - EUREKA SPRINGS 161KV CKT 1 SWPA | 6/1/2013 | 6/1/2016 | | | \$ | 1,362,714 | \$ | 4,130,000 |
| | | | | | Total | \$ | 1,362,714 | \$ | 4,130,000 |

^{*}Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|-----|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| CRGL | 75199999 | SECI | EES | 500 | 7/1/2014 | 7/1/2019 | 1/1/2018 | 1/1/2023 | \$ - | \$ 38,400,000 | \$ 51,340 | \$ 123,282 |
| | | | | | | | | | \$ - | \$ 38,400,000 | \$ 51,340 | \$ 123,282 |

| | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|---|----------|----------|----------------|------------|-----------------|------------------|---------------|
| Reservation Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75199999 HARPER - MILAN TAP 138KV CKT 1 #1 Accelerate | 2/1/2013 | 6/1/2015 | | Yes | \$ 51,340 | \$ 62,990 | \$ 123,282 |
| | | | | Total | \$ 51,340 | \$ 62,990 | \$ 123,282 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|---|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75199999 | Line - Clark County - Thistle 345 kV dbl Ckt | 2/1/2013 | 1/1/2015 | | No |
| | Line - Hitchland - Woodward 345 kV dbl Ckt OKGE | 2/1/2013 | 7/1/2014 | | |
| | Line - Hitchland - Woodward 345 kV dbl Ckt SPS | 2/1/2013 | 7/1/2014 | | |
| | Line - Spearville - Clark County 345 kV dbl Ckt | 2/1/2013 | 1/1/2015 | | No |
| | Line - Thistle - Wichita 345 kV dbl Ckt PW | 2/1/2013 | 1/1/2015 | | No |
| | Line - Thistle - Wichita 345 kV dbl Ckt WERE | 2/1/2013 | 1/1/2015 | | No |
| | Line - Thistle - Woodward 345 kV dbl Ckt OKGE | 2/1/2013 | 1/1/2015 | | No |
| | Line - Thistle - Woodward 345 kV dbl Ckt PW | 2/1/2013 | 1/1/2015 | | No |
| | Line - Tuco - Woodward 345 kV line OKGE | 2/1/2013 | 6/1/2014 | | |
| | Line - Tuco - Woodward 345 kV line SPS | 2/1/2013 | 6/1/2014 | | |
| | XFR - Thistle 345/138 kV | 2/1/2013 | 1/1/2015 | | No |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|------------------------------------|-----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75199999 | Cherry Co - Gentleman 345 kV Ckt1 | 10/1/2014 | 1/1/2018 | | Yes |
| | Cherry Co - Holt Co 345 kV Ckt1 | 10/1/2014 | 1/1/2018 | | Yes |
| | Cherry Co 345 kV Terminal Upgrades | 10/1/2014 | 1/1/2018 | | Yes |

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75199999 | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC | 7/1/2012 | 7/1/2012 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | | |
|----------|-------------|------|-----|-----------|-----------|-------|----------------|----------------|---------------|----------------|-----|--------------|-----------------|---------------|
| | | | | Requested | Requested | tart | Requested Stop | Date Without | Date Without | Plan Funding | Poi | int-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | 1 | Date | Redispatch | Redispatch | Allowable | Bas | e Rate | Cost | Requirements |
| CRGL | 75199802 | OKGE | EES | | 98 12/ | /2012 | 12/1/2032 | 2/1/2013 | 2/1/2033 | \$ - | \$ | 30,105,600 | \$ 686,150 | \$ 2,300,682 |
| | | | | | | | | | | \$ - | \$ | 30,105,600 | \$ 686,150 | \$ 2,300,682 |

| | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|---|----------|----------|----------------|------------|-----------------|------------------|---------------|
| Reservation Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75199802 BEAVER - EUREKA SPRINGS 161KV CKT 1 AEPW | 6/1/2013 | 6/1/2016 | | | \$ 686,150 | \$ 2,635,666 | \$ 2,300,682 |
| | | | | Total | \$ 686,150 | \$ 2,635,666 | \$ 2,300,682 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch | ĺ |
|-------------|----------------------------|----------|----------|----------------|------------|---|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | l |
| 75199802 | IATAN - NASHUA 345KV CKT 1 | 2/1/2013 | 6/1/2015 | | | Ĺ |

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75199802 | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC | 7/1/2012 | 7/1/2012 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |

Third Party Limitations.

| | | | | Earliest Start | Redispatch | *Allo | cated E & C | |
|-------------|--|----------|----------|----------------|------------|-------|-------------|-------------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | | *Total E & C Cost |
| 75199802 | BEAVER - EUREKA SPRINGS 161KV CKT 1 SWPA | 6/1/2013 | 6/1/2016 | | | \$ | 1,075,174 | \$ 4,130,000 |
| | | | | | Total | \$ | 1,075,174 | \$ 4,130,000 |

^{*}Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|-----|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| CRGL | 75199815 | NPPD | EES | 200 | 12/1/2012 | 12/1/2032 | 2/1/2013 | 2/1/203 | 3 \$ - | \$ 61,440,000 | \$ - | \$ - |
| • | | | | | | | | | \$ - | \$ 61,440,000 | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75199815 | None | | | | | \$ - | \$ - | \$ |
| | | | | | Total | Ś - | Ś - | Ś |

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75199815 | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC | 7/1/2012 | 7/1/2012 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number HZN AG1-2011-055

| | | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | | |
|----------|-------------|------|-----|-----------|-------|------------|----------------|----------------|---------------|----------------|--------|-----------|-----------------|---------------|
| | | | | Requested | Reque | sted Start | Requested Stop | Date Without | Date Without | Plan Funding | Point- | to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | | Date | Redispatch | Redispatch | Allowable | Base R | late | Cost | Requirements |
| HZN | 75181743 | WFEC | EES | | 100 | 1/1/2012 | 1/1/2017 | 2/1/2013 | 2/1/2018 | \$ - | \$ | 7,680,000 | \$ 845,582 | \$ 1,613,337 |
| · · | | | | | | | | | | \$ - | \$ | 7,680,000 | \$ 845,582 | \$ 1,613,337 |

| | | | | Earliest Start | Redispatch | Allocat | ed E & C | | Total Revenue |
|-------------|---|----------|----------|----------------|------------|---------|----------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | | Total E & C Cost | Requirements |
| 75181743 | 5 TRIBES - PECAN CREEK 161KV CKT 1 Accelerate | 6/1/2014 | 6/1/2016 | | | \$ | 138,206 | \$ 343,986 | \$ 190,225 |
| | BEAVER - EUREKA SPRINGS 161KV CKT 1 AEPW | 6/1/2013 | 6/1/2016 | | | \$ | 707,376 | \$ 2,635,666 | \$ 1,423,112 |
| | | • | | | Total | Ś | 845.582 | \$ 2,979,652 | \$ 1.613.337 |

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75181743 | GRACMNT4 138.00 - WASHITA 138KV CKT 2 OKGE | 1/1/2012 | 1/1/2012 | | |
| | GRACMNT4 138.00 - WASHITA 138KV CKT 2 WFEC | 1/1/2012 | 1/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC | 7/1/2012 | 7/1/2012 | | |
| | MCNAB REC - TURK 115KV CKT 1 | 7/1/2012 | 7/1/2012 | | |

Third Party Limitations.

| | | | | Earliest Start | Redispatch | *Allo | cated E & C | | | |
|-------------|--|----------|----------|----------------|------------|-------|-------------|----------|------------|--|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | | *Total [| E & C Cost | |
| 75181743 | BEAVER - EUREKA SPRINGS 161KV CKT 1 SWPA | 6/1/2013 | 6/1/2016 | | | \$ | 1,108,434 | \$ | 4,130,000 | |
| | | | | | Total | \$ | 1,108,434 | \$ | 4,130,000 | |

^{*}Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| KCPS | 75181547 | NPPD | KCPL | 20 | 1/1/2014 | 1/1/202 | 4 1/1/2018 | 1/1/2028 | \$ \$ - | \$ - | \$ - | \$ - |
| | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|--------------------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75181547 None | | | | | \$ - | \$ - | \$ - |
| | | | | Total | \$ - | \$ - | \$ - |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|---|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75181547 | IATAN - NASHUA 345KV CKT 1 | 2/1/2013 | 6/1/2015 | | Yes |
| | Line - Thistle - Woodward 345 kV dbl Ckt OKGE | 2/1/2013 | 1/1/2015 | | |
| | Line - Thistle - Woodward 345 kV dbl Ckt PW | 2/1/2013 | 1/1/2015 | | |
| | Line - Tuco - Woodward 345 kV line OKGE | 2/1/2013 | 6/1/2014 | | |
| | Line - Tuco - Woodward 345 kV line SPS | 2/1/2013 | 6/1/2014 | | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|--|-----------|-----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75181547 | Cherry Co - Gentleman 345 kV Ckt1 | 10/1/2014 | 1/1/2018 | | Yes |
| | Cherry Co - Holt Co 345 kV Ckt1 | 10/1/2014 | 1/1/2018 | | Yes |
| | Cherry Co 345 kV Terminal Upgrades | 10/1/2014 | 1/1/2018 | | Yes |
| | MOUNDRIDGE 138/115KV TRANSFORMER CKT 2 | 2/1/2013 | 12/1/2014 | | |

| | | | | Earliest Start | Redispatch |
|-------------|------------------------------------|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75181547 | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| KCPS | 75181564 | NPPD | KCPL | 20 | 1/1/2014 | 1/1/2024 | 6/1/2015 | 6/1/2025 | \$ - | \$ - | \$ - | \$ - |
| · · | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75181564 | None | | | | | \$ - | \$ - | \$ - |
| • | | | | | Total | Ś - | \$ - | \$ - |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|---|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75181564 | IATAN - NASHUA 345KV CKT 1 | 2/1/2013 | 6/1/2015 | | Yes |
| | Line - Thistle - Woodward 345 kV dbl Ckt OKGE | 2/1/2013 | 1/1/2015 | | |
| | Line - Thistle - Woodward 345 kV dbl Ckt PW | 2/1/2013 | 1/1/2015 | | |
| | Line - Tuco - Woodward 345 kV line OKGE | 2/1/2013 | 6/1/2014 | | |
| | Line - Tuco - Woodward 345 kV line SPS | 2/1/2013 | 6/1/2014 | | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|--|-----------|-----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 751815 | 4 Cherry Co - Gentleman 345 kV Ckt1 | 10/1/2014 | 1/1/2018 | | |
| | Cherry Co - Holt Co 345 kV Ckt1 | 10/1/2014 | 1/1/2018 | | |
| | Cherry Co 345 kV Terminal Upgrades | 10/1/2014 | 1/1/2018 | | |
| | MOUNDRIDGE 138/115KV TRANSFORMER CKT 2 | 2/1/2013 | 12/1/2014 | | |

| | | | | Earliest Start | Redispatch |
|-------------|------------------------------------|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75181564 | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| KCPS | 75181568 | NPPD | KCPL | 22 | 1/1/2014 | 1/1/20 | 24 6/1/2015 | 6/1/2025 | \$ - | \$ - | \$ - | \$ - |
| | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Jpgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75181568 | None | | | | | \$ - | \$ - | \$ |
| | | | | | Total | ς - | \$ - | \$ |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|---|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75181568 | IATAN - NASHUA 345KV CKT 1 | 2/1/2013 | 6/1/2015 | | Yes |
| | Line - Thistle - Woodward 345 kV dbl Ckt OKGE | 2/1/2013 | 1/1/2015 | | |
| | Line - Thistle - Woodward 345 kV dbl Ckt PW | 2/1/2013 | 1/1/2015 | | |
| | Line - Tuco - Woodward 345 kV line OKGE | 2/1/2013 | 6/1/2014 | | |
| | Line - Tuco - Woodward 345 kV line SPS | 2/1/2013 | 6/1/2014 | | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|--|-----------|-----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 751815 | 68 Cherry Co - Gentleman 345 kV Ckt1 | 10/1/2014 | 1/1/2018 | | |
| | Cherry Co - Holt Co 345 kV Ckt1 | 10/1/2014 | 1/1/2018 | | |
| | Cherry Co 345 kV Terminal Upgrades | 10/1/2014 | 1/1/2018 | | |
| | MOUNDRIDGE 138/115KV TRANSFORMER CKT 2 | 2/1/2013 | 12/1/2014 | | |

| | | | | Earliest Start | Redispatch |
|-------------|------------------------------------|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75181568 | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| KCPS | 75199886 | SECI | KCPL | 50 | 8/1/2011 | 8/31/201 | 4/1/2012 | 9/1/2013 | \$ - | \$ 746,300 | \$ - | \$ - |
| | | | | | | | | | \$ - | \$ 746,300 | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75199886 | None | | | | | \$ - | \$ - | \$ |
| • | | | | | Total | ς - | \$ - | \$ |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|---|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75199886 | Line - Thistle - Woodward 345 kV dbl Ckt OKGE | 2/1/2013 | 1/1/2015 | | |
| | Line - Thistle - Woodward 345 kV dbl Ckt PW | 2/1/2013 | 1/1/2015 | | |
| | Line - Tuco - Woodward 345 kV line OKGE | 2/1/2013 | 6/1/2014 | | |
| | Line - Tuco - Woodward 345 kV line SPS | 2/1/2013 | 6/1/2014 | | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|-----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75199886 | MOUNDRIDGE 138/115KV TRANSFORMER CKT 2 | 2/1/2013 | 12/1/2014 | | |

| | | | | Earliest Start | Redispatch |
|-------------|--|-----------|-----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 7519988 | FLATRDG3 138.00 - HARPER 138KV CKT 1 | 12/1/2009 | 6/15/2013 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC | 7/1/2012 | 7/1/2012 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - IODINE 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD 345/138KV TRANSFORMER CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | | | | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| KCPS | 75199893 | SECI | KCPL | 50 | 8/1/2011 | 8/31/201 | 4/1/2012 | 9/1/201 | 3 \$ - | \$ 746,300 | \$ - | \$ - |
| | | | | | | | | | \$ - | \$ 746,300 | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75199893 | None | | | | | \$ - | \$ - | \$ |
| • | | | | | Total | ς - | \$ - | \$ |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|---|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75199893 | Line - Thistle - Woodward 345 kV dbl Ckt OKGE | 2/1/2013 | 1/1/2015 | | |
| | Line - Thistle - Woodward 345 kV dbl Ckt PW | 2/1/2013 | 1/1/2015 | | |
| | Line - Tuco - Woodward 345 kV line OKGE | 2/1/2013 | 6/1/2014 | | |
| | Line - Tuco - Woodward 345 kV line SPS | 2/1/2013 | 6/1/2014 | | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch | |
|-------------|--|----------|-----------|----------------|------------|--|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | |
| 75199893 | MOUNDRIDGE 138/115KV TRANSFORMER CKT 2 | 2/1/2013 | 12/1/2014 | | | |

| | | | | Earliest Start | Redispatch |
|-------------|--|-----------|-----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75199893 | FLATRDG3 138.00 - HARPER 138KV CKT 1 | 12/1/2009 | 6/15/2013 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC | 7/1/2012 | 7/1/2012 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - IODINE 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD 345/138KV TRANSFORMER CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|-----|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| KMEA | 75200249 | SPA | SECI | 1 | 11/1/2013 | 12/31/2018 | | 12/1/2018 | \$ 4,621 | \$ - | \$ 4,621 | \$ 7,112 |
| | | | | | | | | | \$ 4,621 | \$ - | \$ 4,621 | \$ 7,112 |

| | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|---|----------|----------|----------------|------------|-----------------|------------------|---------------|
| Reservation Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75200249 HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2 | 6/1/2013 | 6/1/2016 | | | \$ 4,621 | \$ 4,734,006 | \$ 7,112 |
| | | | | Total | \$ 4.621 | \$ 4,734,006 | \$ 7.112 |

| | | | | Earliest Start | Redispatch |
|-------------|---|-----------|------------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75200249 | ALEXANDER - PRATT 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| | ALEXANDER - SAWYER 3 115.00 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| | CIRCLE - RICE_CO 230KV CKT 1 | 10/1/2012 | 11/15/2012 | | |
| | CLIFTON - GREENLEAF 115KV CKT 1 | 6/1/2011 | 6/1/2013 | | |
| | FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | GREENLEAF - KNOB HILL 115KV CKT 1 MKEC | 6/1/2013 | 6/1/2013 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | LYONS - RICE_CO 115KV CKT 1 | 10/1/2012 | 4/1/2013 | | |
| | LYONS - WHEATLAND 115KV CKT 1 #1 | 10/1/2012 | 7/15/2013 | | |
| | LYONS - WHEATLAND 115KV CKT 1 #2 | 10/1/2012 | 7/15/2013 | | |
| | MEDICINE LODGE - SAWYER 115KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 Displacement | 12/1/2009 | 6/1/2013 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | RICE_CO 230/115KV TRANSFORMER CKT 1 | 10/1/2012 | 11/15/2012 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

^{*34.5} kV and lower underlying System Impacts and Upgrades have yet to be determined.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|-----|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| KMEA | 75199561 | OPPD | WR | 6 | 2/1/2012 | 2/1/2017 | 2/1/2013 | 2/1/2018 | \$ - | \$ - | \$ - | - \$ - |
| | | | | | | | | | \$ - | \$ - | \$ - | - \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75199561 | None | | | | | \$ - | \$ - | \$ |
| • | | | | | Total | ς - | \$ - | \$ |

Direct Assignment Facilities - The requested service is contingent upon completion of the following upgrades.

| | | | | Earliest Service | Redispatch | Allocat | ted E & C | |
|-------------|------------------------------|----------|----------|------------------|------------|---------|-----------|------------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | | Total E & C Cost |
| 75199561 | PAWNEE - LARNED 115 KV CKT 1 | 2/1/2013 | 6/1/2013 | | | \$ | 706,833 | \$ 706,83 |
| | | | | | Total | Ś | 706.833 | \$ 706.83 |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|------------------------------------|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75199561 | MEDICINE LODGE - PRATT 115KV CKT 1 | 2/1/2013 | 1/1/2014 | | |

| | | | Earliest Start | Redispatch |
|---|---|--|--|--|
| Upgrade Name | DUN | EOC | Date | Available |
| ALEXANDER - PRATT 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| ALEXANDER - SAWYER 3 115.00 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| FLATRDG3 138.00 - HARPER 138KV CKT 1 | 12/1/2009 | 6/15/2013 | | |
| LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| MEDICINE LODGE - SAWYER 115KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 Displacement | 12/1/2009 | 6/1/2013 | | |
| NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | ALEXANDER - PRATT 115KV CKT 1 ALEXANDER - SAWYER 3 115.00 115KV CKT 1 FLATROG3 138.00 - MADEICINE LODGE 138KV CKT 1 FLATROG3 138.00 - HAPPER 138KV CKT 1 LACYGNE - WEST GARDNER 345KV CKT 1 MEDICINE LODGE - SAWYER 115KV CKT 1 MEDICINE LODGE - SAWYER 115KV CKT 1 MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 Displacement NORTHWEST - TATONGA 345KV CKT 1 | ALEXANDER - PRATT 115KV CKT 1 12/1/2009 ALEXANDER - SAWYER 3 115.00 115KV CKT 1 12/1/2009 FLATROG3 138.00 - MADICINE LODGE 138KV CKT 1 12/1/2009 FLATROG3 138.00 - HARPER 138KV CKT 1 12/1/2009 LACYGNE - WEST GARDNER 345KV CKT 1 6/1/2006 MEDICINE LODGE - SAWYER 115KV CKT 1 12/1/2009 MEDICINE LODGE - SAWYER 115KV CKT 1 12/1/2009 NORTHWEST - TATONGA 345KV CKT 1 1/1/2010 | Upgrade Name DUN EOC ALEXANDER - PRATT 115KV CKT 1 12/1/2009 1/1/2014 ALEXANDER - SAWYER 3 115.00 115KV CKT 1 12/1/2009 1/1/2014 FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 12/1/2009 6/1/2013 FLATRDG3 138.00 - HARPER 138KV CKT 1 12/1/2009 6/1/2016 LCYGNE - WEST GARDINER 345KV CKT 1 6/1/2006 6/1/2008 MEDICINE LODGE - SAWYER 115KV CKT 1 12/1/2009 6/1/2013 MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 Displacement 12/1/2009 6/1/2013 NORTHWEST - TATONGGA 345KV CKT 1 1/1/2010 1/1/2010 | Upgrade Name DUN ECC Date ALEXANDER - PRATT 115KV CKT 1 12/1/2009 1/1/2014 ALEXANDER - SAWYER 3 115.00 115KV CKT 1 12/1/2009 1/1/2014 FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 12/1/2009 6/1/2013 FLATRDG3 138.00 - HARPER 138KV CKT 1 12/1/2009 6/1/2013 LCCYGNE - WEST GARDNER 345KV CKT 1 6/1/2006 6/1/2006 MEDICINE LODGE - SAWYER 115KV CKT 1 12/1/2009 6/1/2013 MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 Displacement 12/1/2009 6/1/2013 NORTHWEST - TATONGA 345KV CKT 1 1/1/2010 1/1/2010 |

^{*}Credits may be required for applicable generation interconnection network upgrades.

^{*}For reservation 75199561, The Maximum Firm Import Capability before the PAWNEE - LARNED 115 KV CKT 1 upgrade is 7MW due to Larned 34.5/12.47kV transformer.

^{*}For reservation 75199561, PAWNEE - LARNED 115 KV CKT 1 upgrade assumes LARNED 115/12.47 KV transformer will be installed by Network Customer or Midwest Energy.

^{*}The estimated engineering and construction cost for the Pawnee to Larned 115 kV line has a 2009 year effective date. This estimate will be updated with a 2012 year effective date.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|------|-----------|-------------|-------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested S | tart | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| KMEA | 75200582 | SECI | SECI | 23 | 1/1 | /2012 | 6/1/202 | 6 1/1/2015 | 6/1/2029 | \$ 203,965 | \$ - | \$ 203,965 | \$ 472,814 |
| | | | | | | | | | | \$ 203,965 | \$ - | \$ 203,965 | \$ 472,814 |

| | | | | Earliest Start | Redispatch | Allocate | d E & C | | Total Revenue |
|-------------|--|----------|----------|----------------|------------|----------|---------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | | Total E & C Cost | Requirements |
| 75200582 | BEAVER - EUREKA SPRINGS 161KV CKT 1 AEPW | 6/1/2013 | 6/1/2016 | | | \$ | 82,605 | \$ 2,635,666 | \$ 232,539 |
| | HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2 | 6/1/2013 | 6/1/2016 | | Yes | \$ | 121,360 | \$ 4,734,006 | \$ 240,275 |
| | | • | | | Total | Ś | 203.965 | \$ 7,369,671 | \$ 472.814 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|---|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75200582 | Line - Thistle - Woodward 345 kV dbl Ckt OKGE | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Thistle - Woodward 345 kV dbl Ckt PW | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Tuco - Woodward 345 kV line OKGE | 2/1/2013 | 6/1/2014 | | Yes |
| | Line - Tuco - Woodward 345 kV line SPS | 2/1/2013 | 6/1/2014 | | Yes |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|------------------------------------|-----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75200582 | Cherry Co - Gentleman 345 kV Ckt1 | 10/1/2014 | 1/1/2018 | | Yes |
| | Cherry Co - Holt Co 345 kV Ckt1 | 10/1/2014 | 1/1/2018 | | Yes |
| | Cherry Co 345 kV Terminal Upgrades | 10/1/2014 | 1/1/2018 | | Yes |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|------------------------------------|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75200582 | MEDICINE LODGE - PRATT 115KV CKT 1 | 2/1/2013 | 1/1/2014 | | |

 Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | Earliest Start | Redispatch | |
|-------------|--|-----------|------------|----------------|------------|-------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | |
| 75200582 | ALEXANDER - PRATT 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | | FALSE |
| | ALEXANDER - SAWYER 3 115.00 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | | #REF! |
| | CHERRY6 230.00 - Harrington Station East Bus 230KV CKT 1 | 6/1/2015 | 6/1/2015 | | | #REF! |
| | CIRCLE - RICE_CO 230KV CKT 1 | 10/1/2012 | 11/15/2012 | | | FALSE |
| | CLIFTON - GREENLEAF 115KV CKT 1 | 6/1/2011 | 6/1/2013 | | | #REF! |
| | FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2009 | 6/1/2013 | | | #REF! |
| | FLATRDG3 138.00 - HARPER 138KV CKT 1 | 12/1/2009 | 6/15/2013 | | | #REF! |
| | GREENLEAF - KNOB HILL 115KV CKT 1 MKEC | 6/1/2013 | 6/1/2013 | | | #REF! |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | | #REF! |
| | LYONS - RICE_CO 115KV CKT 1 | 10/1/2012 | 4/1/2013 | | | #REF! |
| | LYONS - WHEATLAND 115KV CKT 1 #1 | 10/1/2012 | 7/15/2013 | | | #REF! |
| | LYONS - WHEATLAND 115KV CKT 1 #2 | 10/1/2012 | 7/15/2013 | | | #REF! |
| | MEDICINE LODGE - SAWYER 115KV CKT 1 | 12/1/2009 | 6/1/2013 | | | #REF! |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 Displacement | 12/1/2009 | 6/1/2013 | | | #REF! |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | | #REF! |
| | RICE_CO 230/115KV TRANSFORMER CKT 1 | 10/1/2012 | 11/15/2012 | | | #REF! |
| | SUB 110 - ORONOGO JCT SUB 167 - RIVERTON 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | | #REF! |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | | FALSE |
| | WOODWARD - IODINE 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | | #REF! |
| | WOODWARD - WOODWARD EHV 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | | FALSE |
| | WOODWARD - WOODWARD EHV 138KV CKT 2 | 1/1/2010 | 1/1/2010 | | | FALSE |
| | WOODWARD 345/138KV TRANSFORMER CKT 1 | 1/1/2010 | 1/1/2010 | | | FALSE |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

| | | | | Earliest Start | Redispatch | *Alloca | ted E & C | |
|-------------|--|----------|----------|----------------|------------|---------|-----------|-------------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | | *Total E & C Cost |
| 75200582 | BEAVER - EUREKA SPRINGS 161KV CKT 1 SWPA | 6/1/2013 | 6/1/2016 | | | \$ | 129,440 | \$ 4,130,000 |
| | | | | | Total | \$ | 129,440 | \$ 4,130,000 |

^{*}Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

^{*}Credits may be required for applicable generation interconnection network upgrades.
*34.5 kV and lower underlying System Impacts and Upgrades have yet to be determined.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|-----|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| LESM | 75134451 | NPPD | LES | 10 | 10/1/2012 | 10/1/2017 | 2/1/2013 | 2/1/2018 | \$ - | \$ - | \$ - | \$ - |
| · | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75134451 | None | | | | | \$ - | \$ - | \$ - |
| | | | | | Total | Ś - | \$ - | \$. |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|------------------------------------|-----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75134451 | Cherry Co - Gentleman 345 kV Ckt1 | 10/1/2014 | 1/1/2018 | | |
| | Cherry Co - Holt Co 345 kV Ckt1 | 10/1/2014 | 1/1/2018 | | |
| | Cherry Co 345 kV Terminal Upgrades | 10/1/2014 | 1/1/2018 | | |

| | | | | Earliest Start | Redispatch |
|-------------|---------------------------------|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75134451 | ALBION - PETERSBURG 115KV CKT 1 | 1/1/2013 | 1/1/2013 | | |
| | NELIGH - PETERSBURG 115KV CKT 1 | 1/1/2013 | 1/1/2013 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

 Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|-----|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| MEAN | 75179416 | NPPD | MEC | 1 | 7/1/2011 | 7/1/2016 | 2/1/2013 | 2/1/2018 | \$ - | \$ 65,400 | \$ | - \$ - |
| | | | | | | | | | \$ - | \$ 65,400 | \$ | - \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue | |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|---|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements | |
| 75179416 | None | | | | | \$ - | \$ - | \$ | - |
| • | | | | | Total | \$ - | ς - | ς. | _ |

 $^{{}^* \}text{Credits may be required for applicable generation interconnection network upgrades}. \\$

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|-----|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| MEAN | 75179412 | NPPD | MEC | 2 | 7/1/2011 | 7/1/2016 | 2/1/2013 | 2/1/2018 | \$ - | \$ 130,800 | \$ - | \$ - |
| · · | | | | | | | | | \$ - | \$ 130,800 | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue | |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|---|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements | |
| 75179412 | None | | | | | \$ - | \$ - | \$ | - |
| • | | | | | Total | \$ - | ς - | \$ | _ |

 $^{{}^* \}text{Credits may be required for applicable generation interconnection network upgrades}. \\$

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|-----|-----|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|-----------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| MIDW | 75200166 | WR | WR | 15 | 6/1/2012 | 6/1/2017 | 6/1/2016 | 6/1/2021 | \$ 1,682,303 | \$ - | \$ 1,682,30 | \$ \$ 2,444,077 |
| | | | | | | | | | \$ 1,682,303 | \$ - | \$ 1,682,30 | \$ \$ 2,444,077 |

| | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|---|----------|----------|----------------|------------|-----------------|------------------|---------------|
| Reservation Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75200166 HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2 | 6/1/2013 | 6/1/2016 | | Yes | \$ 1,682,30 | 3 \$ 4,734,006 | \$ 2,444,077 |
| | | | | Total | \$ 1,682,30 | 3 \$ 4.734.006 | \$ 2,444,077 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|----------------------------|----------|----------|----------------|------------|
| Reservation | Upgrade Name | | EOC | Date | Available |
| 75200166 | IATAN - NASHUA 345KV CKT 1 | 2/1/2013 | 6/1/2015 | | |

| | | | | Earliest Start | Redispatch |
|-------------|---|-----------|------------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75200166 | ALEXANDER - PRATT 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| | ALEXANDER - SAWYER 3 115.00 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| | CIRCLE - RICE_CO 230KV CKT 1 | 10/1/2012 | 11/15/2012 | | |
| | FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | FLATRDG3 138.00 - HARPER 138KV CKT 1 | 12/1/2009 | 6/15/2013 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | LYONS - WHEATLAND 115KV CKT 1 #1 | 10/1/2012 | 7/15/2013 | | |
| | LYONS - WHEATLAND 115KV CKT 1 #2 | 10/1/2012 | 7/15/2013 | | |
| | MEDICINE LODGE - SAWYER 115KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 Displacement | 12/1/2009 | 6/1/2013 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | RICE_CO 230/115KV TRANSFORMER CKT 1 | 10/1/2012 | 11/15/2012 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|-----|-----|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| MIDW | 75200168 | WR | WR | 5 | 6/1/2012 | 6/1/2017 | 6/1/2016 | 6/1/2021 | \$ 560,768 | \$ - | \$ 560,768 | \$ 814,693 |
| · · | | | | | | | | | \$ 560,768 | \$ - | \$ 560,768 | \$ 814,693 |

| | | | | Earliest Start | Redispatch | Allocate | ed E & C | | Total Revenue |
|-------------|--|----------|----------|----------------|------------|----------|----------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | | Total E & C Cost | Requirements |
| 75200168 | HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2 | 6/1/2013 | 6/1/2016 | | Yes | \$ | 560,768 | \$ 4,734,006 | \$ 814,693 |
| • | | | | | Total | \$ | 560,768 | \$ 4,734,006 | \$ 814,693 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch | ĺ |
|-------------|----------------------------|----------|----------|----------------|------------|---|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | l |
| 75200168 | IATAN - NASHUA 345KV CKT 1 | 2/1/2013 | 6/1/2015 | | | ĺ |

| | | | | Earliest Start | Redispatch |
|-------------|---|-----------|------------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75200168 | ALEXANDER - PRATT 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| | ALEXANDER - SAWYER 3 115.00 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| | CIRCLE - RICE_CO 230KV CKT 1 | 10/1/2012 | 11/15/2012 | | |
| | FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | FLATRDG3 138.00 - HARPER 138KV CKT 1 | 12/1/2009 | 6/15/2013 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | LYONS - WHEATLAND 115KV CKT 1 #1 | 10/1/2012 | 7/15/2013 | | |
| | LYONS - WHEATLAND 115KV CKT 1 #2 | 10/1/2012 | 7/15/2013 | | |
| | MEDICINE LODGE - SAWYER 115KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 Displacement | 12/1/2009 | 6/1/2013 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | RICE_CO 230/115KV TRANSFORMER CKT 1 | 10/1/2012 | 11/15/2012 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|-----|-----|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| MIDW | 75200171 | WR | WR | 5 | 6/1/2012 | 6/1/2017 | 6/1/2016 | 6/1/2021 | \$ 560,768 | \$ - | \$ 560,76 | 8 \$ 814,693 |
| - | | | | | | | | | \$ 560,768 | \$ - | \$ 560,76 | 814,693 |

| | | | Earliest Start | Redispatch | Allocate | d E & C | | Total Revenue |
|---|----------|----------|----------------|------------|----------|---------|------------------|---------------|
| Reservation Upgrade Name | DUN | EOC | Date | Available | Cost | | Total E & C Cost | Requirements |
| 75200171 HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2 | 6/1/2013 | 6/1/2016 | | Yes | \$ | 560,768 | \$ 4,734,006 | \$ 814,693 |
| | | | | Total | \$ | 560,768 | \$ 4,734,006 | \$ 814,693 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|----------------------------|----------|----------|----------------|------------|
| Reservation | Upgrade Name | | EOC | Date | Available |
| 75200171 | IATAN - NASHUA 345KV CKT 1 | 2/1/2013 | 6/1/2015 | | |

| ate . | Available |
|-------|-----------|
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|-----|-----|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| MIDW | 75200180 | WR | WR | 5 | 6/1/2013 | 6/1/2018 | 6/1/2016 | 6/1/2021 | \$ 560,768 | \$ - | \$ 560,768 | \$ 835,099 |
| · · | | | | | | | | | \$ 560,768 | \$ - | \$ 560,768 | \$ 835,099 |

| | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|---|----------|----------|----------------|------------|-----------------|------------------|---------------|
| Reservation Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75200180 HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2 | 6/1/2013 | 6/1/2016 | | Yes | \$ 560,768 | \$ 4,734,006 | \$ 835,099 |
| | | | | Total | \$ 560,768 | \$ 4,734,006 | \$ 835.099 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch | ı |
|-------------|----------------------------|----------|----------|----------------|------------|---|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | ı |
| 75200180 | IATAN - NASHUA 345KV CKT 1 | 2/1/2013 | 6/1/2015 | | | ĺ |

| | | | | Earliest Start | Redispatch |
|-------------|---|-----------|------------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75200180 | ALEXANDER - PRATT 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| | ALEXANDER - SAWYER 3 115.00 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| | CIRCLE - RICE_CO 230KV CKT 1 | 10/1/2012 | 11/15/2012 | | |
| | FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | FLATRDG3 138.00 - HARPER 138KV CKT 1 | 12/1/2009 | 6/15/2013 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | LYONS - WHEATLAND 115KV CKT 1 #1 | 10/1/2012 | 7/15/2013 | | |
| | LYONS - WHEATLAND 115KV CKT 1 #2 | 10/1/2012 | 7/15/2013 | | |
| | MEDICINE LODGE - SAWYER 115KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 Displacement | 12/1/2009 | 6/1/2013 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | RICE_CO 230/115KV TRANSFORMER CKT 1 | 10/1/2012 | 11/15/2012 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|-----|-----|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| MIDW | 75200183 | WR | WR | 5 | 6/1/2013 | 6/1/2018 | 6/1/2016 | 6/1/2021 | \$ 560,768 | \$ - | \$ 560,768 | \$ 835,099 |
| | | | | | | | | | \$ 560,768 | \$ - | \$ 560,768 | \$ 835,099 |

| | | | | Earliest Start | Redispatch | Allocate | ed E & C | | Total Revenue |
|-------------|--|----------|----------|----------------|------------|----------|----------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | | Total E & C Cost | Requirements |
| 7520018 | HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2 | 6/1/2013 | 6/1/2016 | | Yes | \$ | 560,768 | \$ 4,734,006 | \$ 835,099 |
| | | | | • | Total | Ś | 560.768 | \$ 4,734,006 | \$ 835,099 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | | Earliest Start | Redispatch |
|---|-------------|----------------------------|----------|----------|----------------|------------|
| 1 | Reservation | Upgrade Name | DUN | EOC | Date | Available |
| Γ | 75200183 | IATAN - NASHUA 345KV CKT 1 | 2/1/2013 | 6/1/2015 | | |

| | | | | Earliest Start | Redispatch |
|-------------|---|-----------|------------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75200183 | ALEXANDER - PRATT 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| | ALEXANDER - SAWYER 3 115.00 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| | CIRCLE - RICE_CO 230KV CKT 1 | 10/1/2012 | 11/15/2012 | | |
| | FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | FLATRDG3 138.00 - HARPER 138KV CKT 1 | 12/1/2009 | 6/15/2013 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | LYONS - WHEATLAND 115KV CKT 1 #1 | 10/1/2012 | 7/15/2013 | | |
| | LYONS - WHEATLAND 115KV CKT 1 #2 | 10/1/2012 | 7/15/2013 | | |
| | MEDICINE LODGE - SAWYER 115KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 Displacement | 12/1/2009 | 6/1/2013 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | RICE_CO 230/115KV TRANSFORMER CKT 1 | 10/1/2012 | 11/15/2012 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| NPPM | 75200206 | NPPD | NPPD | 1 | 12/1/2012 | 12/1/2017 | 2/1/2013 | 2/1/2018 | \$ - | \$ 110,239 | \$ | - \$ - |
| | | | | | | | | | \$ - | \$ 110,239 | \$ | - \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-------|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75200206 | None | | | | | \$ - | \$ - | \$ |
| • | | Total | Ś - | \$ - | Ś | | | |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|------------------------------------|-----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75200206 | Cherry Co - Gentleman 345 kV Ckt1 | 10/1/2014 | 1/1/2018 | | |
| | Cherry Co - Holt Co 345 kV Ckt1 | 10/1/2014 | 1/1/2018 | | |
| | Cherry Co 345 kV Terminal Upgrades | 10/1/2014 | 1/1/2018 | | |

| | | | | Earliest Start | Redispatch |
|-------------|---------------------------------|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75200206 | ALBION - PETERSBURG 115KV CKT 1 | 1/1/2013 | 1/1/2013 | | |
| | NELIGH - PETERSBURG 115KV CKT 1 | 1/1/2013 | 1/1/2013 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| OMPA | 75180762 | CSWS | CSWS | 50 | 6/1/2014 | 9/30/2018 | 6/1/2014 | 9/30/2018 | \$ - | \$ - | \$ - | \$ - |
| · | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-------|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75180762 | None | | | | | \$ - | \$ - | \$ |
| | | Total | Ś - | \$ - | Ś | | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch | |
|-------------|------------------------------|----------|----------|----------------|------------|--|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | |
| 75180762 | EL PASO - FARBER 138KV CKT 1 | 6/1/2018 | 6/1/2018 | | | |

| | | | | Earliest Start | Redispatch |
|-------------|--------------------------------------|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75180762 | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD 345/138KV TRANSFORMER CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| OMPA | 75196276 | CSWS | OKGE | 3 | 3/1/2012 | 12/31/2027 | 2/1/2013 | 12/1/2028 | \$ - | \$ - | \$ - | \$ - |
| | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75196276 | None | | | | | \$ - | \$ - | \$ |
| • | | | | | Total | Ś - | Ś - | Ś |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch | ĺ |
|-------------|-----------------------------------|----------|----------|----------------|------------|---|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | l |
| 75196276 | BLUEBELL - PRATTVILLE 138KV CKT 1 | 6/1/2018 | 6/1/2018 | | | ĺ |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 751962 | 6 EL PASO - FARBER 138KV CKT 1 | 6/1/2018 | 6/1/2018 | | |
| | NORTHWEST 345/138/13.8KV TRANSFORMER CKT 3 Accelerated | 6/1/2013 | 6/1/2015 | | |

| | | | | Earliest Start | Redispatch |
|-------------|--------------------------------------|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75196276 | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD 345/138KV TRANSFORMER CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|------|-----------|--------|------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Reques | sted Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| OPPM | 75180047 | NPPD | OPPD | | 18 | 12/1/2012 | 12/1/2017 | 2/1/2013 | 2/1/2018 | \$ - | \$ - | \$ - | \$ - |
| | | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75180047 | None | | | | | \$ - | \$ - | \$ |
| • | | | | | Total | Ś - | \$ - | Ś |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch | l |
|-------------|----------------------------|----------|----------|----------------|------------|---|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Ì |
| 75180047 | IATAN - NASHUA 345KV CKT 1 | 2/1/2013 | 6/1/2015 | | | ĺ |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|------------------------------------|-----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75180047 | Cherry Co - Gentleman 345 kV Ckt1 | 10/1/2014 | 1/1/2018 | | |
| | Cherry Co - Holt Co 345 kV Ckt1 | 10/1/2014 | 1/1/2018 | | |
| | Cherry Co 345 kV Terminal Upgrades | 10/1/2014 | 1/1/2018 | | |

| | | | | Earliest Start | Redispatch |
|-------------|-----------------------------------|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 751800 | 7 ALBION - PETERSBURG 115KV CKT 1 | 1/1/2013 | 1/1/2013 | | |
| | NELIGH - PETERSBURG 115KV CKT 1 | 1/1/2013 | 1/1/2013 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| SECI | 75173900 | SECI | SECI | 80 | 7/1/2012 | 7/1/20 | 6/1/201 | 6/1/203 | 6 \$ 469,026 | \$ - | \$ 694,301 | \$ 1,641,313 |
| | | | | | | | | | \$ 469,026 | \$ - | \$ 694,301 | \$ 1,641,313 |

| Reservation | Upgrade Name | DLIN | | | Base Plan Funding for W | | , | Allocated E & C | Total E & C Co | | Total Revenue |
|-------------|--|----------|----------|---------|----------------------------|-----|------------|-----------------|----------------|------|---------------|
| | HARPER - MILAN TAP 138KV CKT 1 #1 Accelerate | 2/1/2013 | | Yes | | 650 | \$ - | \$ 11,650 | | 990 | |
| | HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2 | 6/1/2013 | 6/1/2016 | Yes | \$ 457, | 376 | \$ 225,275 | \$ 682,651 | \$ 4,734, | .006 | \$ 1,598,668 |
| | | | | Total | \$ 469, | 026 | \$ 225,275 | \$ 694,301 | \$ 4,796, | 996 | \$ 1,641,313 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|---|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75173900 | Line - Clark County - Thistle 345 kV dbl Ckt | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Hitchland - Woodward 345 kV dbl Ckt OKGE | 2/1/2013 | 7/1/2014 | | Yes |
| | Line - Hitchland - Woodward 345 kV dbl Ckt SPS | 2/1/2013 | 7/1/2014 | | Yes |
| | Line - Spearville - Clark County 345 kV dbl Ckt | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Thistle - Wichita 345 kV dbl Ckt PW | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Thistle - Wichita 345 kV dbl Ckt WERE | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Thistle - Woodward 345 kV dbl Ckt OKGE | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Thistle - Woodward 345 kV dbl Ckt PW | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Tuco - Woodward 345 kV line OKGE | 2/1/2013 | 6/1/2014 | | Yes |
| | Line - Tuco - Woodward 345 kV line SPS | 2/1/2013 | 6/1/2014 | | Yes |
| | XFR - Thistle 345/138 kV | 2/1/2013 | 1/1/2015 | | Yes |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|--------------------------------------|----------|-----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75173900 | FLATRDG3 138.00 - HARPER 138KV CKT 1 | 2/1/2013 | 6/15/2013 | | Yes |
| | MEDICINE LODGE - PRATT 115KV CKT 1 | 2/1/2013 | 1/1/2014 | | Yes |

| DUN | | | |
|-----------|---|--|--|
| DUN | EOC | Date | Available |
| 12/1/2009 | 1/1/2014 | | |
| 12/1/2009 | 1/1/2014 | | |
| 12/1/2009 | 6/1/2013 | | |
| 12/1/2009 | 6/15/2013 | | |
| 12/1/2009 | 6/1/2013 | | |
| 12/1/2009 | 6/1/2013 | | |
| | 12/1/2009 12/1/2009 12/1/2009 12/1/2009 12/1/2009 | 12/1/2009 1/1/2014 12/1/2009 1/1/2014 12/1/2009 6/1/2013 12/1/2009 6/15/2013 12/1/2009 6/15/2013 | 12/1/2009 1/1/2014 12/1/2009 1/1/2014 12/1/2009 6/1/2013 12/1/2009 6/15/2013 12/1/2009 6/15/2013 |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|-----|-----|-----------|----------|----------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requeste | ed Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| SPSM | 75197996 | SPS | SPS | | 42 | 6/1/2012 | 6/1/2045 | 6/1/2015 | 6/1/2048 | \$ - | \$ - | \$ - | \$ - |
| | | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75197996 | None | | | | | \$ - | \$ - | \$ |
| | | | | | Total | Ś - | Ś - | Ś |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75197996 | BAILEY COUNTY INTERCHANGE - CURRY COUNTY INTERCHANGE 115KV CKT 1 | 2/1/2013 | 6/1/2015 | | Yes |
| | CHAVES COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 2 | 6/1/2020 | 6/1/2020 | | |
| | HITCHLAND INTERCHANGE () 230/115/13.2KV TRANSFORMER CKT 2 | 6/1/2021 | 6/1/2021 | | |
| | Line - Thistle - Woodward 345 kV dbl Ckt OKGE | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Thistle - Woodward 345 kV dbl Ckt PW | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Tuco - Woodward 345 kV line OKGE | 2/1/2013 | 6/1/2014 | | Yes |
| | Line - Tuco - Woodward 345 kV line SPS | 2/1/2013 | 6/1/2014 | | Yes |
| | NEWHART INTERCHANGE PROJECT | 6/1/2013 | 6/1/2015 | - | Yes |

 $Reliability \ Projects - The \ requested \ service \ is \ contingent \ upon \ completion \ of \ the \ following \ upgrades. \ Cost \ is \ not \ assignable \ to \ the \ transmission \ customer.$

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75197996 | ARTESIA INTERCHANGE (GE C254477) 115/69/13.2KV TRANSFORMER CKT 1 | 6/1/2018 | 6/1/2018 | | |
| | ARTESIA INTERCHANGE (MNLY 2118072) 115/69/13.2KV TRANSFORMER CKT 2 | 6/1/2018 | 6/1/2018 | | |
| | CHAVES COUNTY INTERCHANGE - SAMSON SUB 115KV CKT 1 | 6/1/2020 | 6/1/2020 | | |
| | CHAVES COUNTY INTERCHANGE - URTON SUB 115KV CKT 1 | 6/1/2020 | 6/1/2020 | | |

| , | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75197996 | CHERRY6 230.00 - Harrington Station East Bus 230KV CKT 1 | 6/1/2015 | 6/1/2015 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|-----|-----|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| SPSM | 75197998 | SPS | SPS | 29 | 6/1/2012 | 6/1/203 | 6/1/2015 | 6/1/2035 | \$ - | \$ - | \$ - | \$ - |
| | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|--------------------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75197998 None | | | | | \$ - | \$ - | \$ - |
| | | | | Total | \$ - | \$ - | \$ - |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75197998 | BAILEY COUNTY INTERCHANGE - CURRY COUNTY INTERCHANGE 115KV CKT 1 | 2/1/2013 | 6/1/2015 | | Yes |
| | CHAVES COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 2 | 6/1/2020 | 6/1/2020 | | |
| | HITCHLAND INTERCHANGE () 230/115/13.2KV TRANSFORMER CKT 2 | 6/1/2021 | 6/1/2021 | | |
| | Line - Thistle - Woodward 345 kV dbl Ckt OKGE | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Thistle - Woodward 345 kV dbl Ckt PW | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Tuco - Woodward 345 kV line OKGE | 2/1/2013 | 6/1/2014 | | Yes |
| | Line - Tuco - Woodward 345 kV line SPS | 2/1/2013 | 6/1/2014 | | Yes |
| | NEWHART INTERCHANGE PROJECT | 6/1/2013 | 6/1/2015 | | Yes |

 $Reliability \ Projects - The \ requested \ service \ is \ contingent \ upon \ completion \ of \ the \ following \ upgrades. \ Cost \ is \ not \ assignable \ to \ the \ transmission \ customer.$

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 7519799 | ARTESIA INTERCHANGE (GE C254477) 115/69/13.2KV TRANSFORMER CKT 1 | 6/1/2018 | 6/1/2018 | | |
| | ARTESIA INTERCHANGE (MNLY 2118072) 115/69/13.2KV TRANSFORMER CKT 2 | 6/1/2018 | 6/1/2018 | | |
| | CHAVES COUNTY INTERCHANGE - SAMSON SUB 115KV CKT 1 | 6/1/2020 | 6/1/2020 | | |
| | CHAVES COUNTY INTERCHANGE - URTON SUB 115KV CKT 1 | 6/1/2020 | 6/1/2020 | | |

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75197998 | CHERRY6 230.00 - Harrington Station East Bus 230KV CKT 1 | 6/1/2015 | 6/1/2015 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number TNSK AG1-2011-029

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|--------|-----------|---------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Sta | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| TNSK | 75108845 | KCPL | ERCOTE | | 44 8/1/20 | 11 6/1/20 | 6/1/2014 | 6/1/2014 | \$ - | \$ 1,071,565 | \$ - | \$ - |
| | | | | | | | | | \$ - | \$ 1,071,565 | \$ - | \$ - |

| | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue | |
|--------------------------|-----|-----|----------------|------------|-----------------|------------------|---------------|---|
| Reservation Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements | |
| 75108845 None | | | | | \$ - | \$ - | \$ - |] |
| | | | | Total | \$ - | \$ - | \$ - | 1 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|---|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75108845 | IATAN - NASHUA 345KV CKT 1 | 2/1/2013 | 6/1/2015 | | Yes |
| | Line - Thistle - Woodward 345 kV dbl Ckt OKGE | 2/1/2013 | 1/1/2015 | | |
| | Line - Thistle - Woodward 345 kV dbl Ckt PW | 2/1/2013 | 1/1/2015 | | |
| | Line - Tuco - Woodward 345 kV line OKGE | 2/1/2013 | 6/1/2014 | | |
| | Line - Tuco - Woodward 345 kV line SPS | 2/1/2013 | 6/1/2014 | | |

| | | | | Earliest Start | Redispatch |
|-------------|---|-----------|-----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 7510884 | ALEXANDER - PRATT 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| | ALEXANDER - SAWYER 3 115.00 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| | ASHDOWN REC (MILLWOOD) - OKAY 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | ASHDOWN REC (MILLWOOD) - PATTERSON 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | BANN - RED SPRINGS REC 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | DEARING 138KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | FT RANDAL - MADISONCO 230.00 230KV CKT 1 | 10/1/2013 | 11/1/2014 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC | 7/1/2012 | 7/1/2012 | | |
| | HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | KELLY - MADISONCO 230.00 230KV CKT 1 | 10/1/2013 | 11/1/2014 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | MEDICINE LODGE - SAWYER 115KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 Displacement | 12/1/2009 | 6/1/2013 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | OKAY - TURK 138KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | SUB 110 - ORONOGO JCT SUB 167 - RIVERTON 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - IODINE 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 2 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD 345/138KV TRANSFORMER CKT 1 | 1/1/2010 | 1/1/2010 | | |

 $[\]hbox{*Credits may be required for applicable generation interconnection network upgrades}.$

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number TNSK AG1-2011-030

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|--------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| TNSK | 75108838 | KCPL | ERCOTE | 6 | 8/1/2011 | 6/1/201 | 4 2/1/2013 | 6/1/2014 | \$ - | \$ 146,123 | \$ - | \$ - |
| | | | | | | | | | \$ - | \$ 146,123 | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75108838 | None | | | | | \$ - | \$ - | \$ |
| | | | | | Total | ς - | \$ - | ς. |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|---|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75108838 | IATAN - NASHUA 345KV CKT 1 | 2/1/2013 | 6/1/2015 | | |
| | Line - Thistle - Woodward 345 kV dbl Ckt OKGE | 2/1/2013 | 1/1/2015 | | |
| | Line - Thistle - Woodward 345 kV dbl Ckt PW | 2/1/2013 | 1/1/2015 | | |
| | Line - Tuco - Woodward 345 kV line OKGE | 2/1/2013 | 6/1/2014 | | |
| | Line - Tuco - Woodward 345 kV line SPS | 2/1/2013 | 6/1/2014 | | |

| | | | Earliest Start | Redispatch |
|--|---|--|---|--|
| Upgrade Name | DUN | EOC | Date | Available |
| HUGO POWER PLANT - VALLIANT 345 KV AEPW | 7/1/2012 | 7/1/2012 | | |
| HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC | 7/1/2012 | 7/1/2012 | | |
| HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1 | 7/1/2012 | 7/1/2012 | | |
| LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| MCNAB REC - TURK 115KV CKT 1 | 7/1/2012 | 7/1/2012 | | |
| NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | HUGO POWER PLANT - VALLIANT 345 KV AEPW HUGO POWER PLANT - VALLIANT 345 KV CKT 1 WFEC HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1 LACYGNE - WEST GARDNER 345 KV CKT 1 MCNAB REC - TURK 115 KV CKT 1 NORTHWEST - TATONGA 345 KV CKT 1 | HUGO POWER PLANT - VALLIANT 345 KV AEPW 7/1/2012 HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC 7/1/2012 HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1 7/1/2012 LACYGNE - WEST GARDNER 345KV CKT 1 6/1/2006 MCNAB REC - TURK 115KV CKT 1 7/1/2012 NORTHWEST - TATONIGA 345KV CKT 1 1/1/2010 | Upgrade Name DUN EOC HUGO POWER PLANT - VALLIANT 345 KV AEPW 7/1/2012 7/1/2012 HUGO POWER PLANT - VALLIANT 345 KV CKT 1 WFEC 7/1/2012 7/1/2012 HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1 7/1/2012 7/1/2012 LACYORE - WEST GARDNER 345KV CKT 1 6/1/2006 6/1/2006 MCNAB REC - TURK 115KV CKT 1 7/1/2012 7/1/2012 NORTHWEST - TATONGA 345KV CKT 1 1/1/2010 1/1/2010 | Upgrade Name DUN EOC Date HUGO POWER PLANT - VALLIANT 345 KV AEPW 7/1/2012 7/1/2012 HUGO POWER PLANT - VALLIANT 345 KV CKT 1 WFEC 7/1/2012 7/1/2012 HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1 7/1/2012 7/1/2012 LACYGNE - WEST GARDNER 345KV CKT 1 6/1/2006 6/1/2006 MCNAB REC - TURK 115KV CKT 1 7/1/2012 7/1/2012 NORTHWEST - TATONGA 345KV CKT 1 1/1/2010 1/1/2010 |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|------|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| WFEC | 75179329 | CSWS | WFEC | 150 | 1/1/2012 | 1/1/2037 | 1/1/2015 | 1/1/2040 | \$ - | \$ - | \$ - | \$ - |
| | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|--------------------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75179329 None | | | | | \$ - | \$ - | \$ - |
| | | | | Total | \$ - | \$ - | \$ - |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|---|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75179329 | Line - Clark County - Thistle 345 kV dbl Ckt | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Hitchland - Woodward 345 kV dbl Ckt OKGE | 2/1/2013 | 7/1/2014 | | Yes |
| | Line - Hitchland - Woodward 345 kV dbl Ckt SPS | 2/1/2013 | 7/1/2014 | | Yes |
| | Line - Spearville - Clark County 345 kV dbl Ckt | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Thistle - Wichita 345 kV dbl Ckt PW | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Thistle - Wichita 345 kV dbl Ckt WERE | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Thistle - Woodward 345 kV dbl Ckt OKGE | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Thistle - Woodward 345 kV dbl Ckt PW | 2/1/2013 | 1/1/2015 | | Yes |
| | Line - Tuco - Woodward 345 kV line OKGE | 2/1/2013 | 6/1/2014 | | Yes |
| | Line - Tuco - Woodward 345 kV line SPS | 2/1/2013 | 6/1/2014 | | Yes |
| | XFR - Thistle 345/138 kV | 2/1/2013 | 1/1/2015 | | Yes |

| | | | | Earliest Start | Redispatch |
|-------------|--|----------|----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75179329 | CHERRY6 230.00 - Harrington Station East Bus 230KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | G03-05T 138.00 - PARADISE 138KV CKT 1 | 6/1/2010 | 6/1/2013 | | |
| | GRACMNT4 138.00 - WASHITA 138KV CKT 2 OKGE | 1/1/2012 | 1/1/2012 | | |
| | GRACMNT4 138.00 - WASHITA 138KV CKT 2 WFEC | 1/1/2012 | 1/1/2012 | | |
| | HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1 | 7/1/2012 | 7/1/2012 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD - WOODWARD EHV 138KV CKT 2 | 1/1/2010 | 1/1/2010 | | |
| | WOODWARD 345/138KV TRANSFORMER CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

 Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|------|-----|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| WRGS | 74977737 | OKGE | WR | 300 | 1/1/2016 | 6/1/2027 | | | \$ - | \$ - | \$ - | \$ - |
| | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 74977737 | None | | | | | \$ - | \$ - | \$ |
| | | | | | Total | Ś - | \$ - | Ś |

| | | | | Earliest Start | Redispatch |
|-------------|--------------------------------------|-----------|-----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 74977737 | FLATRDG3 138.00 - HARPER 138KV CKT 1 | 12/1/2009 | 6/15/2013 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | NORTHWEST - TATONGA 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |
| | TATONGA - WOODWARD 345KV CKT 1 | 1/1/2010 | 1/1/2010 | | |

^{*}Credits may be required for applicable generation interconnection network upgrades.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | | | Deferred Start | Deferred Stop | Potential Base | | | |
|----------|-------------|-----|-----|-----------|-----------------|----------------|----------------|---------------|----------------|----------------|-----------------|---------------|
| | | | | Requested | Requested Start | Requested Stop | Date Without | Date Without | Plan Funding | Point-to-Point | Allocated E & C | Total Revenue |
| Customer | Reservation | POR | POD | Amount | Date | Date | Redispatch | Redispatch | Allowable | Base Rate | Cost | Requirements |
| WRGS | 75021167 | WR | WR | 201 | 10/1/2012 | 1/1/203 | 2 12/1/2014 | 3/1/2034 | \$ - | \$ - | \$ - | \$ - |
| | | | | | | | | | \$ - | \$ - | \$ - | \$ - |

| | | | | Earliest Start | Redispatch | Allocated E & C | | Total Revenue |
|-------------|--------------|-----|-----|----------------|------------|-----------------|------------------|---------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | Cost | Total E & C Cost | Requirements |
| 75021167 | None | | | | | \$ - | \$ - | \$ - |
| • | | | | | Total | Ś - | \$ - | \$ - |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch | ĺ |
|-------------|--|----------|-----------|----------------|------------|---|
| Reservation | Upgrade Name | DUN | EOC | Date | Available | l |
| 75021167 | MOUNDRIDGE 138/115KV TRANSFORMER CKT 2 | 2/1/2013 | 12/1/2014 | | Yes | ĺ |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| | | | | Earliest Start | Redispatch |
|-------------|-------------------------------------|----------|-----------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75021167 | CIRCLE - RICE_CO 230KV CKT 1 | 2/1/2013 | 2/1/2013 | | |
| | LYONS - RICE_CO 115KV CKT 1 | 2/1/2013 | 4/1/2013 | | Yes |
| | LYONS - WHEATLAND 115KV CKT 1 #1 | 2/1/2013 | 7/15/2013 | | Yes |
| | LYONS - WHEATLAND 115KV CKT 1 #2 | 2/1/2013 | 7/15/2013 | | Yes |
| | RICE_CO 230/115KV TRANSFORMER CKT 1 | 2/1/2013 | 2/1/2013 | | |

| | | | | Earliest Start | Redispatch |
|-------------|---|-----------|------------|----------------|------------|
| Reservation | Upgrade Name | DUN | EOC | Date | Available |
| 75021167 | ALEXANDER - PRATT 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| | ALEXANDER - SAWYER 3 115.00 115KV CKT 1 | 12/1/2009 | 1/1/2014 | | |
| | CIRCLE - RICE_CO 230KV CKT 1 | 10/1/2012 | 11/15/2012 | | |
| | FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | FLATRDG3 138.00 - HARPER 138KV CKT 1 | 12/1/2009 | 6/15/2013 | | |
| | LACYGNE - WEST GARDNER 345KV CKT 1 | 6/1/2006 | 6/1/2006 | | |
| | LYONS - RICE_CO 115KV CKT 1 | 10/1/2012 | 4/1/2013 | | |
| | LYONS - WHEATLAND 115KV CKT 1 #1 | 10/1/2012 | 7/15/2013 | | |
| | LYONS - WHEATLAND 115KV CKT 1 #2 | 10/1/2012 | 7/15/2013 | | |
| | MEDICINE LODGE - SAWYER 115KV CKT 1 | 12/1/2009 | 6/1/2013 | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 Displacement | 12/1/2009 | 6/1/2013 | | |
| | RICE CO 230/115KV TRANSFORMER CKT 1 | 10/1/2012 | 11/15/2012 | | |

| Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) | Estimated Engineering & Construction Cost |
|--------------------|---|---|--------------------------------------|--|---|
| | | Rebuild 1.25 miles of 795 ACSR with 1590 ACSR. Replace wavetrap & | | | |
| AEPW | BEAVER - EUREKA SPRINGS 161KV CKT 1 AEPW | jumpers @ Eureka Springs | 6/1/2013 | 6/1/2016 | \$2,635,665.74 |
| | | Tear down and rebuild of exisiting South Hays - Hays Plant 115 kV line. | | | |
| | | Tentative plans include rebuilding on existing right-of-way with the | | | |
| | | possibility of re-routing a portion of the line to new right-of-way as | | | |
| MIDW | HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2 | necessary. | 6/1/2013 | 6/1/2016 | \$4,734,005.62 |
| MIPU | MIDWAY - ST JOE 161KV CKT 1 Reactor | Install three series reactors in the Midway-St Joseph line at St Joseph Substation. The reactors will be rated 6% impedance and 1200 Amps. | 6/1/2014 | 6/1/2015 | \$425,000.00 |
| MKEC | HARPER - MILAN TAP 138KV CKT 1 #1 Accelerate | Replace Wave Trap at Harper Substation | 2/1/2013 | 6/1/2015 | \$62,990.00 |
| | | Reconductor 4.07 miles of transmission line to 1590AS52 Make 5 Tribes | | | |
| OKGE | 5 TRIBES - PECAN CREEK 161KV CKT 1 Accelerate | substation equipment 2000 amp | 6/1/2014 | 6/1/2016 | \$343,986.00 |

Direct Assignment Facilities - The requested service is contingent upon completion of the following upgrades

| Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) | Estimated Engineering & Construction Cos | t |
|--------------------|------------------------------|---|--|--|--|----|
| MIDW | PAWNEE - LARNED 115 KV CKT 1 | Build 1.5 mile 115 kV line from Pawnee to the City of Larned. | 2/1/2013 | 6/1/2013 | \$ 706,8 | 33 |
| | AG1-2011-081 | | | | | |

| Construction Pending | nstruction Pending Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer. | | | | | |
|----------------------|---|---|--|--|--|--|
| Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) | | |
| MIDW | CIRCLE - RICE_CO 230KV CKT 1 | Convert from 115kV to 230kV operation | 2/1/2013 | 2/1/2013 | | |
| MIDW | LYONS - RICE_CO 115KV CKT 1 | Rebuild 11.7 mile line | 2/1/2013 | 4/1/2013 | | |
| MIDW | RICE_CO 230/115KV TRANSFORMER CKT 1 | Add 230/115kV Transformer | 2/1/2013 | 2/1/2013 | | |
| MKEC | FLATRDG3 138.00 - HARPER 138KV CKT 1 | Rebuild 24.15 mile line | 2/1/2013 | 6/15/2013 | | |
| MKEC | MEDICINE LODGE - PRATT 115KV CKT 1 | Rebuild 26 mile line | 2/1/2013 | 1/1/2014 | | |
| OKGE | NORTHWEST 345/138/13.8KV TRANSFORMER CKT 3 Accelerated | Install third 345/138 kV Bus Tie in Northwest Sub | 6/1/2013 | 6/1/2015 | | |
| WERE | EL PASO - FARBER 138KV CKT 1 | Tear down / Rebuild 3.1 miles with dual 477 ACSR | 6/1/2018 | 6/1/2018 | | |
| WERE | LYONS - WHEATLAND 115KV CKT 1 #1 | Replace CTs | 2/1/2013 | 7/15/2013 | | |
| WERE | LYONS - WHEATLAND 115KV CKT 1 #2 | Rerate circuit to 1000 amps | 2/1/2013 | 7/15/2013 | | |

pansion Plan Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmis Earliest Date Estimated Date of Transmission Owne Upgrade Solution Upgrade Required (DUN) Upgrade Completio (EOC) Build a new 86 mile double circuit 345 kV line with at least 3000 A capaci from the Thistle 345 kV substation to the new Clark County substation. Build a new 345 kV substation at Thistle with a ring bus and necessary 1/1/2015 ITCGP Line - Clark County - Thistle 345 kV dbl Ckt terminal equipment. Build a new 36 mile double circuit 345 kV line with at least 3000 A capacit 2/1/2013 rom the Spearville substation to the new Clark County substation. Build the Clark County 345 kV substation with a ring bus and necessary termina ITCGP Line - Spearville - Clark County 345 kV dbl Ckt equipment. Install a 400 MVA 345/138 kV transformer at the new 345 kV Thistle 2/1/2013 1/1/2015 XFR - Thistle 345/138 kV substation. Tap Nashua 345kV bus in Hawthorn - St. Joseph 345 kV line. Build new 345 1/1/2015 ITCGP 2/1/2013 KACP IATAN - NASHUA 345KV CKT 1 kV line from latan to Nashua,Add Nashua 345/161 kV 2/1/2013 6/1/2015 Build a new 92 mile double circuit 345 kV line with at least 3000 A capacit from the Woodward District EHV substation to the SPS interception from the Hitchland substation. Upgrade the Woodward District EHV substation 7/1/2014 OKGE Line - Hitchland - Woodward 345 kV dbl Ckt OKGE with the necessary breakers and term 2/1/2013 Build a new 79 mile double circuit 345 kV line with at least 3000 A capacit om the Woodward District EHV substation to the Kansas/Oklahoma state order towards the Thistle substation. Upgrade the Woodward Distric EHV Line - Thistle - Woodward 345 kV dbl Ckt OKGE 1/1/2015 OKGE substation with the necessary brea Build new 345 kV line from Woodward EHV to Border - Project costs now 2/1/2013 2/1/2013 OKGE Line - Tuco - Woodward 345 kV line OKGE 6/1/2014 include Border reactor substation Build a new 78 mile double circuit 345 kV line with at least 3000 A capacit from the Wichita substation to the new Thistle 345 kV substation.

Build a new 30 mile double circuit 345 kV line with at least 3000 A capacity from the Thistle substation to the Kansas/Oklahoma state border towards SPSM Line - Thistle - Wichita 345 kV dbl Ckt PW 2/1/2013 1/1/2015 ine - Thistle - Woodward 345 kV dbl Ckt PW the Woodward District EHV substation. 40 miles 115 kV between Bailey and Cu 2/1/2013 1/1/2015 LINE - INISTIE - WOODWATG 345 KV ODLCKT PW
BAILEY COUNTY INTERCHANGE - CURRY COUNTY INTERCHANGE 115KV CKT 1
CHAVES COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 2 Upgrade Chaves 230/115 kV to 225/258 MVA HITCHLAND INTERCHANGE () 230/115/13.2KV TRANSFORMER CKT 2 6/1/2021 6/1/2021 Build 30 mile double circuit 345 kV line with at least 3000 A capacity from he Hitchland substation to the OGE interception point from the Woodward District EHV substation. Upgrade the Hitchland substation with Line - Hitchland - Woodward 345 kV dbl Ckt SPS the necessary breakers and terminal equipme Build new 345 kV line from Tuco to OGE's Border station near TX/OK 2/1/2013 7/1/2014 Stateline. Install line reactor outside Border station and line reactors at Line - Tuco - Woodward 345 kV line SPS 2/1/2013 6/1/2014 Tap the Potter Interchange - Plant X Station 230 kV line for new Newhart Substation and install 230/115 kV, 150/173 MVA transformer. New 15 mile Lampton Interchange - Hart Industrial Substation 115 kV line. New 19 mile Swisher County Interchange - Newhart

Upgrade the Wichita substation with the necessary breakers and terminal equipment to accommodate two new 345 kV circuits from the new Thistle NEWHART INTERCHANGE PROJECT 6/1/2015 6/1/2013 WERE Line - Thistle - Wichita 345 kV dbl Ckt WERE 2/1/2013 1/1/2015 345 kV substation

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) |
|--------------------|--|--|--|--|
| | | Rebuild 9.0 mile Prattville-Bluebell 138 kV line from 795 ACSR to 1590 | | |
| | | ACSR. Replace line switch near Prattville. New summer ratings 287/287 | | |
| AEPW | BLUEBELL - PRATTVILLE 138KV CKT 1 | limited by breaker, switches, CTs, wave trap. | 6/1/2018 | 6/1/2018 |
| EMDE | Brookline – Compton Ridge 345 kV EMDE | Build approx. 50% of 30 mile 345 kV line | 6/1/2013 | 6/1/2019 |
| | | Install 500 MVA, 345/161 kV transformer and Cut EDE Reeds Spring- | | |
| EMDE | Compton Ridge 345/161 kV Transformer | Branson line at 50% and route in & out of Compton Ridge | 6/1/2013 | 6/1/2019 |
| MIPU | BLUE SPRING SOUTH - PRAIRIE LEE 161KV CKT 1 #1 | Upgrade Prairie Lee wave trap to 2000 Amps. | 6/1/2014 | 6/1/2015 |
| | | Build new 345 kV Transmission Line from GGS 345 kV Substation to a new | | |
| NPPD | Cherry Co - Gentleman 345 kV Ckt1 | Cherry County 345 kV Substation (76 miles). | 10/1/2014 | 1/1/2018 |
| NPPD | Cherry Co - Holt Co 345 kV Ckt1 | Build new 345 kV Transmission Line from new Cherry County 345 kV Substation to new 345 kV Holt County Substation. (Estimated 146 miles). | 10/1/2014 | 1/1/2018 |
| NPPD | Cherry Co 345 kV Terminal Upgrades | Build new Cherry County 345 kV Substation. | 10/1/2014 | 1/1/2018 |
| SPRM | Brookline – Compton Ridge 345 kV SPRM | Build approx. 30 mile 345 kV line | 6/1/2013 | 6/1/2019 |
| SPS | ARTESIA INTERCHANGE (GE C254477) 115/69/13.2KV TRANSFORMER CKT 1 | Replace Transformer | 6/1/2018 | 6/1/2018 |
| SPS | ARTESIA INTERCHANGE (MNLY 2118072) 115/69/13.2KV TRANSFORMER CKT 2 | Replace Transformer | 6/1/2018 | 6/1/2018 |
| SPS | CHAVES COUNTY INTERCHANGE - SAMSON SUB 115KV CKT 1 | Reconductor 7.78 miles of Chaves - Sampson 115 kV | 6/1/2020 | 6/1/2020 |
| SPS | CHAVES COUNTY INTERCHANGE - URTON SUB 115KV CKT 1 | Reconductor 3.70 miles of Chaves - Urton 115 kV | 6/1/2020 | 6/1/2020 |
| WERE | MOUNDRIDGE 138/115KV TRANSFORMER CKT 2 | Install second 138/115 kV transformer at Moundridge. Operate both 138/115 kV transformers normally closed. | 2/1/2013 | 12/1/2014 |

| ALDAM TAP- BANN 158KV OCT 1 ALDAM TAP- BANN | Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) |
|--|--------------------|--|---|--|--|
| ## ADMINISTRATION OF THE PROPERTY OF THE PROPE | A EDW | ALLIMAY TAD DANN 120V/ CVT 1 | | 6/1/2009 | 6/1/2009 |
| | AEPVV | ALUMAN TAP - DAMM TOOKY CAT I | | 6/1/2008 | 6/1/2006 |
| ASPONNED INC. MALL MODELS PARTER | AEPW | ASHDOWN REC (MILLWOOD) - OKAY 138KV CKT 1 | | 7/1/2012 | 7/1/2012 |
| MANN | AEDW/ | ACHDOWN DEC (MILLWOOD), DATTEDSON 1299V CVT 1 | | 7/1/2012 | 7/1/2012 |
| Description of State Description Descr | | | | | 7/1/2012 |
| NOSO POWER RANT - VALLIANT 3-SEY NATEW | | | | | |
| ### MCMAR REC. TURK 1156V CKT 1 | | | | | 6/1/2009 |
| MONAB REC. TURK 115KV OCT 1 AND MONAB REC. TURK 115KV OCT 1 AND DESCRIPTION OF THE ADDRESS OF | AEPW | HUGO POWER PLANT - VALLIANT 345 KV AEPW | | 7/1/2012 | 7/1/2012 |
| Build two mile, 138 kV, 1590ACSR line section from Turk Sub to existing One-phope 115 V line and rebuild twelve mile of 115 V line to days Jub 7/1/2012 7/1/2 | | | from Turk Substation to the existing Okay- Hope 115 kV line to form a Turk | | |
| Display | AEPW | MCNAB REC - TURK 115KV CKT 1 | - Hope 115 kV line. | 7/1/2012 | 7/1/2012 |
| SUGAR HILL TURK 158KV CCT 1 | AEPW | OKAY - TURK 138KV CKT 1 | Okay-Hope 115 kV line and rebuild twelve miles of 115 kV line to Okay Sub to 138 kV, 1590 ACSR , to form a Turk-Okay 138 kV line | 7/1/2012 | 7/1/2012 |
| MACE SUB 110 - ORONOGO ICT - 5UB 167 - RIVERTON 16INV CKT 1 Reconductor Cronogo 59467 to Riverton 59469 with Bundled 556 ACSN 6/1/2016 6/1/2006 | AEPW | SE TEXARKANA - TURK 138KV CKT 1 | terminal. | 7/1/2012 | 7/1/2012 |
| LACYGNE - WEST GARDNER 345KV CKT 1 | AEPW | SUGAR HILL - TURK 138KV CKT 1 | Build new Turk-Sugar Hill 138 kV line and add Sugar Hill 138 kV terminal. | 7/1/2012 | 7/1/2012 |
| MIDING CIRCLE - RICE_CO 230W CKT 1 Convert from 115kV to 230W operation 101/12012 11/15/1 | EMDE | SUB 110 - ORONOGO JCT SUB 167 - RIVERTON 161KV CKT 1 | Reconductor Oronogo 59467 to Riverton 59469 with Bundled 556 ACSR | 6/1/2011 | 6/1/2011 |
| MIDW VOYS- RICE_CO 2301/SEV CRT | KACP | LACYGNE - WEST GARDNER 345KV CKT 1 | KCPL Sponsored Project to Reconductor Line to be In-Service by 6/1/2006 | 6/1/2006 | 6/1/2006 |
| MIDW NICE, CO 290/1156V TRANSFORMER CRT | | | | | 11/15/2012 |
| MEC ALEXANDR - PRATT 118V CYT | | | | | 4/1/2013 |
| MREC | | | | | |
| MREC CLIFTON - GREENLEAF 11SW CKT 1 Rebuild 4.4 miles 6/1/2011 6/1/25 | | | | | |
| MREC | | | | | 6/1/2013 |
| MEEC GREENIEAF - KNOB HILL ISSN CKT 1 MIEC Rebuild line 12/12/009 61/1203 | | | | | 6/1/2013 |
| MREC MEDICINE LODGE - SAMYER 115KV CKT 1 Rebuild line 12/1/2009 6/1/200 6/ | | | | | 6/15/2013 |
| NEEC NEDICINE LODGE 138/115KV TRANSFORMER CKT 1 Displacement Uggrade transformer 12/1/2009 6/1/2006 | | | | | 6/1/2013 |
| Replace Breaker Switch 1106-D and jumpers at Albion. Replace main bus at Petersburg. Upgrade and replace transmission structures on 115 W inter for a filter 100 degrees Centigrade line operation. 1/1/2013 1/1/201 Raise structures and line clearances as necessary to re-rate the transmission line to 3200MV. RELLY - MADISONCO 230.00 230KV CKT 1 Raise structures and line clearances as necessary to re-rate the transmission line to 320MV. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nelligh. Replace Breaker 1106, Jumpers, and 115 KV Switch 1106-D2 at Nell | | | | | |
| PPD | | | Replace Breaker Switch 1106-D and jumpers at Albion. Replace main bus at Petersburg. Upgrade and replace transmission structures on 115 kV lineto facilitate 100 degrees Centigrade line operation. | | 1/1/2013 |
| NEPD KELLY - MADISONCO 230.00 230KV CKT 1 transmission line to 320MVA 10/1/2013 11/1/20 11/1/2 | NPPD | FT RANDAL - MADISONCO 230.00 230KV CKT 1 | transmission line to 320MVA | 10/1/2013 | 11/1/2014 |
| Replace Breaker 1106, jumpers, and 115 kV Switch 1106-02 et Netligh. Replace main bus at Peterbusy. Upgrade and replace transmission structures on 115 kV jumper and replace transmission structures of 117 kV jumper and replace transmission and replace transmission structures of 117 kV jumper and | NPPD | KELLY - MADISONCO 230 00 230KV CKT 1 | | 10/1/2013 | 11/1/2014 |
| NPPD NELGH - PETERSBURG 115NV CKT 1 Operation. 11/2013 11/2020 1 | | | Replace Breaker 1106, jumpers, and 115 kV Switch 1106-D2 at Neligh. Replace main bus at Petersburg. Upgrade and replace transmission | | ,-, |
| DICEST SELINE - EXPLORER GLENPOOL 388FV CKT 1 Reconductor - 32-miles of line with Drake ACCC/TW. 6/1/2009 6/1/2008 6/1/2 | NPPD | NELIGH - PETERSBURG 115KV CKT 1 | | 1/1/2013 | 1/1/2013 |
| DICEST SPACE SPA | | | Reconductor .92miles of line with Drake ACCC/TW. | 6/1/2009 | 6/1/2009 |
| NOBERTHLERS 138/69/13.2 keV TRANSFORMER CKT Replace bus the with JODMVA transformer 6/1/2006 6/1/20 | | | | | 6/1/2009 |
| NORTHWEST - TATONGA 345KV CKT 1 | | | | | 1/1/2012 |
| DKGE | | | | | 6/1/2008 1/1/2010 |
| DIAGE WOODWARD - IODINE 138KV CKT 1 | | | | | 1/1/2010 |
| DKGE WOODWARD - WOODWARD EHV 138KV CKT 1 | | | | | 1/1/2010 |
| DKGE WOODWARD 345/138VX TRANSFORMER CKT 1 11/12010 11/12010 11/12010 11/12010 11/12010 11/12010 11/12010 11/12010 11/12010 11/12010 11/12010 11/12010 11/12010 11/12012 6/12012 6/12012 6/12012 6/12012 6/12012 6/12012 6/12012 6/12012 6/12012 6/12012 6/12012 7/15/20 6/12012 7/15/20 8/15/20< | | WOODWARD - WOODWARD EHV 138KV CKT 1 | | 1/1/2010 | 1/1/2010 |
| SPS OHERWE 230.00 - Harrington Station East Bus 230KV CKT 1 Replace wavetrap at Harrington East 6/1/2015 6/1/201 6 | | | | | 1/1/2010 |
| WERE DEARING 138KV Capacitor Dearing 138 kV 20 MVAR Capacitor Addition 6/1/2012 6/1/2012 6/1/2012 6/1/2012 6/1/2012 6/1/2012 6/1/2012 7/15/20 WERE LYONS - WHEATLAND 115KV CKT 1 #1 Replace CTS 10/1/2012 7/15/20 WEFE CANTON - TALOGA 69KV CKT 1 UPGRADE CANTON TO TALOGA TO 336.4 6/1/2011 | | | | | 1/1/2010 |
| WERE LYONS - WHEATLAND 115KV CKT 1 #1 Replace CTs 10/1/2012 7/15/20 WERE LYONS - WHEATLAND 115KV CKT 1 #2 Rerate circuit to 1000 amps 10/1/2012 7/15/20 WEEC CANTON - TALOGA 69KV CKT 1 UPGRADE CANTON TO TALOGA 70 336.4 6/1/2011 6/1/2011 WEEC GG3-05T 138.00 - PARAIDSE 138KV CKT 1 Upgrade Paradises to 050-05T to 1113 6/1/2011 6/1/201 WEEC GRACHMTA 138BO - WASHIRT 138KV CKT 2 WFEC Build approximately 6 mile of 138kV 1/1/2012 1/1/20 WEEC HUGO POWER PLANT - VALLIANT 36KV CKT 1 WFEC New 19 miles 345 KV 7/1/2012 7/1/201 WEEC HUGO POWER PLANT 34/5/138KV TRANSFORMER CKT 1 New 34/5/138 kV Auto 7/1/2012 7/1/202 | | | Replace wavetrap at Harrington East Dearing 138 kV 20 MVAR Canacitor Addition | | |
| WERE LYONS - WHEATLAND 115KV CKT 1 #2 Rerate circuit to 1000 amps 10/1/2012 7/15/2 WFEC CANTON - TALOGA 60KV CKT 1 UPGRADE CANTON TO TALOGA TO 336.4 6/1/2011 1/1/2012 1/1/2012 1/1/2012 1/1/2012 1/1/2012 1/1/2012 1/1/2012 1/1/2012 1/1/2012 1/1/2012 1/1/2012 1/1/2012 1/1 | | | | | 7/15/2012 |
| WEEC CANTON - TALOGA 698/C VCT 1 UPGRADE CANTON TO TALOGA TO 336.4 6/1/2011 6/1/2C WEEC G03-05T 138.00 - PARADISE 138KV CKT 1 Upgrade Paradise to G03-05T to 1113 6/1/2C WEEC GRACMMTA 138.00 - WASHITA 138KV CKT 2 WFEC Build approximately 6 miles of 138kV 11/1/2012 1/1/2C WEEC HIGG POWER PLANT - VALLIANT 36KV CKT 1 WFEC New 19 miles 345 KV 7/1/2012 7/1/2C WEEC HIGG POWER PLANT 36/1/3/EXIT KRANSFORMER CKT 1 New 34/5/1/3 kV Auto 7/1/1/2012 7/1/2C | | | | | 7/15/2013 |
| WFEC GRACMNT1 138.00 - WASHITA 138KV CKT 2 WFEC Build approximately 6 miles of 138kV. 1/1/2012 1/1/2012 1/1/2012 1/1/2012 1/1/2012 1/1/2012 1/1/2012 1/1/2012 1/1/2012 1/1/2012 7/1/2012 | WFEC | CANTON - TALOGA 69KV CKT 1 | UPGRADE CANTON TO TALOGA TO 336.4 | 6/1/2011 | 6/1/2013 |
| WFEC HUGO POWER PLANT - VALUANT 345KV CKT 1 WFEC New 19 miles 345 KV 7/1/2012 7/1/2012 WFEC HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1 New 345/138 kv Auto 7/1/2012 7/1/2012 | | | | | 6/1/2013 |
| WFEC HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1 New 345/138 kv Auto 7/1/2012 7/1/20 | | | | | 1/1/2012 |
| | | | | | 7/1/2012 |
| | WFEC | HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1 TALOGA (TALOGA) 138/69/13.8KV TRANSFORMER CKT 1 | New 345/138 kv Auto Auto XFMR 56 to 112MVA | 10/1/2010 | 7/1/2012 6/1/2013 |

Table 5 - Third Party Facility Constraints

| Transmission Owner | UpgradeName | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) | Estimated Engineering & Construction Cost |
|--------------------|-------------|--|--|--|---|
| SWPA | | Rebuild line using 1590MCM ACSR conductor on tubular steel H-frame structures. Replace breakers and switches at Beaver. Remove wave traps. | 6/1/2013 | 6/1/2016 | \$4,130,000.00 |