

**GEN-2011-054**  
**Impact Restudy for**  
**Generator Modification**  
**(Turbine Change)**

**January 2015**  
**Generator Interconnection**



---

## Executive Summary

---

The GEN-2011-054 interconnection customer has requested a system impact restudy to determine the effects of changing wind turbine generators from the previously studied ninety-nine (99) Vestas V100 VCSS 2.0MW and fifty (50) Vestas V110 VCSS 2.0MW to one hundred fifty (150) Vestas V100 VCSS 2.0MW wind turbine generators.

In this restudy the project uses one hundred fifty (150) Vestas V100 VCSS 2.0MW wind turbine generators for an aggregate power of 300.0MW. The point of interconnection (POI) for GEN-2011-054 is at the Oklahoma Gas and Electric (OKGE) Cimarron 345kV Substation. The interconnection customer has provided documentation that shows the Vestas V100 VCSS 2.0MW wind turbine generators have a reactive capability of 0.98 lagging (providing VARS) and 0.96 leading (absorbing VARS) power factor.

This study was performed to determine whether the request for modification is considered Material. To determine this, study models that included Interconnection Requests through DISIS-2011-002 were used that analyzed the timeframes of 2015 summer, 2015 winter, and 2025 summer models.

The restudy showed that no stability problems were found during the summer and the winter peak conditions as a result of changing to the Vestas V100 VCSS 2.0MW wind turbine generators. Additionally, the project wind farm was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A.

A power factor analysis was performed for this modification request. The facility will be required to maintain a 95% lagging (providing VARs) and 95% leading (absorbing VARs) power factor at the POI. Since the Vestas V100 VCSS 2.0MW wind turbines have limited reactive capability, the generation facility will need external capacitor banks or other reactive equipment to meet the power factor requirement at the POI. Additionally, the project will be required to install approximately 20Mvar of reactor shunts on its substation 34.5kV bus(es). This is necessary to offset the capacitive effect on the transmission network caused by the project's transmission line and collector system during low-wind/no-wind conditions.

With the assumptions outlined in this report and with all the required network upgrades from the GEN-2011-054 GIA in place, GEN-2011-054 with the Vestas V100 VCSS 2.0MW wind turbine generators should be able to interconnect reliably to the SPP transmission grid.

It should be noted that although this study analyzed many of the most probable contingencies, it is not an all-inclusive list and cannot account for every operational situation. Because of this, it is likely that the customer may be required to reduce its generation output to 0 MW, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Nothing in this study should be construed as a guarantee of transmission service or delivery rights. If the customer wishes to obtain deliverability to final customers, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the customer.

## I. Introduction

GEN-2011-054 Impact Restudy is a generation interconnection study performed to study the impacts of interconnecting the project shown in Table I-1. This restudy is for a change from ninety-nine (99) Vestas V100 VCSS 2.0MW and fifty (50) Vestas V110 VCSS 2.0MW to one hundred fifty (150) Vestas V100 VCSS 2.0MW wind turbines.

**Table I-1: Interconnection Request**

Request	Capacity (MW)	Generator Model	Point of Interconnection
GEN-2011-054	300	Vestas V100 VCSS 2.0MW (150 generators)	Cimarron 345kV (514901)

The prior-queued and equally-queued requests shown in Table I-2 were included in this study and the wind farms were dispatched to 100% of rated capacity.

**Table I-2: Prior or Equally Queued Interconnection Requests**

Request	Capacity (MW)	Generator Model	Point of Interconnection
GEN-2001-014	94.5	Suzlon 2.1MW	Ft. Supply 138kV (520920)
GEN-2001-037	102.0	GE 1.5MW	Wind Farm 138kV (515785)
GEN-2005-008	120.0	GE 1.5MW	Woodward 138kV (514785)
GEN-2006-024S	18.9	Suzlon 2.1MW	Buffalo Bear Tap 69kV (521120)
GEN-2006-046	132.0	Mitsubishi 2.4MW	Dewey 138kV (514787)
GEN-2007-021	198.9	GE 1.7MW	Tatonga 345kV (515407)
GEN-2007-043	200.0	GE 1.6MW	Minco 345kV (514801)
GEN-2007-044	299.2	GE 1.7MW	Tatonga 345kV (515407)
GEN-2007-050	170.2	Siemens 2.3MW	Woodward EHV 138kV (515376)
GEN-2007-062	765.0	GE 1.5MW	Woodward EHV 345kV (515375)
GEN-2008-003	101.2	Siemens 2.3MW	Woodward EHV 138kV (515376)
GEN-2008-044	197.8	Siemens 2.3MW &	Tatonga 345kV (515407)
GEN-2010-011	29.7	3.0MW	
GEN-2010-040	298.05	Mitsubishi 2.4 MW Repower 2.05MW	Cimarron 345kV (514901)
GEN-2011-007	250.1	Repower MM92 2.05MW	Matthewson 345kV (515497)
GEN-2011-010	100.8	GE 1.6MW	Minco 345kV (514801)
GEN-2011-019	299.0	Siemens 2.3MW	Woodward 345kV (515375)
GEN-2011-020	299.0	Siemens 2.3MW	Woodward 345kV (515375)
GEN-2011-051	104.4	Vestas V90 1.8MW	Tap Woodward-Tatonga 345kV (515375-515407)

The study included a stability analysis of the interconnection request. Contingencies that resulted in a prior-queued project tripping off-line, if any, were re-run with the prior-queued project's

voltage and frequency tripping relays disabled. The analysis were performed on three seasonal models, the modified versions of the 2015 summer peak, the 2015 winter peak, and the 2025 summer peak cases.

The stability analysis determines the impacts of the new interconnecting project on the stability and voltage recovery of the nearby systems and the ability of the interconnecting project to meet FERC Order 661A. If problems with stability or voltage recovery are identified, the need for reactive compensation or system upgrades is investigated. The three-phase faults and the single line-to-ground faults listed in Table III-1 were used in the stability analysis.

The power factor analysis determines the power factor at the point of interconnection for the wind interconnection project for pre-contingency and post-contingency conditions. The contingencies used in the power factor analysis were a subset of the stability analysis contingencies shown in Table III-1.


The low-wind/no-wind analysis determines the capacitive effect at the POI caused by the project's collector system and transmission line capacitance. A shunt reactor size was determined to offset the capacitive effect and to maintain zero Mvar flow at the POI when the plant generators and capacitors are off-line such as might be seen in low-wind or no-wind conditions.

It should be noted that although this study analyzed many of the most probable contingencies, it is not an all-inclusive list and cannot account for every operational situation. Because of this, it is likely that the customer may be required to reduce its generation output to 0 MW, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Nothing in this study should be construed as a guarantee of transmission service or delivery rights. If the customer wishes to obtain deliverability to final customers, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the customer.

## II. Facilities

A one-line drawing for the GEN-2011-054 generation interconnection request is shown in Figure II-1. The POI is the OKGE Cimarron 345kV substation.



**Figure II-1: GEN-2011-054 One-line Diagram**

---

## III. Stability Analysis

---

Transient stability analysis is used to determine if the transmission system can maintain angular stability and ensure bus voltages stay within planning criteria bandwidth during and after a disturbance while considering the addition of a generator interconnection request.

### Model Preparation

Transient stability analysis was performed using modified versions of the 2014 series of Model Development Working Group (MDWG) dynamic study models including the 2015 summer peak, the 2015 winter peak, and the 2025 summer peak seasonal models. The cases are then loaded with prior queued interconnection requests and network upgrades assigned to those interconnection requests. Finally the prior queued and study generation are dispatched into the SPP footprint. Initial simulations are then carried out for a no-disturbance run of twenty (20) seconds to verify the numerical stability of the model.

### Disturbances

Five (5) contingencies were identified for use in this study and are listed in Table III-1. These contingencies included three-phase faults and single-phase line faults at locations defined by SPP. Single-phase line faults were simulated by applying fault impedance to the positive sequence network at the fault location to represent the effect of the negative and zero sequence networks on the positive sequence network. The fault impedance was computed to give a positive sequence voltage at the specified fault location of approximately 60% of pre-fault voltage. This method is in agreement with SPP current practice.

Except for transformer faults, the typical sequence of events for a three-phase and a single-phase fault is as follows:

1. apply fault at particular location
2. continue fault for five (5) cycles, clear the fault by tripping the faulted facility
3. after an additional twenty (20) cycles, re-close the previous facility back into the fault
4. continue fault for five (5) additional cycles
5. trip the faulted facility and remove the fault

Transformer faults are typically modeled as three-phase faults, unless otherwise noted. The sequence of events for a transformer fault is as follows:

1. apply fault for five (5) cycles
2. clear the fault by tripping the affected transformer facility (unless otherwise noted there will be no re-closing into a transformer fault)

**Table III-1: Contingencies Evaluated**

Cont. No.	Contingency Name	Description
1	FLT_01_Cimarron7_Minco_345kV_3PH	3 phase fault on the Cimarron (514901) to Minco (514801) 345kV line, at Cimarron. a. Apply fault at the Cimarron 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
2	FLT_02_Cimarron7_Northwest_345kV_3PH	3 phase fault on the Cimarron (514901) to Northwest (514880) 345kV line, at Cimarron. a. Apply fault at the Cimarron 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
3	FLT_03_Cimarron7_Draper_345kV_3PH	3 phase fault on the Cimarron (514901) to Draper (514934) 345kV line, at Cimarron. a. Apply fault at the Cimarron 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
4	FLT_04_Cimarron7_Matthewson_345kV_3PH	3 phase fault on the Cimarron (514901) to Matthewson (515497) 345kV line, at Cimarron. a. Apply fault at the Cimarron 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
5	FLT_05_Cimarron7_Cimarron4_345_138kV_3PH	3 phase fault on the Cimarron (514901) 345 / (514898) 138 / (515714) 13.8kV transformer, at Cimarron 345kV bus. a. Apply fault at the Cimarron 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line

**Results**

The stability analysis was performed and the results are summarized in Table III-2. Based on the stability results and with all network upgrades in service, GEN-2011-054 did not cause any stability problems and remained stable for all faults studied. No generators tripped or went unstable, and voltages recovered to acceptable levels.



**Table III-2: Stability Analysis Results**

	Contingency Number and Name	2015SP	2015WP	2025SP
1	FLT_01_Cimarron7_Minco_345kV_3PH	OK	OK	OK
2	FLT_02_Cimarron7_Northwest_345kV_3PH	OK	OK	OK
3	FLT_03_Cimarron7_Draper_345kV_3PH	OK	OK	OK
4	FLT_04_Cimarron7_Matthewson_345kV_3PH	OK	OK	OK
5	FLT_05_Cimarron7_Cimarron4_345_138kV_3PH	OK	OK	OK

NOTE: “- NA -” means the contingency is not applicable

## **FERC LVRT Compliance**

FERC Order #661A places specific requirements on wind farms through its Low Voltage Ride Through (LVRT) provisions. For Interconnection Agreements signed after December 31, 2006, wind farms shall stay on line for faults at the POI that draw the voltage down at the POI to 0.0 pu.

Contingencies 1,2, 3,4 and 5 in Table III-2 simulated the LVRT contingencies. GEN-2011-054 met the LVRT requirements by staying on line and the transmission system remaining stable.

## IV. Power Factor Analysis

A subset of the stability faults was used as power flow contingencies to determine the power factor requirements for the wind farm to maintain scheduled voltage at the POI. The voltage schedule was set equal to the voltages at the POI before the project is added, with a minimum of 1.0 per unit. A fictitious reactive power source replaced the study project to maintain scheduled voltage during all studied contingencies. The MW and Mvar injections from the study project at the POI were recorded and the resulting power factors were calculated for all contingencies for summer peak and winter peak cases. The most leading and most lagging power factors determine the minimum power factor range capability that the study project must install before commercial operation.

Per FERC and SPP Tariff requirements, if the power factor needed to maintain scheduled voltage is less than 0.95 lagging, then the requirement is limited to 0.95 lagging. The lower limit for leading power factor requirement is also 0.95. If a project never operated leading under any contingency, then the leading requirement is set to 1.0. The same applies on the lagging side.

The power factor analysis showed a need for reactive capability by the study project at the POI. The final power factor requirement in the Generator Interconnection Agreement (GIA) will be the pro-forma 0.95 lagging to 0.95 leading at the POI, and this requirement is shown in Table IV-1. The detailed power factor analysis tables are in Appendix B. Since the Vestas V100 2.0MW wind turbines have limited reactive capability (0.98 lagging and 0.96 leading), the generation facility will require external capacitor banks or other reactive equipment to meet the power factor requirement at the POI.

**Table IV-1: Power Factor Requirements <sup>a</sup>**


Request	Size (MW)	Generator Model	Point of Interconnection	Final PF Requirement at POI	
				Lagging <sup>b</sup>	Leading <sup>c</sup>
GEN-2011-054	300	Vestas V100 VCSS 2.0MW	Cimarron 345kV (514901)	0.95 <sup>d</sup>	0.95 <sup>e</sup>

Notes:

- a. The table shows the minimum required power factor capability at the point of interconnection that must be designed and installed with the plant. The power factor capability at the POI includes the net effect of the generators, transformers, line impedances, and any reactive compensation devices installed on the plant side of the meter. Installing more capability than the minimum requirement is acceptable.
- b. Lagging is when the generating plant is supplying reactive power to the transmission grid, like a shunt capacitor. In this situation, the alternating current sinusoid “lags” behind the alternating voltage sinusoid, meaning that the current peaks shortly after the voltage.
- c. Leading is when the generating plant is taking reactive power from the transmission grid, like a shunt reactor. In this situation, the alternating current sinusoid “leads” the alternating voltage sinusoid, meaning that the current peaks shortly before the voltage.
- d. Electrical need is lower, but PF requirement limited to 0.95 by FERC order.
- e. The most leading power factor determined through analysis was 1.00.

In a separate test, the effect of low-wind/no-wind conditions at the wind farm is analyzed. The project generators and capacitors (if any) were turned off in the base case (Figure IV-1). The resulting reactive power injection into the transmission network comes from the capacitance of the project's transmission lines and collector cables. Normally, this reactive power injection is measured at the POI (Cimarron 345kV substation). However, GEN-2011-054 injects power into the transmission network through a tap on the existing transmission line from GEN-2010-040 (which the customer owns) to the POI. It is at this tap (FSHRTAP7 in Figure IV-1) that the reactive power injection is measured.

Shunt reactors were added at the study project substation 34.5 kV buses to bring the Mvar flow into the tap on the GEN-2010-040 to Cimarron 345kV line down to approximately zero (FSHRTAP7 in Figure IV-2). Final shunt reactor requirement for this project is approximately 20Mvars. The one-line diagram in Figure IV-2 shows actual Mvar output at the specific voltages in the base case. The results shown are for the 2015WP case. The other two cases (2015SP and 2025SP) were almost identical since the plant design is the same in all cases.



**Figure IV-1: GEN-2011-054 with generators off and no shunt reactors**



---

## V. Conclusion

---

The SPP GEN-2011-054 Impact Restudy evaluated the impact of interconnecting the project shown below.

Request	Capacity (MW)	Generator Model	Point of Interconnection
GEN-2011-054	300	Vestas V100 VCSS 2.0MW	Cimarron 345kV (514901)

With all Base Case Network Upgrades in service, previously assigned Network Upgrades in service, and required capacitor banks in service, the GEN-2011-054 project was found to remain on line, and the transmission system was found to remain stable for all conditions studied.

The facility will be required to maintain a 95% lagging (providing VARs) and 95% leading (absorbing VARs) power factor at the POI. Since the Vestas V100 VCSS 2.0MW wind turbines have limited reactive capability, the generation facility will require external capacitor banks or other reactive equipment to meet the power factor requirement at the POI.

Additionally, the project will be required to install approximately 20Mvar of reactor shunts on its substation 34.5kV bus. This is necessary to offset the capacitive effect on the transmission network cause by the project's transmission line and collector system during low-wind or no-wind conditions.

Low Voltage Ride Through (LVRT) analysis showed the study generators did not trip offline due to low voltage when all Network Upgrades are in service.

All generators in the monitored areas remained stable for all of the modeled disturbances.

Any changes to the assumptions made in this study, for example, one or more of the previously queued requests withdraw, may require a re-study at the expense of the Customer.

Nothing in this System Impact Study constitutes a request for transmission service or confers upon the Interconnection Customer any right to receive transmission service.

## APPENDIX A

### PLOTS

Available upon request

APPENDIX B  
POWER FACTOR ANALYSIS



GEN-2011-054 POI: Cimarron 345kV (514901) POI voltage for all seasons is 1.0PU	2014 Winter Peak				2015 Summer Peak				2024 Summer Peak			
	MW	Mvar	PF		MW	Mvar	PF		MW	Mvar	PF	
FLT_00_NoFault	298.0	113.4	0.935	LAG	298.0	64.2	0.978	LAG	298.0	109.6	0.939	LAG
FLT_01_CIMARON7_MINCO7_345kV	298.0	136.3	0.909	LAG	298.0	83.5	0.963	LAG	298.0	131.6	0.915	LAG
FLT_03_CIMARON7_NORTWST7_345kV	298.0	104.5	0.944	LAG	298.0	63.2	0.978	LAG	298.0	102.7	0.945	LAG
FLT_05_CIMARON7_DRAPER7_345kV	298.0	140.6	0.904	LAG	298.0	83.0	0.963	LAG	298.0	120.9	0.927	LAG
FLT_07_CIMARON7_MATHWSN7_345kV	298.0	110.8	0.937	LAG	298.0	64.7	0.977	LAG	298.0	106.0	0.942	LAG
FLT_09_MINCO7_GRACMNT7_345kV	298.0	130.7	0.916	LAG	298.0	77.8	0.968	LAG	298.0	122.7	0.925	LAG
FLT_11_GRACMNT7_LES7_345kV	298.0	112.3	0.936	LAG	298.0	70.6	0.973	LAG	298.0	108.4	0.940	LAG
FLT_13_NORTWST7_SPRNGCK7_345kV	298.0	132.2	0.914	LAG	298.0	101.2	0.947	LAG	298.0	147.8	0.896 <sup>a</sup>	LAG
FLT_15_NORTWST7_ARCADIA7_345kV	298.0	132.1	0.914	LAG	298.0	73.6	0.971	LAG	298.0	122.3	0.925	LAG
FLT_17_NORTWST7_MATHWSN7_345kV	298.0	144.2	0.900	LAG	298.0	90.1	0.957	LAG	298.0	138.2	0.907	LAG
FLT_19_SPRNGCK7_SOONER7_345kV	298.0	130.6	0.916	LAG	298.0	76.1	0.969	LAG	298.0	123.8	0.923	LAG
FLT_21_DRAPER7_SEMINOL7_345kV	298.0	123.5	0.924	LAG	298.0	73.1	0.971	LAG	298.0	122.2	0.925	LAG
FLT_23_SEMINOL7_PITTSB7_345kV	298.0	112.9	0.935	LAG	298.0	61.5	0.979	LAG	298.0	112.3	0.936	LAG
FLT_25_SEMINOL7_ARCADIA7_345kV	298.0	119.1	0.929	LAG	298.0	68.3	0.975	LAG	298.0	111.0	0.937	LAG
FLT_27_SEMINOL7_MUSKOGEE7_345kV	298.0	111.9	0.936	LAG	298.0	62.7	0.979	LAG	298.0	108.9	0.939	LAG
FLT_29_MATHWSN7_WOODRNG7_345kV	298.0	144.9	0.899	LAG	298.0	93.1	0.954	LAG	298.0	135.4	0.910	LAG
FLT_31_MATHWSN7_TATONGA7_345kV	298.0	147.7	0.896	LAG	298.0	92.8	0.955	LAG	298.0	138.1	0.907	LAG
FLT_33_TATONGA7_G11051TAP_345kV	298.0	41.8	0.990	LAG	298.0	8.6	1.000 <sup>b</sup>	LAG	298.0	104.0	0.944	LAG
FLT_35_CIMARON4_TUTCONT4_138kV	298.0	109.5	0.939	LAG	298.0	59.0	0.981	LAG	298.0	103.3	0.945	LAG
FLT_37_CIMARON4_ELRENO4_138kV	298.0	111.3	0.937	LAG	298.0	61.6	0.979	LAG	298.0	106.9	0.941	LAG
FLT_39_CIMARON4_JENSENT4_138kV	298.0	111.5	0.937	LAG	298.0	62.0	0.979	LAG	298.0	107.2	0.941	LAG
FLT_41_CIMARON4_HAYMAKR4_138kV	298.0	115.4	0.933	LAG	298.0	63.9	0.978	LAG	298.0	109.7	0.938	LAG
FLT_43_CIMARON4_CZECHAL4_138kV	298.0	115.8	0.932	LAG	298.0	61.5	0.979	LAG	298.0	108.1	0.940	LAG
FLT_45_CIMARON4_SARA4_138kV	298.0	115.4	0.933	LAG	298.0	62.4	0.979	LAG	298.0	108.1	0.940	LAG
FLT_47_CIMARON7_CIMARON4_345_138kV	298.0	101.7	0.946	LAG	298.0	55.4	0.983	LAG	298.0	101.6	0.946	LAG
FLT_48_NORTWST7_NORTWST4_345_138kV	298.0	113.2	0.935	LAG	298.0	64.8	0.977	LAG	298.0	106.4	0.942	LAG

GEN-2011-054 POI: Cimarron 345kV (514901) POI voltage for all seasons is 1.0PU	2014 Winter Peak				2015 Summer Peak				2024 Summer Peak			
	MW	Mvar	PF		MW	Mvar	PF		MW	Mvar	PF	
FLT_49_DRAPER7_DRAPER4_345_138kV	298.0	114.4	0.934	LAG	298.0	63.6	0.978	LAG	298.0	110.1	0.938	LAG
FLT_50_PLSNTHILL3_PLSNTHILL6_115_230kV	298.0	113.5	0.935	LAG	298.0	64.2	0.978	LAG	298.0	109.7	0.938	LAG

## NOTE:

- a. Lowest lagging (supplying vars) power factor requirement for all three seasons
- b. Lowest leading (absorbing vars) power factor requirement for all three seasons

APPENDIX C  
PROJECT MODELS

**GEN-2011-054 (Vestas V100 2.0 MW)****PSS/E 32 Power Flow Data**

```

@! ***** GEN-2011-054 100% *****
@!
@! POI @ Cimarron 345kV 514901 (Tap GEN-2010-040-Cimarron 345kV 515610)
@!
@! Canadian Hills (Kingfisher Wind)
@!
@! Vestas V100 VCSS 60Hz Mk10 Wind Turbine Generator 2.0MW
@!
@! Pmax=300.0MW | Pgen=300.0MW
@!
@! +0.98/-0.96PF Range (Qgen=Qmax=Qmin)
@!
Version 32
@!
@! ----- Bus Data -----
BAT_SPLT,515610,515600,'KNGFSHR7', 345.00;;
BAT_BUS_DATA_2,515600,1,524, 569,524, 345.00,,,'KNGFSHR7';;
BAT_BUS_DATA_2,515601,1,524, 569,524, 34.50,,,'KNGFSR11';;
BAT_BUS_DATA_2,515603,1,524, 569,524, 13.80,,,'KNGFSRT1';;
BAT_BUS_DATA_2,583122,1,524, 569,524, 34.50,,,'G11-054-GSU1';;
BAT_BUS_DATA_2,583123,2,524, 569,524, 0.69,,,'G11-054-GEN1';;
BAT_BUS_DATA_2,515602,1,524, 569,524, 34.50,,,'KNGFSR12';;
BAT_BUS_DATA_2,515604,1,524, 569,524, 13.80,,,'KNGFSRT2';;
BAT_BUS_DATA_2,583125,1,524, 569,524, 34.50,,,'G11-054-GSU2';;
BAT_BUS_DATA_2,583126,2,524, 569,524, 0.69,,,'G11-054-GEN2';;
@!
@! ----- Generator Data -----
BAT_PURGMAC,515601,'1';;
BAT_PURGMAC,515602,'1';;
BAT_PLANT_DATA,583123, 0, 1.00,,;
BAT_PLANT_DATA,583126, 0, 1.00,,;
@! 100%
BAT_MACHINE_DATA_2,583123,'1',1,,,,,0, 150.00, 6.00, 6.0000, 6.0000, 150.00, 0.00, 150.00, 0.0050, 0.1991,,,,,,1.00;;
BAT_MACHINE_DATA_2,583126,'1',1,,,,,0, 150.00, 6.00, 6.0000, 6.0000, 150.00, 0.00, 150.00, 0.0050, 0.1991,,,,,,1.00;;
@!
@! ----- Unit Transformer Data -----
BAT_THREE_WND_IMPEDANCE_DATA,515600,515601,515603,'1',524,0,0,0,2,3,2,1,515600,515600,515601,515603, 187536.,
0.0797,0.0, 0.021,0.0, 0.115, 135.0, 135.0, 135.0,0.0,0.0, 1.0, 1.0, 1.0, 1.0,,,'KNGFSHR1';;
BAT_THREE_WND_WINDING_DATA_3,515600,515601,515603,'1',1,33,0,0,1,0, 345.0,0.0,0.0, 225.0, 225.0,0.0, 1.1, 0.9, 1.1,
0.9,0.0,0.0,0.0,;
BAT_THREE_WND_WINDING_DATA_3,515600,515601,515603,'1',2,33,0,0,1,0, 34.5,0.0,0.0, 225.0, 225.0,0.0, 1.1, 0.9, 1.1,
0.9,0.0,0.0,0.0,;
BAT_THREE_WND_WINDING_DATA_3,515600,515601,515603,'1',3,33,0,0,1,0, 13.8,0.0,-30.0, 75.0, 75.0,0.0, 1.1, 0.9, 1.1,
0.9,0.0,0.0,0.0,;
BAT_SEQ_3_WND_GROUNDING_DATA,515600,515601,515603,'1',2,0.0,0.0,;
BAT_SEQ_3_WND_WINDING_DATA,515600,515601,515603,'1',1, 0.077, 0.112463,;
BAT_SEQ_3_WND_WINDING_DATA,515600,515601,515603,'1',2, 0.0012,-0.00998277,;
BAT_SEQ_3_WND_WINDING_DATA,515600,515601,515603,'1',3, 0.025, 0.0476089,;
BAT_THREE_WND_IMPEDANCE_DATA,515600,515602,515604,'2',524,0,0,0,2,3,2,1,515600,515600,515602,515604, 187536.,
0.0797,0.0, 0.021,0.0, 0.115, 135.0, 135.0, 135.0,0.0,0.0, 1.0, 1.0, 1.0, 1.0,,,'KNGFSHR2';;
BAT_THREE_WND_WINDING_DATA_3,515600,515602,515604,'2',1,33,0,0,1,0, 345.0, 345.0,0.0, 225.0, 225.0,0.0, 1.1, 0.9, 1.1,
0.9,0.0,0.0,0.0,;
BAT_THREE_WND_WINDING_DATA_3,515600,515602,515604,'2',2,33,0,0,1,0, 34.5, 34.5,0.0, 225.0, 225.0,0.0, 1.1, 0.9, 1.1,
0.9,0.0,0.0,0.0,;
BAT_THREE_WND_WINDING_DATA_3,515600,515602,515604,'2',3,33,0,0,1,0, 13.8, 13.8,-30.0, 75.0, 75.0,0.0, 1.1, 0.9, 1.1,
0.9,0.0,0.0,0.0,;

```

```

BAT_SEQ_3_WIND_GROUNDING_DATA,515600,515602,515604,'2',2,0.0,0.0,;
BAT_SEQ_3_WIND_WINDING_DATA,515600,515602,515604,'2',1, 0.077, 0.112463,;
BAT_SEQ_3_WIND_WINDING_DATA,515600,515602,515604,'2',2, 0.0012,-0.00998277,;
BAT_SEQ_3_WIND_WINDING_DATA,515600,515602,515604,'2',3, 0.025, 0.0476089,;
BAT_TWO_WINDING_DATA_3,583122,583123,'1',1,,,,, 5,,,,-1,0,1,2,1, 0.008400, 0.09312,157.50,,,,,150.00,150.00,,,,,;
BAT_TWO_WINDING_DATA_3,583125,583126,'1',1,,,,, 5,,,,-1,0,1,2,1, 0.008400, 0.09312,157.50,,,,,150.00,150.00,,,,,;
@!
@! ----- Collector Cable Data -----
BAT_BRANCH_DATA,583122,515601,'1',1,,,,, 0.002610,0.0035,0.05839,,,,, ;
BAT_BRANCH_DATA,583125,515602,'1',1,,,,, 0.0019171,0.002274120,0.04066,,,,, ;
@!
@! ----- Transmission Line Data -----
@!BAT_BRANCH_DATA,515600,515610,'1',1,,,,, 0.0006227099, 0.00581757, 0.09747,,,,, 11.50,,,,;
CHNG
3
515600 515610 1
Y
1,0.0006227099, 0.00581757, 0.09747,,,,,11.5
N

-1
-1
@!
@END
    
```

**PSS/E 32 Dynamics Data**

```

/ Vestas 2.0MW V100 VCSS 2.0 MW 60 Hz Mk10 (VestasWT_7_6_0_PSSE32.lib)
/ V100 VCSS 2.0 MW 60 Hz Mk10
583123 'USRMDL' '1' 'VWCOR6' 1 1 2 45 23 104 1 0
2000.0000 690.0000 903.3041 700.0000 2.6200 0.9676 0.0232
1.9807 8.3333 1.9807 8.3333 30.0000 0.2000 1.2000
0.1000 0.0012 0.9925 0.0474 1.6118 0.0000 351.8584
161.5343 0.0300 0.0000 0.0300 0.3000 0.0000 1.0000
0.3183 4.9736 2812227.1900 43.2960 90.0120 600000.0000 3.0000
0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 0.0000/
0 'USRMDL' 0 'VWVAR6' 8 0 2 0 0 30 583123 '1' /
0 'USRMDL' 0 'VWLV6' 8 0 3 65 10 35 583123 '1' 1
0.9000 0.0010 0.1500 18.6316 74.5430 74.5430 74.5430
0.5000 1.0000 2.6200 0.9676 1.2000 0.5000 690.0000
903.3041 0.3500 0.0500 0.2500 0.0200 3.0000 4.0000
9999.0000 0.0232 0.9000 0.9000 0.0500 0.0000 0.0100
0.0000 2.0000 0.0000 1.0000 0.0000 0.0000 0.0000
0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 /
0 'USRMDL' 0 'VWPWR6' 8 0 3 30 7 10 583123 '1' 0
1.0000 0.5000 -0.5000 0.6988 0.8844 0.9800 0.9600
0.2000 0.2000 1.0000 1.0000 0.0000 0.0000 0.1000
0.1000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 /
0 'USRMDL' 0 'VWMEC6' 8 0 2 10 8 0 583123 '1'
2000.0000 422.2301 4736.7543 569.9822 106.4850 7976.7600 50.7400
0.0000 0.0000 0.0000 /
0 'USRMDL' 0 'VWMEAG' 8 0 2 10 8 5 583123 '1'
0.1000 0.1000 0.1000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 0.0000/
    
```

```

0 'USRMDL' 0 'VWVPR6' 0 2 7 30 0 18 583123 '1' 1 1 0 0 0
0.8500 11.0000 0.8500 11.0000 0.9000 60.0000 1.1000
60.0000 1.1500 2.0000 1.2000 0.0800 1.2500 0.0050
1.2500 0.0050 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 0.1500 0.8000 2.7000 0.8500 3.5000
0.9000 5.0000 /
0 'USRMDL' 0 'VWFPR6' 0 2 3 12 0 7 583123 '1' 0
56.4000 0.2000 56.4000 0.2000 56.4000 0.2000 63.6000
0.2000 63.6000 0.2000 63.6000 0.2000 /
583126 'USRMDL' '1' 'VWCOR6' 1 1 2 45 23 104 1 0
2000.0000 690.0000 903.3041 700.0000 2.6200 0.9676 0.0232
1.9807 8.3333 1.9807 8.3333 30.0000 0.2000 1.2000
0.1000 0.0012 0.9925 0.0474 1.6118 0.0000 351.8584
161.5343 0.0300 0.0000 0.0300 0.3000 0.0000 1.0000
0.3183 4.9736 2812227.1900 43.2960 90.0120 600000.0000 3.0000
0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 0.0000 /
0 'USRMDL' 0 'VWVAR6' 8 0 2 0 0 30 583126 '1' /
0 'USRMDL' 0 'VWLV6' 8 0 3 65 10 35 583126 '1' 1
0.9000 0.0010 0.1500 18.6316 74.5430 74.5430 74.5430
0.5000 1.0000 2.6200 0.9676 1.2000 0.5000 690.0000
903.3041 0.3500 0.0500 0.2500 0.0200 3.0000 4.0000
9999.0000 0.0232 0.9000 0.9000 0.0500 0.0000 0.0100
0.0000 2.0000 0.0000 1.0000 0.0000 0.0000 0.0000
0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 /
0 'USRMDL' 0 'VWPWR6' 8 0 3 30 7 10 583126 '1' 0
1.0000 0.5000 -0.5000 0.6988 0.8844 0.9800 0.9600
0.2000 0.2000 1.0000 1.0000 0.0000 0.0000 0.1000
0.1000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 /
0 'USRMDL' 0 'VWMEC6' 8 0 2 10 8 0 583126 '1'
2000.0000 422.2301 4736.7543 569.9822 106.4850 7976.7600 50.7400
0.0000 0.0000 0.0000 /
0 'USRMDL' 0 'VWMEA6' 8 0 2 10 8 5 583126 '1'
0.1000 0.1000 0.1000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 0.0000 /
0 'USRMDL' 0 'VWVPR6' 0 2 7 30 0 18 583126 '1' 1 1 0 0 0
0.8500 11.0000 0.8500 11.0000 0.9000 60.0000 1.1000
60.0000 1.1500 2.0000 1.2000 0.0800 1.2500 0.0050
1.2500 0.0050 0.0000 0.0000 0.0000 0.0000 0.0000
0.0000 0.0000 0.1500 0.8000 2.7000 0.8500 3.5000
0.9000 5.0000 /
0 'USRMDL' 0 'VWFPR6' 0 2 3 12 0 7 583126 '1' 0
56.4000 0.2000 56.4000 0.2000 56.4000 0.2000 63.6000
0.2000 63.6000 0.2000 63.6000 0.2000 /
/*****

```