



# Aggregate Facility Study SPP-2012-AG1-AFS-4

8/7/2013

SPP Engineering, SPP Transmission Service Studies



---

# Table of Contents

---

<b>Table of Contents .....</b>	<b>1</b>
<b>Executive Summary .....</b>	<b>2</b>
<b>Introduction.....</b>	<b>3</b>
<b>Financial Analysis .....</b>	<b>5</b>
<b>Third-Party Facilities .....</b>	<b>6</b>
<b>Study Methodology .....</b>	<b>6</b>
Description.....	6
Model Development.....	7
Transmission Request Modeling.....	8
Transfer Analysis .....	8
Curtailment and Redispatch Evaluation.....	8
<b>Study Results .....</b>	<b>9</b>
Study Analysis Results .....	9
Example A:.....	10
Example B:.....	10
Example C:.....	11
Study Definitions .....	11
<b>Conclusion .....</b>	<b>12</b>
<b>Appendix A .....</b>	<b>13</b>
BASE CASE SETTINGS: .....	13
ACCC CASE SETTINGS:.....	13
<b>Appendix B .....</b>	<b>14</b>
Common Acronyms: .....	14
Customer Acronyms: .....	14
Customer Acronyms (Continued): .....	15

## Executive Summary

---

Pursuant to Attachment Z1 of the Southwest Power Pool, Inc. (SPP) Open Access Transmission Tariff (OATT), 2,834 MW of long-term transmission service requests have been studied in this Aggregate Facility Study (AFS). The principal objective of the AFS is to identify system problems and potential modifications necessary to facilitate these transfers while maintaining or improving system reliability, as well as summarizing the operating limits and determination of the financial characteristics associated with facility upgrades. A highly tangible benefit of studying transmission requests aggregately under the SPP OATT Attachment Z1 is the sharing of costs among Transmission Customers using the same facility. Facility upgrade costs are allocated on a prorated basis to all requests positively impacting any individual overloaded facility.

Attachment Z2 further provides for facility upgrade cost recovery by stating: “Transmission Customers paying Directly Assigned Upgrade Costs for Service Upgrades or that are in excess of the Safe Harbor Cost Limit for Network Upgrades associated with new or changed Designated Resources and Project Sponsors paying Directly Assigned Upgrade Costs for Sponsored Upgrades shall receive revenue credits in accordance with Attachment Z2. Generation Interconnection Customers paying for Network Upgrades shall receive credits for new transmission service using the facility as specified in Attachment Z1.”

- The AFS determined that the total assigned facility upgrade Engineering and Construction (E&C) cost is \$26.6 million. Additionally, \$8.7 million of assigned E&C cost for third party facility upgrades are assignable to the customer.
- Total upgrade levelized revenue requirements for all transmission requests after consideration of potential base plan funding is \$9.1 million.

To accommodate the requested SPP Transmission Service, third-party facilities must be upgraded when the third-party transmission provider determines that they are constrained. Third-party facilities include both first-tier neighboring facilities outside SPP and Transmission Owner facilities within SPP that are not under the SPP OATT. In this AFS, third-party facilities were identified. Total E&C cost estimates for required third-party facility upgrades are applicable.

SPP will tender a Letter of Intent on August 7, 2013. This will open a 15-day window for Customer response. To remain in the Aggregate Transmission Service Study (ATSS), SPP must receive from the Customer by August 22, 2013, an executed Letter of Intent. The Letter of Intent will list options the Customer must choose to clarify their commitment to remain in the ATSS. The only action required on OASIS is to withdraw the request or leave the request in study mode.

At the conclusion of the ATSS, Service Agreements for each request for service will be tendered identifying the terms and conditions of the confirmed service.

If Customers withdraw from the ATSS after posting of this AFS, the AFS will be re-performed to determine final cost allocation and Available Transmission Capability (ATC) in consideration of the remaining ATSS participants. All allocated revenue requirements for facility upgrades are assigned

to the Customer in the AFS data tables. Potential base plan funding allowable is contingent upon validation of designated resources meeting Attachment J, Section III B criteria.

---

## Introduction

---

Important milestones and dates in SPP's Aggregate Transmission Study process:

- In 2005, the Federal Energy Regulatory Commission (FERC) accepted SPP's proposed Aggregate Transmission Study procedures in Docket ER05-109.
- In 2008, in Docket ER08-1379-000 SPP filed with FERC to pair open seasons closing during January 2010 with an effective date of August 9, 2008.
- In January 2010, in Docket ER10-659-000 SPP filed with FERC to extend its current practice of pairing open seasons through January 31, 2011, with an effective date of January 28, 2010.
- In March 2010, in Docket ER10-659-000 FERC issued a letter order accepting SPP's proposal to continue to pair open seasons through January 31, 2011, effective January 28, 2010.
- All requests for long-term transmission service with a signed study agreement received before January 1, 2012 for 2012-AG1 have been included in this first Aggregate Transmission Service Study (ATSS) of 2012.

Approximately 2,834 MW of long-term Transmission Service was studied in this Aggregate Facility Study (AFS), and over \$26.6 million in transmission upgrades is proposed. The results of the AFS are detailed in Tables 1 through 6. Detailed results depict individual upgrade costs by study and potential base plan allowances determined by Attachments J and Z1. The [OATT](#) may be accessed at SPP's website by going to [SPP.org](http://SPP.org)>Org Groups>Governing Documents.

To understand the extent to which Base Plan Upgrades may be applied to both Point-to-Point (PTP) and Network Transmission Services, it is necessary to highlight the definition of Designated Resource. Per Section 1.9a of the SPP OATT, a Designated Resource is:

“[a]ny designated generation resource owned, purchased or leased by a Transmission Customer to serve load in the SPP Region. Designated Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Transmission Customer's load on a non-interruptible basis.”

Network and PTP service has potential for base plan funding if the conditions for classifying upgrades associated with designated resources as Base Plan Upgrades as defined in Section III.B of Attachment J are met.

Pursuant to Attachment J, Section III B of the SPP OATT, the Transmission Customer must provide SPP information necessary to verify that the new or changed Designated Resource meets the following conditions:

1. Transmission Customer's commitment to the requested new or changed Designated Resource must have a duration of at least five years.
2. During the first year the Designated Resource is planned to be used by the Transmission Customer, the accredited capacity of the Transmission Customer's existing Designated Resources plus the lesser of:
  - a. The planned maximum net dependable capacity applicable to the Transmission Customer or
  - b. The requested capacity; shall not exceed 125% of the Transmission Customer's projected system peak responsibility determined pursuant to SPP Criteria 2.

According to Attachment Z1 Section VI.A, PTP customers pay the higher of the monthly transmission access charge (base rate) or the monthly revenue requirement associated with the assigned facility upgrades, including any prepayments for redispatch required during construction.

Network Integration Service Customers pay the total monthly transmission access charges and the monthly revenue requirement associated with the facility upgrades, including any prepayments for redispatch during construction.

Transmission Customers paying for a directly assigned Network Upgrade shall receive credits for new transmission service using the facility as specified in Attachment Z2.

Facilities identified as limiting the requested Transmission Service have been reviewed to determine the required in-service date of each Network Upgrade. The year that each Network Upgrade is required to accommodate a request is determined by interpolating between the applicable model years given the respective loading data. Both previously assigned facilities and the facilities assigned to this request for Transmission Service were evaluated.

In some instances, due to lead times for engineering and construction, Network Upgrades may not be available when required to accommodate a request for Transmission Service. When this occurs, the ATC with available Network Upgrades will be less than the capacity requested during either a portion of or all of the requested reservation period. As a result, the lowest seasonal allocated ATC within the requested reservation period will be offered to the Transmission Customer on an applicable annual basis as listed in Table 1. The ATC may be limited by transmission owner planned projects, expansion plan projects, or Customer assigned upgrades.

Some constraints identified in the AFS were not assigned to the Customer because SPP, the Transmission Provider, determined that upgrades are not required due to various reasons or the Transmission Owner has construction plans pending for these upgrades. These facilities are listed by reservation in Table 3. This table also includes constrained facilities in the current planning horizon that limit the rollover rights of the Transmission Customer. Table 6 lists possible redispatch pairs to allow start of service prior to completion of assigned Network Upgrades. Table 7 (if applicable) lists

deferment of expansion plan projects with different upgrades with the new required in service date as a result of this AFS.

---

## Financial Analysis

---

The AFS utilizes the allocated Customer's E&C cost in a present worth analysis to determine the monthly levelized revenue requirement of each facility upgrade over the term of the reservation. In some cases, Network Upgrades cannot be completed within the requested reservation period, thus deferred reservation periods will be utilized in the present worth analysis. If the Customer chose Option 2, Redispatch, in the Letter of Intent sent coincident with the initial AFS, the present worth analysis of revenue requirements will be based on the deferred term with redispatch in the subsequent AFS. The upgrade levelized revenue requirement includes interest, depreciation, and carrying costs.

Each request for Transmission Service is evaluated independently as the cost associated with each Network Upgrade is assigned to a request. When facilities are upgraded throughout the reservation period, the Transmission Customer shall 1) pay the total E&C costs and other annual operating costs associated with the new facilities, and 2) receive credits associated with the depreciated book value of removed usable facilities; salvage value of removed non-usable facilities; and the carrying charges, excluding depreciation, associated with all removed usable facilities based on their respective book values.

In the event that the engineering and construction of a previously assigned Network Upgrade may be accelerated, with no additional upgrades, to accommodate a new request for Transmission Service, the levelized present worth of only the incremental expenses through the reservation period of the new request, excluding depreciation, shall be assigned to the new request. These incremental expenses, excluding depreciation, include:

1. The levelized difference in present worth of the engineering and construction expenses given the change in date to complete construction to account for additional interest expense and reduced engineering and construction expense due to inflation,
2. The levelized present worth of all expediting fees, and
3. The levelized present worth of the incremental annual carrying charges, excluding depreciation and interest, during the new reservation period taking into account both:
  - a. The reservation in which the project was originally assigned, and
  - b. A reservation, if any, in which the project was previously accelerated.

In the case of a Base Plan Upgrade being displaced or deferred by an earlier in service date for a requested upgrade, achievable base plan avoided revenue requirements shall be determined per Attachment J, Section VII.B methodology. A deferred Base Plan Upgrade is defined as a different requested Network Upgrade needed at an earlier date that negates the need for the initial Base Plan

Upgrade within the planning horizon. A displaced Base Plan Upgrade is defined as the same Network Upgrade being displaced by a requested upgrade needed at an earlier date.

A 40-year service life assumption is utilized for Base Plan funded projects, unless another assumption is provided by the Transmission Owner. A present worth analysis of revenue requirements on a common year basis between the Base Plan and Requested Upgrades was performed to determine avoided Base Plan revenue requirements due to the displacement or deferral of the Base Plan Upgrade by the Requested Upgrade. The difference in present worth between the Base Plan and Requested Upgrades is assigned to the transmission requests impacting this upgrade based on the displacement or deferral.

---

## Third-Party Facilities

---

For third-party facilities listed in Table 3 and Table 5, the Transmission Customer is responsible for funding the necessary upgrades of these facilities per Section 21.1 of the Transmission Provider's OATT. In this AFS, third-party facilities were identified. Total E&C cost estimates for required third-party facility upgrades are applicable. The Transmission Provider will undertake reasonable efforts to assist the Transmission Customer in making arrangements for necessary engineering, permitting, and construction of the third-party facilities. Third-party facility upgrade E&C cost estimates are not utilized to determine the present worth value of levelized revenue requirements for SPP system Network Upgrades.

All modeled facilities within the Transmission Provider system were monitored during the development of this study, as well as certain facilities in first-tier neighboring systems. Third-party facilities must be upgraded when it is determined that they are overloaded while accommodating the requested Transmission Service. An agreement between the Customer and third party owner detailing the mitigation of the third party impact must be provided to the Transmission Provider prior to tendering of a Transmission Service Agreement. These facilities also include those owned by members of the Transmission Provider who have not placed their facilities under the Transmission Provider's OATT. Upgrades on the Southwest Power Administration network requires prepayment of the upgrade cost prior to construction of the upgrade.

Third-party facilities are evaluated for only those requests whose load sinks within the SPP footprint. The Customer must arrange for study of third party facilities for load that sinks outside the SPP footprint with the applicable Transmission Providers.

---

## Study Methodology

---

### **Description**

The facility study analysis was conducted to determine the steady-state impact of the requested service on the SPP and first tier non-SPP control area systems. The steady-state analysis was performed to ensure current SPP Criteria and NERC Reliability Standards requirements are fulfilled.

SPP conforms to NERC Reliability Standards, which provide strict requirements related to voltage violations and thermal overloads during normal conditions and during a contingency. NERC Standards require all facilities to be within normal operating ratings for normal system conditions and within emergency ratings after a contingency.

Normal operating ratings and emergency operating ratings monitored are Rate A and B in the SPP Model Development Working Group (MDWG) models, respectively. The upper bound and lower bound of the normal voltage range monitored is 105% and 95%. The upper bound and lower bound of the emergency voltage range monitored is 105% and 90%. Transmission Owner voltage monitoring criteria is used if more restrictive. The SPS Tuco 230 kV bus voltage is monitored at 92.5% due to pre-determined system stability limitations. The WERE Wolf Creek 345 kV bus voltage is monitored at 103.5% and 98.5% due to transmission operating procedure.

The contingency set includes all SPP control area branches and ties 69 kV and above; first tier non-SPP control area branches and ties 115 kV and above; any defined contingencies for these control areas; and generation unit outages for the control areas with SPP reserve share program redispatch. The monitor elements include all SPP control area branches, ties, and buses 69 kV and above, and all first tier non-SPP control area branches and ties 115 kV and above. Voltage monitoring was performed for SPP control area buses 69 kV and above.

A 3 % transfer distribution factor (TDF) cutoff was applied to all SPP control area facilities. For first tier non-SPP control area facilities, a 3 % TDF cutoff was applied to AECI, AMRN (Ameren), and ENTR (Entergy) control areas. A 2 % TDF cutoff was applied to WAPA. For voltage monitoring, a 0.02 per unit change in voltage must occur due to the transfer or modeling upgrades to be considered a valid limit to the transfer.

## **Model Development**

SPP used seven seasonal models to study the aggregate transfers of 2,834 MW over a variety of requested service periods. The following SPP Transmission Expansion Plan 2012 Build 1 Cases were used to study the impact of the requested service on the transmission system:

- 2013/14 Winter Peak (13WP)
- 2014 Summer Peak (14SP)
- 2014/15 Winter Peak (14WP)
- 2018 Summer Peak (18SP)
- 2018/19 Winter Peak (18WP)
- 2023 Summer Peak (23SP)
- 2023/24 Winter Peak (23WP)

The Summer Peak models apply to June through September and the Winter Peak models apply to December through March.

The chosen base case models were modified to reflect the current modeling information. One group of requests was developed from the aggregate of 2,834 MW to model the requested service. From the seven seasonal models, two system scenarios were developed. Scenario 0 includes projected usage of transmission included in the SPP 2012 Series Cases. Scenario 5 includes transmission service not already included in the SPP 2012 Series Cases.



## **Transmission Request Modeling**

Network Integration Transmission Service requests are modeled as Generation to Load transfers in addition to Generation to Generation transfers. Network Integration Transmission Service requests are modeled as Generation to Load transfers in addition to Generation to Generation because the requested Network Integration Transmission Service is a request to serve network load with the new designated network resource, and the impacts on Transmission System are determined accordingly. Point-To-Point Transmission Service requests are modeled as Generation to Generation transfers. Generation to Generation transfers are accomplished by developing a post-transfer case for comparison by dispatching the request source and redispatching the request sink.

## **Transfer Analysis**

Using the selected cases both with and without the requested transfers modeled, the PSS/E Activity ACCC was run on the cases and compared to determine the facility overloads caused or impacted by the transfer. Transfer distribution factor cutoffs (SPP and 1<sup>st</sup>-Tier) and voltage threshold (0.02 change) were applied to determine the impacted facilities. The PSS/E options chosen to conduct the analysis can be found in Appendix A.

## **Curtailement and Redispatch Evaluation**

During any period in which SPP determines that a transmission constraint exists on and may impair Transmission System reliability, SPP will take whatever actions are reasonably necessary to maintain reliability. If SPP determines Transmission System reliability can be maintained by redispatching resources, it will evaluate the interim curtailement of existing confirmed service or interim redispatch of units to provide service prior to completion of any assigned Network Upgrades. Any redispatch may not unduly discriminate between the Transmission Owners' use of the Transmission System on behalf of their Native Load Customers and any Transmission Customer's use of the Transmission System to serve its designated load. Redispatch was evaluated to provide only interim service during the time frame prior to completion of any assigned Network Upgrades. Curtailement of existing confirmed service is evaluated to provide only interim service. Curtailement of existing confirmed service is only evaluated at the request of the transmission Customer.

SPP determined potential relief pairs to relieve the incremental MW impact on limiting facilities as identified in Table 6. Using the selected cases where the limiting facilities were identified, potential incremental and decremental units were identified by determining the generation amount available for increasing and decreasing from the units generation amount, maximum generation amount, and minimum generation amount. If the incremental or decremental amount was greater than 1 MW, the unit was considered as a potential incremental or decremental unit.

Generation shift factors were calculated for the potential incremental and decremental units using Managing and Utilizing System Transmission (MUST). Relief pairs from the generation shift factors for the incremental and decremental units with a greater than 3% TDF on the limiting constraint were determined from the incremental units with the lowest generation shift factors and decremental units with highest generation shift factors. If the aggregate redispatch amount for the potential relief pair was determined to be three times greater than the lower of the increment or decrement, then the pair was determined not to be feasible and is not included. Transmission Customers can request SPP

to provide additional relief pairs beyond those determined. The potential relief pairs were not evaluated to determine impacts on limiting facilities in the SPP and first tier systems. The SPP Reliability Coordinator would call upon the redispatch requirements before implementing NERC TLR Level 5a.

---

## Study Results

---

### **Study Analysis Results**

Tables 1 through 6 contain the AFS steady-state analysis results. Table 1 identifies the participating long-term Transmission Service requests included in the AFS. This table lists deferred start and stop dates both with and without redispatch (based on Customer selection of redispatch if available) and the minimum annual allocated ATC without upgrades and season of first impact.

Table 2 identifies total E&C cost allocated to each Transmission Customer, letter of credit requirements, third party E&C cost assignments, potential base plan E&C funding (lower of allocated E&C or Attachment J Section III B criteria), total revenue requirements for assigned upgrades without consideration of potential base plan funding, point-to-point base rate charge, total revenue requirements for assigned upgrades with consideration of potential base plan funding, and final total cost allocation to the Transmission Customer. In addition, Table 2 identifies SWPA upgrade costs which require prepayment in addition to other allocated costs.

Table 3 provides additional details for each request including all assigned facility upgrades required, allocated E&C costs, allocated revenue requirements for upgrades, upgrades not assigned to the Customer but required for service to be confirmed, credits to be paid for previously assigned AFS or Generation Interconnection Network Upgrades, and any required third party upgrades.

Table 4 lists all upgrade requirements with associated solutions needed to provide Transmission Service for the AFS, minimum ATC per upgrade with season of impact, earliest date upgrade is required (DUN), estimated date the upgrade will be completed, in service (EOC), and estimated E&C cost.

Table 5 lists identified third-party constrained facilities.

Table 6 identifies potential redispatch pairs available to relieve the aggregate impacts on identified constraints to prevent deferral of start of service.

Table 7 (if applicable) identifies deferred expansion plan projects that were replaced with requested upgrades at earlier dates.

The potential base plan funding allowable is contingent on meeting each of the conditions for classifying upgrades associated with designated resources as Base Plan Upgrades as defined in Section III.B of Attachment J. If the additional capacity of the new or changed Designated Resource exceeds the 125% resource to load forecast for the year of start of service, the requested resource is not eligible for base plan funding of required Network Upgrades and the full cost of the upgrades is assignable to the Customer.

If the request is for wind generation, the total requested capacity of wind generation plus existing wind generation capacity shall not exceed 20% of the customer's projected system peak responsibility in the first year the Designated Resource is planned to be used by the customer. If the five-year term and 125% resource to load criteria are met, (as well as the 20% wind resource to load criteria for wind generation requests) the requested capacity is multiplied by \$180,000 to determine the potential base plan funding allowable. The maximum potential base plan funding allowable may be less than the potential base plan funding allowable, due to the E&C cost allocated to the customer being lower than the potential amount allowable to the Customer. The Customer is responsible for any assigned upgrade costs in excess of potential base plan E&C funding allowable. Network Upgrades required for wind generation requests located in a zone other than the Customer POD shall be allocated as 67% base plan region-wide charge and 33% directly assigned to the Customer.

Regarding application of base plan funding for PTP requests, if PTP base rate exceeds upgrade revenue requirements without taking into effect the reduction of revenue requirements by potential base plan funding, then the base rate revenue pays back the Transmission Owner for upgrades and no base plan funding is applicable as the access charge must be paid as it is the higher of "OR" pricing.

However, if initially the upgrade revenue requirements exceed the PTP base rate, then potential base plan funding would be applicable. The test of the higher of "OR" pricing would then be made against the remaining assignable revenue requirements versus PTP base rate. Examples are as follows:

**Example A:**

E&C allocated for upgrades is \$74 million with revenue requirements of \$140 million and PTP base rate of \$101 million. Potential base plan funding is \$47 million, with the difference of \$27 million E&C assignable to the Customer. If the revenue requirements for the assignable portion is \$54 million and the PTP base rate is \$101 million, the Customer will pay the higher amount (so-called "or pricing") of \$101 million base rate of which \$54 million revenue requirements will be paid back to the Transmission Owners for the upgrades, and the remaining revenue requirements of \$86 million (\$140 million less \$54 million) will be paid by base plan funding.

**Example B:**

E&C allocated for upgrades is \$74 million with revenue requirements of \$140 million and PTP base rate of \$101 million. Potential base plan funding is \$10 million with the difference of \$64 million E&C assignable to the Customer. If the revenue requirements for this assignable portion is \$128 million and the PTP base rate is \$101 million, the Customer will pay the higher amount of \$128 million revenue requirements to be paid back to the Transmission Owners, and the remaining revenue requirements of \$12 million (\$140 million less \$128 million) will be paid by base plan funding.

### **Example C:**

E&C allocated for upgrades is \$25 million with revenue requirements of \$50 million and PTP base rate of \$101 million. Potential base plan funding is \$10 million. Base plan funding is not applicable as the higher amount of PTP base rate of \$101 million must be paid and the \$50 million revenue requirements will be paid from this.

The 125% resource to load determination is performed on a per request basis and is not based on a total of Designated Resource requests per Customer. A footnote will provide the maximum resource designation allowable for base plan funding consideration per Customer basis per year.

Base plan funding verification requires that each Transmission Customer with potential for base plan funding provide SPP attestation statements verifying that the firm capacity of the requested Designated Resource is committed for a minimum five year duration.

### **Study Definitions**

- The date upgrade needed date (DUN) is the earliest date the upgrade is required to alleviate a constraint considering all requests.
- End of construction (EOC) is the estimated date the upgrade will be completed and in service.
- Total engineering and construction cost (E&C) is the upgrade solution cost as determined by the Transmission Owner.
- The Transmission Customer's allocation of the E&C cost is based on the request (1) having an impact of at least 3% on the limiting element, and (2) having a positive impact on the upgraded facility.
- Minimum ATC is the portion of the requested capacity that can be accommodated without upgrading facilities.
- Annual ATC allocated to the Transmission Customer is determined by the least amount of allocated seasonal ATC within each year of a reservation period.

---

## Conclusion

---

The results of the AFS show that limiting constraints exist in many areas of the regional Transmission System. Due to these constraints, Transmission Service cannot be granted unless noted in Table 3.

The Transmission Provider will tender a Letter of Intent on August 7, 2013. This will open a 15-day window for Customer response. To remain in the Aggregate Transmission Service Study (ATSS), the Transmission Provider must receive from the Transmission Customer) by August 22, 2013, an executed Letter of Intent. The Letter of Intent will list options the Customer must choose to clarify their commitment to remain in the ATSS. The only action required on OASIS is to WITHDRAW the request or leave the request in STUDY mode.

The Transmission Provider must receive an unconditional and irrevocable letter of credit in the amount of the total allocated E&C costs assigned to the Customer. This letter of credit is not required for those facilities that are fully base plan funded. The amount of the letter of credit will be adjusted down on an annual basis to reflect cost recovery based on revenue allocation. The Transmission Provider will issue notifications to construct Network Upgrades to the constructing Transmission Owner after filing of necessary service agreements at FERC.

---

## Appendix A

---

### PSS/E CHOICES IN RUNNING LOAD FLOW PROGRAM AND ACCC

#### BASE CASE SETTINGS:

- Solutions: Fixed slope decoupled Newton-Raphson solution (FDNS)
- Tap adjustment: Stepping
- Area Interchange Control: Tie lines and loads
- Var limits: Apply immediately
- Solution Options:
  - Phase shift adjustment
  - Flat start
  - Lock DC taps
  - Lock switched shunts

#### ACCC CASE SETTINGS:

- Solutions: AC contingency checking (ACCC)
- MW mismatch tolerance: 0.5
- System intact rating: Rate A
- Contingency case rating: Rate B
- Percent of rating: 100
- Output code: Summary
- Min flow change in overload report: 3mw
- Excl'd cases w/ no overloads from report: YES
- Exclude interfaces from report: NO
- Perform voltage limit check: YES
- Elements in available capacity table: 60000
- Cutoff threshold for available capacity table: 99999.0
- Min. contng. Case Vltg chng for report: 0.02
- Sorted output: None
- Newton Solution:
- Tap adjustment: Stepping
- Area interchange control: Tie lines and loads (Disabled for generator outages)
- Var limits: Apply immediately
- Solution options:
  - Phase shift adjustment
  - Flat start
  - Lock DC taps
  - Lock switched shunts

---

## Appendix B

---

### Common Acronyms:

• Southwest Power Pool Inc.	SPP
• Open Access Transmission Tariff	OATT
• Aggregate Facility Study	AFS
• Engineering and Construction	E&C
• Aggregate Transmission Service Study	ATSS
• Letter of Intent	LOI
• Available Transmission Capacity	ATC
• Federal Regulatory Service Commission	FERC
• Point-to-Point	PTP
• Model Development Working Group	MDWG
• Transfer Distribution Factor	TDF
• Managing and Utilizing System Transmission	MUST
• Date Upgrade Needed	DUN

### Customer Acronyms:

• AECC	Arkansas Electric Cooperative
• AECI	Associated Electric Cooperative
• AEPM	American Electric Power
• APM	Associated Electric Cooperative
• BCPE	British Columbia Power Exchange
• BPAE	BP Wind Energy North America Inc.
• CALP	Calpine Energy Services
• CCG	Constellation Energy Commodities Group
• CMPL	City of Coffeyville
• CRGL	Cargill Power Markets
• CWEP	Carthage Water and Electric Power
• EDE/EDM	The Empire District Electric Company
• ETEC	East Texas Electric Cooperative
• EXGN	Exelon Generation Company, LLC.
• FPLP	Nextera Energy Resources, LLC.
• GRDA	Grand River Dam Authority
• GSEC	Golden Spread Electric Cooperative
• HCPD	Heartland Consumers Power District
• HZN	Horizon Wind Energy
• INDP	City of Independence Power and Light

**Customer Acronyms (Continued):**

- INF Infinity Wind Power
- JUWI JW Prairie Wind Power, LLC.
- KBPU Kansas Board of Public Utilities
- KCPL/KCPS Kansas City Power & Light
- KEPCO Kansas Electric Power Cooperative
- KMEA Kansas Municipal Energy Agency
- KPP Kansas Power Pool
- LES Lincoln Electric System
- MEAN Municipal Entergy Agency of Nebraska
- MIDW Midwest Energy Inc.
- MKEC Mid Kansas Electric
- MOWR Missouri Joint Municipal Utility Commission
- NPPD Nebraska Public Power District
- NTEC North Texas Electric Cooperative
- OGE Oklahoma Gas and Electric Services
- OMPA Oklahoma Municipal Power District
- OPPD Omaha Public Power District
- PEC People's Electric Cooperative
- PPM PPM Energy
- PRBZ Invengery, LLC.
- PSCM Public Service Company of Colorado
- SEPC Sunflower Electric Power Cooperation
- SPRM City Utilities of Springfield
- SPS Southwestern Public Service Company
- SWE Southern Company
- SUNC Sunflower Electric Cooperative
- TEA The Energy Authority
- TEXTL Tex-La Electric Cooperative of Texas Inc.
- TNSK Tenaska Power Services Co.
- TVAM Tennessee Valley Authority
- UCU Aquila Inc.
- WERE Westar Energy
- WFEC Western Farmers Electric Cooperative
- WIND enXco
- WRGS Western Resources Generation Services
- EDPR EDP Renewables
- KVEC KAW Valley Electrical Cooperative
- CHAN City of Chanute
- NMEC Nemaha-Marshall Electric



**Table 1 - Long-Term Transmission Service Requests Included in Aggregate Facility Study**

Customer	Study Number	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date without interim redispatch	Deferred Stop Date without interim redispatch	Start Date with interim redispatch	Stop Date with interim redispatch	Minimum Allocated ATC (MW) within reservation period	Season of Minimum Allocated ATC within reservation period
AECC	2012-AG1-038	76585985	WR	CSWS	51	10/1/2012	10/1/2017	6/1/2018	6/1/2023	1/1/2014	1/1/2019	0	13SP
AECC	2012-AG1-040	76586012	WR	OKGE	51	7/1/2015	7/1/2020	6/1/2018	6/1/2023	7/1/2015	7/1/2020	0	23SP
APEM	2012-AG1-033	76584399	CSWS	CSWS	250	1/1/2016	1/1/2021	6/1/2016	6/1/2021	1/1/2016	1/1/2021	0	23SP
APEM	2012-AG1-034	76584402	CSWS	CSWS	250	1/1/2016	1/1/2021	6/1/2016	6/1/2021	1/1/2016	1/1/2021	0	23SP
APEM	2012-AG1-036	76584451	WR	CSWS	78	10/1/2012	1/1/2032	6/1/2018	9/1/2037	1/1/2014	4/1/2033	0	13SP
APEM	2012-AG1-037	76584464	SPS	CSWS	80	10/1/2012	1/1/2032	12/31/2018	3/31/2038	1/1/2014	4/1/2033	0	13SP
APEM	2012-AG1-042	76586559	OKGE	CSWS	101	10/1/2012	12/31/2032	1/1/2014	3/1/2034	1/1/2014	3/1/2034	0	13SP
APEM	2012-AG1-044	76586582	OKGE	CSWS	53	10/1/2012	12/31/2032	1/1/2014	3/1/2034	1/1/2014	3/1/2034	0	13SP
APEM	2012-AG1-046	76586592	OKGE	CSWS	48	10/1/2012	12/31/2032	1/1/2014	3/1/2034	1/1/2014	3/1/2034	0	13SP
CHAN	2012-AG1-028	76583997	KACY	WR	3	1/1/2014	1/1/2019	1/1/2014	1/1/2019	1/1/2014	1/1/2019	0	14SP
CHAN	2012-AG1-029	76583999	KCPL	WR	45	1/1/2014	1/1/2019	1/1/2014	1/1/2019	1/1/2014	1/1/2019	0	14SP
CHAN	2012-AG1-031	76584004	SPA	WR	1	1/1/2014	1/1/2019	1/1/2014	1/1/2019	1/1/2014	1/1/2019	0	14SP
CHAN	2012-AG1-032	76584010	WR	WR	121	1/1/2014	1/1/2019	1/1/2014	1/1/2019	1/1/2014	1/1/2019	0	14SP
CHAN	2012-AG1-050	76586685	NPPD	WR	2	1/1/2014	1/1/2019	1/1/2014	1/1/2019	1/1/2014	1/1/2019	0	14SP
CHAN	2012-AG1-052	76583977	WR	WR	115	1/1/2014	1/1/2019	1/1/2014	1/1/2019	1/1/2014	1/1/2019	0	14SP
CHAN	2012-AG1-053	76583984	GRDA	WR	2	1/1/2014	1/1/2019	1/1/2014	1/1/2019	1/1/2014	1/1/2019	0	14SP
CRGL	2012-AG1-001	76300099	CSWS	ERCOTN	207	1/1/2014	1/1/2024	12/31/2018	12/31/2028	1/1/2014	1/1/2024	0	14SP
CRGL	2012-AG1-002	76348872	ERCOTN	ERCOTN	207	2/1/2013	2/1/2018	1/1/2014	1/1/2019	1/1/2014	1/1/2019	0	13SP
CRGL	2012-AG1-025	76583812	WPEK	EES	200	1/1/2014	1/1/2024	6/1/2018	6/1/2028	1/1/2015	1/1/2025	0	14SP
CRGL	2012-AG1-026	76583814	WPEK	EES	200	1/1/2014	1/1/2024	6/1/2018	6/1/2028	1/1/2015	1/1/2025	0	14SP
CRGL	2012-AG1-027	76583815	WPEK	EES	100	1/1/2014	1/1/2024	6/1/2018	6/1/2028	1/1/2015	1/1/2025	0	14SP
KMEA	2012-AG1-007	76553455	NPPD	WR	3	2/1/2013	4/1/2025	1/1/2014	3/1/2026	1/1/2014	3/1/2026	0	13SP
KMEA	2012-AG1-012	76580367	NPPD	WR	1	5/1/2013	4/30/2025	1/1/2014	1/1/2026	1/1/2014	1/1/2026	0	13SP
KMEA	2012-AG1-013	76580375	GRDA	WR	3	5/1/2013	5/1/2026	1/1/2014	1/1/2027	1/1/2014	1/1/2027	0	13SP
KMEA	2012-AG1-014	76580381	KACY	WR	4	10/1/2013	6/1/2022	1/1/2014	9/1/2022	1/1/2014	9/1/2022	0	14SP
KMEA	2012-AG1-015	76580392	SPA	WR	1	5/1/2013	1/1/2019	1/1/2014	9/1/2019	1/1/2014	9/1/2019	0	13SP
KMEA	2012-AG1-016	76580395	WR	WR	5	5/1/2013	1/1/2019	6/1/2018	2/1/2024	1/1/2014	9/1/2019	0	13SP
KMEA	2012-AG1-017	76580515	SPA	WR	1	1/1/2014	1/1/2019	1/1/2014	1/1/2019	1/1/2014	1/1/2019	0	14SP
KMEA	2012-AG1-018	76580552	NPPD	WR	1	1/1/2014	5/1/2025	1/1/2014	5/1/2025	1/1/2014	5/1/2025	0	14SP
KMEA	2012-AG1-019	76582326	WR	WR	41	5/1/2013	5/1/2026	1/1/2014	1/1/2027	1/1/2014	1/1/2027	0	13SP
KMEA	2012-AG1-022	76583607	WR	WR	21	1/1/2014	5/1/2026	1/1/2014	5/1/2026	1/1/2014	5/1/2026	0	14SP
KMEA	2012-AG1-023	76583617	GRDA	WR	5	1/1/2014	5/1/2026	1/1/2014	5/1/2026	1/1/2014	5/1/2026	0	14SP
KMEA	2012-AG1-024	76583629	WR	WR	4	1/1/2014	1/1/2019	1/1/2014	1/1/2019	1/1/2014	1/1/2019	0	14SP
KMEA	2012-AG1-048	76586675	KCPL	WR	15	6/1/2013	6/1/2023	6/1/2018	6/1/2028	1/1/2014	1/1/2024	0	13SP
KMEA	2012-AG1-049	76586679	WR	WR	15	6/1/2013	6/1/2023	1/1/2014	1/1/2024	1/1/2014	1/1/2024	0	13SP
KMEA	2012-AG1-051	76586961	NPPD	WR	1	6/1/2013	5/1/2025	1/1/2014	12/1/2025	1/1/2014	12/1/2025	0	13SP
OGE	2012-AG1-008	76571379	OKGE	OKGE	60	12/19/2012	12/19/2032	6/1/2015	6/1/2035	1/1/2014	1/1/2034	0	13SP
PSCM	2012-AG1-021	76582673	SPS	LAM345	208	3/1/2013	3/1/2018	6/1/2017	6/1/2022	Note 4	Note 4	0	13SP
WFEC	2012-AG1-004	76548687	CSWS	WFEC	160	6/1/2014	12/31/2035	6/1/2014	12/1/2035	6/1/2014	12/1/2035	0	14SP
WFEC	2012-AG1-005	76548692	CSWS	WFEC	90	6/1/2017	12/31/2035	6/1/2017	12/1/2035	6/1/2017	12/1/2035	0	23SP
WFEC	2012-AG1-006	76548702	CSWS	WFEC	30	6/1/2019	12/31/2035	6/1/2019	12/1/2035	6/1/2019	12/1/2035	0	23SP

**Table 1 - Long-Term Transmission Service Requests Included in Aggregate Facility Study**

Customer	Study Number	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date without interim redispatch	Deferred Stop Date without interim redispatch	Start Date with interim redispatch	Stop Date with interim redispatch	Minimum Allocated ATC (MW) within reservation period	Season of Minimum Allocated ATC within reservation period
					2834								

**Note 1:** Start and Stop Dates with interim redispatch are determined based on customers choosing option to pursue redispatch to start service at Requested Start and Stop Dates or earliest date possible.

**Note 2:** Start dates with and without redispatch are based on the assumed completion dates of previous Aggregate Transmission Service Studies currently being conducted. Actual start dates may differ from the potential start dates upon completion of the previous studies.

**Note 3:** Request is unable to be deferred due to fixed stop dates.

**Note 4:** Transmission customer did not select "remain in the study using interim redispatch" option.

**Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests**

Customer	Study Number	Reservation	Engineering and Construction Cost of Upgrades Allocated to Customer for Revenue Requirements	<sup>1</sup> Letter of Credit Amount Required	<sup>2</sup> Potential Base Plan Engineering and Construction Funding Allowable	Notes	<sup>4</sup> Additional Engineering and Construction Cost for 3rd Party Upgrades	<sup>3,5</sup> Total Revenue Requirements for Assigned Upgrades Over Term of Reservation WITH Potential Base Plan Funding Allocation	Point-to-Point Base Rate Over Reservation Period	<sup>4</sup> Total Cost of Reservation Assignable to Customer Contingent Upon Base Plan Funding
AEC	2012-AG1-038	76585985	\$ 3,032	\$ -	\$ 3,032			\$ -	\$ -	Schedule 9 & 11 Charges
AEC	2012-AG1-040	76586012	\$ -	\$ -	\$ -			\$ -	\$ -	Schedule 9 & 11 Charges
AEP	2012-AG1-033	76584399	\$ 3,901,489	\$ -	\$ 3,901,489		\$ 2,523,362	\$ -	\$ -	Schedule 9 & 11 Charges
AEP	2012-AG1-034	76584402	\$ 9,219,526	\$ -	\$ 9,219,526		\$ 2,567,569	\$ -	\$ -	Schedule 9 & 11 Charges
AEP	2012-AG1-036	76584451	\$ 350,801	\$ 37,776	\$ 313,025		\$ -	\$ 95,777	\$ -	\$ 95,777
AEP	2012-AG1-037	76584464	\$ 678,737	\$ 18,900	\$ 659,837		\$ -	\$ 47,919	\$ -	\$ 47,919
AEP	2012-AG1-042	76586559	\$ 965,795	\$ -	\$ 965,795		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
AEP	2012-AG1-044	76586582	\$ 506,803	\$ -	\$ 506,803		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
AEP	2012-AG1-046	76586592	\$ 458,991	\$ -	\$ 458,991		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
CHAN	2012-AG1-028	76583997	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
CHAN	2012-AG1-029	76583999	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
CHAN	2012-AG1-031	76584004	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
CHAN	2012-AG1-032	76584010	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
CHAN	2012-AG1-050	76586685	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
CHAN	2012-AG1-052	76583977	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
CHAN	2012-AG1-053	76583984	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
CRGL	2012-AG1-001	76300099	\$ -	\$ -	\$ -	6	\$ -	\$ -	\$ 54,686,005	\$ 54,686,000
CRGL	2012-AG1-002	76348872	\$ -	\$ -	\$ -	7	\$ -	\$ -	\$ 27,343,003	\$ 27,343,000
CRGL	2012-AG1-025	76583812	\$ 1,584,488	\$ 1,584,488	\$ -		\$ 89,870	\$ 3,571,492	\$ 30,720,000	\$ 30,720,000
CRGL	2012-AG1-026	76583814	\$ 1,584,488	\$ 1,584,488	\$ -		\$ 89,870	\$ 3,571,492	\$ 30,720,000	\$ 30,720,000
CRGL	2012-AG1-027	76583815	\$ 792,245	\$ 792,245	\$ -		\$ 44,935	\$ 1,785,748	\$ 15,360,000	\$ 15,360,000
KMEA	2012-AG1-007	76553455	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-012	76580367	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-013	76580375	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-014	76580381	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-015	76580392	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-016	76580395	\$ 29,783	\$ 29,783	\$ -		\$ -	\$ 49,396	\$ -	\$ 49,396
KMEA	2012-AG1-017	76580515	\$ -	\$ -	\$ -		\$ 326	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-018	76580552	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-019	76582326	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-022	76583607	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-023	76583617	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-024	76583629	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-048	76586675	\$ -	\$ -	\$ -		\$ 70,000	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-049	76586679	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-051	76586961	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
OGE	2012-AG1-008	76571379	\$ 2,470,000	\$ -	\$ 2,470,000		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
PSCM	2012-AG1-021	76582673	\$ -	\$ -	\$ -		\$ -	\$ -	\$ 23,137,920	\$ 23,137,920
WFEC	2012-AG1-004	76548687	\$ 2,335,949	\$ -	\$ 2,335,949		\$ 1,890,896	\$ -	\$ -	Schedule 9 & 11 Charges
WFEC	2012-AG1-005	76548692	\$ 1,313,971	\$ -	\$ 1,313,971		\$ 1,063,629	\$ -	\$ -	Schedule 9 & 11 Charges
WFEC	2012-AG1-006	76548702	\$ 437,990	\$ -	\$ 437,990		\$ 354,543	\$ -	\$ -	Schedule 9 & 11 Charges

**Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests**

Customer	Study Number	Reservation	Engineering and Construction Cost of Upgrades Allocated to Customer for Revenue Requirements	<sup>1</sup> Letter of Credit Amount Required	<sup>2</sup> Potential Base Plan Engineering and Construction Funding Allowable	Notes	<sup>4</sup> Additional Engineering and Construction Cost for 3rd Party Upgrades	<sup>3,5</sup> Total Revenue Requirements for Assigned Upgrades Over Term of Reservation WITH Potential Base Plan Funding Allocation	Point-to-Point Base Rate Over Reservation Period	<sup>4</sup> Total Cost of Reservation Assignable to Customer Contingent Upon Base Plan Funding
<b>Grand Total</b>			\$ 26,634,088		\$ 22,586,408		\$ 8,695,000	\$ 9,121,824		
<p><b>Note 1:</b> Letter of Credit required for financial security for transmission owner for network upgrades is determined by allocated engineering and construction costs less engineering and construction costs for upgrades when network customer is the transmission owner less the E &amp; C allocation of expedited projects. Letter of Credit is required for upgrades assigned to PTP requests. The amount of the letter of credit will be adjusted down on an annual basis to reflect cost recovery based on revenue allocation. This letter of credit is not required for those facilities that are fully base plan funded. The Letter Of Credit Amount listed is based on meeting OATT Attachment J requirements for base plan funding.</p> <p><b>Note 2:</b> If potential base plan funding is applicable, this value is the lesser of the Engineering and Construction costs of assignable upgrades or the value of base plan funding calculated pursuant to Attachment J, Section III B criteria. Allocation of base plan funding is contingent upon verification of customer agreements meeting Attachment J, Section II B criteria. Not applicable if Point-to-Point base rate exceeds revenue requirements.</p> <p><b>Note 3:</b> Revenue Requirements (RR) are based upon deferred end dates if applicable. Deferred dates are based upon customer's choice to pursue redispatch. Achievable Base Plan Avoided RR in the case of a Base Plan upgrade being displaced or deferred by an earlier in service date for a Requested Upgrade shall be determined per Attachment J, Section VII.C methodology. Assumption of a 40 year service life is utilized for Base Plan funded projects. A present worth analysis of RR on a common year basis between the Base Plan and Requested Upgrades was performed to determine avoided Base Plan RR due to the displacement or deferral of the Base Plan upgrade by the Requested Upgrade. The incremental increase in present worth of a Requested Upgrade on a common year basis as a Base Plan upgrade is assigned to the transmission requests impacting the upgrade based on the displacement or deferral. If the displacement analysis results in lower RR due to the shorter amortization period of the requested upgrade when compared to a base plan amortization period, then no direct assignment of the upgrade cost is made due to the displacement to an earlier start date.</p> <p><b>Note 4:</b> For Point-to-Point requests, total cost is based on the higher of the base rate or assigned upgrade revenue requirements. For Network requests, the total cost is based on the assigned upgrade revenue requirement. Allocation of base plan funding will be determined after verification of designated resource meeting Attachment J, Section II B Criteria. Additionally E &amp; C of 3rd Party upgrades is assignable to Customer. This includes prepayments required for any SWPA upgrades. Revenue requirements for 3rd Party facilities are not calculated. Total cost to customer is based on assumption of Revenue Requirements with confirmation of base plan funding. Customer is responsible for negotiating redispatch costs if applicable. Customer is also responsible to pay credits for previously assigned upgrades that are impacted by their request. Credits can be paid from base plan funding if applicable.</p> <p><b>Note 5:</b> RR with base plan funding may increase or decrease even if no base plan funding is applicable to a particular request if another request that shares the upgrade is now full base plan funded resulting in a different amortization period for the upgrade and thus different RR.</p> <p><b>Note 6:</b> Mutually exclusive with 76348872. System impacts were identified by only modeling mutually exclusive request 76300099.</p> <p><b>Note 7:</b> Mutually exclusive with 76300099. System impacts were identified by only modeling mutually exclusive request 76300099.</p>										

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 AECC 2012-AG1-038

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AECC	76585985	WR	CSWS	51	10/1/2012	10/1/2017	6/1/2018	6/1/2023	\$ 3,032	\$ -	\$ 3,032	\$ 4,698
									\$ 3,032	\$ -	\$ 3,032	\$ 4,698

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76585985	HANCOCK - MUSKOGEE 161KV CKT 1 Accelerate	6/1/2014	6/1/2016		Yes	\$ 2,276	\$ -	\$ 2,276	\$ 27,470	\$ 3,526
	MUSKOGEE - MUSKOGEE PORT 161KV CKT 1 Accelerate	6/1/2014	6/1/2016		Yes	\$ 756	\$ -	\$ 756	\$ 9,196	\$ 1,171
	<b>Total</b>					\$ 3,032	\$ -	\$ 3,032	\$ 36,666	\$ 4,698

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76585985	CHAMBER SPRINGS - FARMINGTON AECC 161KV CKT 1	6/1/2014	6/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76585985	412SUB - KANSAS TAP 161KV CKT 1	6/1/2015	6/1/2017		Yes
	412SUB - KERR 161KV CKT 1	6/1/2015	6/1/2017		Yes
	Cherry Co - Gentleman 345 kV Ckt1	1/1/2014	1/1/2018		Yes
	Cherry Co - Holt Co 345 kV Ckt1	1/1/2014	1/1/2018		Yes
	Cherry Co 345 kV Terminal Upgrades	1/1/2014	1/1/2018		Yes
	KANSAS TAP - WEST SILOAM SPRINGS 161KV CKT 1 #2	6/1/2015	6/1/2017		Yes
	SILOAM CITY - WEST SILOAM SPRINGS 161KV CKT 1 #2	6/1/2019	6/1/2019		
	Viola - Clearwater 138kV Ckt1	10/1/2014	6/1/2018		Yes
	Viola - Gill 138kV Ckt1	10/1/2014	6/1/2018		Yes
	Viola 345/138kV Transformer Ckt 1	10/1/2014	6/1/2018		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76585985	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015		
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76585985	ASHDOWN REC (MILLWOOD) - OKAY 138KV CKT 1	7/1/2012	7/1/2012		
	ASHDOWN REC (MILLWOOD) - PATTERSON 138KV CKT 1	7/1/2012	7/1/2012		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	MANDEVILTP4 - SE TEXARKANA 138KV CKT 1	7/1/2012	7/1/2012		
	MANDEVILTP4 - TURK 138KV CKT 1	7/1/2012	7/1/2012		
	MCNAB REC - TURK 115KV CKT 1	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	OKAY - TURK 138KV CKT 1	7/1/2012	7/1/2012		
	SUGAR HILL - TURK 138KV CKT 1	7/1/2012	7/1/2012		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3** - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

**Customer**      **Study Number**  
 AECC            2012-AG1-040

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AECC	76586012	WR	OKGE	51	7/1/2015	7/1/2020	6/1/2018	6/1/2023	\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586012	None					\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -
					Total	\$ -	\$ -	\$ -

\*Credits may be required for applicable generation interconnection network upgrades.

\*\*Reservation 76586012 studied as relevation 76585985

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 AEPM 2012-AG1-033

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	76584399	CSWS	CSWS	250	1/1/2016	1/1/2021	6/1/2016	6/1/2021	\$ 3,901,489	\$ -	\$ 3,901,489	\$ 7,851,808
									\$ 3,901,489	\$ -	\$ 3,901,489	\$ 7,851,808

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76584399	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2019	6/1/2019			\$ 3,088,048	\$ 14,500,000	\$ 6,494,381
	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2	6/1/2019	6/1/2019			\$ 798,271	\$ 3,300,000	\$ 1,329,133
	HANCOCK - MUSKOGEE 161KV CKT 1 Accelerate	6/1/2014	6/1/2016		Yes	\$ 11,371	\$ 27,470	\$ 21,209
	MUSKOGEE - MUSKOGEE PORT 161KV CKT 1 Accelerate	6/1/2014	6/1/2016		Yes	\$ 3,799	\$ 9,196	\$ 7,086
Total						\$ 3,901,489	\$ 17,836,666	\$ 7,851,808

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584399	CHAMBER SPRINGS - FARMINGTON AECC 161KV CKT 1	6/1/2014	6/1/2015		

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584399	412SUB - KANSAS TAP 161KV CKT 1	6/1/2015	6/1/2017		
	412SUB - KERR 161KV CKT 1	6/1/2015	6/1/2017		
	KANSAS TAP - WEST SILOAM SPRINGS 161KV CKT 1 #2	6/1/2015	6/1/2017		
	SILOAM CITY - WEST SILOAM SPRINGS 161KV CKT 1 #2	6/1/2019	6/1/2019		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584399	BANN - RED SPRINGS REC 138KV CKT 1	7/1/2012	7/1/2012		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 OKGE	1/1/2012	1/1/2012		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 WFEC	1/1/2012	1/1/2012		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76584399	GORE - MUSKOGEE TAP 161KV CKT 1	6/1/2019	6/1/2019			\$ 2,341,327	\$ 8,000,000
	GORE - SALLISAW 161KV CKT 1 Upgrade #1	6/1/2019	6/1/2019			\$ 182,035	\$ 400,000
Total						\$ 2,523,362	\$ 8,400,000

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 AEPM 2012-AG1-034

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	76584402	CSWS	CSWS	250	1/1/2016	1/1/2021	6/1/2016	6/1/2021	\$ 9,219,526	\$ -	\$ 9,219,526	\$ 15,215,177
									\$ 9,219,526	\$ -	\$ 9,219,526	\$ 15,215,177

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76584402	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2019	6/1/2019			\$ 2,831,835	\$ 14,500,000	\$ 5,955,547
	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2	6/1/2019	6/1/2019			\$ 869,227	\$ 3,300,000	\$ 1,447,276
	HANCOCK - MUSKOGEE 161KV CKT 1 Accelerate	6/1/2014	6/1/2016		Yes	\$ 13,823	\$ 27,470	\$ 25,782
	MUSKOGEE - MUSKOGEE PORT 161KV CKT 1 Accelerate	6/1/2014	6/1/2016		Yes	\$ 4,641	\$ 9,196	\$ 8,656
	PECAN CREEK (PECANCK1) 345/161/13.8KV TRANSFORMER CKT 1	6/1/2019	6/1/2019			\$ 5,500,000	\$ 5,500,000	\$ 7,777,916
<b>Total</b>						\$ 9,219,526	\$ 23,336,666	\$ 15,215,177

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584402	CHAMBER SPRINGS - FARMINGTON AECC 161KV CKT 1	6/1/2014	6/1/2015		

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584402	412SUB - KANSAS TAP 161KV CKT 1	6/1/2015	6/1/2017		
	412SUB - KERR 161KV CKT 1	6/1/2015	6/1/2017		
	KANSAS TAP - WEST SILOAM SPRINGS 161KV CKT 1 #2	6/1/2015	6/1/2017		
	SILOAM CITY - WEST SILOAM SPRINGS 161KV CKT 1 #2	6/1/2019	6/1/2019		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584402	BANN - RED SPRINGS REC 138KV CKT 1	7/1/2012	7/1/2012		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 OKGE	1/1/2012	1/1/2012		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 WFEC	1/1/2012	1/1/2012		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76584402	GORE - MUSKOGEE TAP 161KV CKT 1	6/1/2019	6/1/2019			\$ 2,361,188	\$ 8,000,000
	GORE - SALLISAW 161KV CKT 1 Upgrade #1	6/1/2019	6/1/2019			\$ 206,381	\$ 400,000
<b>Total</b>						\$ 2,567,569	\$ 8,400,000

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

\*Credits may be required for applicable generation interconnection network upgrades.



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 AEPM 2012-AG1-036

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	76584451	WR	CSWS	78	10/1/2012	1/1/2032	6/1/2018	9/1/2037	\$ 313,025	\$ -	\$ 350,801	\$ 868,454
									\$ 313,025	\$ -	\$ 350,801	\$ 868,454

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76584451	CHISHOLM - MAIZEE 4 138.00 138KV CKT 1	6/1/2019	6/1/2019			\$ 76,698	\$ 37,776	\$ 114,474	\$ 827,424	\$ 290,233
	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2	6/1/2019	6/1/2019			\$ 236,327	\$ -	\$ 236,327	\$ 3,300,000	\$ 578,221
<b>Total</b>						<b>\$ 313,025</b>	<b>\$ 37,776</b>	<b>\$ 350,801</b>	<b>\$ 4,127,424</b>	<b>\$ 868,454</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584451	CHAMBER SPRINGS - FARMINGTON AECC 161KV CKT 1	6/1/2014	6/1/2015		
	IATAN - NASHUA 345KV CKT 1	1/1/2014	6/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584451	412SUB - KANSAS TAP 161KV CKT 1	6/1/2015	6/1/2017		
	412SUB - KERR 161KV CKT 1	6/1/2015	6/1/2017		
	KANSAS TAP - WEST SILOAM SPRINGS 161KV CKT 1 #2	6/1/2015	6/1/2017		
	SILOAM CITY - WEST SILOAM SPRINGS 161KV CKT 1 #2	6/1/2019	6/1/2019		
	Viola - Clearwater 138kv Ckt1	10/1/2014	6/1/2018		Yes
	Viola - Gill 138kv Ckt1	10/1/2014	6/1/2018		Yes
	Viola 345/138kv Transformer Ckt 1	10/1/2014	6/1/2018		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584451	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015		
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584451	BANN - RED SPRINGS REC 138KV CKT 1	7/1/2012	7/1/2012		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 OKGE	1/1/2012	1/1/2012		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 WFEC	1/1/2012	1/1/2012		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 AEPM 2012-AG1-037

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	76584464	SPS	CSWS	80	10/1/2012	1/1/2032	12/31/2018	3/31/2038	\$ 659,837	\$ -	\$ 678,737	\$ 1,868,445
									\$ 659,837	\$ -	\$ 678,737	\$ 1,868,445

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76584464	CHISHOLM - MAIZEE 4 138.00 138KV CKT 1	6/1/2019	6/1/2019			\$ 38,374	\$ 18,900	\$ 57,274	\$ 827,424	\$ 145,210
	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2019	6/1/2019			\$ 378,297	\$ -	\$ 378,297	\$ 14,500,000	\$ 1,128,281
	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2	6/1/2019	6/1/2019			\$ 243,166	\$ -	\$ 243,166	\$ 3,300,000	\$ 594,954
	<b>Total</b>					\$ 659,837	\$ 18,900	\$ 678,737	\$ 18,627,424	\$ 1,868,445

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584464	CHAMBER SPRINGS - FARMINGTON AECC 161KV CKT 1	6/1/2014	6/1/2015		
	Cox Interchange - Kiser 115 kV Ckt 1 #2	1/1/2014	2/28/2014		Yes
	Kiser Substation 115/69 kV Ckt 1	1/1/2014	2/28/2014		Yes
	Kress Interchange - Kiser 115 kV Ckt 1	1/1/2014	11/30/2014		Yes
	Line - Clark County - Thistle 345 kV dbl Ckt	1/1/2014	1/1/2015		Yes
	Line - Hitchland - Woodward 345 kV dbl Ckt OKGE	1/1/2014	7/1/2014		Yes
	Line - Hitchland - Woodward 345 kV dbl Ckt SPS	1/1/2014	7/1/2014		Yes
	Line - Spearville - Clark County 345 kV dbl Ckt	1/1/2014	1/1/2015		Yes
	Line - Thistle - Wichita 345 kV dbl Ckt PW	1/1/2014	1/1/2015		Yes
	Line - Thistle - Wichita 345 kV dbl Ckt WERE	1/1/2014	1/1/2015		Yes
	Line - Thistle - Woodward 345 kV dbl Ckt OKGE	1/1/2014	1/1/2015		Yes
	Line - Thistle - Woodward 345 kV dbl Ckt PW	1/1/2014	1/1/2015		Yes
	Line - Tuco - Woodward 345 kV line OKGE	1/1/2014	6/1/2014		Yes
	Line - Tuco - Woodward 345 kV line SPS	1/1/2014	6/1/2014		Yes
	MOUNDRIDGE 138/115KV TRANSFORMER CKT 2	1/1/2014	12/1/2014		Yes
	XFR - Thistle 345/138 kV	1/1/2014	1/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584464	412SUB - KANSAS TAP 161KV CKT 1	6/1/2015	6/1/2017		
	412SUB - KERR 161KV CKT 1	6/1/2015	6/1/2017		
	Cherry Co - Gentleman 345 kV Ckt1	1/1/2014	1/1/2018		Yes
	Cherry Co - Holt Co 345 kV Ckt1	1/1/2014	1/1/2018		Yes
	Cherry Co 345 kV Terminal Upgrades	1/1/2014	1/1/2018		Yes
	KANSAS TAP - WEST SILOAM SPRINGS 161KV CKT 1 #2	6/1/2015	6/1/2017		
	SILOAM CITY - WEST SILOAM SPRINGS 161KV CKT 1 #2	6/1/2019	6/1/2019		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584464	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015		
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes
	Potter to Tolk 345 kV	1/1/2014	12/31/2018		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584464	BANN - RED SPRINGS REC 138KV CKT 1	7/1/2012	7/1/2012		
	CHERRY6 230.00 - Harrington Station East Bus 230KV CKT 1	6/1/2015	6/1/2015		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 OKGE	1/1/2012	1/1/2012		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 WFEC	1/1/2012	1/1/2012		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - IODINE 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - WOODWARD EHV 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD 345/138KV TRANSFORMER CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 AEPM 2012-AG1-042

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	76586559	OKGE	CSWS	101	10/1/2012	12/31/2032	1/1/2014	3/1/2034	\$ 965,795	\$ -	\$ 965,795	\$ 2,797,121
									\$ 965,795	\$ -	\$ 965,795	\$ 2,797,121

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586559	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2019	6/1/2019			\$ 641,037	\$ -	\$ 641,037	\$ 14,500,000	\$ 1,981,183
	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2	6/1/2019	6/1/2019			\$ 324,758	\$ -	\$ 324,758	\$ 3,300,000	\$ 815,939
	<b>Total</b>					\$ 965,795	\$ -	\$ 965,795	\$ 17,800,000	\$ 2,797,121

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586559	CHAMBER SPRINGS - FARMINGTON AECC 161KV CKT 1	6/1/2014	6/1/2015		

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586559	412SUB - KANSAS TAP 161KV CKT 1	6/1/2015	6/1/2017		
	412SUB - KERR 161KV CKT 1	6/1/2015	6/1/2017		
	KANSAS TAP - WEST SILOAM SPRINGS 161KV CKT 1 #2	6/1/2015	6/1/2017		
	SILOAM CITY - WEST SILOAM SPRINGS 161KV CKT 1 #2	6/1/2019	6/1/2019		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586559	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586559	BANN - RED SPRINGS REC 138KV CKT 1	7/1/2012	7/1/2012		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 OKGE	1/1/2012	1/1/2012		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 WFEC	1/1/2012	1/1/2012		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 AEPM 2012-AG1-044

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	76586582	OKGE	CSWS	53	10/1/2012	12/31/2032	1/1/2014	3/1/2034	\$ 506,803	\$ -	\$ 506,803	\$ 1,467,796
									\$ 506,803	\$ -	\$ 506,803	\$ 1,467,796

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586582	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2019	6/1/2019			\$ 336,386	\$ -	\$ 336,386	\$ 14,500,000	\$ 1,039,631
	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2	6/1/2019	6/1/2019			\$ 170,417	\$ -	\$ 170,417	\$ 3,300,000	\$ 428,164
	<b>Total</b>					\$ 506,803	\$ -	\$ 506,803	\$ 17,800,000	\$ 1,467,796

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586582	CHAMBER SPRINGS - FARMINGTON AECC 161KV CKT 1	6/1/2014	6/1/2015		

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586582	412SUB - KANSAS TAP 161KV CKT 1	6/1/2015	6/1/2017		
	412SUB - KERR 161KV CKT 1	6/1/2015	6/1/2017		
	KANSAS TAP - WEST SILOAM SPRINGS 161KV CKT 1 #2	6/1/2015	6/1/2017		
	SILOAM CITY - WEST SILOAM SPRINGS 161KV CKT 1 #2	6/1/2019	6/1/2019		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586582	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586582	BANN - RED SPRINGS REC 138KV CKT 1	7/1/2012	7/1/2012		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 OKGE	1/1/2012	1/1/2012		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 WFEC	1/1/2012	1/1/2012		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 AEPM 2012-AG1-046

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	76586592	OKGE	CSWS	48	10/1/2012	12/31/2032	1/1/2014	3/1/2034	\$ 458,991	\$ -	\$ 458,991	\$ 1,329,323
									\$ 458,991	\$ -	\$ 458,991	\$ 1,329,323

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586592	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2019	6/1/2019			\$ 304,651	\$ -	\$ 304,651	\$ 14,500,000	\$ 941,551
	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2	6/1/2019	6/1/2019			\$ 154,340	\$ -	\$ 154,340	\$ 3,300,000	\$ 387,772
	<b>Total</b>					\$ 458,991	\$ -	\$ 458,991	\$ 17,800,000	\$ 1,329,323

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586592	CHAMBER SPRINGS - FARMINGTON AECC 161KV CKT 1	6/1/2014	6/1/2015		

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586592	412SUB - KANSAS TAP 161KV CKT 1	6/1/2015	6/1/2017		
	412SUB - KERR 161KV CKT 1	6/1/2015	6/1/2017		
	KANSAS TAP - WEST SILOAM SPRINGS 161KV CKT 1 #2	6/1/2015	6/1/2017		
	SILOAM CITY - WEST SILOAM SPRINGS 161KV CKT 1 #2	6/1/2019	6/1/2019		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586592	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586592	BANN - RED SPRINGS REC 138KV CKT 1	7/1/2012	7/1/2012		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 OKGE	1/1/2012	1/1/2012		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 WFEC	1/1/2012	1/1/2012		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3** - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

**Customer**      **Study Number**  
 CHAN            2012-AG1-028

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CHAN	76583997	KACY	WR	3	1/1/2014	1/1/2019			\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583997	None					\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -
					Total	\$ -	\$ -	\$ -

\*Credits may be required for applicable generation interconnection network upgrades.

\*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

**Customer**      **Study Number**  
 CHAN            2012-AG1-029

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CHAN	76583999	KCPL	WR	45	1/1/2014	1/1/2019			\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583999	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583999	CLIFTON - GREENLEAF 115KV CKT 1	6/1/2011	6/1/2013		
	GREENLEAF - KNOB HILL 115KV CKT 1 MKEC	6/1/2013	6/1/2013		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		

\*Credits may be required for applicable generation interconnection network upgrades.

\*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3** - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

**Customer**      **Study Number**  
 CHAN            2012-AG1-031

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CHAN	76584004	SPA	WR	1	1/1/2014	1/1/2019			\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76584004	None					\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -

\*Credits may be required for applicable generation interconnection network upgrades.  
 \*Underlying System Impacts and Upgrades have yet to be determined.



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

**Customer**      **Study Number**  
 CHAN            2012-AG1-032

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CHAN	76584010	WR	WR	121	1/1/2014	1/1/2019			\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76584010	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584010	CLIFTON - GREENLEAF 115KV CKT 1	6/1/2011	6/1/2013		
	GREENLEAF - KNOB HILL 115KV CKT 1 MKEC	6/1/2013	6/1/2013		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		

\*Credits may be required for applicable generation interconnection network upgrades.

\*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

**Customer Study Number**  
 CHAN 2012-AG1-050

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CHAN	76586685	NPPD	WR	2	1/1/2014	1/1/2019			\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586685	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586685	HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2	1/1/2014	6/1/2015		
	Line - Clark County - Thistle 345 kV dbl Ckt	1/1/2014	1/1/2015		
	Line - Hitchland - Woodward 345 kV dbl Ckt OKGE	1/1/2014	7/1/2014		
	Line - Hitchland - Woodward 345 kV dbl Ckt SPS	1/1/2014	7/1/2014		
	Line - Spearville - Clark County 345 kV dbl Ckt	1/1/2014	1/1/2015		
	Line - Thistle - Wichita 345 kV dbl Ckt PW	1/1/2014	1/1/2015		
	Line - Thistle - Wichita 345 kV dbl Ckt WERE	1/1/2014	1/1/2015		
	Line - Thistle - Woodward 345 kV dbl Ckt OKGE	1/1/2014	1/1/2015		
	Line - Thistle - Woodward 345 kV dbl Ckt PW	1/1/2014	1/1/2015		
	Line - Tuco - Woodward 345 kV line OKGE	1/1/2014	6/1/2014		
	Line - Tuco - Woodward 345 kV line SPS	1/1/2014	6/1/2014		
	MOUNDRIDGE 138/115KV TRANSFORMER CKT 2	1/1/2014	12/1/2014		
	XFR - Thistle 345/138 kV	1/1/2014	1/1/2015		

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586685	BUTLER - WEAVER 138KV CKT 1	1/1/2014	6/1/2017		
	Cherry Co - Gentleman 345 kV Ckt1	1/1/2014	1/1/2018		
	Cherry Co - Holt Co 345 kV Ckt1	1/1/2014	1/1/2018		
	Cherry Co 345 kV Terminal Upgrades	1/1/2014	1/1/2018		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586685	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015		
	HAYS PLANT - VINE STREET 115KV CKT 1 #1	6/1/2014	6/1/2015		
	HAYS PLANT - VINE STREET 115KV CKT 1 #2	6/1/2014	6/1/2016		
	Potter to Tolk 345 kV	1/1/2014	12/31/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586685	ALBION - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		
	CLIFTON - GREENLEAF 115KV CKT 1	6/1/2011	6/1/2013		
	DEARING 138KV Capacitor	6/1/2012	6/1/2012		
	GREENLEAF - KNOB HILL 115KV CKT 1 MKEC	6/1/2013	6/1/2013		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	NELIGH - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

\*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3** - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

**Customer**      **Study Number**  
 CHAN            2012-AG1-052

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CHAN	76583977	WR	WR	115	1/1/2014	1/1/2019			\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583977	None					\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -
					Total	\$ -	\$ -	\$ -

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3** - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

**Customer**      **Study Number**  
 CHAN            2012-AG1-053

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CHAN	76583984	GRDA	WR	2	1/1/2014	1/1/2019			\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583984	None					\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -
					Total	\$ -	\$ -	\$ -

\*Credits may be required for applicable generation interconnection network upgrades.

\*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
CRGL 2012-AG1-001

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CRGL	76300099	CSWS	ERCOTN	207	1/1/2014	1/1/2024	12/31/2018	12/31/2028	\$ -	\$ 54,686,005	\$ -	\$ -
									\$ -	\$ 54,686,005	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76300099	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76300099	Cox Interchange - Kiser 115 kV Ckt 1 #2	1/1/2014	2/28/2014		Yes
	Kiser Substation 115/69 kV Ckt 1	1/1/2014	2/28/2014		Yes
	Kress Interchange - Kiser 115 kV Ckt 1	1/1/2014	11/30/2014		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76300099	Potter to Tolk 345 kV	1/1/2014	12/31/2018		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76300099	BANN - RED SPRINGS REC 138KV CKT 1	7/1/2012	7/1/2012		
	BEELINE - EXPLORER GLENPOOL TAP 138KV CKT 1	6/1/2009	6/1/2009		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	EXPLORER GLENPOOL TAP - RIVERSIDE STATION 138KV CKT 1 AEPW	6/1/2009	6/1/2009		
	EXPLORER GLENPOOL TAP - RIVERSIDE STATION 138KV CKT 1 OKGE	6/1/2009	6/1/2009		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 OKGE	1/1/2012	1/1/2012		
	GRACMNT4 138.00 - WASHITA 138KV CKT 2 WFEC	1/1/2012	1/1/2012		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

- \*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.
- \*Credits may be required for applicable generation interconnection network upgrades.
- \*The North DC Tie is derated to 210mw indefinitely.
- \*The NORTH DC tie is scheduled for an outage beginning 12/1/2013 until 3/31/2014 to refurbish the facility.
- \*198 MW of available ERCOT North to South capacity without consideration of prior queued STUDY requests in active Aggregate Transmission Service Studies.
- \*Available capacity will be allocated on a first come first served basis in accordance with Attachment Z1 III.b. of SPP OATT.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

**Customer**      **Study Number**  
 CRGL              2012-AG1-002

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CRGL	76348872	ERCOTN	ERCOTN	207	2/1/2013	2/1/2018	1/1/2014	1/1/2019	\$ -	\$ 27,343,003	\$ -	\$ -
									\$ -	\$ 27,343,003	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76348872	None					\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -
					Total	\$ -	\$ -	\$ -

- \*Credits may be required for applicable generation interconnection network upgrades.
- \*The North DC Tie is derated to 210mw indefinitely.
- \*The NORTH DC tie is scheduled for an outage beginning 12/1/2013 until 3/31/2014 to refurbish the facility.
- \*198 MW of available ERCOT North to South capacity without consideration of prior queued STUDY requests in active Aggregate Transmission Service Studies.
- \*Available capacity will be allocated on a first come first served basis in accordance with Attachment Z1 III.b. of SPP OATT.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
CRGL 2012-AG1-025

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CRGL	76583812	WPEK	EES	200	1/1/2014	1/1/2024	6/1/2018	6/1/2028	\$ -	\$ 30,720,000	\$ 1,584,488	\$ 3,571,492
									\$ -	\$ 30,720,000	\$ 1,584,488	\$ 3,571,492

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583812	CHISHOLM - MAIZEE 4 138.00 138KV CKT 1	6/1/2019	6/1/2019			\$ 250,357	\$ 827,424	\$ 516,434
	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2019	6/1/2019			\$ 1,132,734	\$ 14,500,000	\$ 2,675,440
	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2	6/1/2019	6/1/2019			\$ 201,397	\$ 3,300,000	\$ 379,618
Total						\$ 1,584,488	\$ 18,627,424	\$ 3,571,492

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583812	HARPER - MILAN TAP 138KV CKT 1 #1	10/1/2014	6/1/2016		Yes
	Line - Clark County - Thistle 345 kV dbI Ckt	1/1/2014	1/1/2015		No
	Line - Hitchland - Woodward 345 kV dbI Ckt OKGE	1/1/2014	7/1/2014		
	Line - Hitchland - Woodward 345 kV dbI Ckt SPS	1/1/2014	7/1/2014		
	Line - Spearville - Clark County 345 kV dbI Ckt	1/1/2014	1/1/2015		No
	Line - Thistle - Wichita 345 kV dbI Ckt PW	1/1/2014	1/1/2015		No
	Line - Thistle - Wichita 345 kV dbI Ckt WERE	1/1/2014	1/1/2015		No
	Line - Thistle - Woodward 345 kV dbI Ckt OKGE	1/1/2014	1/1/2015		No
	Line - Thistle - Woodward 345 kV dbI Ckt PW	1/1/2014	1/1/2015		No
	Line - Tuco - Woodward 345 kV line OKGE	1/1/2014	6/1/2014		
	Line - Tuco - Woodward 345 kV line SPS	1/1/2014	6/1/2014		
	XFR - Thistle 345/138 kV	1/1/2014	1/1/2015		No

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583812	Cherry Co - Gentleman 345 kV Ckt1	1/1/2014	1/1/2018		Yes
	Cherry Co - Holt Co 345 kV Ckt1	1/1/2014	1/1/2018		Yes
	Cherry Co 345 kV Terminal Upgrades	1/1/2014	1/1/2018		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583812	CLEARWATER - MILAN TAP 138KV CKT 1 MKEC Accelerate	1/1/2014	6/1/2017		Yes
	CLEARWATER - MILAN TAP 138KV CKT 1 WERE Accelerate	1/1/2014	6/1/2017		Yes
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015		
	HARPER - MILAN TAP 138KV CKT 1 #2 Accelerate	1/1/2014	6/1/2017		Yes
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583812	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76583812	BUFORD 5 161.00 - BULL SHOALS 161KV CKT 1 Upgrade #1	6/1/2015	6/1/2016		Yes	\$ 49,928	\$ 125,000
	BUFORD 5 161.00 - NORFORK 161KV CKT 1 Upgrade #1	6/1/2015	6/1/2016		Yes	\$ 39,942	\$ 100,000
Total						\$ 89,870	\$ 225,000

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

**Customer** Study Number  
CRGL 2012-AG1-026

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CRGL	76583814	WPEK	EES	200	1/1/2014	1/1/2024	6/1/2018	6/1/2028	\$ -	\$ 30,720,000	\$ 1,584,488	\$ 3,571,492
									\$ -	\$ 30,720,000	\$ 1,584,488	\$ 3,571,492

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583814	CHISHOLM - MAIZEE 4 138.00 138KV CKT 1	6/1/2019	6/1/2019			\$ 250,357	\$ 827,424	\$ 516,434
	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2019	6/1/2019			\$ 1,132,734	\$ 14,500,000	\$ 2,675,440
	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2	6/1/2019	6/1/2019			\$ 201,397	\$ 3,300,000	\$ 379,618
	<b>Total</b>					\$ 1,584,488	\$ 18,627,424	\$ 3,571,492

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583814	HARPER - MILAN TAP 138KV CKT 1 #1	10/1/2014	6/1/2016		Yes
	Line - Clark County - Thistle 345 kV dbI Ckt	1/1/2014	1/1/2015		No
	Line - Hitchland - Woodward 345 kV dbI Ckt OKGE	1/1/2014	7/1/2014		
	Line - Hitchland - Woodward 345 kV dbI Ckt SPS	1/1/2014	7/1/2014		
	Line - Spearville - Clark County 345 kV dbI Ckt	1/1/2014	1/1/2015		No
	Line - Thistle - Wichita 345 kV dbI Ckt PW	1/1/2014	1/1/2015		No
	Line - Thistle - Wichita 345 kV dbI Ckt WERE	1/1/2014	1/1/2015		No
	Line - Thistle - Woodward 345 kV dbI Ckt OKGE	1/1/2014	1/1/2015		No
	Line - Thistle - Woodward 345 kV dbI Ckt PW	1/1/2014	1/1/2015		No
	Line - Tuco - Woodward 345 kV line OKGE	1/1/2014	6/1/2014		
	Line - Tuco - Woodward 345 kV line SPS	1/1/2014	6/1/2014		
	XFR - Thistle 345/138 kV	1/1/2014	1/1/2015		No

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583814	Cherry Co - Gentleman 345 kV Ckt1	1/1/2014	1/1/2018		Yes
	Cherry Co - Holt Co 345 kV Ckt1	1/1/2014	1/1/2018		Yes
	Cherry Co 345 kV Terminal Upgrades	1/1/2014	1/1/2018		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583814	CLEARWATER - MILAN TAP 138KV CKT 1 MKEC Accelerate	1/1/2014	6/1/2017		Yes
	CLEARWATER - MILAN TAP 138KV CKT 1 WERE Accelerate	1/1/2014	6/1/2017		Yes
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015		
	HARPER - MILAN TAP 138KV CKT 1 #2 Accelerate	1/1/2014	6/1/2017		Yes
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583814	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76583814	BUFORD 5 161.00 - BULL SHOALS 161KV CKT 1 Upgrade #1	6/1/2015	6/1/2016		Yes	\$ 49,928	\$ 125,000
	BUFORD 5 161.00 - NORFORK 161KV CKT 1 Upgrade #1	6/1/2015	6/1/2016		Yes	\$ 39,942	\$ 100,000
	<b>Total</b>					\$ 89,870	\$ 225,000

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

\*Credits may be required for applicable generation interconnection network upgrades.



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
CRGL 2012-AG1-027

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CRGL	76583815	WPEK	EES	100	1/1/2014	1/1/2024	6/1/2018	6/1/2028	\$ -	\$ 15,360,000	\$ 792,245	\$ 1,785,748
									\$ -	\$ 15,360,000	\$ 792,245	\$ 1,785,748

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583815	CHISHOLM - MAIZEE 4 138.00 138KV CKT 1	6/1/2019	6/1/2019			\$ 125,179	\$ 827,424	\$ 258,218
	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2019	6/1/2019			\$ 566,367	\$ 14,500,000	\$ 1,337,720
	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2	6/1/2019	6/1/2019			\$ 100,699	\$ 3,300,000	\$ 189,810
	<b>Total</b>					\$ 792,245	\$ 18,627,424	\$ 1,785,748

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583815	HARPER - MILAN TAP 138KV CKT 1 #1	10/1/2014	6/1/2016		Yes
	Line - Clark County - Thistle 345 kV dbI Ckt	1/1/2014	1/1/2015		No
	Line - Hitchland - Woodward 345 kV dbI Ckt OKGE	1/1/2014	7/1/2014		
	Line - Hitchland - Woodward 345 kV dbI Ckt SPS	1/1/2014	7/1/2014		
	Line - Spearville - Clark County 345 kV dbI Ckt	1/1/2014	1/1/2015		No
	Line - Thistle - Wichita 345 kV dbI Ckt PW	1/1/2014	1/1/2015		No
	Line - Thistle - Wichita 345 kV dbI Ckt WERE	1/1/2014	1/1/2015		No
	Line - Thistle - Woodward 345 kV dbI Ckt OKGE	1/1/2014	1/1/2015		No
	Line - Thistle - Woodward 345 kV dbI Ckt PW	1/1/2014	1/1/2015		No
	Line - Tuco - Woodward 345 kV line OKGE	1/1/2014	6/1/2014		
	Line - Tuco - Woodward 345 kV line SPS	1/1/2014	6/1/2014		
	XFR - Thistle 345/138 kV	1/1/2014	1/1/2015		No

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583815	Cherry Co - Gentleman 345 kV Ckt1	1/1/2014	1/1/2018		Yes
	Cherry Co - Holt Co 345 kV Ckt1	1/1/2014	1/1/2018		Yes
	Cherry Co 345 kV Terminal Upgrades	1/1/2014	1/1/2018		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583815	CLEARWATER - MILAN TAP 138KV CKT 1 MKEC Accelerate	1/1/2014	6/1/2017		Yes
	CLEARWATER - MILAN TAP 138KV CKT 1 WERE Accelerate	1/1/2014	6/1/2017		Yes
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015		
	HARPER - MILAN TAP 138KV CKT 1 #2 Accelerate	1/1/2014	6/1/2017		Yes
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583815	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76583815	BUFORD 5 161.00 - BULL SHOALS 161KV CKT 1 Upgrade #1	6/1/2015	6/1/2016		Yes	\$ 24,964	\$ 125,000
	BUFORD 5 161.00 - NORFORK 161KV CKT 1 Upgrade #1	6/1/2015	6/1/2016			\$ 19,971	\$ 100,000
	<b>Total</b>					\$ 44,935	\$ 225,000

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

**Customer**      **Study Number**  
 KMEA            2012-AG1-007

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76553455	NPPD	WR	3	2/1/2013	4/1/2025	1/1/2014	3/1/2026	\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76553455	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76553455	Cherry Co - Gentleman 345 kV Ckt1	1/1/2014	1/1/2018		
	Cherry Co - Holt Co 345 kV Ckt1	1/1/2014	1/1/2018		
	Cherry Co 345 kV Terminal Upgrades	1/1/2014	1/1/2018		
	Viola - Clearwater 138kV Ckt1	10/1/2014	6/1/2018		
	Viola - Gill 138kV Ckt1	10/1/2014	6/1/2018		
	Viola 345/138kV Transformer Ckt 1	10/1/2014	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76553455	ALBION - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		
	CLIFTON - GREENLEAF 115KV CKT 1	6/1/2011	6/1/2013		
	GREENLEAF - KNOB HILL 115KV CKT 1 MKEC	6/1/2013	6/1/2013		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	LYONS - RICE_CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	NELIGH - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		

\*Credits may be required for applicable generation interconnection network upgrades.

\*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

**Customer Study Number**  
KMEA 2012-AG1-012

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76580367	NPPD	WR	1	5/1/2013	4/30/2025	1/1/2014	1/1/2026	\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76580367	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580367	Line - Clark County - Thistle 345 kV dbl Ckt	1/1/2014	1/1/2015		
	Line - Hitchland - Woodward 345 kV dbl Ckt OKGE	1/1/2014	7/1/2014		
	Line - Hitchland - Woodward 345 kV dbl Ckt SPS	1/1/2014	7/1/2014		
	Line - Spearville - Clark County 345 kV dbl Ckt	1/1/2014	1/1/2015		
	Line - Thistle - Wichita 345 kV dbl Ckt PW	1/1/2014	1/1/2015		
	Line - Thistle - Wichita 345 kV dbl Ckt WERE	1/1/2014	1/1/2015		
	Line - Thistle - Woodward 345 kV dbl Ckt OKGE	1/1/2014	1/1/2015		
	Line - Thistle - Woodward 345 kV dbl Ckt PW	1/1/2014	1/1/2015		
	Line - Tuco - Woodward 345 kV line OKGE	1/1/2014	6/1/2014		
	Line - Tuco - Woodward 345 kV line SPS	1/1/2014	6/1/2014		
	XFR - Thistle 345/138 kV	1/1/2014	1/1/2015		

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580367	Cherry Co - Gentleman 345 kV Ckt1	1/1/2014	1/1/2018		
	Cherry Co - Holt Co 345 kV Ckt1	1/1/2014	1/1/2018		
	Cherry Co 345 kV Terminal Upgrades	1/1/2014	1/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580367	CLIFTON - GREENLEAF 115KV CKT 1	6/1/2011	6/1/2013		
	GREENLEAF - KNOB HILL 115KV CKT 1 MKEC	6/1/2013	6/1/2013		

\*Credits may be required for applicable generation interconnection network upgrades.

\*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3** - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

**Customer**      **Study Number**  
 KMEA            2012-AG1-013

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76580375	GRDA	WR	3	5/1/2013	5/1/2026	1/1/2014	1/1/2027	\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76580375	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

\*Credits may be required for applicable generation interconnection network upgrades.

\*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3** - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

**Customer**      **Study Number**  
 KMEA            2012-AG1-014

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76580381	KACY	WR	4	10/1/2013	6/1/2022	1/1/2014	9/1/2022	\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76580381	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

\*Credits may be required for applicable generation interconnection network upgrades.  
 \*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3** - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

**Customer**      **Study Number**  
 KMEA            2012-AG1-015

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76580392	SPA	WR	1	5/1/2013	1/1/2019	1/1/2014	9/1/2019	\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76580392	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

\*Credits may be required for applicable generation interconnection network upgrades.  
 \*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

**Customer**      **Study Number**  
 KMEA              2012-AG1-016

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76580395	WR	WR	5	5/1/2013	1/1/2019	6/1/2018	2/1/2024	\$ -	\$ -	\$ 29,783	\$ 49,396
									\$ -	\$ -	\$ 29,783	\$ 49,396

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76580395	CHISHOLM - MAIZEE 4 138.00 138KV CKT 1	6/1/2019	6/1/2019			\$ 29,783	\$ 827,424	\$ 49,396
	<b>Total</b>					\$ 29,783	\$ 827,424	\$ 49,396

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580395	IATAN - NASHUA 345KV CKT 1	1/1/2014	6/1/2015		

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580395	EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1	6/1/2019	6/1/2019		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580395	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015		
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580395	BARBER (BARBER 4) 138/115/2.72KV TRANSFORMER CKT 1	12/1/2009	6/1/2013		
	CIRCLE - RICE_CO 230KV CKT 1	10/1/2012	11/15/2012		
	FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1	12/1/2009	6/1/2013		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	LYONS - RICE_CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	RICE_CO 230/115KV TRANSFORMER CKT 1	10/1/2012	11/15/2012		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

\*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

**Customer**      **Study Number**  
 KMEA              2012-AG1-017

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76580515	SPA	WR	1	1/1/2014	1/1/2019			\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76580515	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580515	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	CIRCLE - RICE_CO 230KV CKT 1	10/1/2012	11/15/2012		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	LYONS - RICE_CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	RICE_CO 230/115KV TRANSFORMER CKT 1	10/1/2012	11/15/2012		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76580515	BUFORD 5 161.00 - BULL SHOALS 161KV CKT 1 Upgrade #1	6/1/2015	6/1/2016			\$ 181	\$ 125,000
	BUFORD 5 161.00 - NORFORK 161KV CKT 1 Upgrade #1	6/1/2015	6/1/2016			\$ 145	\$ 100,000
<b>Total</b>						\$ 326	\$ 225,000

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

\*Credits may be required for applicable generation interconnection network upgrades.

\*Underlying System Impacts and Upgrades have yet to be determined.



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

**Customer Study Number**  
KMEA 2012-AG1-018

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76580552	NPPD	WR	1	1/1/2014	5/1/2025			\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76580552	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580552	HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2	1/1/2014	6/1/2015		
	Line - Clark County - Thistle 345 kV dbI Ckt	1/1/2014	1/1/2015		
	Line - Hitchland - Woodward 345 kV dbI Ckt OKGE	1/1/2014	7/1/2014		
	Line - Hitchland - Woodward 345 kV dbI Ckt SPS	1/1/2014	7/1/2014		
	Line - Spearville - Clark County 345 kV dbI Ckt	1/1/2014	1/1/2015		
	Line - Thistle - Wichita 345 kV dbI Ckt PW	1/1/2014	1/1/2015		
	Line - Thistle - Wichita 345 kV dbI Ckt WERE	1/1/2014	1/1/2015		
	Line - Thistle - Woodward 345 kV dbI Ckt OKGE	1/1/2014	1/1/2015		
	Line - Thistle - Woodward 345 kV dbI Ckt PW	1/1/2014	1/1/2015		
	Line - Tuco - Woodward 345 kV line OKGE	1/1/2014	6/1/2014		
	Line - Tuco - Woodward 345 kV line SPS	1/1/2014	6/1/2014		
	XFR - Thistle 345/138 kV	1/1/2014	1/1/2015		

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580552	Cherry Co - Gentleman 345 kV Ckt1	1/1/2014	1/1/2018		
	Cherry Co - Holt Co 345 kV Ckt1	1/1/2014	1/1/2018		
	Cherry Co 345 kV Terminal Upgrades	1/1/2014	1/1/2018		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580552	HAYS PLANT - VINE STREET 115KV CKT 1 #1	6/1/2014	6/1/2015		
	HAYS PLANT - VINE STREET 115KV CKT 1 #2	6/1/2014	6/1/2016		
	Potter to Tolk 345 kV	1/1/2014	12/31/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580552	ALBION - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		
	CIRCLE - RICE_CO 230KV CKT 1	10/1/2012	11/15/2012		
	CLIFTON - GREENLEAF 115KV CKT 1	6/1/2011	6/1/2013		
	GREENLEAF - KNOB HILL 115KV CKT 1 MKEC	6/1/2013	6/1/2013		
	LYONS - RICE_CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	NELIGH - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	RICE_CO 230/115KV TRANSFORMER CKT 1	10/1/2012	11/15/2012		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

\*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
KMEA 2012-AG1-019

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76582326	WR	WR	41	5/1/2013	5/1/2026	1/1/2014	1/1/2027	\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76582326	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76582326	GOODYEAR JUNCTION - NORTHLAND 115KV CKT 1	6/1/2014	6/1/2016		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76582326	BARBER (BARBER 4) 138/115/2.72KV TRANSFORMER CKT 1	12/1/2009	6/1/2013		
	CIRCLE - RICE_CO 230KV CKT 1	10/1/2012	11/15/2012		
	CLIFTON - GREENLEAF 115KV CKT 1	6/1/2011	6/1/2013		
	FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1	12/1/2009	6/1/2013		
	GREENLEAF - KNOB HILL 115KV CKT 1 MKEC	6/1/2013	6/1/2013		
	LYONS - RICE_CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	RICE_CO 230/115KV TRANSFORMER CKT 1	10/1/2012	11/15/2012		

\*Credits may be required for applicable generation interconnection network upgrades.

\*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3** - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

**Customer**      **Study Number**  
 KMEA            2012-AG1-022

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76583607	WR	WR	21	1/1/2014	5/1/2026			\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583607	None					\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -
					Total	\$ -	\$ -	\$ -

\*Credits may be required for applicable generation interconnection network upgrades.  
 \*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

**Customer**      **Study Number**  
 KMEA            2012-AG1-023

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76583617	GRDA	WR	5	1/1/2014	5/1/2026			\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583617	None					\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583617	LYONS - RICE_CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		

\*Credits may be required for applicable generation interconnection network upgrades.

\*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
KMEA 2012-AG1-024

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76583629	WR	WR	4	1/1/2014	1/1/2019			\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583629	None					\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583629	IATAN - NASHUA 345KV CKT 1	1/1/2014	6/1/2015		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583629	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2015	6/1/2015		
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2015	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583629	BARBER (BARBER 4) 138/115/2.72KV TRANSFORMER CKT 1	12/1/2009	6/1/2013		
	CIRCLE - RICE_CO 230KV CKT 1	10/1/2012	11/15/2012		
	FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1	12/1/2009	6/1/2013		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	LYONS - RICE_CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	RICE_CO 230/115KV TRANSFORMER CKT 1	10/1/2012	11/15/2012		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

\*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

**Customer Study Number**  
KMEA 2012-AG1-048

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76586675	KCPL	WR	15	6/1/2013	6/1/2023	6/1/2018	6/1/2028	\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586675	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586675	IATAN - NASHUA 345KV CKT 1	1/1/2014	6/1/2015		Yes
	MOUNDRIDGE 138/115KV TRANSFORMER CKT 2	1/1/2014	12/1/2014		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586675	EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1	6/1/2019	6/1/2019		
	Viola - Clearwater 138kV Ckt1	10/1/2014	6/1/2018		Yes
	Viola - Gill 138kV Ckt1	10/1/2014	6/1/2018		Yes
	Viola 345/138kV Transformer Ckt 1	10/1/2014	6/1/2018		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586675	ALEXANDER - PRATT 115KV CKT 1	12/1/2009	6/1/2013		
	BARBER - SAWYER 115KV CKT 1	12/1/2009	6/1/2013		
	BARBER (BARBER 4) 138/115/2.72KV TRANSFORMER CKT 1	12/1/2009	6/1/2013		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	CIRCLE - RICE_CO 230KV CKT 1	10/1/2012	11/15/2012		
	CLIFTON - GREENLEAF 115KV CKT 1	6/1/2011	6/1/2013		
	FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1	12/1/2009	6/1/2013		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	GREENLEAF - KNOB HILL 115KV CKT 1 MKEC	6/1/2013	6/1/2013		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	LYONS - RICE_CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	RICE_CO 230/115KV TRANSFORMER CKT 1	10/1/2012	11/15/2012		
	SUB 110 - ORONOJO JCT. - SUB 167 - RIVERTON 161KV CKT 1	6/1/2011	6/1/2011		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76586675	NORTH WARSAW - TRUMAN 161KV CKT 1 SWPA #1	10/1/2019	10/1/2019			\$ 70,000	\$ 70,000
<b>Total</b>						\$ 70,000	\$ 70,000

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

\*Credits may be required for applicable generation interconnection network upgrades.

\*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3** - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

**Customer**      **Study Number**  
 KMEA            2012-AG1-049

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76586679	WR	WR	15	6/1/2013	6/1/2023	1/1/2014	1/1/2024	\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586679	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

\*Credits may be required for applicable generation interconnection network upgrades.  
 \*Underlying System Impacts and Upgrades have yet to be determined.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

**Customer**      **Study Number**  
 KMEA              2012-AG1-051

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76586961	NPPD	WR	1	6/1/2013	5/1/2025	1/1/2014	12/1/2025	\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586961	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586961	Line - Clark County - Thistle 345 kV dbl Ckt	1/1/2014	1/1/2015		
	Line - Hitchland - Woodward 345 kV dbl Ckt OKGE	1/1/2014	7/1/2014		
	Line - Hitchland - Woodward 345 kV dbl Ckt SPS	1/1/2014	7/1/2014		
	Line - Spearville - Clark County 345 kV dbl Ckt	1/1/2014	1/1/2015		
	Line - Thistle - Wichita 345 kV dbl Ckt PW	1/1/2014	1/1/2015		
	Line - Thistle - Wichita 345 kV dbl Ckt WERE	1/1/2014	1/1/2015		
	Line - Thistle - Woodward 345 kV dbl Ckt OKGE	1/1/2014	1/1/2015		
	Line - Thistle - Woodward 345 kV dbl Ckt PW	1/1/2014	1/1/2015		
	Line - Tuco - Woodward 345 kV line OKGE	1/1/2014	6/1/2014		
	Line - Tuco - Woodward 345 kV line SPS	1/1/2014	6/1/2014		
	MOUNDRIDGE 138/115KV TRANSFORMER CKT 2	1/1/2014	12/1/2014		
	XFR - Thistle 345/138 kV	1/1/2014	1/1/2015		

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586961	Cherry Co - Gentleman 345 kV Ckt1	1/1/2014	1/1/2018		
	Cherry Co - Holt Co 345 kV Ckt1	1/1/2014	1/1/2018		
	Cherry Co 345 kV Terminal Upgrades	1/1/2014	1/1/2018		
	Viola - Clearwater 138kV Ckt1	10/1/2014	6/1/2018		
	Viola - Gill 138kV Ckt1	10/1/2014	6/1/2018		
	Viola 345/138kV Transformer Ckt 1	10/1/2014	6/1/2018		

\*Credits may be required for applicable generation interconnection network upgrades.

\*Underlying System Impacts and Upgrades have yet to be determined.



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 OGE 2012-AG1-008

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
OGE	76571379	OKGE	OKGE	60	12/19/2012	12/19/2032	6/1/2015	6/1/2035	\$ 2,470,000	-	\$ 2,470,000	\$ 6,767,885
									\$ 2,470,000	-	\$ 2,470,000	\$ 6,767,885

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76571379	DIVISION AVE - LAKESIDE 138KV CKT 1	6/1/2019	6/1/2019			\$ 1,720,000	-	\$ 1,720,000	\$ 1,720,000	\$ 4,666,619
	HEFNER - TULSA 138KV CKT 1	6/1/2019	6/1/2019			\$ 750,000	-	\$ 750,000	\$ 750,000	\$ 2,101,266
						\$ 2,470,000	-	\$ 2,470,000	\$ 2,470,000	\$ 6,767,885

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76571379	NORTHWEST 345/138/13.8KV TRANSFORMER CKT 3 Accelerated	1/1/2014	6/1/2015		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76571379	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
PSCM 2012-AG1-021

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
PSCM	76582673	SPS	LAM345	208	3/1/2013	3/1/2018	6/1/2017	6/1/2022	\$ -	\$ 23,137,920	\$ -	\$ -
									\$ -	\$ 23,137,920	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76582673	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76582673	CIMARRON RIVER PLANT - CIMARRON RIVER TAP 115KV CKT 1	6/1/2015	6/1/2017		
	CIMARRON RIVER TAP - KISMET 3 115.00 115KV CKT 1	6/1/2015	6/1/2017		
	CUDAHY - KISMET 3 115.00 115KV CKT 1	6/1/2015	6/1/2017		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76582673	CHERRY6 230.00 - Harrington Station East Bus 230KV CKT 1	6/1/2015	6/1/2015		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

**Customer**      **Study Number**  
 WFEC              2012-AG1-004

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
WFEC	76548687	CSWS	WFEC	160	6/1/2014	12/31/2035			\$ 2,335,949	\$ -	\$ 2,335,949	\$ 7,818,000
									\$ 2,335,949	\$ -	\$ 2,335,949	\$ 7,818,000

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76548687	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2019	6/1/2019			\$ 2,335,949	\$ 14,500,000	\$ 7,818,000
	<b>Total</b>					\$ 2,335,949	\$ 14,500,000	\$ 7,818,000

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76548687	PAOLI - PAYNE 138.00 138KV CKT 1	6/1/2019	6/1/2019		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76548687	BLUE CANYON - PARADISE 138KV CKT 1	6/1/2010	6/1/2013		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - WOODWARD EHV 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - WOODWARD EHV 138KV CKT 2	1/1/2010	1/1/2010		
	WOODWARD 345/138KV TRANSFORMER CKT 1	1/1/2010	1/1/2010		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76548687	GORE - MUSKOGEE TAP 161KV CKT 1	6/1/2019	6/1/2019			\$ 1,884,277	\$ 8,000,000
	GORE - SALLISAW 161KV CKT 1 Upgrade #1	6/1/2019	6/1/2019			\$ 6,619	\$ 400,000
	<b>Total</b>					\$ 1,890,896	\$ 8,400,000

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
WFEC 2012-AG1-005

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
WFEC	76548692	CSWS	WFEC	90	6/1/2017	12/31/2035			\$ 1,313,971	\$ -	\$ 1,313,971	\$ 5,259,930
									\$ 1,313,971	\$ -	\$ 1,313,971	\$ 5,259,930

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76548692	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2019	6/1/2019			\$ 1,313,971	\$ 14,500,000	\$ 5,259,930
						\$ 1,313,971	\$ 14,500,000	\$ 5,259,930

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76548692	PAOLI - PAYNE 138.00 138KV CKT 1	6/1/2019	6/1/2019		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76548692	BLUE CANYON - PARADISE 138KV CKT 1	6/1/2010	6/1/2013		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1	7/1/2012	7/1/2012		
	WOODWARD - WOODWARD EHV 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - WOODWARD EHV 138KV CKT 2	1/1/2010	1/1/2010		
	WOODWARD 345/138KV TRANSFORMER CKT 1	1/1/2010	1/1/2010		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76548692	GORE - MUSKOGEE TAP 161KV CKT 1	6/1/2019	6/1/2019			\$ 1,059,906	\$ 8,000,000
	GORE - SALLISAW 161KV CKT 1 Upgrade #1	6/1/2019	6/1/2019			\$ 3,723	\$ 400,000
						\$ 1,063,629	\$ 8,400,000

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

\*Credits may be required for applicable generation interconnection network upgrades.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
WFEC 2012-AG1-006

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
WFEC	76548702	CSWS	WFEC	30	6/1/2019	12/31/2035			\$ 437,990	\$ -	\$ 437,990	\$ 1,963,837
									\$ 437,990	\$ -	\$ 437,990	\$ 1,963,837

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76548702	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2019	6/1/2019			\$ 437,990	\$ 14,500,000	\$ 1,963,837
					Total	\$ 437,990	\$ 14,500,000	\$ 1,963,837

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76548702	PAOLI - PAYNE 138.00 138KV CKT 1	6/1/2019	6/1/2019		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76548702	BLUE CANYON - PARADISE 138KV CKT 1	6/1/2010	6/1/2013		
	CIMARRON - DRAPER LAKE 345KV CKT 1	10/1/2014	6/1/2016		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1	7/1/2012	7/1/2012		
	WOODWARD - WOODWARD EHV 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD 345/138KV TRANSFORMER CKT 1	1/1/2010	1/1/2010		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76548702	GORE - MUSKOGEE TAP 161KV CKT 1	6/1/2019	6/1/2019			\$ 353,302	\$ 8,000,000
	GORE - SALLISAW 161KV CKT 1 Upgrade #1	6/1/2019	6/1/2019			\$ 1,241	\$ 400,000
					Total	\$ 354,543	\$ 8,400,000

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

**Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study**

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)	Estimated Engineering & Construction Cost
GRDA	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2	Replace Terminal Equipment	6/1/2019	6/1/2019	\$ 3,300,000
OKGE	DIVISION AVE - LAKESIDE 138KV CKT 1	Rebuild 3.58 mile line with 1590AS52 Conductor	6/1/2019	6/1/2019	\$ 1,720,000
OKGE	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	Install 2nd 500/345 kV bus tie in Ft. Smith Sub	6/1/2019	6/1/2019	\$ 14,500,000
OKGE	HANCOCK - MUSKOGEE 161KV CKT 1 Accelerate	Upgrade the Muskogee CT rating from 800 amps to 1200 amps	6/1/2014	6/1/2016	\$ 27,470
OKGE	HEFNER - TULSA 138KV CKT 1	Reconductor 1.25 miles of line to 1590AS52	6/1/2019	6/1/2019	\$ 750,000
OKGE	MUSKOGEE - MUSKOGEE PORT 161KV CKT 1 Accelerate	Upgrade the Muskogee CT rating from 800 amps to 1200 amps	6/1/2014	6/1/2016	\$ 9,196
OKGE	PECAN CREEK (PECANCK1) 345/161/13.8KV TRANSFORMER CKT 1	Replace Transformer	6/1/2019	6/1/2019	\$ 5,500,000
WERE	CHISHOLM - MAIZEE 4 138.00 138KV CKT 1	Upgrade disconnect switches, wavetrap, breaker, jumpers	6/1/2019	6/1/2019	\$ 827,424

**Construction Pending Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.**

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
MIDW	HAYS PLANT - VINE STREET 115KV CKT 1 #1	Replace Wavetrap	6/1/2014	6/1/2015
MIDW	HAYS PLANT - VINE STREET 115KV CKT 1 #2	Rebuild 0.23 miles	6/1/2014	6/1/2016
MKEC	CIMARRON RIVER PLANT - CIMARRON RIVER TAP 115KV CKT 1	Rebuild 4 miles and Substation work	6/1/2015	6/1/2017
MKEC	CIMARRON RIVER TAP - KISMET 3 115.00 115KV CKT 1	Rebuild 3.37 miles and Substation work	6/1/2015	6/1/2017
MKEC	CLEARWATER - MILAN TAP 138KV CKT 1 MKEC Accelerate	Rebuild MKEC portion of the 5.6 mile Clearwater-Milan Tap 115 kV with bundled 1192.5 kcmil ACSR conductor (Bunting)	1/1/2014	6/1/2017
MKEC	CUDAHY - KISMET 3 115.00 115KV CKT 1	Rebuild 32 miles and Substation work	6/1/2015	6/1/2017
MKEC	HARPER - MILAN TAP 138KV CKT 1 #2 Accelerate	Reconductor 22.1 mile Harper to Milan Tap 138 kV line.	1/1/2014	6/1/2017
OKGE	NORTHWEST 345/138/13.8KV TRANSFORMER CKT 3 Accelerated	Install third 345/138 kV Bus Tie in Northwest Sub	1/1/2014	6/1/2015
SPS	Potter to Tolk 345 kV	Build 111 mile 345 kV line from Potter to Tolk. Further study analysis will be performed with regard to the SPS North-South Stability Limit to determine whether its rating may be increased based on approved SPP Expansion Plan Network Upgrades scheduled to be placed in service. Pending this analysis, the Potter – Tolk 345 kV Service Upgrade requirement will be re-evaluated.	1/1/2014	12/31/2018
WERE	CLEARWATER - MILAN TAP 138KV CKT 1 WERE Accelerate	Rebuild Westar portion of the Clearwater-Milan tap 115 kV with bundled 1192.5 kcmil ACSR conductor (Bunting)	1/1/2014	6/1/2017
WERE	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	Upgrade disconnect switches, wavetrap, breaker, jumpers	6/1/2015	6/1/2015
WERE	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	Rebuild the JEC - Hoyt 345kV line as a single circuit with new conductor, poles, and shield wire and substation work	6/1/2015	6/1/2018

**Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study**

Expansion Plan Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
AEPW	CHAMBER SPRINGS - FARMINGTON AECC 161KV CKT 1	Rebuild and reconductor 11.1-mile 161 kV line from Chamber Springs to Farmington REC with 2-959.6 ACSR/TW. Upgrade wavetraps, CT ratios, and relay settings at Chamber Springs.	6/1/2014	6/1/2015
ITCGP	Line - Clark County - Thistle 345 kV dbl Ckt	Build a new 86 mile double circuit 345 kV line with at least 3000 A capacity from the Thistle 345 kV substation to the new Clark County substation. Build a new 345 kV substation at Thistle with a ring bus and necessary terminal equipment.	1/1/2014	1/1/2015
ITCGP	Line - Spearville - Clark County 345 kV dbl Ckt	Build a new 36 mile double circuit 345 kV line with at least 3000 A capacity from the Spearville substation to the new Clark County substation. Build the Clark County 345 kV substation with a ring bus and necessary terminal equipment.	1/1/2014	1/1/2015
ITCGP	XFR - Thistle 345/138 kV	Install a 400 MVA 345/138 kV transformer at the new 345 kV Thistle substation.	1/1/2014	1/1/2015
KACP	IATAN - NASHUA 345KV CKT 1	Tap Nashua 345kV bus in Hawthorn - St. Joseph 345 kV line. Build new 345 kV line from Iatan to Nashua, Add Nashua 345/161 kV	1/1/2014	6/1/2015
MIDW	HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2	Tear down and rebuild of existing South Hays - Hays Plant 115 kV line. Tentative plans include rebuilding on existing right-of-way with the possibility of re-routing a portion of the line to new right-of-way as necessary.	1/1/2014	6/1/2015
MKEC	HARPER - MILAN TAP 138KV CKT 1 #1	Replace Wave Trap at Harper Substation	10/1/2014	6/1/2016
OKGE	Line - Hitchland - Woodward 345 kV dbl Ckt OKGE	Build a new 92 mile double circuit 345 kV line with at least 3000 A capacity from the Woodward District EHV substation to the SPS interception from the Hitchland substation. Upgrade the Woodward District EHV substation with the necessary breakers and term	1/1/2014	7/1/2014
OKGE	Line - Thistle - Woodward 345 kV dbl Ckt OKGE	Build a new 79 mile double circuit 345 kV line with at least 3000 A capacity from the Woodward District EHV substation to the Kansas/Oklahoma state border towards the Thistle substation. Upgrade the Woodward District EHV substation with the necessary brea	1/1/2014	1/1/2015
OKGE	Line - Tuco - Woodward 345 kV line OKGE	Build new 345 kV line from Woodward EHV to Border - Project costs now include Border reactor substation	1/1/2014	6/1/2014
PW	Line - Thistle - Wichita 345 kV dbl Ckt PW	Build a new 78 mile double circuit 345 kV line with at least 3000 A capacity from the Wichita substation to the new Thistle 345 kV substation.	1/1/2014	1/1/2015
PW	Line - Thistle - Woodward 345 kV dbl Ckt PW	Build a new 30 mile double circuit 345 kV line with at least 3000 A capacity from the Thistle substation to the Kansas/Oklahoma state border towards the Woodward District EHV substation.	1/1/2014	1/1/2015
SPS	Cox Interchange - Kiser 115 kV Ckt 1 #2	Build new 8.7-mile 115 kV line from Cox to new Kiser substation.	1/1/2014	2/28/2014
SPS	Kiser Substation 115/69 kV Ckt 1	Build new substation at Kiser and install a 115/69 kV transformer and 69 kV terminal equipment to connect to the local 69 kV system.	1/1/2014	2/28/2014
SPS	Kress Interchange - Kiser 115 kV Ckt 1	Build new 22-mile 115 kV line from Kress Interchange to new Kiser substation.	1/1/2014	11/30/2014
SPS	Line - Hitchland - Woodward 345 kV dbl Ckt SPS	Build 30 mile double circuit 345 kV line with at least 3000 A capacity from the Hitchland substation to the OGE interception point from the Woodward District EHV substation. Upgrade the Hitchland substation with the necessary breakers and terminal equipme	1/1/2014	7/1/2014
SPS	Line - Tuco - Woodward 345 kV line SPS	Build new 345 kV line from Tuco to OGE Border station near TX/OK Stateline. Install line reactor outside Border station and line reactors at Tuco.	1/1/2014	6/1/2014
WERE	Line - Thistle - Wichita 345 kV dbl Ckt WERE	Upgrade the Wichita substation with the necessary breakers and terminal equipment to accommodate two new 345 kV circuits from the new Thistle 345 kV substation	1/1/2014	1/1/2015
WERE	MOUNDRIDGE 138/115KV TRANSFORMER CKT 2	Install second 138/115 kV transformer at Moundridge. Operate both 138/115 kV transformers normally closed.	1/1/2014	12/1/2014

**Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study**

**Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.**

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
GRDA	412SUB - KANSAS TAP 161KV CKT 1	Remove limiting Element, Line Switches 1200A increase to 2000A	6/1/2015	6/1/2017
GRDA	412SUB - KERR 161KV CKT 1	Replace 161KV,1200A switch with a 2000A Switch at Kerr Substation bus.	6/1/2015	6/1/2017
GRDA	KANSAS TAP - WEST SILOAM SPRINGS 161KV CKT 1 #2	Replace Terminal Equipment	6/1/2015	6/1/2017
GRDA	SILOAM CITY - WEST SILOAM SPRINGS 161KV CKT 1 #2	Replace Terminal Equipment	6/1/2019	6/1/2019
NPPD	Cherry Co - Gentleman 345 kV Ckt1	Build new 345 kV Transmission Line from GGS 345 kV Substation to a new Cherry County 345 kV Substation (76 miles).	1/1/2014	1/1/2018
NPPD	Cherry Co - Holt Co 345 kV Ckt1	Build new 345 kV Transmission Line from new Cherry County 345 kV Substation to new 345 kV Holt County Substation. (Estimated 146 miles).	1/1/2014	1/1/2018
NPPD	Cherry Co 345 kV Terminal Upgrades	Build new Cherry County 345 kV Substation.	1/1/2014	1/1/2018
WERE	BUTLER - WEAVER 138KV CKT 1	Rebuild 16.31 miles	1/1/2014	6/1/2017
WERE	EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1	Rebuild existing line to 345 kV operated as 230 kV using bundled 1590 ACSR conductor. Upgrade terminal equipment at JEC and East Manhattan to a minimum emergency rating of 2000 Amps.	6/1/2019	6/1/2019
WERE	GOODYEAR JUNCTION - NORTHLAND 115KV CKT 1	Rebuild 3.44 miles and replace buses and jumper to at least 187 MVA Summer Rate B	6/1/2014	6/1/2016
WERE	Viola - Clearwater 138KV Ckt1	Build new 138kV line between new Viola substation 345/138 kV transformer and existing Clearwater 138 kV substation.	10/1/2014	6/1/2018
WERE	Viola - Gill 138KV Ckt1	Build new 138kV line between new Viola substation 345/138 kV transformer and existing Gill 138 kV substation.	10/1/2014	6/1/2018
WERE	Viola 345/138kV Transformer Ckt 1	Install new 345/138 kV transformer at Viola substation	10/1/2014	6/1/2018
WFEC	PAOLI - PAYNE 138.00 138KV CKT 1	Reset CT	6/1/2019	6/1/2019

**Network Upgrades requiring credits per Attachment 22 of the SPP OATT.**

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
AEPW	ASHDOWN REC (MILLWOOD) - OKAY 138KV CKT 1	Reconductor and convert line to 138 kV and replace switches at Ashdown REC	7/1/2012	7/1/2012
AEPW	ASHDOWN REC (MILLWOOD) - PATTERSON 138KV CKT 1	Reconductor Line & Convert Line to 138 kV and convert Patterson station to breaker-and-a-half configuration	7/1/2012	7/1/2012
AEPW	BANN - RED SPRINGS REC 138KV CKT 1	Replace 138 kV breakers 3300 & 3310	7/1/2012	7/1/2012
AEPW	EXPLORER GLENPOOL TAP - RIVERSIDE STATION 138KV CKT 1 AEPW	Reconductor 1.82 miles with ACCC. Replace wave trap jumpers at Riverside.	6/1/2009	6/1/2009
AEPW	HUGO POWER PLANT - VALLIANT 345 KV AEPW	Valliant 345 KV line terminal	7/1/2012	7/1/2012
AEPW	MANDEVILTP4 - SE TEXARKANA 138KV CKT 1	Build new Turk-SE Texarkana 138 kV line and add SE Texarkana 138 kV terminal.	7/1/2012	7/1/2012
AEPW	MANDEVILTP4 - TURK 138KV CKT 1	Build new Turk-SE Texarkana 138 kV line and add SE Texarkana 138 kV terminal.	7/1/2012	7/1/2012
AEPW	MCNAB REC - TURK 115KV CKT 1	Build a new two mile, 138 kV, 1590 ACSR line section (operated at 115 kV) from Turk Substation to the existing Okay- Hope 115 kV line to form a Turk - Hope 115 kV line.	7/1/2012	7/1/2012
AEPW	OKAY - TURK 138KV CKT 1	Build two mile, 138 kV, 1590ACSR line section from Turk Sub to existing Okay-Hope 115 kV line and rebuild twelve miles of 115 kV line to Okay Sub to 138 kV, 1590 ACSR , to form a Turk-Okay 138 kV line	7/1/2012	7/1/2012
AEPW	SUGAR HILL - TURK 138KV CKT 1	Build new Turk-Sugar Hill 138 kV line and add Sugar Hill 138 kV terminal.	7/1/2012	7/1/2012
EMDE	SUB 110 - ORONOJO JCT. - SUB 167 - RIVERTON 161KV CKT 1	Reconductor Oronogo 59467 to Riverton 59469 with Bundled 556 ACSR	6/1/2011	6/1/2011
KACP	LACYGNE - WEST GARDNER 345KV CKT 1	KCPL Sponsored Project to Reconductor Line to be In-Service by 6/1/2006	6/1/2006	6/1/2006
MIDW	CIRCLE - RICE_CO 230KV CKT 1	Convert from 115kV to 230kV operation	10/1/2012	11/15/2012
MIDW	LYONS - RICE_CO 115KV CKT 1	Rebuild 11.7 mile line	10/1/2012	4/1/2013
MIDW	RICE_CO 230/115KV TRANSFORMER CKT 1	Add 230/115kV Transformer	10/1/2012	11/15/2012
MKEC	ALEXANDER - PRATT 115KV CKT 1	Rebuild line	12/1/2009	6/1/2013
MKEC	BARBER - SAWYER 115KV CKT 1	Rebuild line	12/1/2009	6/1/2013
MKEC	BARBER (BARBER 4) 138/115/2.72KV TRANSFORMER CKT 1	Upgrade transformer	12/1/2009	6/1/2013
MKEC	CLIFTON - GREENLEAF 115KV CKT 1	Rebuild 14.4 miles	6/1/2011	6/1/2013
MKEC	FLATRDG3 138.00 - MEDICINE LODGE 138KV CKT 1	Rebuild 8.05 mile line	12/1/2009	6/1/2013
MKEC	FLATRDG3 138.00 - HARPER 138KV CKT 1	Rebuild 24.15 mile line	12/1/2009	6/1/2013
MKEC	GREENLEAF - KNOB HILL 115KV CKT 1 MKEC	Rebuild 43.5% Ownership of 20.9 miles	6/1/2013	6/1/2013
NPPD	ALBION - PETERSBURG 115KV CKT 1	Replace Breaker Switch 1106-D and jumpers at Albion. Replace main bus at Petersburg. Upgrade and replace transmission structures on 115 kV line to facilitate 100 degrees Centigrade line operation.	1/1/2013	1/1/2013
NPPD	NELIGH - PETERSBURG 115KV CKT 1	Replace Breaker 1106, jumpers, and 115 kV Switch 1106-D2 at Neligh. Replace main bus at Petersburg. Upgrade and replace transmission structures on 115 kV line to facilitate 100 degrees Centigrade line operation.	1/1/2013	1/1/2013
OKGE	BEELINE - EXPLORER GLENPOOL TAP 138KV CKT 1	Reconductor .92miles of line with Drake ACCC/TW.	6/1/2009	6/1/2009
OKGE	CIMARRON - DRAPER LAKE 345KV CKT 1	Increase capacity of Draper Lake CT and Cimarron wave trap	10/1/2014	6/1/2016
OKGE	EXPLORER GLENPOOL TAP - RIVERSIDE STATION 138KV CKT 1 OKGE	Reconductor 1.82 miles line with Drake ACCC/TW.	6/1/2009	6/1/2009
OKGE	GRACMNT4 138.00 - WASHITA 138KV CKT 2 OKGE	Build 138kV Terminal.	1/1/2012	1/1/2012
OKGE	NORTHWEST - TATONGA 345KV CKT 1	Build 345 kV line	1/1/2010	1/1/2010
OKGE	TATONGA - WOODWARD 345KV CKT 1	Build 345 kV line	1/1/2010	1/1/2010
OKGE	WOODWARD - IODINE 138KV CKT 1	Tap Iodine to Woodward 138 kV line	1/1/2010	1/1/2010
OKGE	WOODWARD - WOODWARD EHV 138KV CKT 1	Build .5 miles of 138 kV and install terminal equipment	1/1/2010	1/1/2010
OKGE	WOODWARD - WOODWARD EHV 138KV CKT 2	Build .5 miles of 138 kV and install terminal equipment	1/1/2010	1/1/2010
OKGE	WOODWARD 345/138KV TRANSFORMER CKT 1	Install 345/138 kV XF	1/1/2010	1/1/2010
SPS	CHERRY6 230.00 - Harrington Station East Bus 230KV CKT 1	Replace wavetrap at Harrington East	6/1/2015	6/1/2015
WERE	DEARING 138KV Capacitor	Dearing 138 kV 20 MVAR Capacitor Addition	6/1/2012	6/1/2012
WERE	LYONS - WHEATLAND 115KV CKT 1 #1	Replace CTs	10/1/2012	7/15/2013
WERE	LYONS - WHEATLAND 115KV CKT 1 #2	Re-rate circuit to 1000 amps	10/1/2012	7/15/2013
WFEC	BLUE CANYON - PARADISE 138KV CKT 1	Upgrade Paradise to Blue Canyon to 1113	6/1/2010	6/1/2013
WFEC	GRACMNT4 138.00 - WASHITA 138KV CKT 2 WFEC	Build approximately 6 miles of 138kV.	1/1/2012	1/1/2012
WFEC	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	New 19 miles 345 kV	7/1/2012	7/1/2012
WFEC	HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1	New 345/138 kV Auto	7/1/2012	7/1/2012



Table 5 - Third Party Facility Constraints

Transmission Owner	UpgradeName	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)	Estimated Engineering & Construction Cost
SWPA	BUFORD 5 161.00 - BULL SHOALS 161KV CKT 1 Upgrade #1	Replace one structure and make two structures floating deadends	6/1/2015	6/1/2016	\$ 125,000
SWPA	BUFORD 5 161.00 - NORFORK 161KV CKT 1 Upgrade #1	Replace two structures	6/1/2015	6/1/2016	\$ 100,000
SWPA	GORE - MUSKOGEE TAP 161KV CKT 1	Rebuild w/ 1192 ACSR. Upgrade terminal equipment.	6/1/2019	6/1/2019	\$ 8,000,000
SWPA	GORE - SALLISAW 161KV CKT 1 Upgrade #1	Replace eight structures	6/1/2019	6/1/2019	\$ 400,000
SWPA	NORTH WARSAW - TRUMAN 161KV CKT 1 SWPA #1	Replace wave trap and CTs at Truman.	10/1/2019	10/1/2019	\$ 70,000