



**Definitive Interconnection
System Impact Study for
Generation Interconnection
Requests**

(DISIS-2013-001-3)

Group 3 and 8 Restudy

July 2014

Generator Interconnection



Revision History

Date	Author	Change Description
07/31/2013	SPP	Report Issued (DISIS-2013-001) – Group 6 Interconnection Requests not included in this issue.
08/30/2013	SPP	Group 6 Interconnection Requests results appended and NRIS withdrawals accounted, Report Re-Posted (DISIS-2013-001-1)
01/31/2014	SPP	Account for Withdrawn Projects, Report Re-Posted (DISIS-2013-001-2)
07/30/2014	SPP	Account for Withdrawn Projects, Report Re-Posted (DISIS-2013-001-3, Group 3 and 8 Restudy)

Executive Summary

Generation Interconnection customers have requested a Definitive Interconnection System Impact Study (DISIS) under the Generation Interconnection Procedures (GIP) in the Southwest Power Pool Open Access Transmission Tariff (OATT). The Interconnection Customers' requests have been clustered together for the following System Impact Cluster Study window which closed March 31, 2013. The customers will be referred to in this study as the DISIS-2013-001 Interconnection Customers. Only study results for those requests within DISIS-2013-001 Group 3 and Group 8 are included within this restudy. The study results for the previous restudy are still valid for the remaining groups included within this DISIS-2013-001. This System Impact Study analyzes the interconnection of a generation interconnection request associated with new Group 3 and Group 8 generation totaling approximately 346.3 MW of new generation which would be located within the transmission systems of American Electric Cooperative Corporation (AEPW), Oklahoma Gas and Electric (OKGE), Sunflower Electric Power Corporation/Mid-Kansas Electric Power LLC (SUNC)/(MKEC). The generation interconnection request has a differing proposed in-service date¹. The generation interconnection request included in this System Impact Cluster Study is listed in Appendix A by its queue number, amount, requested interconnection service, area, requested interconnection point, proposed interconnection point, and the requested in-service date.

Power flow analysis has indicated that for the power flow cases studied, 346.3 MW of nameplate generation may be interconnected with transmission system reinforcements within the SPP transmission system. Dynamic stability and power factor analysis has determined the need for reactive compensation in accordance with FERC Order #661A for wind farm interconnection requests and those requirements are listed for each interconnection request within the contents of this report. Dynamic stability analysis has determined that the transmission system will remain stable with the assigned Network Upgrades and necessary reactive compensation requirements.

In no way does this study guarantee operation for all periods of time. This interconnection study identifies and assigns transmission reinforcements for Energy Resource (ER) interconnection injection constraints (defined as a 20% distribution factor impact) and Network Resource (NR) constraints if requested by the Customer. This interconnection study does not assign transmission reinforcements for all potential transmission constraints. It should be noted that although this study analyzed many of the most probable contingencies, it is not an all-inclusive list and cannot account for every operational situation. Because of this, it is likely that the Customer(s) may be required to reduce their generation output to 0 MW, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

¹ The generation interconnection requests in-service dates will need to be deferred based on the required lead time for the Network Upgrades necessary. The Interconnection Customers that proceed to the Facility Study will be provided a new in-service date based on the Facility Study's time for completion of the Network Upgrades necessary.

The total estimated minimum cost for interconnecting the DISIS-2013-001 Group 3 and Group 8 Interconnection Customers is estimated at \$42,567,553. These costs are shown in Appendix E and F. Interconnection Service to DISIS-2013-001 Interconnection Customers is also contingent upon higher queued customers paying for certain required network upgrades. **The in-service date for the DISIS customers will be deferred until the construction of these network upgrades can be completed.**

These costs do not include the Interconnection Customer Interconnection Facilities as defined by the SPP Open Access Transmission Tariff (OATT). This cost does not include additional network constraints in the SPP transmission system identified and shown in Appendix H.

Network constraints listed in Appendix H are in the local area of the new generation when this generation is injected throughout the SPP footprint for Energy Resource Interconnection Service (ERIS) requests. Certain Interconnection Requests were also studied for Network Resource Interconnection Service (NRIS). Those constraints are also listed in Appendix H. Additional network constraints will have to be verified with a Transmission Service Request (TSR) and associated studies. With a defined source and sink in a TSR, this list of Network Constraints will be refined and expanded to account for all Network Upgrade requirements.

The required interconnection costs listed in Appendix E and F do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP OATT.

Table of Contents

Introduction	1
Model Development.....	2
Identification of Network Constraints.....	5
Determination of Cost Allocated Network Upgrades	6
Required Interconnection Facilities	7
Power Flow Analysis.....	7
Stability Analysis	11
Conclusion.....	13
Appendices.....	14
A: Generation Interconnection Requests Considered for Impact Study	A0
B: Generation Interconnection Requests in Impact Study	B0
C: Study Groupings	C0
D: Proposed Point of Interconnection One Line Diagrams	D0
E: Cost Allocation per Interconnection Request (Including Prior Queued Upgrades)	E0
F: Cost Allocation per Proposed Study Network Upgrade	F0
G: Power Flow Analysis (Constraints Used For Mitigation)	G0
H: Power Flow Analysis (Other Constraints Not Requiring Mitigation)	H0
I: Power Flow Analysis (Constraints from Category C Contingencies)	I0
J: Group 3 Dynamic Stability Analysis Report	J0

Introduction

Pursuant to the Southwest Power Pool (SPP) Open Access Transmission Tariff (OATT), SPP has conducted this Definitive Interconnection System Impact Study (DISIS) for certain generation interconnection requests in the SPP Generation Interconnection Queue. These interconnection requests have been clustered together for the following System Impact Study window which closed March 31, 2013. The customers will be referred to in this study as the DISIS-2013-001 Interconnection Customers. Only study results for those requests within DISIS-2013-001 Group 3 and Group 8 are included within this restudy. The study results for the previous restudy are still valid for the remaining groups included within this DISIS-2013-001. This System Impact Study analyzes the interconnection of a generation interconnection request associated with new Group 3 and Group 8 generation totaling approximately 346.3 MW of new generation which would be located within the transmission systems of American Electric Cooperative Corporation (AEPW), Oklahoma Gas and Electric (OKGE), Sunflower Electric Power Corporation/Mid-Kansas Electric Power LLC (SUNC)/(MKEC). The generation interconnection request has a differing proposed in-service date². The generation interconnection requests included in this System Impact Study are listed in Appendix A by their queue number, amount, requested interconnection service, area, requested interconnection point, proposed interconnection point, and the requested in-service date.

The primary objective of this DISIS is to identify the system constraints associated with connecting the generation to the area transmission system. The Impact Study and other subsequent Interconnection Studies are designed to identify required interconnection facilities, Network Upgrades and other Direct Assignment Facilities needed to accept power into the grid at each specific interconnection receipt point.

² The generation interconnection requests in-service dates will need to be deferred based on the required lead time for the Network Upgrades necessary. The Interconnection Customers that proceed to the Facility Study will be provided a new in-service date based on the completion of the Facility Study.

Model Development

Interconnection Requests Included in the Cluster

SPP has included all interconnection requests that submitted a Definitive Interconnection System Impact Study Agreement no later than March 31, 2013 and were subsequently accepted by Southwest Power Pool under the terms of the Generator Interconnection Procedures (GIP) that became effective March 30, 2010. The interconnection requests that are included in this study are listed in Appendix A.

Affected System Interconnection Request

Also included in this Definitive Interconnection System Impact Study are three Affected System Studies. The Affected System Study Requests have been given the designations: ASGI-2013-001 (11.5MW, Point of Interconnection is PanTex South 115kV), ASGI-2013-002 (18.4 MW, Point of Interconnection is Farmers Electric Tucumcari 115kV), and ASGI-2013-003 (18.4 MW, Point of Interconnection is Farmers Electric Clovis 115kV). ASGI-2013-001 is located on a Customer distribution voltage bus served by the Southwestern Public Service Transmission System. ASGI-2013-001 was studied in Group 5 (Amarillo Area), ASGI-2013-002 and ASGI-2013-003 was studied in Group 6 (southern Texas Panhandle).

Previously Queued Interconnection Requests

The previous queued requests included in this study are listed in Appendix C. In addition to the Base Case Upgrades, the previous queued requests and associated upgrades were assumed to be in-service and added to the Base Case models. These projects were dispatched as Energy Resources with equal distribution across the SPP footprint. Prior queued projects that requested Network Resource Interconnection Service (NRIS) were dispatched in an additional analysis into the balancing authority of the interconnecting transmission owner.

Development of Base Cases

Power Flow

The 2013 series Transmission Service Request (TSR) Models 2014 spring, 2014 summer and winter peak, and the 2019 summer and winter peak, and 2024 summer peak scenario 0 cases were used for this study. After the cases were developed, each of the control areas' resources were then re-dispatched to account for the new generation requests using current dispatch orders.

Dynamic Stability

The 2013 series SPP Model Development Working Group (MDWG) Models 2014 winter, 2015 summer, and 2024 summer peak cases were used as starting points for this study.

Base Case Upgrades

The following facilities are part of the SPP Transmission Expansion Plan, the Balanced Portfolio or recently approved Priority Projects. These facilities have an approved Notification to Construct (NTC) or are in construction stages and were assumed to be in-service at the time of dispatch and added to the base case models. The DISIS-2013-001 Interconnection Customers have not been assigned acceleration costs for the below listed projects. The DISIS-2013-001 Interconnection Customers Generation Facilities in service dates may need to be delayed until the completion of

the following upgrades. If for some reason, construction on these projects is discontinued, additional restudies will be needed to determine the interconnection needs of the DISIS Interconnection Customers.

- **Balanced Portfolio Projects³:**
 - Woodward – Border – TUCO 345kV project, scheduled for 9/30/2014 in-service
 - Woodward 345/138kV circuit #2 autotransformer , placed in-service in 2014
 - TUCO 345/230kV circuit #2 autotransformer, placed in-service in 2014
 - Reactors at Woodward and Border, placed in-service in 2014
 - Iatan – Nashua 345kV, scheduled for 6/1/2015 in-service
 - Nashua 345/161kV autotransformer
 - Muskogee – Seminole 345kV, placed in-service in 2013
- **Priority Projects⁴:**
 - Hitchland – Woodward double circuit 345kV, placed in-service in 2014
 - Hitchland 345/230kV circuit #2 autotransformer, placed in-service in 2014
 - Woodward – Thistle double circuit 345kV, scheduled for 12/31/2014 in-service
 - Spearville – Clark County double circuit 345kV, scheduled for 12/31/2014 in-service
 - Clark County – Thistle double circuit 345kV, scheduled for 12/31/2014 in-service
 - Thistle – Wichita double circuit 345kV, placed in-service in 2014
 - Thistle 345/138kV autotransformer, placed in-service in 2014
 - Thistle – Flat Ridge 138kV, placed in-service in 2014
- Sheldon – SW 7th and Pleasant Hill 115kV circuit #2 rebuild, placed in-service in 2013⁵
- Arcadia – Redbud 345kV circuit #1 and #2 terminal equipment replacement, placed in-service in 2013⁶

Contingent Upgrades

The following facilities do not yet have approval. These facilities have been assigned to higher queued interconnection customers. These facilities have been included in the models for the DISIS-2013-001 study and are assumed to be in service. This list may not be all inclusive. The DISIS-2013-001 Interconnection Customers, at this time, do not have responsibility for these facilities but may later be assigned the cost of these facilities if higher queued customers terminate their Generation Interconnection Agreement or withdraw from the interconnection queue. The DISIS-2013-001 Interconnection Customer Generation Facilities in-service dates may need to be delayed until the completion of the following upgrades.

³ Notification to Construct (NTC) issued June 2009

⁴ Notification to Construct (NTC) issued June 2010

⁵ SPP Regional Reliability 2012 ITPNT Project Per SPP-NTC-200171

⁶ SPP Regional Reliability 2013 ITPNT Project Per SPP-NTC-200204

- Upgrades assigned to ICS-2008-001 Interconnection Customers
- Upgrades assigned to DISIS-2009-001 Interconnection Customers:
 - Lancer Project
 - Spearville – Lancer 345kV addition
 - Lancer 345/115kV transformer circuit #1 addition
 - Lancer – North Ft. Dodge 115kV addition
 - Ft Dodge – North Ft. Dodge circuit #2 addition
 - Move Fort Dodge terminal of Shooting Star 115kV at North Ft Dodge
 - Fort Randall – Meadow Grove – Kelly 230kV circuit #1 rerate (320MVA)
- Upgrades assigned to DISIS-2010-001 Interconnection Customers:
 - Beaver County 345kV Expansion (Tap & Tie Hitchland – Woodward circuit #2 into Beaver County 345kV)
 - Switch 2749 – Wildorado 69kV circuit # 1 rebuild
- Upgrades assigned to DISIS-2010-002 Interconnection Customers:
 - Buckner – Spearville 345kV terminal equipment
 - Twin Church – Dixon County 230kV circuit #1 rerate (320MVA)
- Upgrades assigned to DISIS-2011-001 Interconnection Customers:
 - Hoskins – Dixon County – Twin Church 230kV circuit #1 conductor clearance increase
 - (NRIS only) Glass Mountain – Mooreland – FPL Switch – Woodward 138kV circuit #1 rebuild
 - (NRIS only) New Deal – TUCO Interchange – Stanton 345kV/115kV Project
 - New Deal – TUCO Interchange 345kV circuit #1 build
 - TUCO Interchange – Stanton 115kV circuit #1 build
 - New Deal 345/115/13kV transformer circuit #1 build
- Upgrades assigned to DISIS-2011-002 interconnection Customers:
 - Power System Stabilizers - Install Power System Stabilizers @ Tolk (Units: 1,2) and Jones (Units: 1,2,3,4)
 - Jones – Lubbock South 230kV circuit #2 replace line traps, placed in-service in 2014
 - SUB 967 – SUB 968 – SUB 969 – SUB 974 69kV circuit #1 replace terminal equipment
 - (NRIS only) Hydro Carbon Tap – SUB 974 69kV circuit #1 replace terminal equipment
 - (NRIS only) Nebraska City U Syracuse – SUB 970 circuit #1 replace terminal equipment
- Upgrades assigned to DISIS-2012-001 interconnection Customers:
 - GEN-2011-017 Tap 100MVAR Static VAR Compensator (SVC) and 100 MVAR Capacitor Bank(s)
- Upgrades assigned to DISIS-2012-002 interconnection Customers:
 - Amoco Wasson – Oxy Tap 230kV circuit #1 replace line traps
 - Associated Electric Cooperatives Inc. (AECI) Fairfax 138/69kV circuit #1 replace transformer
 - Lake Creek – Lone Wolf 69kV circuit #1 reset CT
 - Remington – Fairfax 138kV circuit #1 conductor clearance increase
 - Thistle 100MVAR Static VAR Compensator (SVC) and 100 MVAR Capacitor Bank(s)

Potential Upgrades Not in the Base Case

Any potential upgrades that do not have a Notification to Construct (NTC) and not explicitly listed within this report have not been included in the base case. These upgrades include any identified

in the SPP Extra-High Voltage (EHV) overlay plan, or any other SPP planning study other than the upgrades listed above in the previous section.

Regional Groupings

The interconnection requests listed in Appendix A were grouped together into twelve active regional groups based on geographical and electrical impacts. These groupings are shown in Appendix C.

To determine interconnection impacts, fifteen different generation dispatch scenarios of the spring base case models were developed to accommodate the regional groupings.

Power Flow

For each group, the various wind generating plants were modeled at 100% nameplate of maximum generation. The other wind generating plants in each area were modeled at 80% nameplate while the wind generating plants in the other areas were modeled at 20% nameplate of maximum generation. These projects were dispatched as Energy Resources with a load factor by area distribution across the SPP footprint. Certain projects that requested Network Resource Interconnection Service were dispatched in an additional analysis into the balancing authority of the interconnecting transmission owner. This method allowed for the identification of network constraints that were common to the regional groupings that could then in turn have the mitigating upgrade cost allocated throughout the entire cluster. Other sensitivity analyses are also performed with all interconnection requests in each group being dispatched at 100% nameplate.

Peaking units were not dispatched in the 2014 spring model. To study peaking units' impacts, the 2014 summer and winter and 2019 summer and winter, and 2024 summer seasonal models were chosen and peaking units were modeled at 100% of the nameplate rating and wind generating facilities were modeled at 10% of the nameplate rating. Each interconnection request was also modeled separately at 100% nameplate for certain analyses.

Dynamic Stability

For each group, all interconnection requests were studied at 100% nameplate output while the other groups were dispatched at 20% output for wind requests and 100% output for thermal requests.

Identification of Network Constraints

The initial set of network constraints were found by using PSS®MUST First Contingency Incremental Transfer Capability (FCITC) analysis on the entire cluster grouping dispatched at the various levels mentioned above. These constraints were then screened to determine if any of the generation interconnection requests had at least a 20% Distribution Factor (DF) upon the constraint. Constraints that measured at least a 20% DF from at least one interconnection request were considered for mitigation. Interconnection Requests that have requested Network Resource

Interconnection Service (NRIS) were also studied in the NRIS analysis to determine if any constraint had at least a 3% DF. If so, these constraints were also considered for mitigation.

Determination of Cost Allocated Network Upgrades

Cost Allocated Network Upgrades of wind generation interconnection requests were determined using the 2014 spring model. Cost Allocated Network Upgrades of peaking units was determined using the 2019 summer peak model. A PSS®MUST sensitivity analysis was performed to determine the Distribution Factors (DF), a distribution factor with no contingency that each generation interconnection request had on each new upgrade. The impact each generation interconnection request had on each upgrade project was weighted by the size of each request. Finally the costs due by each request for a particular project were then determined by allocating the portion of each request's impact over the impact of all affecting requests.

For example, assume that there are three Generation Interconnection requests, X, Y, and Z that are responsible for the costs of Upgrade Project '1'. Given that their respective PTDF for the project have been determined, the cost allocation for Generation Interconnection request 'X' for Upgrade Project 1 is found by the following set of steps and formulas:

- Determine an Impact Factor on a given project for all responsible GI requests:

$$\text{Request X Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(X) * \text{MW}(X) = X1$$

$$\text{Request Y Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(Y) * \text{MW}(Y) = Y1$$

$$\text{Request Z Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(Z) * \text{MW}(Z) = Z1$$

- Determine each request's Allocation of Cost for that particular project:

$$\text{Request X's Project 1 Cost Allocation (\$)} = \frac{\text{Network Upgrade Project 1 Cost(\$)} * X1}{X1 + Y1 + Z1}$$

- Repeat previous for each responsible GI request for each Project

The cost allocation of each needed Network Upgrade is determined by the size of each request and its impact on the given project. This allows for the most efficient and reasonable mechanism for sharing the costs of upgrades.

Credits for Amounts Advanced for Network Upgrades

Interconnection Customer shall be entitled to credits in accordance with Attachment Z2 of the SPP Tariff for any Network Upgrades including any tax gross-up or any other tax-related payments associated with the Network Upgrades, and not refunded to the Interconnection Customer.

Required Interconnection Facilities

The requirement to interconnect the 346.3 MW of Group 3 and Group 8 generation into the existing and proposed transmission systems in the affected areas of the SPP transmission footprint consist of the necessary cost allocated shared facilities listed in Appendix F by upgrade. The interconnection requirements for Group 3 and Group 8 total an estimated \$42,567,553. Interconnection Facilities specific to each generation interconnection request are listed in Appendix E. A preliminary one-line drawing for the Group 3 and Group 8 generation interconnection request is listed in Appendix D.

A list of constraints that were identified and used for mitigation are listed in Appendix G. Listed within Appendix G are the ERIS constraints with greater than or equal to a 20% DF, as well as, the NRIS constraints that have a DF of 3% or greater. Other Network Constraints which are not requiring mitigation are shown in Appendix H. With a defined source and sink in a TSR, this list of Network Constraints will be refined and expanded to account for all Network Upgrade requirements. Additional constraints identified by NERC category “C” contingencies are listed in Appendix I.

Power Flow Analysis

Power Flow Analysis Methodology

The ACCC function of PSS®E was used to simulate single element and special (i.e., breaker-to-breaker, multi-element, etc) contingencies in portions or all of the modeled control areas of SPP, as well as, other control areas external to SPP and the resulting scenarios analyzed. NERC single and multiple contingencies were evaluated.

Power Flow Analysis

A power flow analysis was conducted for each Interconnection Customer’s facility using modified versions of the 2014 spring peak, 2014 summer and winter peak, and the 2019 summer and winter peak, 2024 summer peak models. The output of the Interconnection Customer’s facility was offset in each model by a reduction in output of existing online SPP generation. This method allows the request to be studied as an Energy Resource Interconnection Service request (ERIS). Certain requests that are pursuing Network Resource Interconnection Service (NRIS) had an additional analysis conducted for displacing resources in the interconnecting Transmission Owner’s balancing authority.

This analysis was conducted assuming that previous queued requests in the immediate area of these interconnect requests were in-service. The analysis of Group 3 and Group Interconnection Customer’s project indicates that criteria violations will occur on the SUNC/MKEC transmission systems under system intact and contingency conditions in the peak seasons.

Cluster Group 1 (Woodward Area)

In addition to the 4,284.6 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No new constraints were found in this area.

Cluster Group 2 (Hitchland Area)

In addition to the 2,662.2 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No new constraints were found in this area.

Cluster Group 3 (Spearville Area)

In addition to the 4,010.4 MW of previously queued generation in the area, 99.0 MW of new interconnection service was studied. Due to higher queued requests and SPP GI assigned network upgrade withdrawals, a new ERIS constraint was identified with the addition of Interconnection Customer GEN-2013-010. The outage of Post Rock – GEN-2013-010 Tapping Substation on Spearville – Post Rock 345kV circuit #1 transmission line causes voltage issues in the Thistle area. To mitigate the voltage issues, an additional 100MVAR Static VAR Compensator (SVC) and 75 MVAR of switchable capacitor bank(s) is needed at Thistle 345kV.

Group 3: ERIS Constraints			
MONITORED ELEMENT	RATE B (MVA)	TC%LOADING (% MVA)	CONTINGENCY
Non-Converged Contingency	-	-	G12-011T 345.00 - POST ROCK 345KV CKT 1

Cluster Group 4/11 (NW Kansas Group)

In addition to the 1,988.1 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No new constraints were found in this area.

Cluster Group 5 (Amarillo Area)

In addition to the 692.6 MW of previously queued generation in the area, 11.5 MW of new interconnection service was studied. No new constraints were found in this area.

This group was not analyzed for this restudy and previously identified results remain valid.

Cluster Group 6 (South Texas Panhandle/New Mexico)

In addition to the 3,091.65 MW of previously queued generation in the area, 488.2 MW of new interconnection service was studied.

This group was not analyzed for this restudy and previously identified results remain valid.

Cluster Group 7 (Southwestern Oklahoma)

In addition to the 1,900.0 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No new constraints were found in this area.

Cluster Group 8 (South Central Kansas/North Oklahoma)

In addition to the 2,757.3 MW of previously queued generation in the area, 247.3 MW of new interconnection service was studied. An additional 1,200 MW of existing generation was studied for Interconnection Requests that share a Point of Interconnection (POI) with the studied

generation. ERIS constraints observed included the Vinita Junction 138/69kV transformer and Vinita – Vinita Junction 69kV circuit #1. Replacement of the Vinita Junction transformer to a larger size along upgrading ac the Vinita – Vinita Junction and upgrading associated terminal equipment will relieve the ERIS overloads. GEN-2013-009 requested a modification to drop Network Resource Interconnection Service. The request was accepted as no lower queued Interconnection Requests were impacted.

Group 8: ERIS Constraints			
MONITORED ELEMENT	RATE B (MVA)	TC%LOADING (% MVA)	CONTINGENCY
VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	122.5414	SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
VINITA - VINITA JUNCTION 69KV CKT 1	69	117.3672	SUB 404 - HOCKERVILLE – VINITA JUNCTION 138KV CKT 1

Group 8: NRIS Constraints			
MONITORED ELEMENT	RATE B (MVA)	TC%LOADING (% MVA)	CONTINGENCY
No NRIS Constraints			

Cluster Group 9/10 (Nebraska)

In addition to the 1,562.7 MW of previously queued generation in the area, 414.2 MW of new interconnection service was studied.

This group was not analyzed for this restudy and previously identified results remain valid.

Cluster Group 12 (Northwest Arkansas)

In addition to the 0.0 MW of previously queued generation in the area, 30.0 MW of new interconnection service was studied. An additional 620.0 MW of existing generation was studied for Interconnection Requests that share a Point of Interconnection (POI) with the studied generation.

This group was not analyzed for this restudy and previously identified results remain valid.

Cluster Group 13 (Northwest Missouri)

In addition to the 285.8 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No new constraints were found in this area.

Cluster Group 14 (South Central Oklahoma)

In addition to the 262.2 MW of previously queued generation in the area, 100.3 MW of new interconnection service was studied.

This group was not analyzed for this restudy and previously identified results remain valid.

Curtailment and System Reliability

In no way does this study guarantee operation for all periods of time. It should be noted that although this study analyzed many of the most probable contingencies, it is not an all-inclusive list and cannot account for every operational situation. Because of this, it is likely that the Customer(s) may be required to reduce their generation output to 0 MW, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Stability Analysis

A stability analysis was conducted for each Interconnection Customer using modified versions of the 2013 series SPP Model Development Working Group (MDWG) Models 2014 winter, 2015 summer, and 2024 summer peak dynamic cases. The stability analysis was conducted with all upgrades in service that were identified in the power flow analysis. For each group, the interconnection requests were studied at 100% nameplate output while the other groups were dispatched at 20% output for wind requests and 100% output for fossil requests. The output of the Interconnection Customer's facility was offset in each model by a reduction in output of existing online SPP generation. The following synopsis is included for each group. The entire stability study for each group can be found in the Appendices section.

Cluster Group 1 (Woodward Area)

The Group 1 stability analysis was not performed again for this restudy. No requests remain in this Group.

Cluster Group 2 (Hitchland Area)

There was no stability analysis conducted in the Hitchland area due to no requests in the area.

Cluster Group 3 (Spearville Area)

The Group 3 stability analysis for this restudy was performed by SPP Staff. The analysis was performed to evaluate the impacts of the removal of the previously assigned Beaver-Buckner 345kV line. Stability analysis has determined that when all previously assigned and currently assigned network upgrades are placed in-service the transmission system will remain stable and low voltage ride through requirements are satisfied for the contingencies studied.

Power Factor analysis was not performed again for this restudy. With the power factor requirements and all network upgrades in service, all interconnection request in Group 3 will meet FERC Order #661A low voltage ride through (LVRT) requirements.

Cluster Group 4/11 (Northwest Kansas Area)

There was no stability analysis conducted in the northwest Kansas area due to no requests in the area.

Cluster Group 5 (Amarillo Area)

The Group 5 stability analysis was not performed again for this restudy. The original analysis in DISIS-2013-001 is still valid.

Cluster Group 6 (South Texas Panhandle/New Mexico)

The Group 6 stability analysis was not performed again for this restudy. The analysis in DISIS-2013-001-2 is still valid.

Cluster Group 7 (Southwest Oklahoma Area)

There was no stability analysis conducted in the southwest Oklahoma area due to no requests in the area.

Cluster Group 8 (South Central Kansas/North Oklahoma)

The Group 8 stability analysis was not performed again for this restudy. The original analysis in DISIS-2013-001 is still valid.

Cluster Group 9/10 (Nebraska)

The Group 9/10 stability analysis was not performed again for this restudy. The original analysis in DISIS-2013-001 is still valid.

Cluster Group 12 (Northwest Arkansas Area)

The Group 12 stability analysis was not performed again for this restudy. The original analysis in DISIS-2013-001 is still valid.

Cluster Group 13 (Northwest Missouri Area)

There was no stability analysis conducted in the Northwest Missouri area due to no requests in the area.

Cluster Group 14 (South Central Oklahoma)

The Group 14 stability analysis was not performed again for this restudy. The original analysis in DISIS-2013-001 is still valid.

Conclusion

Only study results for those requests within DISIS-2013-001 Group 3 and Group 8 are included within this restudy. The minimum cost of Group 3 and Group 8 interconnecting 346.3 MW of new interconnection requests included in this Definitive Interconnection System Impact Study is estimated at \$42,567,553 for the Allocated Network Upgrades and Transmission Owner Interconnection Facilities are listed in Appendix E and F. These costs do not include the cost of upgrades of other transmission facilities listed in Appendix H which are Network Constraints.

These interconnection costs do not include any cost of Network Upgrades determined to be required by short circuit analysis. These studies will be performed if the Interconnection Customer executes the appropriate Interconnection Facilities Study Agreement and provides the required data along with demonstration of Site Control and the appropriate deposit. At the time of the Interconnection Facilities Study, a better determination of the interconnection facilities may be available.

The required interconnection costs listed in Appendices E, and F, and other upgrades associated with Network Constraints do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request (TSR) through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP Open Access Transmission Tariff (OATT).

Appendices

A: Generation Interconnection Requests Considered for Impact Study

See next page.

A: Generation Interconnection Requests Considered for Impact Restudy

Request	Amount	Service	Area	Requested Point of Interconnection	Proposed Point of Interconnection	Requested In-Service Date	In Service Date Delayed Until no earlier than*
GEN-2013-009	100.30	ER	AEPW	Tap Northeastern - Vinita 138kV	Tap Alluwe Tap - Vinita Junction 138kV	12/31/2015	TBD
GEN-2013-010	99.00	ER	SUNCMKEC	Tap Spearville - Post Rock 345kV	Tap Spearville - Post Rock 345kV (GEN-2012-011 Tap)	12/31/2015	TBD
GEN-2013-012	147.00	ER	OKGE	Redbud 345kV	Redbud 345kV	11/30/2014	TBD
Total:		346.30					

Requests included in Appendix A are those found to be affected and considered for this system impact restudy.

B: Generation Interconnection Requests in Impact Study

See next page.

B: Generation Interconnection Requests in Impact Study

Request	Amount	Service	Area	Requested Point of Interconnection	Proposed Point of Interconnection	Requested In-Service Date	In Service Date Delayed Until no earlier than*
ASGI-2013-001	11.50	ER	SPS	PanTex South 115kV	PanTex South 115kV		
ASGI-2013-002	18.40	ER	SPS	FE Tucumcari 115kV	FE Tucumcari 115kV		
ASGI-2013-003	18.40	ER	SPS	FE Clovis 115kV	FE Clovis 115kV		
GEN-2012-005	81.00	ER/NR	NPPD	Tap Fort Randall - Columbus (North of Meadow Grove) 230kV	Tap Fort Randall - Columbus (North of Meadow Grove) 230kV	6/1/2015	TBD
GEN-2013-002	50.60	ER/NR	LES	Tap Sheldon - Folsom & Pleasant Hill 115kV CKT 2	Tap Sheldon - Folsom & Pleasant Hill 115kV CKT 2	12/31/2013	TBD
GEN-2013-004	6.00	ER/NR	NPPD	Tap Fort Randall - Columbus (Meadow Grove) 230kV	Tap Fort Randall - Columbus (Meadow Grove) 230kV	1/1/2014	TBD
GEN-2013-005	73.50	ER/NR	NPPD	Meadow Grove (GEN-2008-086N2 Sub) 230kV	Meadow Grove (GEN-2008-086N2 Sub) 230kV	12/31/2014	TBD
GEN-2013-006	50.60	ER	NPPD	Tap Fort Randall - Columbus (Meadow Grove) 230kV	Tap Fort Randall - Columbus (Meadow Grove) 230kV	10/1/2014	TBD
GEN-2013-007	100.30	ER/NR	OKGE	Tap Prices Falls - Carter 138kV	Tap Prices Falls - Carter 138kV	12/31/2014	TBD
GEN-2013-008	1.20	ER	NPPD	Steele City 115kV	Steele City 115kV	12/31/2013	
GEN-2013-009	100.30	ER	AEPW	Tap Northeastern - Vinita 138kV	Tap Alluwe Tap - Vinita Junction 138kV	12/31/2015	TBD
GEN-2013-010	99.00	ER	SUNCMKEC	Tap Spearville - Post Rock 345kV	Tap Spearville - Post Rock 345kV (GEN-2012-011 Tap)	12/31/2015	TBD
GEN-2013-011	30.00	ER	AEPW	Turk 138kV	Turk 138kV		TBD
GEN-2013-012	147.00	ER	OKGE	Redbud 345kV	Redbud 345kV	11/30/2014	TBD
GEN-2013-013	248.40	ER/NR	SPS	Tap Eddy County - Tolk 345kV	Tap Eddy County - Tolk (Crossroads) 345kV	12/1/2014	TBD
GEN-2013-014	25.50	ER/NR	NPPD	Tap Guide Rock - Pauline (GEN-2008-123N Tap) 115kV	Tap Guide Rock - Pauline (GEN-2008-123N Tap) 115kV	12/31/2014	TBD
GEN-2013-015	125.80	ER/NR	NPPD	Tap Pauline - Hildreth 115kV	Tap Pauline - Hildreth 115kV	12/31/2015	TBD
GEN-2013-016	203.00	ER	SPS	TUCO 345kV	TUCO 345kV	12/1/2016	TBD
Total: 1,390.50							

Appendix B is a complete list of Generation Interconnection Requests in the original system impact study.

C: Study Groupings

See next page

C. Study Groups

GROUP 1: WOODWARD AREA			
Request	Capacity	Area	Proposed Point of Interconnection
GEN-2001-014	96.00	WFEC	Ft Supply 138kV
GEN-2001-037	100.00	OKGE	FPL Moreland Tap 138kV
GEN-2005-008	120.00	OKGE	Woodward 138kV
GEN-2006-024S	19.80	WFEC	Buffalo Bear Tap 69kV
GEN-2006-046	131.00	OKGE	Dewey 138kV
GEN-2007-021	201.00	OKGE	Tatonga 345kV
GEN-2007-043	200.00	OKGE	Minco 345kV
GEN-2007-044	300.00	OKGE	Tatonga 345kV
GEN-2007-050	170.00	OKGE	Woodward EHV 138kV
GEN-2007-062	765.00	OKGE	Woodward EHV 345kV
GEN-2008-003	101.00	OKGE	Woodward EHV 138kV
GEN-2008-044	197.80	OKGE	Tatonga 345kV
GEN-2010-011	29.70	OKGE	Tatonga 345kV
GEN-2010-040	300.00	OKGE	Cimarron 345kV
GEN-2011-007	250.10	OKGE	Tap Cimarron - Woodring (Mathewson) 345kV
GEN-2011-010	100.80	OKGE	Minco 345kV
GEN-2011-019	299.00	OKGE	Woodward 345kV
GEN-2011-020	299.00	OKGE	Woodward 345kV
GEN-2011-051	104.40	OKGE	Tap Woodward - Tatonga 345kV
GEN-2011-054	300.00	OKGE	Cimarron 345kV
GEN-2012-031	200.00	OKGE	Cimarron 345kV (GEN-2010-040 Sub)
PRIOR QUEUED SUBTOTAL	4,284.60		
AREA TOTAL	4,284.60		

GROUP 2: HITCHLAND AREA			
Request	Capacity	Area	Proposed Point of Interconnection
ASGI-2011-002	20.00	SPS	Herring 115kV
GEN-2002-008	240.00	SPS	Hitchland 345kV
GEN-2002-009	80.00	SPS	Hansford 115kV
GEN-2003-020	160.00	SPS	Martin 115kV
GEN-2006-020S	18.90	SPS	DWS Frisco 115kV
GEN-2006-044	370.00	SPS	Hitchland 345kV
GEN-2007-046	199.50	SPS	Hitchland 115kV
GEN-2008-047	300.00	OKGE	Tap Hitchland - Woodward Dbl Ckt (Beaver County) 345kV
GEN-2010-001	300.00	OKGE	Tap Hitchland - Woodward Dbl Ckt (Beaver County) 345kV
GEN-2010-014	358.80	SPS	Hitchland 345kV
GEN-2011-014	201.00	OKGE	Tap Hitchland - Woodward Dbl Ckt (Beaver County) 345kV
GEN-2011-022	299.00	SPS	Hitchland 345kV
SPS Distributed (Dumas 19th St)	20.00	SPS	Dumas 19th Street 115kV
SPS Distributed (Etter)	20.00	SPS	Etter 115kV
SPS Distributed (Moore E)	25.00	SPS	Moore East 115kV
SPS Distributed (Sherman)	20.00	SPS	Sherman 115kV
SPS Distributed (Spearman)	10.00	SPS	Spearman 69kV
SPS Distributed (TC-Texas County)	20.00	SPS	Texas County 115kV
PRIOR QUEUED SUBTOTAL	2,662.20		
AREA TOTAL	2,662.20		

GROUP 3: SPEARVILLE AREA			
Request	Capacity	Area	Proposed Point of Interconnection
ASGI-2012-006	22.50	SUNCMKEC	Tap Hugoton - Rolla 69kV
GEN-2001-039A	105.00	SUNCMKEC	Tap Greensburg - Ft Dodge (Shooting Star Tap) 115kV
GEN-2002-025A	150.00	SUNCMKEC	Spearville 230kV
GEN-2004-014	154.50	SUNCMKEC	Spearville 230kV
GEN-2005-012	250.00	SUNCMKEC	Ironwood 345kV
GEN-2006-006	205.50	SUNCMKEC	Spearville 345kV
GEN-2006-021	101.00	SUNCMKEC	Flat Ridge Tap 138kV
GEN-2007-040	200.00	SUNCMKEC	Buckner 345kV
GEN-2008-018	250.00	SPS	Finney 345kV
GEN-2008-079	99.20	SUNCMKEC	Tap Cudahy - Ft Dodge 115kV
GEN-2008-124	200.10	SUNCMKEC	Ironwood 345kV
GEN-2010-009	165.60	SUNCMKEC	Buckner 345kV
GEN-2010-015	200.10	SUNCMKEC	Spearville 345kV
GEN-2010-045	197.80	SUNCMKEC	Buckner 345kV
GEN-2011-008	600.00	SUNCMKEC	Clark County 345kV
GEN-2011-016	200.10	SUNCMKEC	Spearville 345kV
GEN-2011-017	299.00	SUNCMKEC	Tap Spearville - PostRock (GEN-2011-017T) 345kV
GEN-2012-007	120.00	SUNCMKEC	Rubart 115kV
GEN-2012-011	200.00	SUNCMKEC	Tap Spearville - Post Rock 345kV (North of GEN-2011-017 Tap)
GEN-2012-024	180.00	SUNCMKEC	Clark County 345kV
Gray County Wind (Montezuma)	110.00	SUNCMKEC	Gray County Tap 115kV
PRIOR QUEUED SUBTOTAL	4,010.40		
GEN-2013-010	99.00	SUNCMKEC	Tap Spearville - Post Rock 345kV (GEN-2012-011 Tap)
CURRENT CLUSTER SUBTOTAL	99.00		
AREA TOTAL	4,109.40		

GROUP 4/11: NW KANSAS AREA

Request	Capacity	Area	Proposed Point of Interconnection
GEN-2001-039M	100.00	SUNCMKEC	Central Plains Tap 115kV
GEN-2003-006A	200.00	SUNCMKEC	Elm Creek 230kV
GEN-2003-019	250.00	MIDW	Smoky Hills Tap 230kV
GEN-2006-031	75.00	MIDW	Knoll 115kV
GEN-2006-040	108.00	SUNCMKEC	Mingo 115kV
GEN-2007-011	135.00	SUNCMKEC	Syracuse 115kV
GEN-2008-017	300.00	SUNCMKEC	Setab 345kV
GEN-2008-092	201.00	MIDW	Post Rock 230kV
GEN-2009-008	199.50	MIDW	South Hays 230kV
GEN-2009-020	48.60	MIDW	Tap Nekoma - Bazine (Walnut Creek) 69kV
GEN-2010-048	70.00	MIDW	Tap Beach Station - Redline 115kV
GEN-2010-057	201.00	MIDW	Rice County 230kV
GEN-2012-026	100.00	MIDW	Colby 115kV
PRIOR QUEUED SUBTOTAL	1,988.10		
AREA TOTAL	1,988.10		

GROUP 5: AMARILLO AREA

Request	Capacity	Area	Proposed Point of Interconnection
GEN-2002-022	240.00	SPS	Bushland 230kV
GEN-2008-051	322.00	SPS	Potter County 345kV
GEN-2008-088	50.60	SPS	Vega 69kV
Llano Estacado (White Deer)	80.00	SPS	Llano Wind 115kV
PRIOR QUEUED SUBTOTAL	692.60		
ASGI-2013-001	11.50	SPS	PanTex South 115kV
CURRENT CLUSTER SUBTOTAL	11.50		
AREA TOTAL	704.10		

GROUP 6: S-TX PANHANDLE/W-TX AREA

Request	Capacity	Area	Proposed Point of Interconnection
ASGI-2010-010	42.20	SPS	Lovington 115kV
ASGI-2010-020	30.00	SPS	Tap LE-Tatum - LE-Crossroads 69kV
ASGI-2010-021	15.00	SPS	Tap LE-Saunders Tap - LE-Anderson 69kV
ASGI-2011-001	28.80	SPS	Lovington 115kV
ASGI-2011-003	10.00	SPS	Hendricks 115kV
ASGI-2011-004	20.00	SPS	Pleasant Hill 69kV
ASGI-2012-002	18.15	SPS	FE-Clovis Interchange 115kV
GEN-2001-033	180.00	SPS	San Juan Tap 230kV
GEN-2001-036	80.00	SPS	Norton 115kV
GEN-2006-018	170.00	SPS	TUCO Interchange 230kV
GEN-2006-026	604.00	SPS	Hobbs 230kV & Hobbs 115kV
GEN-2008-022	300.00	SPS	Tap Eddy County - Tolk (Crossroads) 345kV
GEN-2010-006	205.00	SPS	Jones 230kV
GEN-2010-046	56.00	SPS	TUCO Interchange 230kV
GEN-2011-025	82.30	SPS	Tap Floyd County - Crosby County 115kV
GEN-2011-045	205.00	SPS	Jones 230kV
GEN-2011-046	27.00	SPS	Lopez 115kV
GEN-2011-048	175.00	SPS	Mustang 230kV
GEN-2012-001	61.20	SPS	Tap Grassland - Borden County 230kV
GEN-2012-009	15.00	SPS	Mustang 230kV
GEN-2012-010	15.00	SPS	Mustang 230kV
GEN-2012-020	478.00	SPS	TUCO 230kV
GEN-2012-034	7.00	SPS	Mustang 230kV
GEN-2012-035	7.00	SPS	Mustang 230kV
GEN-2012-036	7.00	SPS	Mustang 230kV
GEN-2012-037	203.00	SPS	TUCO 345kV
SPS Distributed (Hopi)	10.00	SPS	Hopi 115kV
SPS Distributed (Jal)	10.00	SPS	S_Jal 115kV
SPS Distributed (Lea Road)	10.00	SPS	Lea Road 115kV
SPS Distributed (Monument)	10.00	SPS	Monument 115kV
SPS Distributed (Ocotillo)	10.00	SPS	S_Jal 115kV
PRIOR QUEUED SUBTOTAL	3,091.65		
ASGI-2013-002	18.40	SPS	FE Tucumcari 115kV
ASGI-2013-003	18.40	SPS	FE Clovis 115kV
GEN-2013-013	248.40	SPS	Tap Eddy County - Tolk (Crossroads) 345kV
GEN-2013-016	203.00	SPS	TUCO 345kV
CURRENT CLUSTER SUBTOTAL	488.20		
AREA TOTAL	3,579.85		

GROUP 7: SW-OKLAHOMA AREA			
Request	Capacity	Area	Proposed Point of Interconnection
GEN-2001-026	74.00	WFEC	Washita 138kV
GEN-2002-005	120.00	WFEC	Red Hills Tap 138kV
GEN-2003-004	100.00	WFEC	Washita 138kV
GEN-2003-005	100.00	WFEC	Anadarko - Paradise (Blue Canyon) 138kV
GEN-2003-022	120.00	AEPW	Washita 138kV
GEN-2004-020	27.00	AEPW	Washita 34.5kV
GEN-2004-023	20.60	WFEC	Washita 138kV
GEN-2005-003	30.60	WFEC	Washita 138kV
GEN-2006-002	101.00	AEPW	Sweetwater 230kV
GEN-2006-035	225.00	AEPW	Sweetwater 230kV
GEN-2006-043	99.00	AEPW	Sweetwater 230kV
GEN-2007-032	150.00	WFEC	Tap Clinton Junction - Clinton 138kV
GEN-2007-052	150.00	WFEC	Anadarko 138kV
GEN-2008-023	150.00	AEPW	Hobart Junction 138kV
GEN-2008-037	101.00	WFEC	Tap Washita - Blue Canyon Wind 138kV
GEN-2011-037	7.00	WFEC	Blue Canyon 5 138kV
GEN-2011-049	250.00	OKGE	Border 345kV
GEN-2012-028	74.80	WFEC	Gotebo 69kV
PRIOR QUEUED SUBTOTAL	1,900.00		
AREA TOTAL	1,900.00		

GROUP 8: N-OK/S-KS AREA			
Request	Capacity	Area	Proposed Point of Interconnection
ASGI-2010-006	150.00	AECI	Tap Fairfax (AECI) - Shilder (AEPW) 138kV
GEN-2002-004	200.00	WERE	Latham 345kV
GEN-2005-013	201.00	WERE	Tap Latham - Neosho (Caney River) 345kV
GEN-2007-025	300.00	WERE	Viola 345kV
GEN-2008-013	300.00	OKGE	Tap Wichita - Woodring (Hunter) 345kV
GEN-2008-021	42.00	WERE	Wolf Creek 345kV
GEN-2008-098	100.80	WERE	Tap Lacygne - Wolf Creek (Anderson County) 345kV
GEN-2009-025	60.00	OKGE	Nardins 69kV
GEN-2010-003	100.80	WERE	Tap Lacygne - Wolf Creek (Anderson County) 345kV
GEN-2010-005	300.00	WERE	Viola 345kV
GEN-2010-055	4.50	AEPW	Wekiwa 138kV
GEN-2011-057	150.40	WERE	Creswell 138kV
GEN-2012-023	115.00	WERE	Viola 345kV
GEN-2012-027	136.00	AEPW	Shidler 138kV
GEN-2012-032	300.00	OKGE	Tap Rose Hill - Sooner (Ranch) 345kV
GEN-2012-033	98.80	OKGE	Tap and Tie South 4th - Bunch Creek & Enid Tap - Fairmont (GEN-2012-033T) 138kV
GEN-2012-040	76.50	WFEC	Chilocco 138kV
GEN-2012-041	121.50	OKGE	Tap Rose Hill - Sooner 345kV
PRIOR QUEUED SUBTOTAL	2,757.30		
GEN-2013-009	100.30	AEPW	Tap Alluwe Tap - Vinita Junction 138kV
GEN-2013-012	147.00	OKGE	Redbud 345kV
CURRENT CLUSTER SUBTOTAL	247.30		
AREA TOTAL	3,004.60		

GROUP 9/10: NEBRASKA AREA			
Request	Capacity	Area	Proposed Point of Interconnection
GEN-2002-023N	0.80	NPPD	Harmony 115kV
GEN-2003-021N	75.00	NPPD	Ainsworth Wind Tap 115kV
GEN-2004-023N	75.00	NPPD	Columbus Co 115kV
GEN-2006-020N	42.00	NPPD	Bloomfield 115kV
GEN-2006-037N1	75.00	NPPD	Broken Bow 115kV
GEN-2006-038N005	80.00	NPPD	Broken Bow 115kV
GEN-2006-038N019	80.00	NPPD	Petersburg North 115kV
GEN-2006-044N	40.50	NPPD	North Petersburg 115kV
GEN-2007-011N08	81.00	NPPD	Bloomfield 115kV
GEN-2008-086N02	200.00	NPPD	Tap Ft Randle - Columbus (Meadow Grove) 230kV
GEN-2008-1190	60.00	OPPD	S1399 161kV
GEN-2008-123N	89.70	NPPD	Tap Guide Rock - Pauline (Rosemont) 115kV
GEN-2009-040	108.00	WERE	Marshall 115kV
GEN-2010-041	10.50	OPPD	S 1399 161kV
GEN-2010-051	200.00	NPPD	Tap Twin Church - Hoskins 230kV
GEN-2011-018	73.60	NPPD	Steele City 115kV
GEN-2011-027	120.00	NPPD	Tap Twin Church - Hoskins 230kV (GEN-2010-51 Tap)
GEN-2011-055	52.80	OPPD	South Sterling 69kV
GEN-2011-056	3.60	NPPD	Jeffrey 115kV
GEN-2011-056A	3.60	NPPD	John 1 115kV
GEN-2011-056B	4.50	NPPD	John 2 115kV
GEN-2012-021	4.80	LES	Terry Bundy Generating Station 115kV
NPPD Distributed (Broken Bow)	8.30	NPPD	Broken Bow 115kV
NPPD Distributed (Burt County Wind)	12.00	NPPD	Tekamah & Oakland 115kV
NPPD Distributed (Burwell)	3.00	NPPD	Ord 115kV
NPPD Distributed (Columbus Hydro)	45.00	NPPD	Columbus 115kV
NPPD Distributed (Ord)	11.90	NPPD	Ord 115kV
NPPD Distributed (Stuart)	2.10	NPPD	Ainsworth 115kV
PRIOR QUEUED SUBTOTAL	1,562.70		
GEN-2012-005	81.00	NPPD	Tap Fort Randall - Columbus (North of Meadow Grove) 230kV
GEN-2013-002	50.60	LES	Tap Sheldon - Folsom & Pleasant Hill 115kV CKT 2
GEN-2013-004	6.00	NPPD	Tap Fort Randall - Columbus (Meadow Grove) 230kV
GEN-2013-005	73.50	NPPD	Meadow Grove (GEN-2008-086N2 Sub) 230kV
GEN-2013-006	50.60	NPPD	Tap Fort Randall - Columbus (Meadow Grove) 230kV
GEN-2013-008	1.20	NPPD	Steele City 115kV
GEN-2013-014	25.50	NPPD	Tap Guide Rock - Pauline (GEN-2008-123N Tap) 115kV
GEN-2013-015	125.80	NPPD	Tap Pauline - Hildreth 115kV
CURRENT CLUSTER SUBTOTAL	414.20		
AREA TOTAL	1,976.90		

GROUP 12: NW-AR AREA

Request	Capacity	Area	Proposed Point of Interconnection
GEN-2013-011	30.00	AEPW	Turk 138kV
CURRENT CLUSTER SUBTOTAL	30.00		
AREA TOTAL	30.00		

GROUP 13: NW MISSOURI AREA

Request	Capacity	Area	Proposed Point of Interconnection
GEN-2008-129	80.00	MIPU	Pleasant Hill 161kV
GEN-2010-036	4.60	WERE	6th Street 115kV
GEN-2010-056	151.20	MIPU	Tap Saint Joseph - Cooper 345kV
GEN-2011-011	50.00	KACP	Iatan 345kV
PRIOR QUEUED SUBTOTAL	285.80		
AREA TOTAL	285.80		

GROUP 14: S-OKLAHOMA AREA

Request	Capacity	Area	Proposed Point of Interconnection
GEN-2011-040	111.00	OKGE	Tap Ratliff - Pooleville (Carter County) 138kV
GEN-2011-050	109.80	AEPW	Santa Fe Station 138kV
GEN-2012-004	41.40	OKGE	Tap Ratliff - Pooleville (Carter County) 138kV
PRIOR QUEUED SUBTOTAL	262.20		
GEN-2013-007	100.30	OKGE	Tap Prices Falls - Carter 138kV
CURRENT CLUSTER SUBTOTAL	100.30		
AREA TOTAL	362.50		


CLUSTER TOTAL (CURRENT STUDY)	1,390.5	MW
PQ TOTAL (PRIOR QUEUED)	23,497.6	MW
CLUSTER TOTAL (INCLUDING PRIOR QUEUED)	24,888.1	MW

D: Proposed Point of Interconnection One Line Diagrams

GEN-2013-009

****Refer to Facility Study for an updated one-line****

GEN-2013-010



GEN-2013-012

****Refer to Facility Study for an updated one-line****

E: Cost Allocation per Interconnection Request (Including Prior Queued Upgrades)

Important Note:

****WITHDRAWAL OF HIGHER QUEUED PROJECTS WILL CAUSE A RESTUDY
AND MAY RESULT IN HIGHER INTERCONNECTION COSTS****

This section shows the Group 3 and Group 8 Generation Interconnection Request Customer, their current study impacted Network Upgrades, and the previously allocated upgrades upon which they rely to accommodate their interconnection to the transmission system.

The costs associated with the current study Network Upgrades are allocated to the Customer shown in this report.

In addition should a higher queued request, defined as one this study includes as a prior queued request, withdraw, the Network Upgrades assigned to the withdrawn request may be reallocated to the remaining requests that have an impact on the Network Upgrade under a restudy. Also, should an Interconnection Request choose to go into service prior to the operation date of any necessary Network Upgrades, the costs associated with those upgrades may be reallocated to the impacted Interconnection Request. The actual costs allocated to each Generation Interconnection Request Customer will be determined at the time of a restudy.

The required interconnection costs listed do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP OATT. In addition, costs associated with a short circuit analysis will be allocated should the Interconnection Request Customer choose to execute a Facility Study Agreement.

There may be additional costs allocated to the Group 3 and Group 8 Customer. See Appendix F for more details.

Appendix E. Cost Allocation Per Request

(Including Previously Allocated Network Upgrades*)

Interconnection Request and Upgrades	Upgrade Type	Allocated Cost	Upgrade Cost
GEN-2013-009			
GEN-2013-009 Interconnection Costs See Facility Study for One-Line Diagram and Cost Allocation	Current Study	\$8,650,000.00	\$8,650,000.00
Vinita - Vinita Junction 69kV CKT 1 Replace terminal equipment	Current Study	\$1,038,535.00	\$1,038,535.00
Vinita Junction 138/69/13.2kV Transformer CKT 1 Replace existing Vinita Junction transformer	Current Study	\$3,939,904.00	\$3,939,904.00
Arcadia - Redbud 345kV Dbl CKT 1 Per 2014 ITP NT: Upgrade terminal equipment for both circuits	In-Service		\$1,010,523.00
	Current Study Total	\$13,628,439.00	
GEN-2013-010			
GEN-2013-010 Interconnection Costs See One-Line Diagram.	Current Study	\$1,939,114.00	\$1,939,114.00
Thistle 345kV Additional Reactive Power Support Add additional Thistle +100MVAR SVC and 75MVAR Switchable Capacitor Bank(s).	Current Study	\$27,000,000.00	\$27,000,000.00
Border - Woodward 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)	In-Service		\$249,247,072.00
Hitchland - Woodward 345kV Dbl CKT Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	In-Service		\$226,040,727.00
Hitchland 345/230kV Autotransformer CKT 2 Priority Project: Hitchland 345/230kV Autotransformer CKT 2 (Total Project E&C Cost Shown).	In-Service		\$8,883,760.00
Thistle - Wichita 345KV Dbl CKT Priority Project: Thistle - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)	In-Service		\$426,504,292.00
Woodward XFMR 345/138/13.8kV CKT 2 Balanced Portfolio: Woodward 345/138kV Transformer CKT 2 & 50 MVAR Reactor (Total Project E&C Cost Shown).	In-Service		\$249,247,072.00
Beaver County 345kV Expansion Beaver County Expansion: Tap & Tie in Hitchland - Woodward 345kV CKT 2	Previously Allocated		\$3,500,000.00
Bucker - Spearville 345V CKT 1 Replace Terminal equipment	Previously Allocated		\$771,000.00

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

Interconnection Request and Upgrades	Upgrade Type	Allocated Cost	Upgrade Cost
Clark - Thistle 345KV Dbl CKT Priority Project: Spearville - Clark - Thistle Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$426,504,292.00
GEN-2011-017 Tap 345kV Reactive Power Support Build GEN-2011-017 Tap +100MVAR SVC and 100MVAR Switchable Capacitor Bank(s).	Previously Allocated		\$30,000,000.00
Spearville - Clark 345KV Dbl CKT Priority Project: Spearville - Clark - Thistle Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$426,504,292.00
Thistle 345kV Reactive Power Support Build Thistle +100MVAR SVC and 100MVAR Switchable Capacitor Bank(s).	Previously Allocated		\$30,000,000.00
	Current Study Total	\$28,939,114.00	
GEN-2013-012			
GEN-2013-012 Interconnection Costs See Facility Study for One-Line Diagram and Cost Allocation	Current Study	\$0.00	\$0.00
Arcadia - Redbud 345kV Dbl CKT 1 Per 2014 ITP NT: Upgrade terminal equipment for both circuits	In-Service		\$1,010,523.00
	Current Study Total	\$0.00	
TOTAL CURRENT STUDY COSTS:		\$42,567,553.00	

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

F: Cost Allocation per Proposed Study Network Upgrade

Important Note:

****WITHDRAWAL OF HIGHER QUEUED PROJECTS WILL CAUSE A RESTUDY
AND MAY RESULT IN HIGHER INTERCONNECTION COSTS****

This section shows each Direct Assigned Facility and Network Upgrade and the Generation Interconnection Request Customer(s) which have an impact in this study assuming all higher queued projects remain in the queue and achieve commercial operation.

The required interconnection costs listed do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP OATT. In addition, costs associated with a short circuit analysis will be allocated should the Interconnection Request Customer choose to execute a Facility Study Agreement.

There may be additional costs allocated to each Customer. See Appendix E for more details.

Appendix F. Cost Allocation by Upgrade

GEN-2013-009 Interconnection Costs **\$8,650,000.00**

See Facility Study for One-Line Diagram and Cost Allocation

GEN-2013-009 \$8,650,000.00

Total Allocated Costs **\$8,650,000.00**

GEN-2013-010 Interconnection Costs **\$1,939,114.00**

See One-Line Diagram.

GEN-2013-010 \$1,939,114.00

Total Allocated Costs **\$1,939,114.00**

GEN-2013-012 Interconnection Costs **\$0.00**

See Facility Study for One-Line Diagram and Cost Allocation

GEN-2013-012 \$0.00

Total Allocated Costs **\$0.00**

Thistle 345kV Additional Reactive Power Support **\$27,000,000.00**

Add additional Thistle +100MVAR SVC and 75MVAR Switchable Capacitor Bank(s).

GEN-2013-010 \$27,000,000.00

Total Allocated Costs **\$27,000,000.00**

Vinita - Vinita Junction 69kV CKT 1 **\$1,038,535.00**

Replace terminal equipment

GEN-2013-009 \$1,038,535.00

Total Allocated Costs **\$1,038,535.00**

Vinita Junction 138/69/13.2kV Transformer CKT 1 **\$3,939,904.00**

Replace existing Vinita Junction transformer

GEN-2013-009 \$3,939,904.00

Total Allocated Costs **\$3,939,904.00**

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

G: Power Flow Analysis (Constraints Used For Mitigation)

See next page.

SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
							(MVA)	TDF	(% MVA)		
FDNS	00G13_009	0	14SP	G13_009	TO->FROM	VINITA - VINITA JUNCTION 69KV CKT 1	69	0.25943	104.6497		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	0	14SP	G13_009	TO->FROM	VINITA - VINITA JUNCTION 69KV CKT 1	69	0.25943	104.482		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	00G13_009	0	19SP	G13_009	TO->FROM	VINITA - VINITA JUNCTION 69KV CKT 1	69	0.25934	104.2421		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	0	19SP	G13_009	TO->FROM	VINITA - VINITA JUNCTION 69KV CKT 1	69	0.25934	104.085		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	00G13_009	0	19WP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25913	122.5414		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	00G13_009	0	19WP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25913	122.4623		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	0	19WP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25913	121.164		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	00G13_009	0	19WP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25913	120.8999		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	0	14SP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25943	117.4397		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	00G13_009	0	14SP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25943	117.357		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	0	19SP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25934	116.8132		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	00G13_009	0	19SP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25934	116.7193		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	0	14SP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25943	116.4096		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	00G13_009	0	14SP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25943	116.1495		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	0	19SP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25934	115.9013		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	00G13_009	0	19SP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25934	115.6312		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	0	14WP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25932	113.7364		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	00G13_009	0	14WP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25932	113.7051		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	0	14WP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25932	112.3799		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	00G13_009	0	14WP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25932	112.176		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	0	24SP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25944	110.4419		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	00G13_009	0	24SP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25944	110.4171		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	0	24SP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25944	109.4955		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	00G13_009	0	24SP	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25944	109.4059		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	8	0	14G	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25925	101.4313		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	8	0	14G	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25925	101.411		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	8	0	14G	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25925	100.1776		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	8	0	14G	G13_009	FROM->TO	VINITA JUNCTION (VINITAJC) 138/69/13.8KV TRANSFORMER CKT 1	62	0.25925	100		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	2	14SP	G13_009	TO->FROM	VINITA - VINITA JUNCTION 69KV CKT 1	69	0.29533	117.3672		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	2	14SP	G13_009	TO->FROM	VINITA - VINITA JUNCTION 69KV CKT 1	69	0.29533	117.2489		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	00G13_009	2	19SP	G13_009	TO->FROM	VINITA - VINITA JUNCTION 69KV CKT 1	69	0.29522	116.9824		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	2	19SP	G13_009	TO->FROM	VINITA - VINITA JUNCTION 69KV CKT 1	69	0.29522	116.8768		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	00G13_009	2	24SP	G13_009	TO->FROM	VINITA - VINITA JUNCTION 69KV CKT 1	69	0.29533	110.4821		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	2	24SP	G13_009	TO->FROM	VINITA - VINITA JUNCTION 69KV CKT 1	69	0.29533	110.4398		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	00G13_009	2	19WP	G13_009	TO->FROM	VINITA - VINITA JUNCTION 69KV CKT 1	78	0.29499	107.7664		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	2	19WP	G13_009	TO->FROM	VINITA - VINITA JUNCTION 69KV CKT 1	78	0.29499	107.6478		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FDNS	00G13_009	2	14WP	G13_009	TO->FROM	VINITA - VINITA JUNCTION 69KV CKT 1	78	0.29521	99.7		SUB 404 - HOCKERVILLE - VINITA JUNCTION 138KV CKT 1
FDNS	00G13_009	2	14WP	G13_009	TO->FROM	VINITA - VINITA JUNCTION 69KV CKT 1	78	0.29521	99.6		SUB 404 - HOCKERVILLE (HOCK 138) 161/138/12.5KV TRANSFORMER CKT 1
FNLS-Blown up	03ALL	0	14G	G13_010		Non-Converged Contingency	1793	0.48033	-		G12-011T 345.00 - POST ROCK 345KV CKT 1

H: Power Flow Analysis (Other Constraints Not Requiring Mitigation)

See next page.

SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB (MVA)	TDF	TC%LOADING (% MVA)	CONTINGENCY
FDNS	06ALL	0	14G	G13_009	FROM->TO	TUCXFR345230	300	0.0447	102	BASE CASE
FDNS	0	0	14SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03602	105.7726	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1
FDNS	00G13_009	0	14SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03602	106.7705	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1
FDNS	0	0	19SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03664	123.5593	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1
FDNS	00G13_009	0	19SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03666	124.4122	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1
FDNS	0	0	19WP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	375	0.03966	101.3489	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1
FDNS	00G13_009	0	19WP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	375	0.03968	102.1872	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1
FDNS	0	0	24SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03686	131.8105	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1
FDNS	00G13_009	0	24SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03685	132.7012	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1
FNSL-Blown up	03ALL	0	14G	G13_010		Non-Converged Contingency	0	0.32511	-	DBL-IRON-CLR
FNSL-Blown up	03ALL	0	14G	G13_010		Non-Converged Contingency	0	0.32511	-	DBL-THIS-CLR
FNSL-Blown up	03ALL	0	14G	G13_010		Non-Converged Contingency	0	0.17576	-	DBL-WICH-THI
FNSL-Blown up	03G13_010	0	14G	G13_010		Non-Converged Contingency	0	0.32696	-	DBL-THIS-CLR
FDNS	03ALL	0	14G	G13_010	FROM->TO	SOUTH HAYS (S HAYS T1) 230/115/12.47KV TRANSFORMER CKT 1	166.7	0.06717	102.6188	KNOLL 230 - POSTROCK6 230.00 230KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SOUTH HAYS (S HAYS T1) 230/115/12.47KV TRANSFORMER CKT 1	166.7	0.06717	101.334	KNOLL 230 - POSTROCK6 230.00 230KV CKT 1
FDNS	3	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.12572	119.4455	DBL-WICH-THI
FDNS	3	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.15034	117.4994	DBL-IRON-CLR
FDNS	3	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.15034	102.7541	DBL-SPRVL-CL
FNSL	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11212	107.502	KNOLL - SALINE RIVER 115KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.09794	105.3271	SUMMIT (SUMMIT1X) 345/230/14.4KV TRANSFORMER CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10911	99.4	HOYT - STRANGER CREEK 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11132	107.75	ST JOHN - ST JOHN 115KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10999	107.5793	LAWTON EASTSIDE - OKLAUNION 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11061	107.0315	FLATRDG3 - HARPER 138KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11066	106.8997	MEDICINE LODGE - SUN CITY 115KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11061	106.7077	HARPER - MILAN TAP 138KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11061	106.5748	CLEARWATER - MILAN TAP 138KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.14986	135.0461	AXTELL - POST ROCK 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.14958	126.5552	DBL-SPRVL-CL
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.12511	125.3562	CIRCLE - MULLERGREN 230KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11817	122.1061	CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11817	122.1061	CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11816	121.0048	FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11367	115.2605	THISTLE7 345.00 - WICHITA 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11367	115.2605	THISTLE7 345.00 - WICHITA 345KV CKT 2
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11816	113.3974	FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11527	113.0083	BUCKNER7 345.00 - HOLCOMB 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11552	111.9993	AXTELL - PAULINE 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.13143	111.7527	MULLERGREN - SOUTH HAYS 230KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11266	111.1707	GRAND ISLAND - SWEETWATER 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	111.1024	GEN532652 1-JEFFREY ENERGY CENTER UNIT 2
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	111.1018	GEN532653 1-JEFFREY ENERGY CENTER UNIT 3
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11448	110.8739	MOORE - PAULINE 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	110.8438	GEN532651 1-JEFFREY ENERGY CENTER UNIT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11168	110.7549	NORTHWEST - TATONGA7 345.00 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	110.075	GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11168	109.4964	G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.1104	109.4831	DBL-BVR-WWRD
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11168	109.3682	G11_051T 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11245	108.8954	CIRCLE - EAST MCPHERSON 230KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11402	108.8716	CLARKCOUNTY7345.00 - IRONWOOD7 345.00 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.12327	108.7974	POSTROCK6 230.00 - SOUTH HAYS 230KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11402	108.7462	CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11047	108.0505	MINGO - RED WILLOW 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11281	107.9436	PHILLIPSBURG - SMITH CENTER 115KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.1104	107.8459	DBL-HTCH-BVR
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11136	107.6777	GRAND ISLAND - MCCOOL 345KV CKT 1
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11072	107.5876	DBL-THIS-WWR
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	107.4835	GEN542962 2-IATAN UNIT #2

SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
							(MVA)	TDF	(% MVA)		
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11042	107.4334	STEGALL - STEGALL TRANSFORMER 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11042	107.4283	STEGALL - STEGALL TY 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11042	107.428	TRF-STEGALL	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11042	107.4227	NEB01WAPAB3	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11111	107.3641	SPP-MKEC-08	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11212	107.2843	PLAINVILLE - SALINE RIVER 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11066	107.279	SPP-MKEC-09B	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	107.2645	GEN542955 1-LACYGNE UNIT #1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	107.2597	GEN542956 2-LACYGNE UNIT #2	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11066	107.1561	GREENSBURG - SSTARTP3 115.00 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11182	107.1405	SPP-MKEC-06	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11135	107.129	MCCOOL - MOORE 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	107.1209	GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11182	107.1206	SEWARD - ST JOHN 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	107.0795	GEN542957 1-IATAN UNIT #1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11112	107.0575	G10-056T 345.00 - ST JOE 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11225	106.9255	ELM CREEK - NORTHWEST MANHATTAN 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11212	106.8442	PHILLIPSBURG - PLAINVILLE 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11112	106.8313	COOPER - G10-056T 345.00 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11132	106.7964	HUNTSVILLE - ST_JOHN 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11132	106.751	MIDW-CATB05	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11066	106.7129	BARBER 3 115.00 - MEDICINE LODGE 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	106.6893	GEN542951 5-HAWTHORN UNIT #5	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11061	106.6669	SPP-MKEC-03A	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11061	106.6398	SPP-MKEC-05	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11132	106.6199	HUNTSVILLE - HUTCHINSON ENERGY CENTER 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11043	106.6124	NUNDRWD - WAYSIDE 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11061	106.6026	SPP-MKEC-03B	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11073	106.5548	EMPORIA ENERGY CENTER - WICHITA 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11094	106.3756	GREAT BEND TAP - SEWARD 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11232	106.3711	KNOLL 230 (KNOLL T1) 230/115/11.49KV TRANSFORMER CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11094	106.3698	GREAT BEND TAP - MULLERGREN 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	105.2582	BASE CASE	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	105.2582	NC1_GEN-NEBRASKA CITY 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10885	104.2873	WR-DOUBLE18	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11007	104.2357	MULLERGREN - SPEARVILLE 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11091	104.1721	COLBY - MINGO 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.1106	104.1239	EASTOWN7 345.00 - IATAN 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10885	104.1174	WR-DOUBLE16	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10885	104.0947	SPP-WR-305B	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.8227	GEN640009 1-COOPER NUCLEAR STATION	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.7805	GEN523971 1-HARRINGTON GEN #1 24 KV	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.7804	GEN523972 1-HARRINGTON GEN #2 24 KV	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.7762	GEN523973 1-HARRINGTON GEN #3 24 KV	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.7491	GEN641089 2-ENERGY CENTER 2	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10877	103.7062	RENO COUNTY - SUMMIT 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.6985	GEN645011 1-NEBRASKA CITY 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.6798	GEN531459 2-S2 GENERATOR	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.6685	GEN539762 1-SSWIND 1 34.500	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.6627	GEN645001 1-FORT CALHOUN 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.1091	103.6587	RENFROW7 345.00 - VIOLA 7 345.00 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11527	103.6152	BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10885	103.61	WR-DOUBLE17	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.5834	GEN539677 3-A. M. MULLERGREN GENERATOR	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10984	103.5829	EMPORIA ENERGY CENTER - MORRIS COUNTY 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.557	GEN560522 1-G05-12-2 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.5181	GEN539785 1-ENSGW 1 0.5750	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.4146	GEN560696 1-G11-008-4 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.3501	GEN645012 2-NEBRASKA CITY 2	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.3262	GEN560140 1-G09-08 0.7000	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.2362	GEN525562 1-TOLK GEN #2 24 KV	

SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
							(MVA)	TDF	(% MVA)		
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.2355	GEN525561 1-TOLK GEN #1 24 KV	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.1928	GEN560267 1-G10-15-1 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.1786	GEN539767 1-GRAY COUNTY WIND FARM	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.1419	GEN560268 1-G10-15-2 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.9807	GEN560235 1-G08-92 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.9535	GEN659111 2-LELAND OLDS UNIT2	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.1057	102.9364	MORRIS COUNTY - UNIONRG6 230.00 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.9106	GEN560695 1-G11-008-3 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.814	GEN659103 1-ANTELOPE VALLEY UNIT1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.814	GEN659107 2-ANTELOPE VALLEY UNIT2	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.7838	GEN560694 1-G11-008-2 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.6304	GEN539670 4-JUDSON LARGE GENERATOR	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10897	102.3097	SWISSVALE - WEST GARDNER 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.2698	GEN562298 1-G12-024 0.6500	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.1919	GEN560238 1-G10-09 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.1109	GEN542902 1-GPW_G1 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.1057	102.0036	SUMMIT - UNIONRG6 230.00 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.963	GEN560514 1-G04_014 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.9495	GEN560693 1-G11-008-1 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.7618	GEN539807 1-G05-12 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.5789	GEN560329 1-G10-45 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.5687	GEN531503 1-CIMRRN 1 34.500	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.5478	GEN560725 1-G13_010_3 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.1764	GEN523117 1-BUFF_DUNES210.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.1233	GEN562035 1-G11_016_3 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.1196	GEN560432 1-G08-124 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.0069	GEN560549 1-G06-06 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	100.7287	GEN640011 2-GERALD GENTLEMAN STATION UNIT 2	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	100.6357	GEN640010 1-GERALD GENTLEMAN STATION UNIT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	99.8	GEN530600 02-SMKYP2G1 0.6900	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	99.5	GEN531447 1-HOLCOMB GENERATOR	
FDNS	03G13_010	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.15024	124.3577	DBL-IRON-CLR	
FDNS	03G13_010	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.12564	124.2147	DBL-WICH-THI	
FDNS	03G13_010	0	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.15024	109.0301	DBL-SPRVL-CL	
FDNS	3	0	14G	G13_010	FROM->TO	SEWARD - ST JOHN 115KV CKT 1	87.6	0.03844	117.7216	DBL-IRON-CLR	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SEWARD - ST JOHN 115KV CKT 1	87.6	0.03144	134.7378	CIRCLE - MULLERGREN 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	SEWARD - ST JOHN 115KV CKT 1	87.6	0.03824	115.0474	DBL-SPRVL-CL	
FDNS	03G13_010	0	14G	G13_010	FROM->TO	SEWARD - ST JOHN 115KV CKT 1	87.6	0.03839	126.0191	DBL-IRON-CLR	
FDNS	03G13_010	0	14G	G13_010	FROM->TO	SEWARD - ST JOHN 115KV CKT 1	87.6	0.03839	101.555	DBL-SPRVL-CL	
FDNS	03ALL	0	14G	G13_010	TO->FROM	N HAYS3 115.00 - VINE STREET 115KV CKT 1	99	0.06717	136.9579	KNOLL 230 - POSTROCK6 230.00 230KV CKT 1	
FDNS	3	0	14G	G13_010	TO->FROM	MULLERGREN - SPEARVILLE 230KV CKT 1	398	0.06328	105.5474	DBL-IRON-CLR	
FDNS	03ALL	0	14G	G13_010	TO->FROM	MULLERGREN - SPEARVILLE 230KV CKT 1	398	0.08395	118.1277	POST ROCK (POSTROCK T1) 345/230/13.8KV TRANSFORMER CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	MULLERGREN - SPEARVILLE 230KV CKT 1	398	0.0623	113.2268	DBL-SPRVL-CL	
FDNS	03ALL	0	14G	G13_010	TO->FROM	MULLERGREN - SPEARVILLE 230KV CKT 1	398	0.05235	100.3137	MULLERGREN - SOUTH HAYS 230KV CKT 1	
FDNS	03G13_010	0	14G	G13_010	TO->FROM	MULLERGREN - SPEARVILLE 230KV CKT 1	398	0.06322	110.1012	DBL-IRON-CLR	
FDNS	3	0	14G	G13_010	TO->FROM	MEDICINE LODGE - SUN CITY 115KV CKT 1	115.1	0.03421	129.6206	DBL-IRON-CLR	
FDNS	3	0	14G	G13_010	TO->FROM	MEDICINE LODGE - SUN CITY 115KV CKT 1	115.1	0.03421	107.2721	DBL-SPRVL-CL	
FDNS	03ALL	0	14G	G13_010	TO->FROM	MEDICINE LODGE - SUN CITY 115KV CKT 1	115.1	0.03373	139.9942	DBL-SPRVL-CL	
FDNS	03G13_010	0	14G	G13_010	TO->FROM	MEDICINE LODGE - SUN CITY 115KV CKT 1	115.1	0.03416	136.5648	DBL-IRON-CLR	
FDNS	03G13_010	0	14G	G13_010	TO->FROM	MEDICINE LODGE - SUN CITY 115KV CKT 1	115.1	0.03416	113.1144	DBL-SPRVL-CL	
FDNS	03ALL	0	14G	G13_010	FROM->TO	KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1	330	0.14986	102.709	AXTELL - POST ROCK 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	KNOLL 230 - POSTROCK6 230.00 230KV CKT 1	398	0.20194	112.3303	AXTELL - POST ROCK 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	KNOLL - N HAYS3 115.00 115KV CKT 1	88	0.06717	148.9391	KNOLL 230 - POSTROCK6 230.00 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	FROM->TO	HAYS PLANT - VINE STREET 115KV CKT 1	88	0.06717	162.0264	KNOLL 230 - POSTROCK6 230.00 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	HAYS PLANT - SOUTH HAYS 115KV CKT 1	99	0.06717	161.9226	KNOLL 230 - POSTROCK6 230.00 230KV CKT 1	
FDNS	3	0	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03677	233.8508	DBL-WICH-THI	
FDNS	5	0	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03738	128.5016	DBL-WICH-THI	
FDNS	6	0	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03711	144.6528	DBL-WICH-THI	
FDNS	9	0	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03743	117.6357	DBL-WICH-THI	
FDNS	14	0	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03755	113.4113	DBL-WICH-THI	
FDNS	03G13_010	0	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03672	241.6025	DBL-WICH-THI	

SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
							(MVA)	TDF	(% MVA)		
FDNS	05ALL	0	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03724	137.8174	DBL-WICH-THI	
FDNS	06ALL	0	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03696	159.9267	DBL-WICH-THI	
FDNS	09ALL	0	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.0374	123.365	DBL-WICH-THI	
FDNS	14ALL	0	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03741	119.0514	DBL-WICH-THI	
FDNS	3	0	14G	G13_010	FROM->TO	GREENSBURG - SUN CITY 115KV CKT 1	115.1	0.03421	134.6157	DBL-IRON-CLR	
FDNS	3	0	14G	G13_010	FROM->TO	GREENSBURG - SUN CITY 115KV CKT 1	115.1	0.03421	112.2721	DBL-SPRVL-CL	
FDNS	03ALL	0	14G	G13_010	FROM->TO	GREENSBURG - SUN CITY 115KV CKT 1	115.1	0.03373	145.199	DBL-SPRVL-CL	
FDNS	03G13_010	0	14G	G13_010	FROM->TO	GREENSBURG - SUN CITY 115KV CKT 1	115.1	0.03416	141.5802	DBL-IRON-CLR	
FDNS	03G13_010	0	14G	G13_010	FROM->TO	GREENSBURG - SUN CITY 115KV CKT 1	115.1	0.03416	118.1059	DBL-SPRVL-CL	
FDNS	3	0	14G	G13_010	TO->FROM	GREENSBURG - SSTARTP3 115.00 115KV CKT 1	115.1	0.03421	145.6049	DBL-IRON-CLR	
FDNS	3	0	14G	G13_010	TO->FROM	GREENSBURG - SSTARTP3 115.00 115KV CKT 1	115.1	0.03421	123.0563	DBL-SPRVL-CL	
FDNS	03ALL	0	14G	G13_010	TO->FROM	GREENSBURG - SSTARTP3 115.00 115KV CKT 1	115.1	0.03373	156.4155	DBL-SPRVL-CL	
FDNS	03G13_010	0	14G	G13_010	TO->FROM	GREENSBURG - SSTARTP3 115.00 115KV CKT 1	115.1	0.03416	152.7017	DBL-IRON-CLR	
FDNS	03G13_010	0	14G	G13_010	TO->FROM	GREENSBURG - SSTARTP3 115.00 115KV CKT 1	115.1	0.03416	128.9202	DBL-SPRVL-CL	
FDNS	3	0	14G	G13_010	FROM->TO	GREAT BEND TAP - SEWARD 115KV CKT 1	80.3	0.03063	111.5826	DBL-IRON-CLR	
FDNS	03ALL	0	14G	G13_010	FROM->TO	GREAT BEND TAP - SEWARD 115KV CKT 1	80.3	0.03048	108.3114	DBL-SPRVL-CL	
FDNS	03G13_010	0	14G	G13_010	FROM->TO	GREAT BEND TAP - SEWARD 115KV CKT 1	80.3	0.03058	118.405	DBL-IRON-CLR	
FDNS	3	0	14G	G13_010	TO->FROM	GREAT BEND TAP - MULLERGREN 115KV CKT 1	79.7	0.03063	112.4987	DBL-IRON-CLR	
FDNS	03ALL	0	14G	G13_010	TO->FROM	GREAT BEND TAP - MULLERGREN 115KV CKT 1	79.7	0.03048	109.1976	DBL-SPRVL-CL	
FDNS	03G13_010	0	14G	G13_010	TO->FROM	GREAT BEND TAP - MULLERGREN 115KV CKT 1	79.7	0.03058	119.3683	DBL-IRON-CLR	
FDNS	3	0	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.04032	153.1194	DBL-WICH-THI	
FDNS	03ALL	0	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03525	170.0549	NORTHWEST - TATONGA7 345.00 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03525	156.3099	G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03525	154.6158	G11_051T 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03124	122.055	RENFROW7 345.00 - VIOLA 7 345.00 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03124	116.3753	VIOLA 7 345.00 - WICHITA 345KV CKT 1	
FDNS	03G13_010	0	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.04025	158.2368	DBL-WICH-THI	
FDNS	05ALL	0	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.0342	112.9024	NORTHWEST - TATONGA7 345.00 345KV CKT 1	
FDNS	05ALL	0	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.039	105.7277	DBL-WICH-THI	
FDNS	05ALL	0	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.0342	99.7	G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1	
FDNS	06ALL	0	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03364	138.1828	NORTHWEST - TATONGA7 345.00 345KV CKT 1	
FDNS	06ALL	0	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03841	130.7413	DBL-WICH-THI	
FDNS	06ALL	0	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03364	124.864	G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1	
FDNS	06ALL	0	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03364	123.1966	G11_051T 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1	
FDNS	09ALL	0	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03412	107.9753	NORTHWEST - TATONGA7 345.00 345KV CKT 1	
FDNS	09ALL	0	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03887	100	DBL-WICH-THI	
FDNS	3	0	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03677	223.345	DBL-WICH-THI	
FDNS	5	0	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03738	117.9811	DBL-WICH-THI	
FDNS	6	0	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03711	134.1188	DBL-WICH-THI	
FDNS	9	0	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03743	107.1424	DBL-WICH-THI	
FDNS	14	0	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03755	102.8853	DBL-WICH-THI	
FDNS	03G13_010	0	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03672	231.0951	DBL-WICH-THI	
FDNS	05ALL	0	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03724	127.2284	DBL-WICH-THI	
FDNS	06ALL	0	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03696	149.3514	DBL-WICH-THI	
FDNS	09ALL	0	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.0374	112.8165	DBL-WICH-THI	
FDNS	14ALL	0	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03741	108.4856	DBL-WICH-THI	
FDNS	3	0	14G	G13_010	FROM->TO	CLEARWATER - GILL ENERGY CENTER WEST 138KV CKT 1	191	0.03677	121.6012	DBL-WICH-THI	
FDNS	03G13_010	0	14G	G13_010	FROM->TO	CLEARWATER - GILL ENERGY CENTER WEST 138KV CKT 1	191	0.03672	126.0571	DBL-WICH-THI	
FDNS	3	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.09483	121.5944	DBL-WICH-THI	
FDNS	3	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.12248	116.8642	DBL-IRON-CLR	
FDNS	3	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.12248	99.7	DBL-SPRVL-CL	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.0745	99	HOYT - STRANGER CREEK 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07582	101.5417	CIRCLE - HUTCHINSON ENERGY CENTER 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07905	111.4533	ST JOHN - ST JOHN 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07631	106.7837	ELLSWTP3 115.00 - MULLERGREN 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07631	105.771	ELLSWTP3 115.00 - RUSSELL 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07498	105.4025	LAWTON EASTSIDE - OKLAUNION 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07581	104.9866	FLATRDG3 - HARPER 138KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07581	104.5947	HARPER - MILAN TAP 138KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07581	104.4288	CLEARWATER - MILAN TAP 138KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07687	104.108	FLATRDG3 - MEDICINE LODGE 138KV CKT 1	

SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
							(MVA)	TDF	(% MVA)		
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.10018	128.0898	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.12156	126.6712	DBL-SPRVL-CL	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08461	121.5654	CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08461	121.5654	CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.10018	120.323	KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.09797	120.2296	AXTELL - POST ROCK 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08477	120.0827	FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07962	114.711	THISTLE7 345.00 - WICHITA 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07962	114.711	THISTLE7 345.00 - WICHITA 345KV CKT 2	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08477	111.9915	FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08836	111.5255	KNOLL 230 - POSTROCK6 230.00 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08081	110.861	BUCKNER7 345.00 - HOLCOMB 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08177	110.3035	SPP-MKEC-06	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08176	110.2493	SEWARD - ST JOHN 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07698	108.6975	NORTHWEST - TATONGA7 345.00 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07612	108.6385	MINGO - RED WILLOW 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07905	108.4135	HUNTSVILLE - ST JOHN 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07905	108.193	MIDW-CATB05	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07905	107.8521	HUNTSVILLE - HUTCHINSON ENERGY CENTER 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07547	107.6599	DBL-BVR-WWRD	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	107.6185	GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07698	107.4601	G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.0771	107.3283	GRAND ISLAND - SWEETWATER 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07698	107.3235	G11_051T 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07877	107.3078	AXTELL - PAULINE 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07833	107.0012	GREAT BEND TAP - SEWARD 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07833	106.9962	GREAT BEND TAP - MULLERGREN 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07631	106.9518	SPP-MKEC-02	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07972	106.9291	CLARKCOUNTY7345.00 - IRONWOOD7 345.00 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07972	106.7848	CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	106.7673	GEN532652 1-JEFFREY ENERGY CENTER UNIT 2	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	106.7669	GEN532653 1-JEFFREY ENERGY CENTER UNIT 3	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07817	106.6721	MOORE - PAULINE 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	106.4872	GEN532651 1-JEFFREY ENERGY CENTER UNIT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07732	105.8402	SPP-MKEC-08	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07547	105.8015	DBL-HTCH-BVR	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07541	104.7624	STEGALL - STEGALL TRANSFORMER 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07541	104.7576	STEGALL - STEGALL TY 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07541	104.757	TRF-STEGALL	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07541	104.752	NEB01WAPAB3	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	104.6874	GEN530690 1-PRWINDG1 0.6900	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07611	104.6848	GRAND ISLAND - MCCOOL 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07568	104.6788	SPP-MKEC-09B	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07631	104.6684	RUSSELL - WALDO 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07748	104.5929	ELM CREEK - NORTHWEST MANHATTAN 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07581	104.4684	SPP-MKEC-05	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07581	104.4654	SPP-MKEC-03A	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	104.4646	GEN542955 1-LACYGNE UNIT #1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	104.4614	GEN542956 2-LACYGNE UNIT #2	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07581	104.4268	SPP-MKEC-03B	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	104.3989	GEN542962 2-IATAN UNIT #2	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07556	104.2879	GERALD GENTLEMAN STATION - RED WILLOW 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07611	104.2721	MCCOOL - MOORE 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07581	104.2617	CLEARWATER - GILL ENERGY CENTER WEST 138KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07631	104.2401	COVERT 3 115.00 - WALDO 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07631	104.2184	COVERT 3 115.00 - SMITH CENTER 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.0759	104.1463	G10-056T 345.00 - ST JOE 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07628	104.127	MULLERGREN (MULGREN6) 230/115/13.8KV TRANSFORMER CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	104.1207	GEN542957 1-IATAN UNIT #1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07687	104.1018	MEDICINE LODGE (BARBER 4) 138/115/2.72KV TRANSFORMER CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	104.0896	GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5	

SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
							(MVA)	TDF	(% MVA)		
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07627	104.0735	HEIZER 6 230.00 (HEIZER T1) 230/115/12.5KV TRANSFORMER CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07627	104.0692	HEIZER 6 230.00 - MULLERGREN 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	103.9784	COOPER - G10-056T 345.00 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	102.828	BASE CASE	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	102.828	NC1_GEN-NEBRASKA CITY 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07486	101.7924	CIRCLE - RICE 6 230.00 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	101.7622	GEN640009 1-COOPER NUCLEAR STATION	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07371	101.7204	VIOLA 7 345.00 - WICHITA 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	101.6871	GEN645011 1-NEBRASKA CITY 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	101.6618	GEN645001 1-FORT CALHOUN 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07309	101.6267	MORRIS COUNTY - UNIONRG6 230.00 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07414	101.5987	MOUNDRIDGE (MOUND10X) 138/115/13.8KV TRANSFORMER CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07414	101.5939	WR-B3-9	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	101.5925	GEN560235 1-G08-92 0.6900	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07429	101.575	BENTON - WICHITA 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07418	101.5339	HUNTERS7 345.00 - WOODRING 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07608	101.5238	MINGO (MINGO) 345/115/13.8KV TRANSFORMER CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	101.4295	GEN645012 2-NEBRASKA CITY 2	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07571	101.3341	BEELER - NESS CITY 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	101.2391	GEN560140 1-G09-08 0.7000	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07571	101.2151	BEELER - DIGHTON TAP 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07309	101.2115	SUMMIT - UNIONRG6 230.00 230KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07589	101.1953	SPP-MKEC-12	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07486	101.1741	RICE 6 230.00 (RICE T1) 230/115/12.47KV TRANSFORMER CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07589	101.1693	ALEXANDER - SAWYER 3 115.00 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	101.1628	GEN523971 1-HARRINGTON GEN #1 24 KV	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	101.1627	GEN523972 1-HARRINGTON GEN #2 24 KV	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	101.158	GEN523973 1-HARRINGTON GEN #3 24 KV	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07507	101.1566	SPP-WR-335A	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07589	101.1401	BARBER 3 115.00 - SAWYER 3 115.00 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	101.1315	GEN659111 2-LELAND OLDS UNIT2	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07487	101.0974	EAST MCPHERSON (EMCPHR1X) 230/115/13.8KV TRANSFORMER CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08081	101.0914	BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07633	101.0439	MIDW-CATB04	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	101.0264	GEN659103 1-ANTELOPE VALLEY UNIT1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	101.0264	GEN659107 2-ANTELOPE VALLEY UNIT2	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	101	GEN531459 2-S2 GENERATOR	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07441	100.9628	SWISSVALE - WEST GARDNER 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.9417	GEN560522 1-G05-12-2 0.6900	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07571	100.9387	DIGHTON TAP - MANNING TAP 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07632	100.8635	ALEXANDER - NEKOMA 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.7966	GEN560696 1-G11-008-4 0.6900	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07371	100.7947	RENFROW7 345.00 - VIOLA 7 345.00 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07632	100.7653	ALEXANDER - NESS CITY 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07571	100.7639	MANNING TAP - SCOTT CITY 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07364	100.7521	WR-B3-8	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07364	100.7289	MOUNDRIDGE - RENO COUNTY 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.693	GEN539785 1-ENSGW 1 0.5750	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.6819	GEN539762 1-SSWIND 1 34.500	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07486	100.5828	MIDW-CATB06	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.5593	GEN525562 1-TOLK GEN #2 24 KV	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.5586	GEN525561 1-TOLK GEN #1 24 KV	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.5445	GEN560267 1-G10-15-1 0.6900	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.508	GEN560268 1-G10-15-2 0.6900	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07632	100.5016	NESS CITY - NESS CITY 115KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.2743	GEN560695 1-G11-008-3 0.6900	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.2444	GEN539767 1-GRAY COUNTY WIND FARM	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.2207	GEN560725 1-G13_010_3 0.6900	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.1361	GEN560694 1-G11-008-2 0.6900	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.09385	99.7	G11-17T 345.00 - SPEARVILLE 345KV CKT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.6	GEN562298 1-G12-024 0.6500	

SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
							(MVA)	TDF	(% MVA)		
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.5	GEN539670 4-JUDSON LARGE GENERATOR	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.5	GEN560238 1-G10-09	0.6900
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.2	GEN560693 1-G11-008-1 0.6900	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.2	GEN640010 1-GERALD GENTLEMAN STATION UNIT 1	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.2	GEN640011 2-GERALD GENTLEMAN STATION UNIT 2	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99	GEN539807 1-G05-12 0.6900	
FDNS	03G13_010	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.0947	126.7885	DBL-WICH-THI	
FDNS	03G13_010	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.12234	123.7977	DBL-IRON-CLR	
FDNS	03G13_010	0	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.12234	105.8	DBL-SPRVL-CL	
FDNS	03ALL	0	14G	G13_010	TO->FROM	CHISHOLM - MAIZEE 4 138.00 138KV CKT 1	287	0.04224	104.6975	BENTON - WICHITA 345KV CKT 1	
FDNS	03G13_010	0	14G	G13_010	FROM->TO	BUCKNER7 345.00 - HOLCOMB 345KV CKT 1	717.1	0.28859	101.1088	DBL-IRON-CLR	
FDNS	0	0	14WP	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03674	101.9121	DBL-WICH-THI	
FNSL	00G13_010	0	14WP	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03625	138.3989	DBL-WICH-THI	
FDNS	00G13_010	0	14WP	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03667	111.8705	DBL-WICH-THI	
FNSL	00G13_010	0	14WP	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03625	128.1672	DBL-WICH-THI	
FDNS	00G13_010	0	14WP	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03667	101.6097	DBL-WICH-THI	
FNSL	00G13_010	0	19WP	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03857	118.5019	DBL-WICH-THI	
FNSL	00G13_010	0	19WP	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03857	107.1135	DBL-WICH-THI	
FDNS	06ALL	2	14G	G13_009	FROM->TO	TUCXFR345230	300	0.04423	100.6	BASE CASE	
FDNS	0	2	14SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03695	105.8565	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	2	14SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03604	105.8014	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	2	14SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03604	105.7949	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	00G13_009	2	14SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03695	106.8837	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	2	19SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03759	123.6502	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	2	19SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03666	123.5928	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	2	19SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03666	123.5841	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	00G13_009	2	19SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03761	124.5336	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	2	19WP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	375	0.04061	101.4147	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	2	19WP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	375	0.03969	101.3723	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	2	19WP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	375	0.03969	101.3645	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	00G13_009	2	19WP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	375	0.04063	102.2782	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	2	24SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03781	131.9832	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	2	24SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03688	131.9439	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	2	24SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03688	131.9352	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	00G13_009	2	24SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.0378	132.9302	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FNSL-Blown up	3	2	14G	G13_010		Non-Converged Contingency	0	0.3273	-	DBL-THIS-CLR	
FNSL-Blown up	03ALL	2	14G	G13_010		Non-Converged Contingency	0	0.32511	-	DBL-IRON-CLR	
FNSL-Blown up	03ALL	2	14G	G13_010		Non-Converged Contingency	0	0.32511	-	DBL-THIS-CLR	
FNSL-Blown up	03ALL	2	14G	G13_010		Non-Converged Contingency	0	0.17576	-	DBL-WICH-THI	
FNSL-Blown up	03G13_010	2	14G	G13_010		Non-Converged Contingency	0	0.32697	-	DBL-THIS-CLR	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SOUTH HAYS (S HAYS T1) 230/115/12.47KV TRANSFORMER CKT 1	166.7	0.06717	100.9551	KNOLL 230 - POSTROCK6	230.00 230KV CKT 1
FDNS	03ALL	2	14G	G13_010	FROM->TO	SOUTH HAYS (S HAYS T1) 230/115/12.47KV TRANSFORMER CKT 1	166.7	0.06717	99.8	KNOLL 230 - POSTROCK6	230.00 230KV CKT 1
FDNS	3	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.12572	118.7822	DBL-WICH-THI	
FDNS	3	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.15034	117.5783	DBL-IRON-CLR	
FDNS	3	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.15034	102.6854	DBL-SPRVL-CL	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.09793	104.1109	SUMMIT (SUMMIT1X) 345/230/14.4KV TRANSFORMER CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11132	106.3811	ST JOHN - ST JOHN 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10999	106.1081	LAWTON EASTSIDE - OKLAUNION 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11061	105.6103	FLATRDG3 - HARPER 138KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11066	105.6069	GREENSBURG - SUN CITY 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11066	105.5298	MEDICINE LODGE - SUN CITY 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11061	105.3382	HARPER - MILAN TAP 138KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11061	105.1736	CLEARWATER - MILAN TAP 138KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.14986	132.3219	AXTELL - POST ROCK 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.14958	127.099	DBL-SPRVL-CL	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.12511	123.5505	CIRCLE - MULLERGREN 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11817	120.5942	CLARKCOUNTY7345.00 - THISTLE7	345.00 345KV CKT 1
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11817	120.5942	CLARKCOUNTY7345.00 - THISTLE7	345.00 345KV CKT 2
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11816	118.174	SPP-SWPS-05	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11816	117.9218	FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11367	113.3916	THISTLE7	345.00 - WICHITA 345KV CKT 1

SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
							(MVA)	TDF	(% MVA)		
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11367	113.3916	THISTLE7 345.00 - WICHITA 345KV CKT 2	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11816	111.5691	FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11527	110.6777	BUCKNER7 345.00 - HOLCOMB 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11552	110.4636	AXTELL - PAULINE 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.13143	110.2025	MULLERGREN - SOUTH HAYS 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	109.7194	GEN532652 1-JEFFREY ENERGY CENTER UNIT 2	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	109.7187	GEN532653 1-JEFFREY ENERGY CENTER UNIT 3	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11266	109.679	GRAND ISLAND - SWEETWATER 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	109.4656	GEN532651 1-JEFFREY ENERGY CENTER UNIT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11448	109.3611	MOORE - PAULINE 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11168	109.0636	NORTHWEST - TATONGA7 345.00 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	108.6125	GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.1104	107.9659	DBL-BVR-WWRD	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11168	107.919	G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11168	107.7849	G11_051T 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11402	107.677	CLARKCOUNTY7345.00 - IRONWOOD7 345.00 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11402	107.5522	CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11244	107.528	CIRCLE - EAST MCPHERSON 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.12327	107.3788	POSTROCK6 230.00 - SOUTH HAYS 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11047	106.566	MINGO - RED WILLOW 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11281	106.5639	PHILLIPSBURG - SMITH CENTER 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.1104	106.4084	DBL-HTCH-BVR	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11135	106.2606	GRAND ISLAND - MCCOOL 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11212	106.1446	KNOLL - SALINE RIVER 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	106.1411	GEN542962 2-IATAN UNIT #2	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11041	106.0597	STEGALL - STEGALL TRANSFORMER 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11041	106.0579	NEB01WAPAB3	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11041	106.0517	STEGALL TY 345/230KV TRANSFORMER CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11041	106.0458	TRF-STEGALL	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11041	106.0328	STEGALL - STEGALL TY 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.1111	105.9927	SPP-MKEC-08	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11212	105.951	PLAINVILLE - SALINE RIVER 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	105.9121	GEN542955 1-LACYGNE UNIT #1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	105.9075	GEN542956 2-LACYGNE UNIT #2	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11066	105.8796	SPP-MKEC-09B	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11066	105.76	GREENSBURG - SSTARTP3 115.00 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	105.7594	GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11182	105.7483	SPP-MKEC-06	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	105.7445	THISTLE7 345.00 345/13.0KV TRANSFORMER CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	105.7433	GEN542957 1-IATAN UNIT #1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11135	105.735	MCCOOL - MOORE 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11182	105.7252	SEWARD - ST JOHN 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11112	105.6665	G10-056T 345.00 - ST JOE 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11225	105.5917	ELM CREEK - NORTHWEST MANHATTAN 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11212	105.4876	PHILLIPSBURG - PLAINVILLE 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11112	105.4473	COOPER - G10-056T 345.00 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11132	105.4466	HUNTSVILLE - ST_JOHN 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11132	105.403	MIDW-CATB05	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	105.3509	GEN542951 5-HAWTHORN UNIT #5	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11066	105.3366	BARBER 3 115.00 - MEDICINE LODGE 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11132	105.2746	HUNTSVILLE - HUTCHINSON ENERGY CENTER 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11061	105.2683	SPP-MKEC-05	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11061	105.2657	SPP-MKEC-03A	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11072	105.2629	EMPORIA ENERGY CENTER - WICHITA 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11043	105.2308	NUNDRWD - WAYSIDE 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11061	105.1999	SPP-MKEC-03B	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11232	105.0302	KNOLL 230 (KNOLL T1) 230/115/11.49KV TRANSFORMER CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.9542	BASE CASE	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	103.9542	NC1_GEN-NEBRASKA CITY 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10989	103.152	NORTHVIEW - SUMMIT 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10885	102.9739	WR-DOUBLE18	

SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
							(MVA)	TDF	(% MVA)		
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11007	102.8775	MULLERGREN - SPEARVILLE 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11091	102.8364	COLBY - MINGO 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10885	102.8111	WR-DOUBLE16	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.1106	102.8087	EASTOWN7 345.00 - IATAN 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10885	102.7746	SPP-WR-305B	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.5512	GEN640009 1-COOPER NUCLEAR STATION	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.5238	GEN523971 1-HARRINGTON GEN #1 24 KV	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.5237	GEN523972 1-HARRINGTON GEN #2 24 KV	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.5197	GEN523973 1-HARRINGTON GEN #3 24 KV	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.4846	GEN641089 2-ENERGY CENTER 2	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.4417	GEN531459 2-S2 GENERATOR	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10876	102.4392	RENO COUNTY - SUMMIT 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.4191	GEN539762 1-SSWIND 1 34.500	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.4127	GEN645011 1-NEBRASKA CITY 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.1091	102.4079	RENFROW7 345.00 - VIOLA 7 345.00 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.3873	GEN645001 1-FORT CALHOUN 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.3137	GEN560522 1-G05-12-2 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.2878	GEN539677 3-A. M. MULLERGREN GENERATOR	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10885	102.2847	WR-DOUBLE17	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10984	102.2841	EMPORIA ENERGY CENTER - MORRIS COUNTY 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11527	102.282	BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.2807	GEN539785 1-ENSGW 1 0.5750	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.1898	GEN560696 1-G11-008-4 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.075	GEN645012 2-NEBRASKA CITY 2	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.0199	GEN560140 1-G09-08 0.7000	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.0115	GEN525561 1-TOLK GEN #1 24 KV	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	102.0078	GEN525562 1-TOLK GEN #2 24 KV	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.963	GEN560267 1-G10-15-1 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.9545	GEN539767 1-GRAY COUNTY WIND FARM	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.9172	GEN560268 1-G10-15-2 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.7076	GEN560695 1-G11-008-3 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.6828	GEN659111 2-LELAND OLDS UNIT2	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.6806	GEN560235 1-G08-92 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.1057	101.6452	MORRIS COUNTY - UNIONRG6 230.00 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.5849	GEN560694 1-G11-008-2 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.5466	GEN659103 1-ANTELOPE VALLEY UNIT1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.5466	GEN659107 2-ANTELOPE VALLEY UNIT2	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.4168	GEN539670 4-JUDSON LARGE GENERATOR	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	101.1125	GEN562298 1-G12-024 0.6500	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.10897	101.0403	SWISSVALE - WEST GARDNER 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	100.9971	GEN560238 1-G10-09 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	100.9332	GEN542902 1-GPW_G1 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	100.8414	GEN560693 1-G11-008-1 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	100.7976	GEN560514 1-G04_014 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.1057	100.7223	SUMMIT - UNIONRG6 230.00 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	100.6155	GEN539807 1-G05-12 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	100.4336	GEN560329 1-G10-45 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	100.4334	GEN531503 1-CIMRRN 1 34.500	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	100.3244	GEN560725 1-G13_010_3 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	100	GEN523117 1-BUFF_DUNES210.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	100	GEN560432 1-G08-124 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	100	GEN562035 1-G11_016_3 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	99.9	GEN560549 1-G06-06 0.6900	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	99.6	GEN640011 2-GERALD GENTLEMAN STATION UNIT 2	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.11017	99.5	GEN640010 1-GERALD GENTLEMAN STATION UNIT 1	
FDNS	03G13_010	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.12564	124.4076	DBL-WICH-THI	
FDNS	03G13_010	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.15024	123.9805	DBL-IRON-CLR	
FDNS	03G13_010	2	14G	G13_010	FROM->TO	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	330	0.15024	108.8452	DBL-SPRVL-CL	
FDNS	3	2	14G	G13_010	FROM->TO	SEWARD - ST JOHN 115KV CKT 1	87.6	0.03844	118.983	DBL-IRON-CLR	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SEWARD - ST JOHN 115KV CKT 1	87.6	0.03144	133.6445	CIRCLE - MULLERGREN 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	SEWARD - ST JOHN 115KV CKT 1	87.6	0.03824	116.7849	DBL-SPRVL-CL	

SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
							(MVA)	TDF	(% MVA)		
FDNS	03G13_010	2	14G	G13_010	FROM->TO	SEWARD - ST JOHN 115KV CKT 1	87.6	0.03839	125.1864	DBL-IRON-CLR	
FDNS	03G13_010	2	14G	G13_010	FROM->TO	SEWARD - ST JOHN 115KV CKT 1	87.6	0.03839	101.1203	DBL-SPRVL-CL	
FDNS	03ALL	2	14G	G13_010	TO->FROM	N HAYS3 115.00 - VINE STREET 115KV CKT 1	99	0.06717	133.8663	KNOLL 230 - POSTROCK6 230.00 230KV CKT 1	
FDNS	3	2	14G	G13_010	TO->FROM	MULLERGREEN - SPEARVILLE 230KV CKT 1	398	0.06328	106.1446	DBL-IRON-CLR	
FDNS	03ALL	2	14G	G13_010	TO->FROM	MULLERGREEN - SPEARVILLE 230KV CKT 1	398	0.1354	153.1241	G12-011T 345.00 - POST ROCK 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	MULLERGREEN - SPEARVILLE 230KV CKT 1	398	0.08395	116.3242	POST ROCK (POSTROCK T1) 345/230/13.8KV TRANSFORMER CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	MULLERGREEN - SPEARVILLE 230KV CKT 1	398	0.0623	114.3569	DBL-SPRVL-CL	
FDNS	03ALL	2	14G	G13_010	TO->FROM	MULLERGREEN - SPEARVILLE 230KV CKT 1	398	0.05235	99.3	MULLERGREEN - SOUTH HAYS 230KV CKT 1	
FDNS	03G13_010	2	14G	G13_010	TO->FROM	MULLERGREEN - SPEARVILLE 230KV CKT 1	398	0.06322	109.2356	DBL-IRON-CLR	
FDNS	3	2	14G	G13_010	TO->FROM	MEDICINE LODGE - SUN CITY 115KV CKT 1	115.1	0.03421	130.965	DBL-IRON-CLR	
FDNS	3	2	14G	G13_010	TO->FROM	MEDICINE LODGE - SUN CITY 115KV CKT 1	115.1	0.03421	108.1982	DBL-SPRVL-CL	
FDNS	03ALL	2	14G	G13_010	TO->FROM	MEDICINE LODGE - SUN CITY 115KV CKT 1	115.1	0.03373	141.9288	DBL-SPRVL-CL	
FDNS	03G13_010	2	14G	G13_010	TO->FROM	MEDICINE LODGE - SUN CITY 115KV CKT 1	115.1	0.03416	135.7332	DBL-IRON-CLR	
FDNS	03G13_010	2	14G	G13_010	TO->FROM	MEDICINE LODGE - SUN CITY 115KV CKT 1	115.1	0.03416	112.562	DBL-SPRVL-CL	
FDNS	03ALL	2	14G	G13_010	FROM->TO	KNOLL 230 - SMOKYHLE 230.00 230KV CKT 1	330	0.14986	100.6639	AXTELL - POST ROCK 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	KNOLL 230 - POSTROCK6 230.00 230KV CKT 1	398	0.20194	110.0147	AXTELL - POST ROCK 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	KNOLL - N HAYS3 115.00 115KV CKT 1	88	0.06717	145.4039	KNOLL 230 - POSTROCK6 230.00 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	HAYS PLANT - VINE STREET 115KV CKT 1	88	0.06717	158.6227	KNOLL 230 - POSTROCK6 230.00 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	HAYS PLANT - SOUTH HAYS 115KV CKT 1	99	0.06717	159.0275	KNOLL 230 - POSTROCK6 230.00 230KV CKT 1	
FDNS	3	2	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03677	235.4645	DBL-WICH-THI	
FDNS	6	2	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03629	144.9311	DBL-WICH-THI	
FDNS	9	2	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03661	116.7103	DBL-WICH-THI	
FDNS	03G13_010	2	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03672	240.0525	DBL-WICH-THI	
FDNS	06ALL	2	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03614	160.3855	DBL-WICH-THI	
FDNS	09ALL	2	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03659	122.3388	DBL-WICH-THI	
FDNS	3	2	14G	G13_010	FROM->TO	GREENSBURG - SUN CITY 115KV CKT 1	115.1	0.03421	135.892	DBL-IRON-CLR	
FDNS	3	2	14G	G13_010	FROM->TO	GREENSBURG - SUN CITY 115KV CKT 1	115.1	0.03421	113.116	DBL-SPRVL-CL	
FDNS	03ALL	2	14G	G13_010	FROM->TO	GREENSBURG - SUN CITY 115KV CKT 1	115.1	0.03373	147.0852	DBL-SPRVL-CL	
FDNS	03G13_010	2	14G	G13_010	FROM->TO	GREENSBURG - SUN CITY 115KV CKT 1	115.1	0.03416	140.7336	DBL-IRON-CLR	
FDNS	03G13_010	2	14G	G13_010	FROM->TO	GREENSBURG - SUN CITY 115KV CKT 1	115.1	0.03416	117.5535	DBL-SPRVL-CL	
FDNS	3	2	14G	G13_010	TO->FROM	GREENSBURG - SSTARTP3 115.00 115KV CKT 1	115.1	0.03421	146.8422	DBL-IRON-CLR	
FDNS	3	2	14G	G13_010	TO->FROM	GREENSBURG - SSTARTP3 115.00 115KV CKT 1	115.1	0.03421	123.8774	DBL-SPRVL-CL	
FDNS	03ALL	2	14G	G13_010	TO->FROM	GREENSBURG - SSTARTP3 115.00 115KV CKT 1	115.1	0.03373	158.2997	DBL-SPRVL-CL	
FDNS	03G13_010	2	14G	G13_010	TO->FROM	GREENSBURG - SSTARTP3 115.00 115KV CKT 1	115.1	0.03416	151.8427	DBL-IRON-CLR	
FDNS	03G13_010	2	14G	G13_010	TO->FROM	GREENSBURG - SSTARTP3 115.00 115KV CKT 1	115.1	0.03416	128.3728	DBL-SPRVL-CL	
FDNS	3	2	14G	G13_010	FROM->TO	GREAT BEND TAP - SEWARD 115KV CKT 1	80.3	0.03063	112.4509	DBL-IRON-CLR	
FDNS	03ALL	2	14G	G13_010	FROM->TO	GREAT BEND TAP - SEWARD 115KV CKT 1	80.3	0.03048	109.3888	DBL-SPRVL-CL	
FDNS	03G13_010	2	14G	G13_010	FROM->TO	GREAT BEND TAP - SEWARD 115KV CKT 1	80.3	0.03059	117.6906	DBL-IRON-CLR	
FDNS	3	2	14G	G13_010	TO->FROM	GREAT BEND TAP - MULLERGREEN 115KV CKT 1	79.7	0.03063	113.3822	DBL-IRON-CLR	
FDNS	03ALL	2	14G	G13_010	TO->FROM	GREAT BEND TAP - MULLERGREEN 115KV CKT 1	79.7	0.03048	110.2972	DBL-SPRVL-CL	
FDNS	03G13_010	2	14G	G13_010	TO->FROM	GREAT BEND TAP - MULLERGREEN 115KV CKT 1	79.7	0.03059	118.6533	DBL-IRON-CLR	
FDNS	3	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.04032	152.4032	DBL-WICH-THI	
FDNS	03ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03525	166.2628	NORTHWEST - TATONGA7 345.00 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03525	152.787	G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03525	151.071	G11_051T 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03458	120.172	G12-011T 345.00 - POST ROCK 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03124	120.1519	RENFROW7 345.00 - VIOLA 7 345.00 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03124	113.8781	VIOLA 7 345.00 - WICHITA 345KV CKT 1	
FDNS	03G13_010	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.04025	158.1422	DBL-WICH-THI	
FDNS	06ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.0382	134.3233	NORTHWEST - TATONGA7 345.00 345KV CKT 1	
FDNS	06ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.04159	129.3494	DBL-WICH-THI	
FDNS	06ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.0382	121.346	G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1	
FDNS	06ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.0382	119.7128	G11_051T 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1	
FDNS	06ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03016	115.4742	WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1	
FDNS	06ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03165	110.0638	IODINE - WOODWARD EHV 138KV CKT 1	
FDNS	06ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03165	108.3249	DEWEY - IODINE 138KV CKT 1	
FDNS	06ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03016	102.2247	WOODWARD - WOODWARD 69KV CKT 1	
FDNS	09ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03862	109.8767	NORTHWEST - TATONGA7 345.00 345KV CKT 1	
FDNS	09ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.04201	101.8209	DBL-WICH-THI	
FDNS	09ALL	2	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03042	100.0843	WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1	
FDNS	3	2	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03677	224.8323	DBL-WICH-THI	

SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
							(MVA)	TDF	(% MVA)		
FDNS	6	2	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03629	134.3882	DBL-WICH-THI	
FDNS	9	2	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03661	106.1898	DBL-WICH-THI	
FDNS	03G13_010	2	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03672	229.5679	DBL-WICH-THI	
FDNS	06ALL	2	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03614	149.802	DBL-WICH-THI	
FDNS	09ALL	2	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03659	111.7637	DBL-WICH-THI	
FDNS	3	2	14G	G13_010	FROM->TO	CLEARWATER - GILL ENERGY CENTER WEST 138KV CKT 1	191	0.03677	122.5052	DBL-WICH-THI	
FDNS	03G13_010	2	14G	G13_010	FROM->TO	CLEARWATER - GILL ENERGY CENTER WEST 138KV CKT 1	191	0.03672	125.1655	DBL-WICH-THI	
FDNS	3	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.09483	121.2719	DBL-WICH-THI	
FDNS	3	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.12248	117.3989	DBL-IRON-CLR	
FDNS	3	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.12248	99.9	DBL-SPRVL-CL	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07582	100.5912	CIRCLE - HUTCHINSON ENERGY CENTER 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07905	110.2254	ST JOHN - ST JOHN 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07631	105.7409	ELLSWTP3 115.00 - MULLERGREN 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07631	104.7387	ELLSWTP3 115.00 - RUSSELL 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07498	104.3213	LAWTON EASTSIDE - OKLAUNION 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.0758	103.9528	FLATRDG3 - HARPER 138KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.0758	103.5864	HARPER - MILAN TAP 138KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.0758	103.4146	CLEARWATER - MILAN TAP 138KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.12156	127.9006	DBL-SPRVL-CL	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.10018	126.5025	SMOKYHL6 230.00 - SUMMIT 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08461	120.6084	CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08461	120.6084	CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.10018	118.8197	KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.09797	118.393	AXTELL - POST ROCK 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08477	117.9578	SPP-SWPS-05	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08477	117.6493	FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07962	113.1038	THISTLE7 345.00 - WICHITA 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07962	113.1038	THISTLE7 345.00 - WICHITA 345KV CKT 2	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08477	110.5452	FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08836	110.358	KNOLL 230 - POSTROCK6 230.00 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08177	109.2097	SPP-MKEC-06	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08176	109.1713	SEWARD - ST JOHN 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08081	109.1183	BUCKNER7 345.00 - HOLCOMB 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07698	107.5347	NORTHWEST - TATONGA7 345.00 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07612	107.5115	MINGO - RED WILLOW 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07905	107.3431	HUNTSVILLE - ST JOHN 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07905	107.1248	MIDW-CATB05	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07905	106.7899	HUNTSVILLE - HUTCHINSON ENERGY CENTER 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	106.5486	GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07547	106.5211	DBL-BVR-WWRD	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07698	106.2801	G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07709	106.2428	GRAND ISLAND - SWEETWATER 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07877	106.1966	AXTELL - PAULINE 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07972	106.1354	CLARKCOUNTY7345.00 - IRONWOOD7 345.00 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07698	106.1348	G11_051T 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07972	105.9913	CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07833	105.9405	GREAT BEND TAP - SEWARD 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07631	105.9154	SPP-MKEC-02	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07833	105.9137	GREAT BEND TAP - MULLERGREN 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	105.7795	GEN532652 1-JEFFREY ENERGY CENTER UNIT 2	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	105.7791	GEN532653 1-JEFFREY ENERGY CENTER UNIT 3	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07817	105.5722	MOORE - PAULINE 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	105.5034	GEN532651 1-JEFFREY ENERGY CENTER UNIT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07732	104.8189	SPP-MKEC-08	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07547	104.7413	DBL-HTCH-BVR	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07541	103.74	STEGALL - STEGALL TRANSFORMER 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07541	103.7394	STEGALL - STEGALL TY 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07541	103.7372	NEB01WAPAB3	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07541	103.7322	STEGALL TY 345/230KV TRANSFORMER CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07541	103.7259	TRF-STEGALL	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07631	103.693	RUSSELL - WALDO 115KV CKT 1	

SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
							(MVA)	TDF	(% MVA)		
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	103.6888	GEN530690 1-PRWINDG1	0.6900
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07568	103.6728	SPP-MKEC-09B	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07611	103.6517	GRAND ISLAND - MCCOOL 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07748	103.6352	ELM CREEK - NORTHWEST MANHATTAN 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	103.4889	GEN542955 1-LACYGNE UNIT #1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	103.4858	GEN542956 2-LACYGNE UNIT #2	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.0758	103.4564	SPP-MKEC-03A	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.0758	103.4556	SPP-MKEC-05	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	103.4358	GEN542962 2-IATAN UNIT #2	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.0758	103.4115	SPP-MKEC-03B	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	103.2878	GEN532722 1-EVANS ENERGY CENTER UNIT 2	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07631	103.2777	COVERT 3 115.00 - WALDO 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07556	103.2769	GERALD GENTLEMAN STATION - RED WILLOW 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07611	103.2577	MCCOOL - MOORE 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07631	103.2517	COVERT 3 115.00 - SMITH CENTER 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.0758	103.2499	CLEARWATER - GILL ENERGY CENTER WEST 138KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	103.1603	GEN542957 1-IATAN UNIT #1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07628	103.1451	MULLERGREN (MULGREN6) 230/115/13.8KV TRANSFORMER CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.0759	103.141	G10-056T 345.00 - ST JOE 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07627	103.1258	HEIZER 6 230.00 - MULLERGREN 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	103.1136	GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07627	103.0956	HEIZER 6 230.00 (HEIZER T1) 230/115/12.5KV TRANSFORMER CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	101.8961	BASE CASE	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	101.8961	NC1_GEN-NEBRASKA CITY 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.8354	GEN640009 1-COOPER NUCLEAR STATION	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07486	100.8107	LYONS - RICE_CO 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07371	100.76	VIOLA 7 345.00 - WICHITA 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.7568	GEN645011 1-NEBRASKA CITY 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07486	100.7418	CIRCLE - RICE 6 230.00 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.7286	GEN645001 1-FORT CALHOUN 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07414	100.7002	MOUNDRIDGE (MOUND10X) 138/115/13.8KV TRANSFORMER CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07309	100.7001	MORRIS COUNTY - UNIONRG6 230.00 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07414	100.6988	WR-B3-9	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.6741	GEN560235 1-G08-92 0.6900	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07429	100.6359	BENTON - WICHITA 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07418	100.6013	HUNTERS7 345.00 - WOODRING 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07607	100.5708	MINGO (MINGO) 345/115/13.8KV TRANSFORMER CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.5079	GEN645012 2-NEBRASKA CITY 2	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07571	100.3853	BEELER - NESS CITY 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.3027	GEN560140 1-G09-08 0.7000	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07309	100.2867	SUMMIT - UNIONRG6 230.00 230KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.2801	GEN523971 1-HARRINGTON GEN #1 24 KV	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.28	GEN523972 1-HARRINGTON GEN #2 24 KV	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.2754	GEN523973 1-HARRINGTON GEN #3 24 KV	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07571	100.2688	BEELER - DIGHTON TAP 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07589	100.2378	SPP-MKEC-12	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07486	100.2254	RICE 6 230.00 (RICE T1) 230/115/12.47KV TRANSFORMER CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07589	100.2133	ALEXANDER - SAWYER 3 115.00 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07507	100.2063	SPP-WR-335A	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07589	100.1937	BARBER 3 115.00 - SAWYER 3 115.00 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.1933	GEN659111 2-LELAND OLDS UNIT2	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07487	100.1536	EAST MCPHERSON (EMCPHR1X) 230/115/13.8KV TRANSFORMER CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.1339	GEN531459 2-S2 GENERATOR	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.08081	100.1168	BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07633	100.0977	MIDW-CATB04	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.0906	GEN659103 1-ANTELOPE VALLEY UNIT1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.0906	GEN659107 2-ANTELOPE VALLEY UNIT2	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	100.0725	GEN560522 1-G05-12-2 0.6900	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07571	100	DIGHTON TAP - MANNING TAP 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07441	100	SWISSVALE - WEST GARDNER 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07631	99.9	ALEXANDER - NEKOMA 115KV CKT 1	

SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
							(MVA)	TDF	(% MVA)		
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.9	GEN560696 1-G11-008-4 0.6900	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07371	99.9	RENFROW7 345.00 - VIOLA 7 345.00 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07364	99.9	WR-B3-8	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07631	99.8	ALEXANDER - NESS CITY 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.8	GEN539762 1-SSWIND 1 34.500	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.8	GEN539785 1-ENSNOW 1 0.5750	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07571	99.8	MANNING TAP - SCOTT CITY 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07364	99.8	MOUNDRIDGE - RENO COUNTY 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.7	GEN525561 1-TOLK GEN #1 24 KV	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.7	GEN525562 1-TOLK GEN #2 24 KV	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.7	GEN560267 1-G10-15-1 0.6900	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07486	99.7	MIDW-CAT806	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.6	GEN560268 1-G10-15-2 0.6900	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07631	99.6	NESS CITY - NESS CITY 115KV CKT 1	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.4	GEN539767 1-GRAY COUNTY WIND FARM	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.4	GEN560695 1-G11-008-3 0.6900	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.4	GEN560725 1-G13_010_3 0.6900	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.07519	99.3	GEN560694 1-G11-008-2 0.6900	
FDNS	03G13_010	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.09471	126.6179	DBL-WICH-THI	
FDNS	03G13_010	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.12234	122.999	DBL-IRON-CLR	
FDNS	03G13_010	2	14G	G13_010	TO->FROM	CIRCLE - MULLERGREN 230KV CKT 1	318.7	0.12234	105.3462	DBL-SPRVL-CL	
FDNS	03ALL	2	14G	G13_010	TO->FROM	CHISHOLM - MAIZEE 4 138.00 138KV CKT 1	287	0.04225	104.9727	BENTON - WICHITA 345KV CKT 1	
FDNS	03ALL	2	14G	G13_010	FROM->TO	BUCKNER7 345.00 - HOLCOMB 345KV CKT 1	717.1	0.29008	107.1164	G12-011T 345.00 - POST ROCK 345KV CKT 1	
FDNS	03G13_010	2	14G	G13_010	FROM->TO	BUCKNER7 345.00 - HOLCOMB 345KV CKT 1	717.1	0.2886	100	DBL-IRON-CLR	
FDNS	0	2	14WP	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03593	101.8436	DBL-WICH-THI	
FDNS	0	2	14WP	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03593	101.8212	DBL-WICH-THI	
FDNS	0	2	14WP	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03593	101.7381	DBL-WICH-THI	
FDNS	0	3	14SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03702	105.8624	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	3	14SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03604	105.8036	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	00G13_009	3	14SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03702	106.8943	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	3	19SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03767	123.6561	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	3	19SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03666	123.5891	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	00G13_009	3	19SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03769	124.5442	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	3	19WP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	375	0.04069	101.4195	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	3	19WP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	375	0.03969	101.366	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	00G13_009	3	19WP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	375	0.04071	102.2868	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	3	24SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03789	131.9875	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	0	3	24SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03688	131.9412	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	00G13_009	3	24SP	G13_009	FROM->TO	SILOAM CITY - SILOAM SPRINGS 161KV CKT 1	317	0.03787	132.9358	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1	
FDNS	9	3	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03661	116.7009	DBL-WICH-THI	
FDNS	09ALL	3	14G	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03658	122.3245	DBL-WICH-THI	
FDNS	09ALL	3	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03861	109.8682	NORTHWEST - TATONGA7 345.00 345KV CKT 1	
FDNS	09ALL	3	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.04201	101.8102	DBL-WICH-THI	
FDNS	09ALL	3	14G	G13_010	TO->FROM	FPL SWITCH - WOODWARD 138KV CKT 1	153	0.03042	100.0781	WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1	
FDNS	9	3	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03661	106.1805	DBL-WICH-THI	
FDNS	09ALL	3	14G	G13_010	TO->FROM	CLEARWATER - MILAN TAP 138KV CKT 1	110	0.03658	111.7494	DBL-WICH-THI	
FDNS	0	3	14WP	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03593	101.8208	DBL-WICH-THI	
FDNS	0	3	14WP	G13_010	FROM->TO	HARPER - MILAN TAP 138KV CKT 1	110	0.03592	101.7604	DBL-WICH-THI	

I: Power Flow Analysis (Constraints from Category C Contingencies)

Available on Request

J: Group 3 Dynamic Stability Analysis Report

Available on request.