

Screening Study

SPP-LTSR-2013-004

For OASIS Request #78485373

MAINTAINED BY
SPP Engineering, SPP Transmission Service Studies
August 5, 2013

Copyright © 2011 by Southwest Power Pool, Inc. All rights reserved.



Table of Contents

| | |
|------------------------------------|----------|
| Executive Summary | 2 |
| Introduction..... | 3 |
| Study Methodology | 4 |
| Description | 4 |
| Model Updates | 4 |
| Transmission Request Modeling..... | 5 |
| Transfer Analysis..... | 5 |
| Study Results..... | 6 |
| Study Analysis Results..... | 6 |
| Conclusion | 7 |
| Appendix A..... | 8 |

Executive Summary

American Electric Power has requested a Screening Study to determine the impacts on SPP facilities due to the Long Term Service Requests for 136 MW. The service type requested for this screening study is Long Term Service Request (LTSR). OASIS# 78485373 was studied as one request from 1/1/2016 to 1/1/2026.

The principal objective of this study is to identify system problems and potential system modifications necessary to facilitate the LTSR request while maintaining system reliability. The LTSR request was studied using two system scenarios. The service was modeled by the transfers from CSWS to CSWS. The two scenarios were studied to capture system limitations caused or impacted by the requested service. An analysis was conducted on the planning horizon from 1/1/2016 to 1/1/2026.

The service was modeled from CSWS to CSWS. Facilities on the SPP system were identified for the requested service due to the SPP Study Methodology criteria. Tables 1 and 2 summarize the results of the screening study analysis for the transfers for the scenarios listed in the table. Table 1 lists SPP thermal transfer limitations identified. Table 2 lists SPP voltage transfer limitations identified. Table 3 lists the network upgrades required to mitigate the limitations impacted by this request.

Introduction

American Power Electric has requested a screening study to determine the impacts on SPP facilities for the Long Term Service Requests for 136 MW.

The purpose of the LTSR Option Screening Study is to provide the Eligible Customer with an approximation of the transmission remediation costs of each potential LTSR and a reasonable cost differential between alternatives for the purpose of an Eligible Customer's ranking of its potential LTSRs. The results of the Screening Study are not binding and the Eligible Customer retains the rights to enter the Aggregate Transmission Service Study. The Screening Study results will not assess the third party impacts and upgrades required. Service will not be granted based on the Screening Study for potential LTSRs on the Transmission System. To obtain a Service Agreement, Eligible Customers must apply for service and follow the application process set forth in Parts II and III of the Tariff.

This study includes steady-state contingency analysis (PSS/E function ACCC). The steady-state analysis considers the impact of the request on transmission line and transformer loadings for outages of single transmission lines, transformers, and generating units, and selected multiple transmission lines and transformers on the SPP and first-tier third party systems.

The LTSR request was studied using two system scenarios. The service was modeled by a transfer from CSWS to CSWS. The two scenarios were studied to capture the system limitations caused or impacted by the requested service. Scenario 0 includes projected usage of transmission service included in the SPP 2011 Series Cases. Scenario 5 includes transmission service not already included in the SPP 2011 Series Cases.

Study Methodology

Description

The facility study analysis was conducted to determine the steady-state impact of the requested service on the SPP system. The steady-state analysis was performed to ensure current SPP Criteria and NERC Reliability Standards requirements are fulfilled. SPP conforms to NERC Reliability Standards, which provide strict requirements related to voltage violations and thermal overloads during normal conditions and during a contingency. NERC Standards require all facilities to be within normal operating ratings for normal system conditions and within emergency ratings after a contingency.

Normal operating ratings and emergency operating ratings monitored are Rate A and B in the SPP Model Development Working Group (MDWG) models, respectively. The upper bound and lower bound of the normal voltage range monitored is 105% and 95%. The upper bound and lower bound of the emergency voltage range monitored is 105% and 90%. Transmission Owner voltage monitoring criteria is used if more restrictive. The SPS Tuco 230 kV bus voltage is monitored at 92.5% due to pre-determined system stability limitations. The WERE Wolf Creek 345 kV bus voltage is monitored at 103.5% and 98.5% due to transmission operating procedure.

The contingency set includes all SPP control area branches and ties 69 kV and above; first tier non-SPP control area branches and ties 115 kV and above; any defined contingencies for these control areas; and generation unit outages for the control areas with SPP reserve share program redispatch. The monitor elements include all SPP control area branches, ties, and buses 69 kV. and above,. Voltage monitoring was performed for SPP control area buses 69 kV and above.

A 3 % transfer distribution factor (TDF) cutoff was applied to all SPP control area facilities. For voltage monitoring, a 0.02 per unit change in voltage must occur due to the transfer or modeling upgrades to be considered a valid limit to the transfer.

Model Updates

SPP used four seasonal models to study the CSWS to CSWS 136 MW request for the requested service period. The following SPP Transmission Expansion Plan 2012 Build 1

Cases were used to study the impact of the requested service on the transmission system:

- 2014/15 Winter Peak (14WP)
- 2018 Summer Peak (18SP)
- 2018/19 Winter Peak (18WP)
- 2023 Summer Peak (23SP)
- 2023/24 Winter Peak (23WP)

The Summer Peak models apply to June through September, and the Winter Peak models apply to December through March.

The chosen base case models were modified to reflect the current modeling information. From the six seasonal models, two system scenarios were developed. Scenario 0 includes projected usage of transmission included in the SPP 2012 Series Cases. Scenario 5 includes transmission not already included in the SPP 2012 Series Cases.

Transmission Request Modeling

Network Integration Transmission Service requests are modeled as Generation to Load transfers in addition to Generation to Generation because the requested Network Integration Transmission Service is a request to serve network load with the new designated network resource, and the impacts on the Transmission System are determined accordingly. Generation to Generation transfers are accomplished by developing a post-transfer case for comparison by dispatching the request source and redispatching the request sink.

Transfer Analysis

Using the selected cases both with and without the requested transfer modeled, the PSS/E Activity ACCC was run on the cases and compared to determine the facility overloads caused or impacted by the transfer. Transfer distribution factor cutoffs and voltage threshold (0.02 change) were applied to determine the impacted facilities. The PSS/E options chosen to conduct the analysis can be found in Appendix A.

Study Results

Study Analysis Results

Tables 1 and 2 contain the initial steady-state analysis results of the LTSR. The tables are attached to the end of this report, if applicable. The tables identify the scenario and season in which the event occurred, the transfer amount studied, the facility control area location, applicable ratings of the thermal transfer limitations and voltage transfer limitations, and the loading percentage and voltage per unit (pu).

Table 1 lists the SPP thermal transfer limitations caused or impacted by the 136 MW requested transfers for applicable scenarios. Solutions are identified for the limitations in this table.

Table 2 lists the SPP voltage transfer limitations caused or impacted by the 136 MW requested transfers for applicable scenarios. Solutions are identified for the violations in this table.

Table 3 lists the network upgrades required to mitigate the limitations caused or impacted by this request. Engineering and construction costs are provided for assigned upgrades in this table.

Conclusion

The results of the screening study show that limiting constraints exist within the SPP regional transmission system for the requested transfer of 136 MW. The next steps are to WITHDRAW the request on OASIS and, if desired, enter a new OASIS request into the aggregate study queue.

The results contained in this study are for informational purposes only. Service will not be granted based on the Screening Study results. To obtain a Service Agreement, Eligible Customers must apply for service and follow the application processes set forth in Parts II and III of the Tariff and enter the Aggregate Study process. The results of the Aggregate Study may vary from the results of this screening study.

As a final step in this process, it is requested that the customer WITHDRAW the LTSR screening study request on OASIS.

Appendix A

PSS/E CHOICES IN RUNNING LOAD FLOW PROGRAM AND ACCC

BASE CASES:

- Solutions: Fixed slope decoupled Newton-Raphson solution (FDNS)
- Tap adjustment: Stepping
- Area interchange control: Tie lines and loads
- VAR limits: Apply immediately
- Solution options:
 - Phase shift adjustment
 - Flat start
 - Lock DC taps
 - Lock switched shunts

ACCC CASES for system intact:

- Solutions: AC contingency checking (ACCC)
- MW mismatch tolerance: 0.5
- Contingency case rating: Rate A
- Percent of rating: 100
- Output code: Summary
- Min flow change in overload report: 3 MW
- Excl cases w/ no overloads form report: YES
- Exclude interfaces from report: NO
- Perform voltage limit check: YES
- Elements in available capacity table: 60000
- Cutoff threshold for available capacity table: 99999.0
- Min. contng. case Vltg chng for report: 0.02
- Sorted output: None
- Newton Solution: Stepping
- Tap adjustment: Tie lines and loads
- Area interchange control: Apply automatically
- VAR limits:
- Solution options:
 - Phase shift adjustment
 - Flat start
 - Lock DC taps
 - Lock switched shunts

ACCC CASES for branch and transformer contingencies:

- Solutions: AC contingency checking (ACCC)
- MW mismatch tolerance: 0.5
- Contingency case rating: Rate B
- Percent of rating: 100
- Output code: Summary

- Min flow change in overload report: 3mw
- Excl cases w/ no overloads form report: YES
- Exclude interfaces from report: NO
- Perform voltage limit check: YES
- Elements in available capacity table: 60000
- Cutoff threshold for available capacity table: 99999.0
- Min. contng. case Vltg chng for report: 0.02
- Sorted output: None
- Newton Solution:
- Tap adjustment: Stepping
- Area interchange control: Tie lines and loads
- VAR limits: Apply automatically
- Solution options:
 - X Phase shift adjustment
 - _ Flat start
 - _ Lock DC taps
 - _ Lock switched shunts

ACCC CASES for generator contingencies (largest machine at a bus):

- Solutions: AC contingency checking (ACCC)
- MW mismatch tolerance: 0.5
- Contingency case rating: Rate B
- Percent of rating: 100
- Output code: Summary
- Min flow change in overload report: 3mw
- Excl cases w/ no overloads form report: YES
- Exclude interfaces from report: NO
- Perform voltage limit check: YES
- Elements in available capacity table: 60000
- Cutoff threshold for available capacity table: 99999.0
- Min. contng. case Vltg chng for report: 0.02
- Sorted output: None
- Newton Solution:
- Tap adjustment: Stepping
- Area interchange control: Disabled
- Var limits: Apply automatically
- Solution options:
 - X Phase shift adjustment
 - _ Flat start
 - _ Lock DC taps
 - _ Lock switched shunts

| Scenario | Season | From Area | To Area | Monitored Branch Over 100% Rate B | Transfer Case % Loading | TDF (%) | Outaged Branch Causing Overload | Upgrade Name | Solution |
|----------|--------|-----------|---------|--|-------------------------|---------|--|--|--|
| 5 | 18SP | AEPW | AEPW | ARSENAL HILL - RAINES 138KV CKT 1 | 124.1 | 24.30% | SPP-AEPW-05 | Messick 500/230 kV Transformer Ckt 1 | Build Messick 500/230 kV station. Connect to Carroll, Clarence, and Western Kraft 230 kV lines. Install 500/230 kV 675 MVA transformer. This upgrade is contingent upon approval from Cleco Power LLC. |
| 5 | 18SP | AEPW | AEPW | ARSENAL HILL - RAINES 138KV CKT 1 | 108.6 | 22.03% | LIEBERMAN - LONGWOOD 138KV CKT 1 | Messick 500/230 kV Transformer Ckt 1 | Build Messick 500/230 kV station. Connect to Carroll, Clarence, and Western Kraft 230 kV lines. Install 500/230 kV 675 MVA transformer. This upgrade is contingent upon approval from Cleco Power LLC. |
| 5 | 14WP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 137.9 | 30.12% | 4REMNGTON_138.00 - FAIRFAX 138KV CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 14WP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 131.3 | 19.68% | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 14WP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 131.3 | 19.68% | DELAWARE (DELAWARE) 345/138/13.8KV TRANSFORMER CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 14WP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 112.7 | 20.29% | SPP-AEPW-39 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 14WP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 111.7 | 20.08% | LACYGNE - NEOSHO 345KV CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 14WP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 111.5 | 19.89% | SPP-WERE-18 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 14WP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 109.4 | 19.95% | SPP-WERE-15 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 14WP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 108.8 | 20.05% | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 14WP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 108.7 | 20.05% | SHIDWFC - WEBB CITY TAP 138KV CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 14WP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 105.9 | 20.05% | BASE CASE | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 153.3 | 28.75% | 4REMNGTON_138.00 - FAIRFAX 138KV CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 150.2 | 18.26% | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 150.2 | 18.26% | DELAWARE (DELAWARE) 345/138/13.8KV TRANSFORMER CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 125.1 | 18.38% | SPP-WERE-18 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 124.5 | 18.65% | LACYGNE - NEOSHO 345KV CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 122.4 | 18.45% | SPP-WERE-15 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 122.0 | 18.58% | SPP-AEPW-39 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 120.4 | 18.70% | OMPA-PAWHUSKA NORTHEAST - PAWHUSKA TAP 138KV CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 120.0 | 18.70% | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 116.2 | 18.70% | BASE CASE | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 18WP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 123.0 | 31.37% | 4REMNGTON_138.00 - FAIRFAX 138KV CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 18WP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 115.4 | 21.15% | DELAWARE (DELAWARE) 345/138/13.8KV TRANSFORMER CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 18WP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 115.4 | 21.15% | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 23SP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 129.9 | 30.17% | 4REMNGTON_138.00 - FAIRFAX 138KV CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 23SP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 124.3 | 19.77% | DELAWARE (DELAWARE) 345/138/13.8KV TRANSFORMER CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 23SP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 124.2 | 19.77% | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 23SP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 104.0 | 18.44% | SPP-AEPW-02 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 23WP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 123.6 | 28.84% | 4REMNGTON_138.00 - FAIRFAX 138KV CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 23WP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 119.0 | 18.19% | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 23WP | AEPW | AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | 118.9 | 18.19% | DELAWARE (DELAWARE) 345/138/13.8KV TRANSFORMER CKT 1 | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW |
| 5 | 18WP | AEPW | SWPA | BETHEL - BROKEN BOW 138KV CKT 1 | 107.9 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - LONE OAK 138KV CKT 1 | Rebuild 0.32 miles of 3/0 CWC with 1272 ACSR. Replace jumpers @ Lone Oak |
| 5 | 18WP | AEPW | SWPA | BETHEL - BROKEN BOW 138KV CKT 1 | 107.9 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - BROKEN BOW 138KV CKT 1 | Rebuild 9.19 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 18WP | AEPW | SWPA | BETHEL - BROKEN BOW 138KV CKT 1 | 107.9 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - NASHOBA 138KV CKT 1 | Rebuild 22.43 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 18WP | AEPW | SWPA | BETHEL - BROKEN BOW 138KV CKT 1 | 107.9 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - NASHOBA 138KV CKT 1 | Rebuild 11.57 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | SWPA | BETHEL - BROKEN BOW 138KV CKT 1 | 107.9 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - SARDIS 138KV CKT 1 | Rebuild 1.46 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | SWPA | BETHEL - BROKEN BOW 138KV CKT 1 | 107.9 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - SARDIS 138KV CKT 1 | Rebuild 13.8 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | SWPA | BETHEL - BROKEN BOW 138KV CKT 1 | 107.9 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | Rebuild 11.63 |
| 5 | 18WP | AEPW | AEPW | BETHEL - NASHOBA 138KV CKT 1 | 113.1 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - LONE OAK 138KV CKT 1 | Rebuild 0.32 miles of 3/0 CWC with 1272 ACSR. Replace jumpers @ Lone Oak |
| 5 | 18WP | AEPW | AEPW | BETHEL - NASHOBA 138KV CKT 1 | 113.1 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - BROKEN BOW 138KV CKT 1 | Rebuild 9.19 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | BETHEL - NASHOBA 138KV CKT 1 | 113.1 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - NASHOBA 138KV CKT 1 | Rebuild 22.43 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | BETHEL - NASHOBA 138KV CKT 1 | 113.1 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - NASHOBA 138KV CKT 1 | Rebuild 11.57 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | BETHEL - NASHOBA 138KV CKT 1 | 113.1 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - SARDIS 138KV CKT 1 | Rebuild 1.46 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | BETHEL - NASHOBA 138KV CKT 1 | 113.1 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - SARDIS 138KV CKT 1 | Rebuild 13.8 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | BETHEL - NASHOBA 138KV CKT 1 | 113.1 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | Rebuild 11.63 |
| 5 | 23WP | AEPW | AEPW | BETHEL - NASHOBA 138KV CKT 1 | 102.9 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - LONE OAK 138KV CKT 1 | Rebuild 0.32 miles of 3/0 CWC with 1272 ACSR. Replace jumpers @ Lone Oak |
| 5 | 23WP | AEPW | AEPW | BETHEL - NASHOBA 138KV CKT 1 | 102.9 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - BROKEN BOW 138KV CKT 1 | Rebuild 9.19 miles of 3/0 Copperweld with 1272 ACSR |

| Scenario | Season | From Area | To Area | Monitored Branch Over 100% Rate B | Transfer Case % Loading | TDF (%) | Outaged Branch Causing Overload | Upgrade Name | Solution |
|----------|--------|-----------|---------|---|-------------------------|---------|--|---|--|
| 5 | 23WP | AEPW | AEPW | BETHEL - NASHOBA 138KV CKT 1 | 102.9 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - NASHOBA 138KV CKT 1 | Rebuild 22.43 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | BETHEL - NASHOBA 138KV CKT 1 | 102.9 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - NASHOBA 138KV CKT 1 | Rebuild 11.57 miles of 3/0 CWC with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | BETHEL - NASHOBA 138KV CKT 1 | 102.9 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - SARDIS 138KV CKT 1 | Rebuild 1.46 miles of 3/0 CWC with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | BETHEL - NASHOBA 138KV CKT 1 | 102.9 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - SARDIS 138KV CKT 1 | Rebuild 13.8 miles of 3/0 CWC with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | BETHEL - NASHOBA 138KV CKT 1 | 102.9 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | Rebuild 11.63 |
| 5 | 18WP | SWPA | AEPW | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | 101.1 | 3.55% | BBDAMTP4 - MOUNTAIN RIVER 138KV CKT 1 | ENOWILT - LONE OAK 138KV CKT 1 | Rebuild 0.32 miles of 3/0 CWC with 1272 ACSR. Replace jumpers @ Lone Oak |
| 5 | 18WP | SWPA | AEPW | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | 101.1 | 3.55% | BBDAMTP4 - MOUNTAIN RIVER 138KV CKT 1 | BETHEL - BROKEN BOW 138KV CKT 1 | Rebuild 9.19 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 18WP | SWPA | AEPW | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | 101.1 | 3.55% | BBDAMTP4 - MOUNTAIN RIVER 138KV CKT 1 | BETHEL - NASHOBA 138KV CKT 1 | Rebuild 22.43 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 18WP | SWPA | AEPW | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | 101.1 | 3.55% | BBDAMTP4 - MOUNTAIN RIVER 138KV CKT 1 | CLAYTON - NASHOBA 138KV CKT 1 | Rebuild 11.57 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | SWPA | AEPW | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | 101.1 | 3.55% | BBDAMTP4 - MOUNTAIN RIVER 138KV CKT 1 | CLAYTON - SARDIS 138KV CKT 1 | Rebuild 1.46 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | SWPA | AEPW | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | 101.1 | 3.55% | BBDAMTP4 - MOUNTAIN RIVER 138KV CKT 1 | ENOWILT - SARDIS 138KV CKT 1 | Rebuild 13.8 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | SWPA | AEPW | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | 101.1 | 3.55% | BBDAMTP4 - MOUNTAIN RIVER 138KV CKT 1 | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | Rebuild 11.63 |
| 5 | 14WP | OKGE | OKGE | CIMARRON - DRAPER LAKE 345KV CKT 1 | 101.5 | 10.47% | ARCADIA - SEMINOLE 345KV CKT 1 | CIMARRON - DRAPER LAKE 345KV CKT 1 | Increase capacity of Draper Lake CT and Cimarron wave trap |
| 5 | 14WP | OKGE | OKGE | CIMARRON - DRAPER LAKE 345KV CKT 1 | 100.8 | 10.26% | GRACEMONT - MINCO 345KV CKT 1 | CIMARRON - DRAPER LAKE 345KV CKT 1 | Increase capacity of Draper Lake CT and Cimarron wave trap |
| 5 | 18WP | OKGE | OKGE | CIMARRON - DRAPER LAKE 345KV CKT 1 | 104.4 | 9.89% | ARCADIA - SEMINOLE 345KV CKT 1 | CIMARRON - DRAPER LAKE 345KV CKT 1 | Increase capacity of Draper Lake CT and Cimarron wave trap |
| 5 | 18WP | OKGE | OKGE | CIMARRON - DRAPER LAKE 345KV CKT 1 | 100.6 | 9.55% | GRACEMONT - MINCO 345KV CKT 1 | CIMARRON - DRAPER LAKE 345KV CKT 1 | Increase capacity of Draper Lake CT and Cimarron wave trap |
| 5 | 18WP | OKGE | OKGE | CIMARRON - DRAPER LAKE 345KV CKT 1 | 100.1 | 8.78% | GRACEMONT - LAWTON EASTSIDE 345KV CKT 1 | CIMARRON - DRAPER LAKE 345KV CKT 1 | Increase capacity of Draper Lake CT and Cimarron wave trap |
| 5 | 23WP | OKGE | OKGE | CIMARRON - DRAPER LAKE 345KV CKT 1 | 118.9 | 10.94% | ARCADIA - SEMINOLE 345KV CKT 1 | CIMARRON - DRAPER LAKE 345KV CKT 1 | Increase capacity of Draper Lake CT and Cimarron wave trap |
| 5 | 23WP | OKGE | OKGE | CIMARRON - DRAPER LAKE 345KV CKT 1 | 114.9 | 10.33% | GRACEMONT - MINCO 345KV CKT 1 | CIMARRON - DRAPER LAKE 345KV CKT 1 | Increase capacity of Draper Lake CT and Cimarron wave trap |
| 5 | 23WP | OKGE | OKGE | CIMARRON - DRAPER LAKE 345KV CKT 1 | 113.9 | 9.58% | GRACEMONT - LAWTON EASTSIDE 345KV CKT 1 | CIMARRON - DRAPER LAKE 345KV CKT 1 | Increase capacity of Draper Lake CT and Cimarron wave trap |
| 5 | 23WP | OKGE | OKGE | CIMARRON - DRAPER LAKE 345KV CKT 1 | 103.0 | 8.52% | SPP-AEPW-32 | CIMARRON - DRAPER LAKE 345KV CKT 1 | Increase capacity of Draper Lake CT and Cimarron wave trap |
| 5 | 23WP | OKGE | OKGE | CIMARRON - DRAPER LAKE 345KV CKT 1 | 102.0 | 8.47% | OGE3TERM14 | CIMARRON - DRAPER LAKE 345KV CKT 1 | Increase capacity of Draper Lake CT and Cimarron wave trap |
| 5 | 23WP | OKGE | OKGE | CIMARRON - DRAPER LAKE 345KV CKT 1 | 101.9 | 8.43% | OGE3TERM12 | CIMARRON - DRAPER LAKE 345KV CKT 1 | Increase capacity of Draper Lake CT and Cimarron wave trap |
| 5 | 23WP | OKGE | OKGE | CIMARRON - DRAPER LAKE 345KV CKT 1 | 101.1 | 8.46% | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 | CIMARRON - DRAPER LAKE 345KV CKT 1 | Increase capacity of Draper Lake CT and Cimarron wave trap |
| 5 | 23WP | OKGE | OKGE | CIMARRON - DRAPER LAKE 345KV CKT 1 | 100.6 | 8.46% | HOYT - STRANGER CREEK 345KV CKT 1 | CIMARRON - DRAPER LAKE 345KV CKT 1 | Increase capacity of Draper Lake CT and Cimarron wave trap |
| 5 | 23WP | OKGE | OKGE | CIMARRON - DRAPER LAKE 345KV CKT 1 | 100.6 | 8.37% | LACYGNE - NEOSHO 345KV CKT 1 | CIMARRON - DRAPER LAKE 345KV CKT 1 | Increase capacity of Draper Lake CT and Cimarron wave trap |
| 5 | 18WP | AEPW | AEPW | CLAYTON - NASHOBA 138KV CKT 1 | 114.7 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - LONE OAK 138KV CKT 1 | Rebuild 0.32 miles of 3/0 CWC with 1272 ACSR. Replace jumpers @ Lone Oak |
| 5 | 18WP | AEPW | AEPW | CLAYTON - NASHOBA 138KV CKT 1 | 114.7 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - BROKEN BOW 138KV CKT 1 | Rebuild 9.19 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | CLAYTON - NASHOBA 138KV CKT 1 | 114.7 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - NASHOBA 138KV CKT 1 | Rebuild 22.43 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | CLAYTON - NASHOBA 138KV CKT 1 | 114.7 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - NASHOBA 138KV CKT 1 | Rebuild 11.57 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | CLAYTON - NASHOBA 138KV CKT 1 | 114.7 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - SARDIS 138KV CKT 1 | Rebuild 1.46 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | CLAYTON - NASHOBA 138KV CKT 1 | 114.7 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - SARDIS 138KV CKT 1 | Rebuild 13.8 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | CLAYTON - NASHOBA 138KV CKT 1 | 114.7 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | Rebuild 11.63 |
| 5 | 23WP | AEPW | AEPW | CLAYTON - NASHOBA 138KV CKT 1 | 104.5 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - LONE OAK 138KV CKT 1 | Rebuild 0.32 miles of 3/0 CWC with 1272 ACSR. Replace jumpers @ Lone Oak |
| 5 | 23WP | AEPW | AEPW | CLAYTON - NASHOBA 138KV CKT 1 | 104.5 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - BROKEN BOW 138KV CKT 1 | Rebuild 9.19 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | CLAYTON - NASHOBA 138KV CKT 1 | 104.5 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - NASHOBA 138KV CKT 1 | Rebuild 22.43 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | CLAYTON - NASHOBA 138KV CKT 1 | 104.5 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - NASHOBA 138KV CKT 1 | Rebuild 11.57 miles of 3/0 CWC with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | CLAYTON - NASHOBA 138KV CKT 1 | 104.5 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - SARDIS 138KV CKT 1 | Rebuild 1.46 miles of 3/0 CWC with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | CLAYTON - NASHOBA 138KV CKT 1 | 104.5 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - SARDIS 138KV CKT 1 | Rebuild 13.8 miles of 3/0 CWC with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | CLAYTON - NASHOBA 138KV CKT 1 | 104.5 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | Rebuild 11.63 |
| 5 | 18WP | AEPW | AEPW | CLAYTON - SARDIS 138KV CKT 1 | 117.0 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - LONE OAK 138KV CKT 1 | Rebuild 0.32 miles of 3/0 CWC with 1272 ACSR. Replace jumpers @ Lone Oak |
| 5 | 18WP | AEPW | AEPW | CLAYTON - SARDIS 138KV CKT 1 | 117.0 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - BROKEN BOW 138KV CKT 1 | Rebuild 9.19 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | CLAYTON - SARDIS 138KV CKT 1 | 117.0 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - NASHOBA 138KV CKT 1 | Rebuild 22.43 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | CLAYTON - SARDIS 138KV CKT 1 | 117.0 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - NASHOBA 138KV CKT 1 | Rebuild 11.57 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | CLAYTON - SARDIS 138KV CKT 1 | 117.0 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - SARDIS 138KV CKT 1 | Rebuild 1.46 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | CLAYTON - SARDIS 138KV CKT 1 | 117.0 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - SARDIS 138KV CKT 1 | Rebuild 13.8 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | CLAYTON - SARDIS 138KV CKT 1 | 117.0 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | Rebuild 11.63 |
| 5 | 23WP | AEPW | AEPW | CLAYTON - SARDIS 138KV CKT 1 | 106.8 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - LONE OAK 138KV CKT 1 | Rebuild 0.32 miles of 3/0 CWC with 1272 ACSR. Replace jumpers @ Lone Oak |

| Scenario | Season | From Area | To Area | Monitored Branch Over 100% Rate B | Transfer Case % Loading | TDF (%) | Outaged Branch Causing Overload | Upgrade Name | Solution |
|----------|--------|-----------|---------|-----------------------------------|-------------------------|---------|--|---|--|
| 5 | 23WP | AEPW | AEPW | CLAYTON - SARDIS 138KV CKT 1 | 106.8 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - BROKEN BOW 138KV CKT 1 | Rebuild 9.19 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | CLAYTON - SARDIS 138KV CKT 1 | 106.8 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - NASHOBA 138KV CKT 1 | Rebuild 22.43 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | CLAYTON - SARDIS 138KV CKT 1 | 106.8 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - NASHOBA 138KV CKT 1 | Rebuild 11.57 miles of 3/0 CWC with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | CLAYTON - SARDIS 138KV CKT 1 | 106.8 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - SARDIS 138KV CKT 1 | Rebuild 1.46 miles of 3/0 CWC with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | CLAYTON - SARDIS 138KV CKT 1 | 106.8 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - SARDIS 138KV CKT 1 | Rebuild 13.8 miles of 3/0 CWC with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | CLAYTON - SARDIS 138KV CKT 1 | 106.8 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | Rebuild 11.63 |
| 5 | 14WP | AEPW | AEPW | DOMES - MOUND ROAD 138KV CKT 1 | 114.8 | 41.90% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | DOMES - MOUND ROAD 138KV CKT 1 | Rebuild 13.59 miles |
| 5 | 14WP | AEPW | AEPW | DOMES - MOUND ROAD 138KV CKT 1 | 103.7 | 41.90% | 4REMNGTON 138.00 - SHIDLER 138KV CKT 1 | DOMES - MOUND ROAD 138KV CKT 1 | Rebuild 13.59 miles |
| 5 | 18SP | AEPW | AEPW | DOMES - MOUND ROAD 138KV CKT 1 | 131.2 | 40.48% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | DOMES - MOUND ROAD 138KV CKT 1 | Rebuild 13.59 miles |
| 5 | 18SP | AEPW | AEPW | DOMES - MOUND ROAD 138KV CKT 1 | 117.4 | 40.48% | 4REMNGTON 138.00 - SHIDLER 138KV CKT 1 | DOMES - MOUND ROAD 138KV CKT 1 | Rebuild 13.59 miles |
| 5 | 18SP | AEPW | AEPW | DOMES - MOUND ROAD 138KV CKT 1 | 111.8 | 35.54% | FAIRFAX - FAXTAP4 138.00 138KV CKT 1 | DOMES - MOUND ROAD 138KV CKT 1 | Rebuild 13.59 miles |
| 5 | 18WP | AEPW | AEPW | DOMES - MOUND ROAD 138KV CKT 1 | 106.5 | 42.56% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | DOMES - MOUND ROAD 138KV CKT 1 | Rebuild 13.59 miles |
| 5 | 23SP | AEPW | AEPW | DOMES - MOUND ROAD 138KV CKT 1 | 122.4 | 41.83% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | DOMES - MOUND ROAD 138KV CKT 1 | Rebuild 13.59 miles |
| 5 | 23SP | AEPW | AEPW | DOMES - MOUND ROAD 138KV CKT 1 | 108.5 | 41.83% | 4REMNGTON 138.00 - SHIDLER 138KV CKT 1 | DOMES - MOUND ROAD 138KV CKT 1 | Rebuild 13.59 miles |
| 5 | 23SP | AEPW | AEPW | DOMES - MOUND ROAD 138KV CKT 1 | 101.9 | 36.85% | FAIRFAX - FAXTAP4 138.00 138KV CKT 1 | DOMES - MOUND ROAD 138KV CKT 1 | Rebuild 13.59 miles |
| 5 | 23WP | AEPW | AEPW | DOMES - MOUND ROAD 138KV CKT 1 | 104.6 | 41.20% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | DOMES - MOUND ROAD 138KV CKT 1 | Rebuild 13.59 miles |
| 5 | 14WP | AEPW | AEPW | DOMES - PAWHUSKA TAP 138KV CKT 1 | 117.2 | 41.90% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | DOMES - PAWHUSKA TAP 138KV CKT 1 | Rebuild 5.74 miles |
| 5 | 14WP | AEPW | AEPW | DOMES - PAWHUSKA TAP 138KV CKT 1 | 105.9 | 41.90% | 4REMNGTON 138.00 - SHIDLER 138KV CKT 1 | DOMES - PAWHUSKA TAP 138KV CKT 1 | Rebuild 5.74 miles |
| 5 | 14WP | AEPW | AEPW | DOMES - PAWHUSKA TAP 138KV CKT 1 | 101.5 | 36.90% | FAIRFAX - FAXTAP4 138.00 138KV CKT 1 | DOMES - PAWHUSKA TAP 138KV CKT 1 | Rebuild 5.74 miles |
| 5 | 18SP | AEPW | AEPW | DOMES - PAWHUSKA TAP 138KV CKT 1 | 134.7 | 40.48% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | DOMES - PAWHUSKA TAP 138KV CKT 1 | Rebuild 5.74 miles |
| 5 | 18SP | AEPW | AEPW | DOMES - PAWHUSKA TAP 138KV CKT 1 | 120.9 | 40.48% | 4REMNGTON 138.00 - SHIDLER 138KV CKT 1 | DOMES - PAWHUSKA TAP 138KV CKT 1 | Rebuild 5.74 miles |
| 5 | 18SP | AEPW | AEPW | DOMES - PAWHUSKA TAP 138KV CKT 1 | 115.3 | 35.54% | FAIRFAX - FAXTAP4 138.00 138KV CKT 1 | DOMES - PAWHUSKA TAP 138KV CKT 1 | Rebuild 5.74 miles |
| 5 | 18SP | AEPW | AEPW | DOMES - PAWHUSKA TAP 138KV CKT 1 | 101.4 | 26.09% | LACYGNE - NEOSHO 345KV CKT 1 | DOMES - PAWHUSKA TAP 138KV CKT 1 | Rebuild 5.74 miles |
| 5 | 18SP | AEPW | AEPW | DOMES - PAWHUSKA TAP 138KV CKT 1 | 100.5 | 26.13% | OMPA-PAWHUSKA NORTHEAST - PAWHUSKA TAP 138KV CKT 1 | DOMES - PAWHUSKA TAP 138KV CKT 1 | Rebuild 5.74 miles |
| 5 | 18WP | AEPW | AEPW | DOMES - PAWHUSKA TAP 138KV CKT 1 | 108.9 | 42.56% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | DOMES - PAWHUSKA TAP 138KV CKT 1 | Rebuild 5.74 miles |
| 5 | 23SP | AEPW | AEPW | DOMES - PAWHUSKA TAP 138KV CKT 1 | 126.2 | 41.83% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | DOMES - PAWHUSKA TAP 138KV CKT 1 | Rebuild 5.74 miles |
| 5 | 23SP | AEPW | AEPW | DOMES - PAWHUSKA TAP 138KV CKT 1 | 112.3 | 41.83% | 4REMNGTON 138.00 - SHIDLER 138KV CKT 1 | DOMES - PAWHUSKA TAP 138KV CKT 1 | Rebuild 5.74 miles |
| 5 | 23SP | AEPW | AEPW | DOMES - PAWHUSKA TAP 138KV CKT 1 | 105.7 | 36.85% | FAIRFAX - FAXTAP4 138.00 138KV CKT 1 | DOMES - PAWHUSKA TAP 138KV CKT 1 | Rebuild 5.74 miles |
| 5 | 23WP | AEPW | AEPW | DOMES - PAWHUSKA TAP 138KV CKT 1 | 107.2 | 41.20% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | DOMES - PAWHUSKA TAP 138KV CKT 1 | Rebuild 5.74 miles |
| 5 | 18WP | AEPW | AEPW | ENOWILT - LONE OAK 138KV CKT 1 | 121.7 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - LONE OAK 138KV CKT 1 | Rebuild 0.32 miles of 3/0 CWC with 1272 ACSR. Replace jumpers @ Lone Oak |
| 5 | 18WP | AEPW | AEPW | ENOWILT - LONE OAK 138KV CKT 1 | 121.7 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - BROKEN BOW 138KV CKT 1 | Rebuild 9.19 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | ENOWILT - LONE OAK 138KV CKT 1 | 121.7 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - NASHOBA 138KV CKT 1 | Rebuild 22.43 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | ENOWILT - LONE OAK 138KV CKT 1 | 121.7 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - NASHOBA 138KV CKT 1 | Rebuild 11.57 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | ENOWILT - LONE OAK 138KV CKT 1 | 121.7 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - SARDIS 138KV CKT 1 | Rebuild 1.46 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | ENOWILT - LONE OAK 138KV CKT 1 | 121.7 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - SARDIS 138KV CKT 1 | Rebuild 13.8 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | ENOWILT - LONE OAK 138KV CKT 1 | 121.7 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | Rebuild 11.63 |
| 5 | 23WP | AEPW | AEPW | ENOWILT - LONE OAK 138KV CKT 1 | 111.5 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - LONE OAK 138KV CKT 1 | Rebuild 0.32 miles of 3/0 CWC with 1272 ACSR. Replace jumpers @ Lone Oak |
| 5 | 23WP | AEPW | AEPW | ENOWILT - LONE OAK 138KV CKT 1 | 111.5 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - BROKEN BOW 138KV CKT 1 | Rebuild 9.19 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | ENOWILT - LONE OAK 138KV CKT 1 | 111.5 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - NASHOBA 138KV CKT 1 | Rebuild 22.43 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | ENOWILT - LONE OAK 138KV CKT 1 | 111.5 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - NASHOBA 138KV CKT 1 | Rebuild 11.57 miles of 3/0 CWC with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | ENOWILT - LONE OAK 138KV CKT 1 | 111.5 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - SARDIS 138KV CKT 1 | Rebuild 1.46 miles of 3/0 CWC with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | ENOWILT - LONE OAK 138KV CKT 1 | 111.5 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - SARDIS 138KV CKT 1 | Rebuild 13.8 miles of 3/0 CWC with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | ENOWILT - LONE OAK 138KV CKT 1 | 111.5 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | Rebuild 11.63 |
| 5 | 18WP | AEPW | AEPW | ENOWILT - SARDIS 138KV CKT 1 | 120.8 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - LONE OAK 138KV CKT 1 | Rebuild 0.32 miles of 3/0 CWC with 1272 ACSR. Replace jumpers @ Lone Oak |
| 5 | 18WP | AEPW | AEPW | ENOWILT - SARDIS 138KV CKT 1 | 120.8 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - BROKEN BOW 138KV CKT 1 | Rebuild 9.19 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | ENOWILT - SARDIS 138KV CKT 1 | 120.8 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - NASHOBA 138KV CKT 1 | Rebuild 22.43 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | ENOWILT - SARDIS 138KV CKT 1 | 120.8 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - NASHOBA 138KV CKT 1 | Rebuild 11.57 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | ENOWILT - SARDIS 138KV CKT 1 | 120.8 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - SARDIS 138KV CKT 1 | Rebuild 1.46 miles of 3/0 CWC with 1272 ACSR |

| Scenario | Season | From Area | To Area | Monitored Branch Over 100% Rate B | Transfer Case % Loading | TDF (%) | Outaged Branch Causing Overload | Upgrade Name | Solution |
|----------|--------|-----------|---------|--|-------------------------|---------|---|--|--|
| 5 | 18WP | AEPW | AEPW | ENOWILT - SARDIS 138KV CKT 1 | 120.8 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - SARDIS 138KV CKT 1 | Rebuild 13.8 miles of 3/0 CWC with 1272 ACSR |
| 5 | 18WP | AEPW | AEPW | ENOWILT - SARDIS 138KV CKT 1 | 120.8 | 4.82% | PITTSBURG - VALLIANT 345KV CKT 1 | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | Rebuild 11.63 |
| 5 | 23WP | AEPW | AEPW | ENOWILT - SARDIS 138KV CKT 1 | 110.6 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - LONE OAK 138KV CKT 1 | Rebuild 0.32 miles of 3/0 CWC with 1272 ACSR. Replace jumpers @ Lone Oak |
| 5 | 23WP | AEPW | AEPW | ENOWILT - SARDIS 138KV CKT 1 | 110.6 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - BROKEN BOW 138KV CKT 1 | Rebuild 9.19 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | ENOWILT - SARDIS 138KV CKT 1 | 110.6 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | BETHEL - NASHOBA 138KV CKT 1 | Rebuild 22.43 miles of 3/0 Copperweld with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | ENOWILT - SARDIS 138KV CKT 1 | 110.6 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - NASHOBA 138KV CKT 1 | Rebuild 11.57 miles of 3/0 CWC with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | ENOWILT - SARDIS 138KV CKT 1 | 110.6 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | CLAYTON - SARDIS 138KV CKT 1 | Rebuild 1.46 miles of 3/0 CWC with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | ENOWILT - SARDIS 138KV CKT 1 | 110.6 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | ENOWILT - SARDIS 138KV CKT 1 | Rebuild 13.8 miles of 3/0 CWC with 1272 ACSR |
| 5 | 23WP | AEPW | AEPW | ENOWILT - SARDIS 138KV CKT 1 | 110.6 | 6.02% | PITTSBURG - VALLIANT 345KV CKT 1 | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | Rebuild 11.63 |
| 5 | 23WP | GRDA | AEPW | FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 | 101.4 | 4.23% | CHAMBER SPRINGS - CLARKSVILLE 345KV CKT 1 | FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 AEPW | Replace Terminal Equipment |
| 5 | 23SP | OKGE | WFEC | FRANKLIN SW - MIDWEST TAP 138KV CKT 1 | 107.4 | 3.71% | HAMMETT TAP - HAMMETT2 138KV CKT 1 | FRANKLIN SW - MIDWEST TAP 138KV CKT 1 | Replace Terminal Equipment |
| 5 | 23SP | OKGE | WFEC | FRANKLIN SW - MIDWEST TAP 138KV CKT 1 | 104.5 | 3.71% | HAMMETT2 - MEEKER 138KV CKT 1 | FRANKLIN SW - MIDWEST TAP 138KV CKT 1 | Replace Terminal Equipment |
| 5 | 23SP | OKGE | WFEC | FRANKLIN SW - MIDWEST TAP 138KV CKT 1 | 102.3 | 5.11% | GRACEMONT - MINCO 345KV CKT 1 | FRANKLIN SW - MIDWEST TAP 138KV CKT 1 | Replace Terminal Equipment |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 121.2 | 8.97% | GEN336821 1-GRAND GULF UNIT | Arkansas Nuclear One 500/345 Transformer | Build 500/345 KV Transformer at ANO |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 121.2 | 8.97% | GEN336821 1-GRAND GULF UNIT | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 121.2 | 8.97% | GEN336821 1-GRAND GULF UNIT | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 121.2 | 8.97% | GEN336821 1-GRAND GULF UNIT | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 121.2 | 8.97% | GEN336821 1-GRAND GULF UNIT | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 119.5 | 12.20% | PITTSBURG - VALLIANT 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 KV Transformer at ANO |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 119.5 | 12.20% | PITTSBURG - VALLIANT 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 119.5 | 12.20% | PITTSBURG - VALLIANT 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 119.5 | 12.20% | PITTSBURG - VALLIANT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 119.5 | 12.20% | PITTSBURG - VALLIANT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 117.8 | 8.97% | GEN336153 1-WATERFORD UNIT#3 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 KV Transformer at ANO |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 117.8 | 8.97% | GEN336153 1-WATERFORD UNIT#3 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 117.8 | 8.97% | GEN336153 1-WATERFORD UNIT#3 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 117.8 | 8.97% | GEN336153 1-WATERFORD UNIT#3 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 117.8 | 8.97% | GEN336153 1-WATERFORD UNIT#3 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.2 | 11.72% | SPP-AEPW-01 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 KV Transformer at ANO |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.2 | 11.72% | SPP-AEPW-01 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.2 | 11.72% | SPP-AEPW-01 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.2 | 11.72% | SPP-AEPW-01 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.2 | 11.72% | SPP-AEPW-01 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.0 | 8.95% | SPP-AEPW-32 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 KV Transformer at ANO |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.0 | 8.95% | SPP-AEPW-32 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.0 | 8.95% | SPP-AEPW-32 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.0 | 8.95% | SPP-AEPW-32 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.0 | 8.95% | SPP-AEPW-32 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 111.7 | 9.17% | OVERTON-TRF | Arkansas Nuclear One 500/345 Transformer | Build 500/345 KV Transformer at ANO |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 111.7 | 9.17% | OVERTON-TRF | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 111.7 | 9.17% | OVERTON-TRF | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 111.7 | 9.17% | OVERTON-TRF | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 111.7 | 9.17% | OVERTON-TRF | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 110.6 | 9.03% | LACYGNE - STILWELL 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 KV Transformer at ANO |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 110.6 | 9.03% | LACYGNE - STILWELL 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 110.6 | 9.03% | LACYGNE - STILWELL 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 110.6 | 9.03% | LACYGNE - STILWELL 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 14WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 110.6 | 9.03% | LACYGNE - STILWELL 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |

| Scenario | Season | From Area | To Area | Monitored Branch Over 100% Rate B | Transfer Case % Loading | TDF (%) | Outaged Branch Causing Overload | Upgrade Name | Solution |
|----------|--------|-----------|---------|-----------------------------------|-------------------------|---------|--|--|--|
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 107.7 | 10.48% | BASE CASE | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 107.7 | 10.48% | BASE CASE | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 107.7 | 10.48% | BASE CASE | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 107.7 | 10.48% | BASE CASE | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 107.0 | 10.51% | ROSE HILL - WOLF CREEK 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 107.0 | 10.51% | ROSE HILL - WOLF CREEK 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 107.0 | 10.51% | ROSE HILL - WOLF CREEK 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 107.0 | 10.51% | ROSE HILL - WOLF CREEK 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 107.0 | 10.51% | ROSE HILL - WOLF CREEK 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 105.6 | 10.15% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 105.6 | 10.15% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 105.6 | 10.15% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 105.6 | 10.15% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 105.6 | 10.15% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 105.3 | 10.57% | LACYGNE - NEOSHO 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 105.3 | 10.57% | LACYGNE - NEOSHO 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 105.3 | 10.57% | LACYGNE - NEOSHO 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 105.3 | 10.57% | LACYGNE - NEOSHO 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18SP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 105.3 | 10.57% | LACYGNE - NEOSHO 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 124.0 | 12.62% | PITTSBURG - VALLIANT 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 124.0 | 12.62% | PITTSBURG - VALLIANT 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 124.0 | 12.62% | PITTSBURG - VALLIANT 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 124.0 | 12.62% | PITTSBURG - VALLIANT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 124.0 | 12.62% | PITTSBURG - VALLIANT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 119.3 | 12.09% | SPP-AEPW-01 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 119.3 | 12.09% | SPP-AEPW-01 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 119.3 | 12.09% | SPP-AEPW-01 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 119.3 | 12.09% | SPP-AEPW-01 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 119.3 | 12.09% | SPP-AEPW-01 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 119.2 | 9.65% | GEN336153 1-WATERFORD UNIT#3 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 119.2 | 9.65% | GEN336153 1-WATERFORD UNIT#3 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 119.2 | 9.65% | GEN336153 1-WATERFORD UNIT#3 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 119.2 | 9.65% | GEN336153 1-WATERFORD UNIT#3 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 119.2 | 9.65% | GEN336153 1-WATERFORD UNIT#3 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 119.2 | 9.65% | GEN336153 1-WATERFORD UNIT#3 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.5 | 9.63% | SPP-AEPW-32 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.5 | 9.63% | SPP-AEPW-32 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.5 | 9.63% | SPP-AEPW-32 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.5 | 9.63% | SPP-AEPW-32 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.5 | 9.63% | SPP-AEPW-32 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 112.4 | 10.11% | AI03 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 112.4 | 10.11% | AI03 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 112.4 | 10.11% | AI03 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 112.4 | 10.11% | AI03 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 112.4 | 10.11% | AI03 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 110.6 | 9.71% | LACYGNE - STILWELL 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 110.6 | 9.71% | LACYGNE - STILWELL 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 110.6 | 9.71% | LACYGNE - STILWELL 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 110.6 | 9.71% | LACYGNE - STILWELL 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |

| Scenario | Season | From Area | To Area | Monitored Branch Over 100% Rate B | Transfer Case % Loading | TDF (%) | Outaged Branch Causing Overload | Upgrade Name | Solution |
|----------|--------|-----------|---------|-----------------------------------|-------------------------|---------|---|--|--|
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 110.6 | 9.71% | LACYGNE - STILWELL 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 110.1 | 9.68% | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 110.1 | 9.68% | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 110.1 | 9.68% | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 110.1 | 9.68% | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 110.1 | 9.68% | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 109.6 | 9.68% | HOYT - STRANGER CREEK 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 109.6 | 9.68% | HOYT - STRANGER CREEK 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 109.6 | 9.68% | HOYT - STRANGER CREEK 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 109.6 | 9.68% | HOYT - STRANGER CREEK 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 109.6 | 9.68% | HOYT - STRANGER CREEK 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 109.2 | 9.65% | 15TH & FULTON TAP - TULSA SOUTHEAST 138KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 109.2 | 9.65% | 15TH & FULTON TAP - TULSA SOUTHEAST 138KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 109.2 | 9.65% | 15TH & FULTON TAP - TULSA SOUTHEAST 138KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 109.2 | 9.65% | 15TH & FULTON TAP - TULSA SOUTHEAST 138KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 109.2 | 9.65% | 15TH & FULTON TAP - TULSA SOUTHEAST 138KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 109.1 | 9.65% | 15TH & FULTON TAP - TULSA SOUTHEAST 138KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 109.1 | 9.68% | LACYGNE - WEST GARDNER 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 109.1 | 9.68% | LACYGNE - WEST GARDNER 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 109.1 | 9.68% | LACYGNE - WEST GARDNER 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 109.1 | 9.68% | LACYGNE - WEST GARDNER 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 109.1 | 9.68% | LACYGNE - WEST GARDNER 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 108.0 | 9.65% | BASE CASE | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 108.0 | 9.65% | BASE CASE | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 108.0 | 9.65% | BASE CASE | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 108.0 | 9.65% | BASE CASE | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 108.0 | 9.65% | BASE CASE | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 107.3 | 9.68% | ROSE HILL - WOLF CREEK 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 107.3 | 9.68% | ROSE HILL - WOLF CREEK 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 107.3 | 9.68% | ROSE HILL - WOLF CREEK 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 107.3 | 9.68% | ROSE HILL - WOLF CREEK 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 107.3 | 9.68% | ROSE HILL - WOLF CREEK 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 106.2 | 9.36% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 106.2 | 9.36% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 106.2 | 9.36% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 106.2 | 9.36% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 106.2 | 9.36% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 105.6 | 9.74% | LACYGNE - NEOSHO 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 105.6 | 9.74% | LACYGNE - NEOSHO 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 105.6 | 9.74% | LACYGNE - NEOSHO 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 105.6 | 9.74% | LACYGNE - NEOSHO 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 105.6 | 9.74% | LACYGNE - NEOSHO 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 105.6 | 9.74% | LACYGNE - NEOSHO 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 128.5 | 11.13% | PITTSBURG - VALLIANT 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 128.5 | 11.13% | PITTSBURG - VALLIANT 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 128.5 | 11.13% | PITTSBURG - VALLIANT 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 128.5 | 11.13% | PITTSBURG - VALLIANT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 128.5 | 11.13% | PITTSBURG - VALLIANT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 126.5 | 7.82% | GEN336153 1-WATERFORD UNIT#3 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 126.5 | 7.82% | GEN336153 1-WATERFORD UNIT#3 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |

| Scenario | Season | From Area | To Area | Monitored Branch Over 100% Rate B | Transfer Case % Loading | TDF (%) | Outaged Branch Causing Overload | Upgrade Name | Solution |
|----------|--------|-----------|---------|-----------------------------------|-------------------------|---------|---|--|--|
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 126.5 | 7.82% | GEN336153 1-WATERFORD UNIT#3 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 126.5 | 7.82% | GEN336153 1-WATERFORD UNIT#3 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 126.5 | 7.82% | GEN336153 1-WATERFORD UNIT#3 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 124.9 | 7.82% | GEN335831 1-RIVERBEND UNIT#1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 KV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 124.9 | 7.82% | GEN335831 1-RIVERBEND UNIT#1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 124.9 | 7.82% | GEN335831 1-RIVERBEND UNIT#1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 124.9 | 7.82% | GEN335831 1-RIVERBEND UNIT#1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 124.9 | 7.82% | GEN335831 1-RIVERBEND UNIT#1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 124.8 | 9.04% | SPP-AEPW-01 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 KV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 124.8 | 9.04% | SPP-AEPW-01 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 124.8 | 9.04% | SPP-AEPW-01 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 124.8 | 9.04% | SPP-AEPW-01 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 124.8 | 9.04% | SPP-AEPW-01 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 122.6 | 7.80% | SPP-AEPW-32 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 KV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 122.6 | 7.80% | SPP-AEPW-32 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 122.6 | 7.80% | SPP-AEPW-32 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 122.6 | 7.80% | SPP-AEPW-32 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 122.6 | 7.80% | SPP-AEPW-32 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 118.3 | 8.22% | AI03 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 KV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 118.3 | 8.22% | AI03 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 118.3 | 8.22% | AI03 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 118.3 | 8.22% | AI03 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 118.3 | 8.22% | AI03 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.5 | 7.88% | LACYGNE - STILWELL 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 KV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.5 | 7.88% | LACYGNE - STILWELL 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.5 | 7.88% | LACYGNE - STILWELL 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.5 | 7.88% | LACYGNE - STILWELL 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.5 | 7.88% | LACYGNE - STILWELL 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.1 | 7.85% | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.1 | 7.85% | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 KV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.1 | 7.85% | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.1 | 7.85% | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 116.1 | 7.85% | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 115.5 | 7.85% | HOYT - STRANGER CREEK 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 KV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 115.5 | 7.85% | HOYT - STRANGER CREEK 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 115.5 | 7.85% | HOYT - STRANGER CREEK 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 115.5 | 7.85% | HOYT - STRANGER CREEK 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 115.5 | 7.85% | HOYT - STRANGER CREEK 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 115.1 | 7.82% | 15TH & FULTON TAP - TULSA SOUTHEAST 138KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 KV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 115.1 | 7.82% | 15TH & FULTON TAP - TULSA SOUTHEAST 138KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 115.1 | 7.82% | 15TH & FULTON TAP - TULSA SOUTHEAST 138KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 115.1 | 7.82% | 15TH & FULTON TAP - TULSA SOUTHEAST 138KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 115.1 | 7.82% | 15TH & FULTON TAP - TULSA SOUTHEAST 138KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 115.0 | 7.84% | LACYGNE - WEST GARDNER 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 KV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 115.0 | 7.84% | LACYGNE - WEST GARDNER 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 115.0 | 7.84% | LACYGNE - WEST GARDNER 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 115.0 | 7.84% | LACYGNE - WEST GARDNER 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 115.0 | 7.84% | LACYGNE - WEST GARDNER 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |

| Scenario | Season | From Area | To Area | Monitored Branch Over 100% Rate B | Transfer Case % Loading | TDF (%) | Outaged Branch Causing Overload | Upgrade Name | Solution |
|----------|--------|-----------|---------|--|-------------------------|---------|--|--|--|
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 114.5 | 7.83% | MCCREDIE - THOMAS HILL 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 114.5 | 7.83% | MCCREDIE - THOMAS HILL 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 114.5 | 7.83% | MCCREDIE - THOMAS HILL 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 114.5 | 7.83% | MCCREDIE - THOMAS HILL 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 114.5 | 7.83% | MCCREDIE - THOMAS HILL 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 113.9 | 7.82% | BASE CASE | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 113.9 | 7.82% | BASE CASE | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 113.9 | 7.82% | BASE CASE | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 113.9 | 7.82% | BASE CASE | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 113.9 | 7.82% | BASE CASE | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 113.2 | 7.85% | ROSE HILL - WOLF CREEK 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 113.2 | 7.85% | ROSE HILL - WOLF CREEK 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 113.2 | 7.85% | ROSE HILL - WOLF CREEK 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 113.2 | 7.85% | ROSE HILL - WOLF CREEK 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 113.2 | 7.85% | ROSE HILL - WOLF CREEK 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 112.1 | 7.61% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 112.1 | 7.61% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 112.1 | 7.61% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 112.1 | 7.61% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 112.1 | 7.61% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 112.1 | 7.61% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 112.1 | 7.61% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 112.1 | 7.61% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 112.1 | 7.61% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 112.1 | 7.61% | DOLET HILLS - SOUTHWEST SHREVEPORT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 111.7 | 7.90% | LACYGNE - NEOSHO 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 111.7 | 7.90% | LACYGNE - NEOSHO 345KV CKT 1 | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 111.7 | 7.90% | LACYGNE - NEOSHO 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 111.7 | 7.90% | LACYGNE - NEOSHO 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 111.7 | 7.90% | LACYGNE - NEOSHO 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | 103.1 | 8.88% | FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1 | FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1 | Install 2nd 500/345 kV bus tie in Ft. Smith Sub |
| 5 | 14WP | OKGE | OKGE | FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1 | 102.3 | 10.30% | FT SMITH (FTSMITH5) 345/161/13.8KV TRANSFORMER CKT 5 | FT SMITH (FTSMITH5) 345/161/13.8KV TRANSFORMER CKT 5 | Install 2nd 500/345 kV bus tie in Ft. Smith Sub |
| 5 | 18SP | OKGE | OKGE | FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1 | 103.4 | 9.49% | FT SMITH (FTSMITH5) 345/161/13.8KV TRANSFORMER CKT 5 | FT SMITH (FTSMITH5) 345/161/13.8KV TRANSFORMER CKT 5 | Install 2nd 500/345 kV bus tie in Ft. Smith Sub |
| 5 | 18WP | OKGE | OKGE | FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1 | 108.6 | 7.70% | FT SMITH (FTSMITH5) 345/161/13.8KV TRANSFORMER CKT 5 | FT SMITH (FTSMITH5) 345/161/13.8KV TRANSFORMER CKT 5 | Install 2nd 500/345 kV bus tie in Ft. Smith Sub |
| 5 | 23WP | OKGE | OKGE | FT SMITH (FTSMITH5) 345/161/13.8KV TRANSFORMER CKT 5 | 117.1 | 6.24% | FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1 | FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1 | Install 2nd 500/345 kV bus tie in Ft. Smith Sub |
| 5 | 14WP | OKGE | OKGE | FT SMITH (FTSMITH5) 345/161/13.8KV TRANSFORMER CKT 5 | 122.2 | 7.58% | FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1 | FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1 | Install 2nd 500/345 kV bus tie in Ft. Smith Sub |
| 5 | 18WP | OKGE | OKGE | FT SMITH (FTSMITH5) 345/161/13.8KV TRANSFORMER CKT 5 | 119.8 | 6.98% | FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1 | FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1 | Install 2nd 500/345 kV bus tie in Ft. Smith Sub |
| 5 | 23WP | OKGE | OKGE | FT SMITH (FTSMITH5) 345/161/13.8KV TRANSFORMER CKT 5 | 126.2 | 5.64% | FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1 | FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1 | Install 2nd 500/345 kV bus tie in Ft. Smith Sub |
| 5 | 14WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 109.1 | 3.48% | FT SMITH - MUSKOGEE 345KV CKT 1 | ADABELL - VBI 161KV CKT 1 | Replace existing 800 amp wave trap with 1200 amp in VBI sub |
| 5 | 14WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 109.1 | 3.48% | FT SMITH - MUSKOGEE 345KV CKT 1 | Lacygne - Mariosa 345KV KACP | Build approximately 181 miles of 345kV from KCPL Lacygne - AMRN Mariosa |
| 5 | 14WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 109.1 | 3.48% | FT SMITH - MUSKOGEE 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 14WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 109.1 | 3.48% | FT SMITH - MUSKOGEE 345KV CKT 1 | Lacygne - Mariosa 345KV AMRN | Indeterminate |
| 5 | 14WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 109.1 | 3.48% | FT SMITH - MUSKOGEE 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 14WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 109.1 | 3.48% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 14WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 109.1 | 3.48% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18SP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 123.6 | 3.81% | FT SMITH - MUSKOGEE 345KV CKT 1 | ADABELL - VBI 161KV CKT 1 | Replace existing 800 amp wave trap with 1200 amp in VBI sub |
| 5 | 18SP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 123.6 | 3.81% | FT SMITH - MUSKOGEE 345KV CKT 1 | Lacygne - Mariosa 345KV KACP | Build approximately 181 miles of 345kV from KCPL Lacygne - AMRN Mariosa |
| 5 | 18SP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 123.6 | 3.81% | FT SMITH - MUSKOGEE 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18SP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 123.6 | 3.81% | FT SMITH - MUSKOGEE 345KV CKT 1 | Lacygne - Mariosa 345KV AMRN | Indeterminate |
| 5 | 18SP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 123.6 | 3.81% | FT | | |

| Scenario | Season | From Area | To Area | Monitored Branch Over 100% Rate B | Transfer Case % Loading | TDF (%) | Outaged Branch Causing Overload | Upgrade Name | Solution |
|----------|--------|-----------|---------|---|-------------------------|---------|---|--|--|
| 5 | 18WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 105.3 | 3.63% | FT SMITH - MUSKOGEE 345KV CKT 1 | Lacygne - Mariosa 345KV KACP | Build approximately 181 miles of 345kV from KCPL Lacygne - AMRN Mariosa |
| 5 | 18WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 105.3 | 3.63% | FT SMITH - MUSKOGEE 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 105.3 | 3.63% | FT SMITH - MUSKOGEE 345KV CKT 1 | Lacygne - Mariosa 345KV AMRN | Indeterminate |
| 5 | 18WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 105.3 | 3.63% | FT SMITH - MUSKOGEE 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 KV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 KV bus ties near VBI sub and 10 miles of 161 KV line |
| 5 | 18WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 105.3 | 3.63% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 105.3 | 3.63% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 113.1 | 3.26% | FT SMITH - MUSKOGEE 345KV CKT 1 | ADABELL - VBI 161KV CKT 1 | Replace existing 800 amp wave trap with 1200 amp in VBI sub |
| 5 | 23WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 113.1 | 3.26% | FT SMITH - MUSKOGEE 345KV CKT 1 | Lacygne - Mariosa 345KV KACP | Build approximately 181 miles of 345kV from KCPL Lacygne - AMRN Mariosa |
| 5 | 23WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 113.1 | 3.26% | FT SMITH - MUSKOGEE 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 23WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 113.1 | 3.26% | FT SMITH - MUSKOGEE 345KV CKT 1 | Lacygne - Mariosa 345KV AMRN | Indeterminate |
| 5 | 23WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 113.1 | 3.26% | FT SMITH - MUSKOGEE 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 KV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 KV bus ties near VBI sub and 10 miles of 161 KV line |
| 5 | 23WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 113.1 | 3.26% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | SWPA | SWPA | GORE - MUSKOGEE TAP 161KV CKT 1 | 113.1 | 3.26% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | AEPW | GRACEMONT - LAWTON EASTSIDE 345KV CKT 1 | 102.2 | 7.34% | G12-038 TAP 345.00 - TUCO INTERCHANGE 345KV CKT 1 | GRACEMONT - LAWTON EASTSIDE 345KV CKT 1 | Replace Terminal Equipment |
| 5 | 23WP | OKGE | AEPW | GRACEMONT - LAWTON EASTSIDE 345KV CKT 1 | 110.5 | 8.19% | G12-038 TAP 345.00 - TUCO INTERCHANGE 345KV CKT 1 | GRACEMONT - LAWTON EASTSIDE 345KV CKT 1 | Replace Terminal Equipment |
| 5 | 23WP | OKGE | AEPW | GRACEMONT - LAWTON EASTSIDE 345KV CKT 1 | 105.9 | 8.97% | OKLAUNION - TUCO INTERCHANGE 345KV CKT 1 | GRACEMONT - LAWTON EASTSIDE 345KV CKT 1 | Replace Terminal Equipment |
| 5 | 23WP | OKGE | AEPW | GRACEMONT - LAWTON EASTSIDE 345KV CKT 1 | 105.9 | 8.97% | SPP-SWPS-01 | GRACEMONT - LAWTON EASTSIDE 345KV CKT 1 | Replace Terminal Equipment |
| 5 | 23WP | OKGE | AEPW | GRACEMONT - LAWTON EASTSIDE 345KV CKT 1 | 103.0 | 7.94% | BASE CASE | GRACEMONT - LAWTON EASTSIDE 345KV CKT 1 | Replace Terminal Equipment |
| 5 | 18SP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 110.8 | 5.22% | CHAMBER SPRINGS - CLARKSVILLE 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2 | Replace Terminal Equipment |
| 5 | 18SP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 110.8 | 5.22% | CHAMBER SPRINGS - CLARKSVILLE 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #1 | Add new pole to increase line clearance |
| 5 | 18SP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 103.7 | 6.88% | 7JASPER 345.00 - BLACKBERRY 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2 | Replace Terminal Equipment |
| 5 | 18SP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 103.7 | 6.88% | 7JASPER 345.00 - BLACKBERRY 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #1 | Add new pole to increase line clearance |
| 5 | 18SP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 100.3 | 6.65% | 7JASPER 345.00 - MORGAN 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2 | Replace Terminal Equipment |
| 5 | 18SP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 100.3 | 6.65% | 7JASPER 345.00 - MORGAN 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #1 | Add new pole to increase line clearance |
| 5 | 18WP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 114.5 | 4.95% | CHAMBER SPRINGS - CLARKSVILLE 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2 | Replace Terminal Equipment |
| 5 | 18WP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 114.5 | 4.95% | CHAMBER SPRINGS - CLARKSVILLE 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #1 | Add new pole to increase line clearance |
| 5 | 18WP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 107.6 | 6.62% | 7JASPER 345.00 - BLACKBERRY 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2 | Replace Terminal Equipment |
| 5 | 18WP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 107.6 | 6.62% | 7JASPER 345.00 - BLACKBERRY 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #1 | Add new pole to increase line clearance |
| 5 | 18WP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 104.2 | 6.40% | 7JASPER 345.00 - MORGAN 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2 | Replace Terminal Equipment |
| 5 | 18WP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 104.2 | 6.40% | 7JASPER 345.00 - MORGAN 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #1 | Add new pole to increase line clearance |
| 5 | 23WP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 121.0 | 4.32% | CHAMBER SPRINGS - CLARKSVILLE 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2 | Replace Terminal Equipment |
| 5 | 23WP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 121.0 | 4.32% | CHAMBER SPRINGS - CLARKSVILLE 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #1 | Add new pole to increase line clearance |
| 5 | 23WP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 113.0 | 6.02% | 7JASPER 345.00 - BLACKBERRY 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2 | Replace Terminal Equipment |
| 5 | 23WP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 113.0 | 6.02% | 7JASPER 345.00 - BLACKBERRY 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #1 | Add new pole to increase line clearance |
| 5 | 23WP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 109.2 | 5.83% | 7JASPER 345.00 - MORGAN 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2 | Replace Terminal Equipment |
| 5 | 23WP | GRDA | GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 | 109.2 | 5.83% | 7JASPER 345.00 - MORGAN 345KV CKT 1 | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #1 | Add new pole to increase line clearance |
| 5 | 14WP | GRDA | OKGE | HIGHWAY 59 - TAHLERUAH 161KV CKT 1 | 118.4 | 3.46% | FT SMITH - MUSKOGEE 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 KV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 KV bus ties near VBI sub and 10 miles of 161 KV line |
| 5 | 14WP | GRDA | OKGE | HIGHWAY 59 - TAHLERUAH 161KV CKT 1 | 118.4 | 3.46% | FT SMITH - MUSKOGEE 345KV CKT 1 | ADABELL - VBI 161KV CKT 1 | Replace existing 800 amp wave trap with 1200 amp in VBI sub |
| 5 | 14WP | GRDA | OKGE | HIGHWAY 59 - TAHLERUAH 161KV CKT 1 | 118.4 | 3.46% | FT SMITH - MUSKOGEE 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 14WP | GRDA | OKGE | HIGHWAY 59 - TAHLERUAH 161KV CKT 1 | 118.4 | 3.46% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 14WP | GRDA | OKGE | HIGHWAY 59 - TAHLERUAH 161KV CKT 1 | 118.4 | 3.46% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18SP | GRDA | OKGE | HIGHWAY 59 - TAHLERUAH 161KV CKT 1 | 112.8 | 3.90% | FT SMITH - MUSKOGEE 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 KV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 KV bus ties near VBI sub and 10 miles of 161 KV line |
| 5 | 18SP | GRDA | OKGE | HIGHWAY 59 - TAHLERUAH 161KV CKT 1 | 112.8 | 3.90% | FT SMITH - MUSKOGEE 345KV CKT 1 | ADABELL - VBI 161KV CKT 1 | Replace existing 800 amp wave trap with 1200 amp in VBI sub |
| 5 | 18SP | GRDA | OKGE | HIGHWAY 59 - TAHLERUAH 161KV CKT 1 | 112.8 | 3.90% | FT SMITH - MUSKOGEE 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18SP | GRDA | OKGE | HIGHWAY 59 - TAHLERUAH 161KV CKT 1 | 112.8 | 3.90% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18SP | GRDA | OKGE | HIGHWAY 59 - TAHLERUAH 161KV CKT 1 | 112.8 | 3.90% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | GRDA | OKGE | HIGHWAY 59 - TAHLERUAH 161KV CKT 1 | 116.8 | 3.66% | FT SMITH - MUSKOGEE 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 KV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 KV bus ties near VBI sub and 10 miles of 161 KV line |
| 5 | 18WP | GRDA | OKGE | HIGHWAY 59 - TAHLERUAH 161KV CKT 1 | 116.8 | 3.66% | FT SMITH - MUSKOGEE 345KV CKT 1 | ADABELL - VBI 161KV CKT 1 | Replace existing 800 amp wave trap with 1200 amp in VBI sub |

| Scenario | Season | From Area | To Area | Monitored Branch Over 100% Rate B | Transfer Case % Loading | TDF (%) | Outaged Branch Causing Overload | Upgrade Name | Solution |
|----------|--------|-----------|---------|--|-------------------------|---------|--|--|--|
| 5 | 18WP | GRDA | OKGE | HIGHWAY 59 - TAHLERQUAH 161KV CKT 1 | 116.8 | 3.66% | FT SMITH - MUSKOGEE 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | GRDA | OKGE | HIGHWAY 59 - TAHLERQUAH 161KV CKT 1 | 116.8 | 3.66% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | GRDA | OKGE | HIGHWAY 59 - TAHLERQUAH 161KV CKT 1 | 116.8 | 3.66% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | GRDA | OKGE | HIGHWAY 59 - TAHLERQUAH 161KV CKT 1 | 121.3 | 3.16% | FT SMITH - MUSKOGEE 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | GRDA | OKGE | HIGHWAY 59 - TAHLERQUAH 161KV CKT 1 | 121.3 | 3.16% | FT SMITH - MUSKOGEE 345KV CKT 1 | ADABELL - VBI 161KV CKT 1 | Replace existing 800 amp wave trap with 1200 amp in VBI sub |
| 5 | 23WP | GRDA | OKGE | HIGHWAY 59 - TAHLERQUAH 161KV CKT 1 | 121.3 | 3.16% | FT SMITH - MUSKOGEE 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 23WP | GRDA | OKGE | HIGHWAY 59 - TAHLERQUAH 161KV CKT 1 | 121.3 | 3.16% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | GRDA | OKGE | HIGHWAY 59 - TAHLERQUAH 161KV CKT 1 | 121.3 | 3.16% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 14WP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 126.4 | 3.46% | FT SMITH - MUSKOGEE 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 14WP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 126.4 | 3.46% | FT SMITH - MUSKOGEE 345KV CKT 1 | ADABELL - VBI 161KV CKT 1 | Replace existing 800 amp wave trap with 1200 amp in VBI sub |
| 5 | 14WP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 126.4 | 3.46% | FT SMITH - MUSKOGEE 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 14WP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 126.4 | 3.46% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 14WP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 126.4 | 3.46% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18SP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 118.9 | 3.90% | FT SMITH - MUSKOGEE 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18SP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 118.9 | 3.90% | FT SMITH - MUSKOGEE 345KV CKT 1 | ADABELL - VBI 161KV CKT 1 | Replace existing 800 amp wave trap with 1200 amp in VBI sub |
| 5 | 18SP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 118.9 | 3.90% | FT SMITH - MUSKOGEE 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18SP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 118.9 | 3.90% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18SP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 118.9 | 3.90% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18WP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 124.8 | 3.66% | FT SMITH - MUSKOGEE 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18WP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 124.8 | 3.66% | FT SMITH - MUSKOGEE 345KV CKT 1 | ADABELL - VBI 161KV CKT 1 | Replace existing 800 amp wave trap with 1200 amp in VBI sub |
| 5 | 18WP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 124.8 | 3.66% | FT SMITH - MUSKOGEE 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 124.8 | 3.66% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 124.8 | 3.66% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 129.7 | 3.16% | FT SMITH - MUSKOGEE 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 129.7 | 3.16% | FT SMITH - MUSKOGEE 345KV CKT 1 | ADABELL - VBI 161KV CKT 1 | Replace existing 800 amp wave trap with 1200 amp in VBI sub |
| 5 | 23WP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 129.7 | 3.16% | FT SMITH - MUSKOGEE 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 23WP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 129.7 | 3.16% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | OKGE | OKGE | HIGHWAY 59 - VBI 161KV CKT 1 | 129.7 | 3.16% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18SP | AEPW | AEPW | KNOX LEE - SOUTH TEXAS EASTMAN 138KV CKT 1 | 106.9 | 27.60% | EASTON REC - PIRKEY 138KV CKT 1 | KNOX LEE - SOUTH TEXAS EASTMAN 138KV CKT 1 Accelerate | Rebuild 5.5 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | KNOX LEE - SOUTH TEXAS EASTMAN 138KV CKT 1 | 105.8 | 27.60% | EASTON REC - KNOX LEE 138KV CKT 1 | KNOX LEE - SOUTH TEXAS EASTMAN 138KV CKT 1 Accelerate | Rebuild 5.5 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | LIEBERMAN - LONGWOOD 138KV CKT 1 | 110.8 | 15.34% | LONGWOOD - NORAM 138KV CKT 1 | Messick 500/230 kV Transformer Ckt 1 | Build Messick 500/230 kV station. Connect to Carroll, Clarence, and Western Kraft 230 kV lines. Install 500/230 kV 675 MVA transformer. This upgrade is contingent upon approval from Cleco Power LLC. |
| 5 | 18SP | AEPW | AEPW | LIEBERMAN - LONGWOOD 138KV CKT 1 | 110.2 | 15.34% | NORAM - RAINES 138KV CKT 1 | Messick 500/230 kV Transformer Ckt 1 | Build Messick 500/230 kV station. Connect to Carroll, Clarence, and Western Kraft 230 kV lines. Install 500/230 kV 675 MVA transformer. This upgrade is contingent upon approval from Cleco Power LLC. |
| 5 | 18SP | AEPW | AEPW | LIEBERMAN - LONGWOOD 138KV CKT 1 | 105.1 | 15.34% | ARSENAL HILL - RAINES 138KV CKT 1 | Messick 500/230 kV Transformer Ckt 1 | Build Messick 500/230 kV station. Connect to Carroll, Clarence, and Western Kraft 230 kV lines. Install 500/230 kV 675 MVA transformer. This upgrade is contingent upon approval from Cleco Power LLC. |
| 5 | 18SP | AEPW | AEPW | LONGWOOD - NORAM 138KV CKT 1 | 121.6 | 24.30% | SPP-AEPW-05 | Messick 500/230 kV Transformer Ckt 1 | Build Messick 500/230 kV station. Connect to Carroll, Clarence, and Western Kraft 230 kV lines. Install 500/230 kV 675 MVA transformer. This upgrade is contingent upon approval from Cleco Power LLC. |
| 5 | 18SP | AEPW | AEPW | LONGWOOD - NORAM 138KV CKT 1 | 108.1 | 22.03% | LIEBERMAN - LONGWOOD 138KV CKT 1 | Messick 500/230 kV Transformer Ckt 1 | Build Messick 500/230 kV station. Connect to Carroll, Clarence, and Western Kraft 230 kV lines. Install 500/230 kV 675 MVA transformer. This upgrade is contingent upon approval from Cleco Power LLC. |
| 5 | 18SP | AEPW | AEPW | LONGWOOD - OAK PAN-HARR REC 138KV CKT 1 | 102.0 | 7.28% | SPP-AEPW-05 | Messick 500/230 kV Transformer Ckt 1 | Build Messick 500/230 kV station. Connect to Carroll, Clarence, and Western Kraft 230 kV lines. Install 500/230 kV 675 MVA transformer. This upgrade is contingent upon approval from Cleco Power LLC. |
| 5 | 18SP | AEPW | AEPW | LONGWOOD (LONGWOOD) 345/138/13.2KV TRANSFORMER CKT 1 | 103.4 | 34.23% | SPP-AEPW-05 | Messick 500/230 kV Transformer Ckt 1 | Build Messick 500/230 kV station. Connect to Carroll, Clarence, and Western Kraft 230 kV lines. Install 500/230 kV 675 MVA transformer. This upgrade is contingent upon approval from Cleco Power LLC. |
| 5 | 18WP | AEPW | AEPW | LYDIA - VALLIANT 345KV CKT 1 | 115.0 | 41.47% | NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1 | ADABELL - VBI 161KV CKT 1 | Replace existing 800 amp wave trap with 1200 amp in VBI sub |
| 5 | 18WP | AEPW | AEPW | LYDIA - VALLIANT 345KV CKT 1 | 115.0 | 41.47% | NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1 | Lacygne - Mariosa 345KV KACP | Build approximately 181 miles of 345kV from KCPL Lacygne - AMRN Mariosa |
| 5 | 18WP | AEPW | AEPW | LYDIA - VALLIANT 345KV CKT 1 | 115.0 | 41.47% | NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 18WP | AEPW | AEPW | LYDIA - VALLIANT 345KV CKT 1 | 115.0 | 41.47% | NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1 | Lacygne - Mariosa 345KV AMRN | Indeterminate |
| 5 | 18WP | AEPW | AEPW | LYDIA - VALLIANT 345KV CKT 1 | 115.0 | 41.47% | NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 18WP | AEPW | AEPW | LYDIA - VALLIANT 345KV CKT 1 | 115.0 | 41.47% | NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 18WP | AEPW | AEPW | LYDIA - VALLIANT 345KV CKT 1 | 115.0 | 41.47% | NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 23WP | AEPW | AEPW | LYDIA - VALLIANT 345KV CKT 1 | 107.9 | 42.25% | NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1 | ADABELL - VBI 161KV CKT 1 | Replace existing 800 amp wave trap with 1200 amp in VBI sub |
| 5 | 23WP | AEPW | AEPW | LYDIA - VALLIANT 345KV CKT 1 | 107.9 | 42.25% | NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1 | Lacygne - Mariosa 345KV KACP | Build approximately 181 miles of 345kV from KCPL Lacygne - AMRN Mariosa |
| 5 | 23WP | AEPW | AEPW | LYDIA - VALLIANT 345KV CKT 1 | 107.9 | 42.25% | NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 23WP | AEPW | AEPW | LYDIA - VALLIANT 345KV CKT 1 | 107.9 | 42.25% | NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1 | Lacygne - Mariosa 345KV AMRN | Indeterminate |

| Scenario | Season | From Area | To Area | Monitored Branch Over 100% Rate B | Transfer Case % Loading | TDF (%) | Outaged Branch Causing Overload | Upgrade Name | Solution |
|----------|--------|-----------|---------|--|-------------------------|---------|--|--|--|
| 5 | 23WP | AEPW | AEPW | LYDIA - VALLIANT 345KV CKT 1 | 107.9 | 42.25% | NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | AEPW | AEPW | LYDIA - VALLIANT 345KV CKT 1 | 107.9 | 42.25% | NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | AEPW | AEPW | LYDIA - VALLIANT 345KV CKT 1 | 107.9 | 42.25% | NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| 5 | 18SP | AEPW | AEPW | NORAM - RAINES 138KV CKT 1 | 120.5 | 24.30% | SPP-AEPW-05 | Messick 500/230 kV Transformer Ckt 1 | Build Messick 500/230 kV station. Connect to Carroll, Clarence, and Western Kraft 230 kV lines. Install 500/230 kV 675 MVA transformer. This upgrade is contingent upon approval from Cleco Power LLC. |
| 5 | 18SP | AEPW | AEPW | NORAM - RAINES 138KV CKT 1 | 107.0 | 22.03% | LIEBERMAN - LONGWOOD 138KV CKT 1 | Messick 500/230 kV Transformer Ckt 1 | Build Messick 500/230 kV station. Connect to Carroll, Clarence, and Western Kraft 230 kV lines. Install 500/230 kV 675 MVA transformer. This upgrade is contingent upon approval from Cleco Power LLC. |
| 5 | 18SP | AEPW | AEPW | NORTH NEW BOSTON - NW TEXARKANA-BANN T 138KV CKT 1 | 109.6 | 4.21% | PATTERSON - SOUTH FOREMAN REC 138KV CKT 1 | NORTH NEW BOSTON - NW TEXARKANA-BANN T 138KV CKT 1 | Rebuild 14.19 miles to 1533.6 ACSR/TW 54/19 |
| 5 | 18SP | AEPW | AEPW | NORTH NEW BOSTON - NW TEXARKANA-BANN T 138KV CKT 1 | 105.6 | 3.44% | SPP-AEPW-04 | NORTH NEW BOSTON - NW TEXARKANA-BANN T 138KV CKT 1 | Rebuild 14.19 miles to 1533.6 ACSR/TW 54/19 |
| 5 | 14WP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 121.1 | 41.90% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 14WP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 109.9 | 41.90% | 4REMNGTON 138.00 - SHIDLER 138KV CKT 1 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 14WP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 105.5 | 36.90% | FAIRFAX - FAXTAP4 138.00 138KV CKT 1 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 143.2 | 40.48% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 129.2 | 40.48% | 4REMNGTON 138.00 - SHIDLER 138KV CKT 1 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 123.6 | 35.54% | FAIRFAX - FAXTAP4 138.00 138KV CKT 1 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 109.7 | 26.09% | LACYGNE - NEOSHO 345KV CKT 1 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 108.3 | 26.13% | SHIDWF - WEBB CITY TAP 138KV CKT 1 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 107.8 | 26.13% | WRTOD400 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 107.7 | 26.13% | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 107.7 | 25.98% | SPP-WERE-18 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 107.7 | 26.13% | SPP-AEPW-32 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 18SP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 104.8 | 26.13% | BASE CASE | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 18WP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 113.0 | 42.56% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 18WP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 101.7 | 42.56% | 4REMNGTON 138.00 - SHIDLER 138KV CKT 1 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 23SP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 135.1 | 41.83% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 23SP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 121.1 | 41.83% | 4REMNGTON 138.00 - SHIDLER 138KV CKT 1 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 23SP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 114.5 | 36.85% | FAIRFAX - FAXTAP4 138.00 138KV CKT 1 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 23WP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 111.5 | 41.20% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 23WP | AEPW | AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | 100.2 | 41.20% | 4REMNGTON 138.00 - SHIDLER 138KV CKT 1 | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW |
| 5 | 14WP | GMO | GMO | PECULIAR - PLEASANT HILL 345KV CKT 1 | 114.0 | 3.87% | EASTOWN7 345.00 - IATAN 345KV CKT 1 | IATAN - NASHUA 345KV CKT 1 | Tap Nashua 345kV bus in Hawthorn - St. Joseph 345 kV line. Build new 345 kV line from Iatan to Nashua; Add Nashua 345/161 kV |
| 5 | 14WP | GMO | GMO | PECULIAR - PLEASANT HILL 345KV CKT 1 | 101.2 | 3.18% | HAWTHORN - ST JOE 345KV CKT 1 | IATAN - NASHUA 345KV CKT 1 | Tap Nashua 345kV bus in Hawthorn - St. Joseph 345 kV line. Build new 345 kV line from Iatan to Nashua; Add Nashua 345/161 kV |
| 5 | 18WP | AEPW | AEPW | PITTSBURG - VALLIANT 345KV CKT 1 | 108.8 | 35.43% | HUGO - SUNNYSIDE 345KV CKT 1 | PITTSBURG - VALLIANT 345KV CKT 1 | Replace wavetrap and associated equipment at Pittsburg |
| 5 | 18WP | AEPW | AEPW | PITTSBURG - VALLIANT 345KV CKT 1 | 108.7 | 33.79% | HUGO - VALLIANT 345KV CKT 1 | PITTSBURG - VALLIANT 345KV CKT 1 | Replace wavetrap and associated equipment at Pittsburg |
| 5 | 23WP | AEPW | AEPW | PITTSBURG - VALLIANT 345KV CKT 1 | 101.9 | 37.65% | HUGO - VALLIANT 345KV CKT 1 | PITTSBURG - VALLIANT 345KV CKT 1 | Replace wavetrap and associated equipment at Pittsburg |
| 5 | 23WP | AEPW | AEPW | PITTSBURG - VALLIANT 345KV CKT 1 | 101.4 | 39.90% | HUGO - SUNNYSIDE 345KV CKT 1 | PITTSBURG - VALLIANT 345KV CKT 1 | Replace wavetrap and associated equipment at Pittsburg |
| 5 | 14WP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 121.9 | 41.90% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 14WP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 110.7 | 41.90% | 4REMNGTON 138.00 - SHIDLER 138KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 14WP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 106.3 | 36.90% | FAIRFAX - FAXTAP4 138.00 138KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 18SP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 144.4 | 40.48% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 18SP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 130.5 | 40.48% | 4REMNGTON 138.00 - SHIDLER 138KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 18SP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 124.9 | 35.54% | FAIRFAX - FAXTAP4 138.00 138KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 18SP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 118.5 | 26.13% | BASE CASE | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 18SP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 111.0 | 26.09% | LACYGNE - NEOSHO 345KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 18SP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 109.5 | 26.13% | SHIDWF - WEBB CITY TAP 138KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 18SP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 109.1 | 26.13% | WRTOD400 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 18SP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 109.0 | 26.13% | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 18SP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 108.9 | 26.13% | SPP-AEPW-32 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 18SP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 108.9 | 25.98% | SPP-WERE-18 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 18SP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 108.2 | 26.13% | HOYT - STRANGER CREEK 345KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 18WP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 113.8 | 42.56% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |

| Scenario | Season | From Area | To Area | Monitored Branch Over 100% Rate B | Transfer Case % Loading | TDF (%) | Outaged Branch Causing Overload | Upgrade Name | Solution |
|----------|--------|-----------|---------|---|-------------------------|---------|--|--|--|
| 5 | 18WP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 102.6 | 42.56% | 4REMNGTON 138.00 - SHIDLER 138KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 23SP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 136.4 | 41.83% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 23SP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 122.5 | 41.83% | 4REMNGTON 138.00 - SHIDLER 138KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 23SP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 115.8 | 36.85% | FAIRFAX - FAXTAP4 138.00 138KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 23SP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 106.3 | 27.49% | BASE CASE | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 23WP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 112.4 | 41.20% | 4REMNGTON 138.00 - FAIRFAX 138KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 23WP | AEPW | AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | 101.1 | 41.20% | 4REMNGTON 138.00 - SHIDLER 138KV CKT 1 | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 |
| 5 | 18SP | AEPW | AEPW | SOUTHWEST SHREVEPORT - WESTERN ELECTRIC T 138KV CKT 1 | 101.0 | 13.99% | NEW PROSPEST - ROCK HILL 138KV CKT 1 | SOUTHWEST SHREVEPORT - WESTERN ELECTRIC T 138KV CKT 1 | Rebuild 2.9 miles |
| 5 | 23SP | WFEC | AEPW | SOUTHWESTERN STATION - WASHITA 138KV CKT 1 | 131.9 | 13.81% | GRACEMONT - LAWTON EASTSIDE 345KV CKT 1 | SOUTHWESTERN STATION - WASHITA 138KV CKT 2 | Add Second 138 kV line |
| 5 | 23SP | WFEC | AEPW | SOUTHWESTERN STATION - WASHITA 138KV CKT 1 | 114.8 | 13.44% | BASE CASE | SOUTHWESTERN STATION - WASHITA 138KV CKT 2 | Add Second 138 kV line |
| 5 | 23SP | WFEC | AEPW | SOUTHWESTERN STATION - WASHITA 138KV CKT 1 | 112.4 | 14.00% | ANADARKO - GRACMNT4 138.00 138KV CKT 1 | SOUTHWESTERN STATION - WASHITA 138KV CKT 2 | Add Second 138 kV line |
| 5 | 23SP | AEPW | AEPW | TERRA NITROGEN TAP - VERDIGRIS 138KV CKT 1 | 106.4 | 4.07% | SPP-AEPW-41 | TERRA NITROGEN TAP - VERDIGRIS 138KV CKT 1 | Rebuild 4.31 miles |
| 5 | 23SP | AEPW | AEPW | TERRA NITROGEN TAP - VERDIGRIS 138KV CKT 1 | 101.0 | 3.83% | SPP-AEPW-31 | TERRA NITROGEN TAP - VERDIGRIS 138KV CKT 1 | Rebuild 4.31 miles |
| 5 | 23SP | AEPW | AEPW | TERRA NITROGEN TAP - VERDIGRIS 138KV CKT 1 | 100.4 | 3.83% | NORTHEAST STATION - OWASSO SOUTH 138KV CKT 1 | TERRA NITROGEN TAP - VERDIGRIS 138KV CKT 1 | Rebuild 4.31 miles |
| 5 | 23WP | SWPA | OKGE | VAN BUREN - VBI 161KV CKT 1 | 102.2 | 3.20% | FT SMITH - MUSKOGEE 345KV CKT 1 | ADABELL - VBI 161KV CKT 1 | Replace existing 800 amp wave trap with 1200 amp in VBI sub |
| 5 | 23WP | SWPA | OKGE | VAN BUREN - VBI 161KV CKT 1 | 102.2 | 3.20% | FT SMITH - MUSKOGEE 345KV CKT 1 | Lacygne - Mariosa 345KV KACP | Build approximately 181 miles of 345kV from KCPL Lacygne - AMRN Mariosa |
| 5 | 23WP | SWPA | OKGE | VAN BUREN - VBI 161KV CKT 1 | 102.2 | 3.20% | FT SMITH - MUSKOGEE 345KV CKT 1 | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO |
| 5 | 23WP | SWPA | OKGE | VAN BUREN - VBI 161KV CKT 1 | 102.2 | 3.20% | FT SMITH - MUSKOGEE 345KV CKT 1 | Lacygne - Mariosa 345KV AMRN | Indeterminate |
| 5 | 23WP | SWPA | OKGE | VAN BUREN - VBI 161KV CKT 1 | 102.2 | 3.20% | FT SMITH - MUSKOGEE 345KV CKT 1 | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line |
| 5 | 23WP | SWPA | OKGE | VAN BUREN - VBI 161KV CKT 1 | 102.2 | 3.20% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV EES | Indeterminate |
| 5 | 23WP | SWPA | OKGE | VAN BUREN - VBI 161KV CKT 1 | 102.2 | 3.20% | FT SMITH - MUSKOGEE 345KV CKT 1 | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line |
| | | | | | | | | | |

| Scenario | Season | Area | Monitored Bus with Violation | Transfer Case Voltage (PU) | Outaged Branch Causing Overload | Upgrade Name | Solution |
|----------|--------|------|------------------------------|----------------------------|---------------------------------|--------------|----------|
| | | | No Voltage Limitation | | | | |

| Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) | Estimated Engineering & Construction Cost |
|--------------------|---|---------------------|--------------------------------------|--|---|
| AEPW | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | Rebuild 11.63 | 10/1/2015 | 10/1/2018 | \$ 11,630,000 |
| AEPW | DOMES - MOUND ROAD 138KV CKT 1 | Rebuild 13.59 miles | 10/1/2014 | 10/1/2017 | \$ 13,600,000 |
| AEPW | DOMES - PAWHUSKA TAP 138KV CKT 1 | Rebuild 5.74 miles | 10/1/2014 | 10/1/2017 | \$ 5,800,000 |
| AEPW | SOUTHWEST SHREVEPORT - WESTERN ELECTRIC T 138KV CKT 1 | Rebuild 2.9 miles | 6/1/2015 | 6/1/2018 | \$ 2,900,000 |
| AEPW | TERRA NITROGEN TAP - VERDIGRIS 138KV CKT 1 | Rebuild 4.31 miles | 6/1/2019 | 6/1/2019 | \$ 4,320,000 |

Construction Pending Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) | Estimated Engineering & Construction Cost |
|--------------------|--|--|--------------------------------------|--|---|
| AEPW | BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1 | Rebuild 3.8 miles with 1533.3 ACSR/TW | 10/1/2014 | 6/1/2017 | \$ 4,750,000 |
| AEPW | BETHEL - BROKEN BOW 138KV CKT 1 | Rebuild 9.19 miles of 3/0 Copperweld with 1272 ACSR | 10/1/2015 | 6/1/2018 | \$ 9,190,000 |
| AEPW | BETHEL - NASHOBA 138KV CKT 1 | Rebuild 22.43 miles of 3/0 Copperweld with 1272 ACSR | 10/1/2015 | 6/1/2018 | \$ 22,430,000 |
| AEPW | CLAYTON - NASHOBA 138KV CKT 1 | Rebuild 11.57 miles of 3/0 CWC with 1272 ACSR | 10/1/2015 | 6/1/2018 | \$ 11,570,000 |
| AEPW | CLAYTON - SARDIS 138KV CKT 1 | Rebuild 1.46 miles of 3/0 CWC with 1272 ACSR | 10/1/2015 | 6/1/2018 | \$ 1,460,000 |
| AEPW | ENOWILT - LONE OAK 138KV CKT 1 | Rebuild 0.32 miles of 3/0 CWC with 1272 ACSR. Replace jumpers @ Lone Oak | 10/1/2015 | 6/1/2017 | \$ 625,000 |
| AEPW | ENOWILT - SARDIS 138KV CKT 1 | Rebuild 13.8 miles of 3/0 CWC with 1272 ACSR | 10/1/2015 | 6/1/2018 | \$ 13,800,000 |
| AEPW | FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 AEPW | Replace Terminal Equipment | 6/1/2019 | 6/1/2019 | \$ 1,220,000 |
| AEPW | GRACEMONT - LAWTON EASTSIDE 345KV CKT 1 | Replace Terminal Equipment | 10/1/2019 | 10/1/2019 | \$ 305,000 |
| AEPW | KNOX LEE - SOUTH TEXAS EASTMAN 138KV CKT 1 Accelerate | Rebuild 5.5 miles with 1533.3 ACSR/TW | 6/1/2015 | 6/1/2018 | \$ 7,150,000 |
| AEPW | NORTH NEW BOSTON - NW TEXARKANA-BANN T 138KV CKT 1 | Rebuild 14.19 miles to 1533.6 ACSR/TW 54/19 | 6/1/2015 | 6/1/2017 | \$ 17,028,000 |
| AEPW | PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1 | Rebuild 5.98 miles with 1533.3 ACSR/TW | 6/1/2015 | 6/1/2018 | \$ 6,000,000 |
| AEPW | PITTSBURG - VALLIANT 345KV CKT 1 | Replace wavetrap and associated equipment at Pittsburg | 10/1/2015 | 6/1/2017 | \$ 303,750 |
| AEPW | SHIDLER - WEST PAWHUSKA 138KV CKT 1 | Rebuild 16.11 | 6/1/2015 | 6/1/2018 | \$ 12,243,600 |
| AMRN | Lacygne - Mariosa 345KV AMRN | Indeterminate | 10/1/2014 | 6/1/2019 | |
| EES | Arkansas Nuclear One 500/345 Transformer | Build 500/345 kV Transformer at ANO | 6/1/2014 | 6/1/2019 | \$ 12,000,000 |
| EES | VBI - Arkansas Nuclear One 345kV EES | Indeterminate | 6/1/2014 | 6/1/2019 | |
| GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #1 | Add new pole to increase line clearance | 6/1/2015 | 6/1/2016 | \$ 350,000 |
| GRDA | GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 #2 | Replace Terminal Equipment | 6/1/2015 | 6/1/2016 | \$ 3,300,000 |
| KACP | Lacygne - Mariosa 345KV KACP | Build approximately 181 miles of 345kV from KCPL Lacygne - AMRN Mariosa | 10/1/2014 | 6/1/2019 | \$ 275,120,000 |
| OKGE | ADABELL - VBI 161KV CKT 1 | Replace existing 800 amp wave trap with 1200 amp in VBI sub | 6/1/2014 | 6/1/2016 | \$ 150,000 |
| OKGE | CIMARRON - DRAPER LAKE 345KV CKT 1 | Increase capacity of Draper Lake CT and Cimarron wave trap | 10/1/2015 | 6/1/2016 | \$ 150,000 |
| OKGE | FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1 | Install 2nd 500/345 kV bus tie in Ft. Smith Sub | 10/1/2014 | 6/1/2018 | \$ 14,500,000 |
| OKGE | FT SMITH - MUSKOGEE 345KV CKT 1 | Upgrade Ft. Smith 345 kV breakers and switches to 2000 amps | 10/1/2014 | 6/1/2015 | \$ 1,800,000 |
| OKGE | Muskogee - VBI 345 kV with 345/161 kV bus tie near VBI | Build 70.95 mile 345 kV line plus two new 345/161 kV bus ties near VBI sub and 10 miles of 161 kV line | 6/1/2014 | 6/1/2019 | \$ 129,000,000 |
| OKGE | VBI - Arkansas Nuclear One 345kV OKGE | Build 73 miles of 345kV line | 6/1/2014 | 6/1/2019 | \$ 119,355,000 |
| WFEC | FRANKLIN SW - MIDWEST TAP 138KV CKT 1 | Replace Terminal Equipment | 6/1/2019 | 6/1/2019 | \$ 225,000 |
| WFEC | SOUTHWESTERN STATION - WASHITA 138KV CKT 2 | Add Second 138 kV line | 10/1/2014 | 6/1/2017 | \$ 2,260,000 |

Expansion Plan Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) |
|--------------------|--------------------------------------|--|--------------------------------------|--|
| AEPW | Messick 500/230 kV Transformer Ckt 1 | Build Messick 500/230 kV station. Connect to Carroll, Clarence, and Western Kraft 230 kV lines. Install 500/230 kV 675 MVA transformer. This upgrade is contingent upon approval | 10/1/2014 | 12/31/2015 |
| KACP | IATAN - NASHUA 345KV CKT 1 | Tap Nashua 345kV bus in Hawthorn - St. Joseph 345 kV line. Build new 345 kV line from Iatan to Nashua, Add Nashua 345/161 kV | 10/1/2014 | 6/1/2015 |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) |
|--------------------|-------------------------|----------|--------------------------------------|--|
| | No Reliability Projects | | | |