



SPP

*Southwest
Power Pool*

***System Impact Study
SPP-2014-010
For Transmission Service
Requested By:
TNSK***

From WFEK to ERCOTN

***For a Reserved Amount Of
15 MW***

For 6/1/2014 – 9/1/2014

1. Executive Summary

TNSK has requested a system impact study for monthly firm transmission service from WFEC to ERCOTN. The period of the transaction is from 6/1/2014 00:00 to 9/1/2014 00:00. The request is for reservation 79626987.

The 15 MW transaction from WFEC has an impact on the following flowgates with no AFC: SPSNORTH_STH, ANACORSWSNOR, and POTXFRHITXFR. To provide the AFC necessary for this transfer, the impact on these flowgates must be relieved.

After studying many scenarios using generation redispatch, there are several feasible scenarios that will relieve the flowgate(s) in question.

2. Introduction

TNSK has requested a system impact study for transmission service from WFEC to ERCOTN.

There are 3 constrained flowgates that require relief in order for this reservation to be accepted. The flowgates and the explanations are as follows:

- SPSNORTH_STH: SPS North to South Stability Interface
- ANACORSWSNOR: Anadarko – Corn Tap 138 kV line for the loss of the Southwestern Station – Norge 138 kV line
- POTXFRHITXFR: Potter County 345/230 kV transformer for the loss of the Hitchland 345/230 kV transformer

3. Study Methodology

A. Description

Southwest Power Pool used Transmission Adequacy & Reliability Assessment (TARA) to obtain possible unit pairings that would relieve the constraint. TARA calculates impacts on monitored facilities for all units within the Southwest Power Pool Footprint. The SPP ATC Calculator is used to determine response factors for the time period of the reservation.

B. Model Updates

The 2014 Southwest Power Pool model was used for the study. This model was updated to reflect the most current information available.

C. Transfer Analysis

Using the short-term calculator, the limiting constraints for the transfer are identified. The response factor of the transfer on each constraint is also determined.

The product of the transfer amount and the response factor is the impact of a transfer on a limiting flowgate that must be relieved. With multiple flowgates affected by a transfer, relief of the largest impact may also provide relief of smaller impacts.

Using Transmission Adequacy & Reliability Assessment (TARA), specific generator pairs are chosen to reflect the units available for redispatch. The quotient of the amount of impact that must be relieved and the generation sensitivity factor calculated by TARA is the amount of redispatch necessary to relieve the impact on the affected flowgate.

4. Study Results

After studying the impacts of the request, three flowgates require relief. The flowgates and associated amount of relief are as follows:

Table 1

Flowgate	Duration	Sensitivity (%)	Impact (MW)
5196:SPSNORTH_STH	6/1/2014 - 9/1/2014	16.7%	3
5358:ANACORSWSNOR	6/1/2014 - 9/1/2014	10.1%	2
5420:POTXFRHITXFR	6/1/2014 - 9/1/2014	6.1%	1

Table 2 displays a list of generator pairs that are possible relief options for each flowgates in question and the amount of redispatch capacity needed.

Table 2

5196:SPSNORTH_STH			
Increment	Decrement	Sensitivity (%)	Impact (MW)
Plant X SPS	Harrington SPS	81.7%	4
Plant X SPS	Nichols SPS	81.7%	4
Tolk SPS	Harrington SPS	80.4%	4
Tolk SPS	Nichols SPS	80.4%	4
Cunningham SPS	Harrington SPS	78.9%	4
Cunningham SPS	Nichols SPS	78.8%	4
Plant X SPS	Blackhawk SPS	78.8%	4
Tolk SPS	Blackhawk SPS	77.5%	4
Cunningham SPS	Blackhawk SPS	75.9%	4

5358:ANACORSWSNOR			
Increment	Decrement	Sensitivity (%)	Impact (MW)
Seminole OKGE	Anadarko/Genco/Orme WFEC	13.0%	15
Weleetka AEP	Anadarko/Genco/Orme WFEC	13.0%	15
Mustang OKGE	Anadarko/Genco/Orme WFEC	12.7%	16
Hugo WFEC	Anadarko/Genco/Orme WFEC	12.7%	16
Seminole OKGE	SW Station AEP	6.5%	31
Weleetka AEP	SW Station AEP	6.4%	31
Mustang OKGE	SW Station AEP	6.1%	33
Hugo WFEC	SW Station AEP	6.1%	33

5420:POTXFRHITXFR			
Increment	Decrement	Sensitivity (%)	Impact (MW)
Harrington SPS	Holcomb SECI	36.1%	3
Harrington SPS	Garden City SECI	36.1%	3
Nichols SPS	Holcomb SECI	36.0%	3
Nichols SPS	Garden City SECI	35.9%	3
Blackhawk SPS	Holcomb SECI	30.2%	3
Blackhawk SPS	Garden City SECI	30.2%	3

5. Conclusion

Generation redispatch options were studied in order to relieve the necessary constraints. The results of this study shows that the constraints on the flowgates in question could be relieved by executing one or more of the options described in the Study Results section of this document. Before the Transmission Provider accepts the reservations, agreement to the redispatch options must be presented to Southwest Power Pool. Noncompliance with this guideline will result in the refusal of the reservation.