



*System Impact Study SPP-2001-176
For Transmission Service
Requested By
NRG Power Marketing*

*From Oklahoma Gas & Electric To
Central Louisiana Electric Co.*

*For a Reserved Amount Of 200MW
From 7/1/01
To 7/1/02*

SPP Transmission Planning

Table of Contents

1. EXECUTIVE SUMMARY	3
2. INTRODUCTION	4
3. STUDY METHODOLOGY	5
A. DESCRIPTION.....	5
B. MODEL UPDATES.....	5
C. TRANSFER ANALYSIS	5
4. STUDY RESULTS.....	6
A. STUDY ANALYSIS RESULTS	6
TABLE 1 – SPP FACILITY OVERLOADS CAUSED BY THE OKGE TO CLEC 200MW TRANSFER.....	7
TABLE 2 – NON - SPP FACILITY OVERLOADS CAUSED BY THE OKGE TO CLEC 200MW TRANSFER	7
TABLE 3 – PREVIOUSLY ASSIGNED AND IDENTIFIED SPP FACILITIES IMPACTED BY THE OKGE TO CLEC 200MW TRANSFER.	8
5. CONCLUSION	10
APPENDIX A	11

1. Executive Summary

NRG Power Marketing has requested a system impact study for long-term Firm Point-to-Point transmission service from Oklahoma Gas & Electric to Central Louisiana Electric Co. The period of the transaction is from 7/1/01 to 7/1/02. The request is for OASIS reservations 252495-252498, totaling 200MW.

The principal objective of this study is to identify system problems and potential system modifications necessary to facilitate the additional 200MW transfer while maintaining system reliability.

The 200MW transfer was studied independently of the previous NRG Power Marketing requests for 200MW from OKGE to Entergy, 150MW from OKGE to MEC, and 250MW from OKGE to AECI. The previous requests were assumed refused per the results of System Impact Studies SPP-2001-173, 174, and 175, respectively. The System Impact Study for 200MW transfer will need to be revised if the assumed statuses of these previous requests change.

New overloads caused by the 200MW transfer were identified along with determining the impact of the transfer on any previously assigned and identified facilities.

The OKGE to CLEC transfer impacts several facilities that have been identified as limiting constraints for previously studied transfers. Due to the inability to upgrade these limiting constraints within the reservation period using normal construction practices, the ATC is zero for the requested OKGE to CLEC 200MW transfer.

The SPP and effected member companies shall use due diligence to coordinate the addition of necessary facilities or transmission system upgrades to provide the requested transmission service. NRG Power Marketing is to compensate SPP for such costs pursuant to the terms of section 27 of the SPP Open Access Transmission Tariff.

Expedited procedures for new facilities and upgrades are available to NRG Power Marketing per section 19.8 of the SPP Open Access Transmission Service Tariff.

Engineering and construction of any new facilities or modifications will not start until after a transmission service agreement and/or construction agreement is in place and effected member companies receive the appropriate authorization to proceed from the SPP after receiving authorization from the transmission customer.

2. Introduction

NRG Power Marketing has requested an impact study for transmission service from OKGE control area with a sink of CLEC.

The principal objective of this study is to identify the restraints on the SPP Regional Tariff System that may limit the transfer to less than 200 MW. This study includes steady-state contingency analyses (PSS/E function ACCC) and Available Transfer Capability (ATC) analyses.

The steady-state analyses consider the impact of the 200 MW transfer on transmission line loading and transmission bus voltages for outages of single and selected multiple transmission lines and transformers on the SPP system.

ATC analyses shows the amount of First Contingency Incremental Transfer Capabilities (FCITC) between the given study systems and what the limitations are, if any, for transferring up to 200 MW.

3. Study Methodology

A. Description

Two analyses were conducted to determine the impact of the 200MW transfer on the system. The first analysis was conducted to identify any new overloads caused by the 200MW transfer. The second analysis was done to ensure that available capacity exists on previously identified circuits.

The first analysis was to study the steady-state analysis impact of the 200MW transfer on the SPP system. The second step was to study Available Transfer Capability (ATC) of the facilities identified in the steady-state analysis impact. The steady-state analysis was done to ensure current SPP Criteria and NERC Planning Standards requirements are fulfilled. The Southwest Power Pool (SPP) conforms to the NERC Planning Standards, which provide the strictest requirements, related to thermal overloads with a contingency. It requires that all facilities be within emergency ratings after a contingency.

The second analysis was done to determine the impact of the transfer on previously assigned and identified facilities.

B. Model Updates

SPP used three seasonal models to study the 200MW request. The SPP 2001 Series Cases 2001 Summer Peak, 2001/02 Winter Peak, and 2002 Summer Peak were used to study the impact of the 200MW transfer on the SPP system during the transaction period of 7/01/01 to 7/1/02.

The chosen base case models were modified to reflect the most current modeling information. The cases were modified to reflect future firm transfers during the request period that were not already included in the January 2001 base case series models.

C. Transfer Analysis

Using the created models and the ACCC function of PSS/E, single and select double contingency outages were analyzed. Then full AC solution was used to obtain the most accurate results possible. Any facility overloaded, using MVA ratings, in the transfer case and not overloaded in the base case was flagged. The PSS/E options chosen to conduct the Impact Study analysis can be found in Appendix A.

4. Study Results

A. Study Analysis Results

Tables 1, 2, and 3 contain the analysis results of the System Impact Study. The tables identify the seasonal case in which the event occurred; the emergency rating of the overloaded circuit (Rate B), the contingent loading percentage of circuit with and without the studied transfer, the estimated ATC value using interpolation if calculated, any SPP identification or assignment of the event, and any solutions received from the transmission owners.

Table 1 shows the new facility overloads caused by the 200MW transfer. Upgrades associated with these new overloads can be directly assigned to the OKGE to CLEC 200MW transfer.

Table 2 documents overloads on Non SPP Regional Tariff participants' transmission systems caused by the 200MW transfer.

Table 3 documents the 200MW transfer impact on previously assigned and identified facilities. Available estimated in-service dates for the completion of the previously assigned upgrades are given in the table.

Table 1 – SPP Facility Overloads caused by the OKGE to CLEC 200MW Transfer

Study Year	From Area - To Area	Branch Over 100% RateB	RATEB	BC % I Loading	TC % I Loading	Outaged Branch That Caused Overload	ATC (MW)
01SP	AEPW-AEPW	BANN to ALUMAX TAP, 138KV 53250 BANN 4 138 to 53245 ALUMXT 4 138 CKT 1	261	99.8	101.4	NW TEXARKANA-BANN T to NW TEXARKANA, 138KV 53299 NWT-BNT4 138 to 53300 NWTXARK4 138 CKT1	30
01WP	WERE-WERE	KING HILL N.M. COOP to KELLY, 115KV 57331 KING HL3 115 to 57217 KELLY 3 115 CKT 1	92	99.6	100.7	HOYT to STRANGER CREEK, 345KV 56765 HOYT 7 345 to 56772 STRANGR7 345 CKT1	70
01WP	WFEC-WFEC	GOLDSBY TO OKLAHOMA UNIVERSITY SW, 69KV 55924 GOLDSBY269.0 to 56018 OU SW 269.0 CKT 1	34	98.2	100.3	FRANKLIN SW 138/69KV TRANSFORMER 55916 FRNKLNS269.0 to 55917 FRNKLNS4 138 CKT1	170
02SP	EMDE-EMDE	MONETT TO AURORA H.T., 161KV 59480 MON383 5 161 to 59468 AUR124 5 161 CKT 1	157	99.7	101.3	DADEVILLE EAST TO MORGAN, 161KV 59478 DAD368 5 161 to 96101 5MORGAN 161 CKT1	36
02SP	WERE-WERE	166TH TO JAGGARD JUNCTION, 115 KV 57233 166TH 3 115 to 57243 JAGGARD3 115 CKT 1	119	99.9	100.3	CAPTAIN JUNCTION TO 95TH & WAVERLY, 115 KV 57235 CAPTAIN3 115 to 57278 WAVERLY3 115 CKT1	38
02SP	EES-SWPA	MIDWAY TO BULL SHOALS, 161KV 99825 5MIDWAY# 161 to 52660 BULL SH5 161 CKT 1	162	99.2	100.6	BATESVILLE-NORTH TO CUSHMAN, 161KV 99798 5BATEVL 161 to 99808 5CUSHMN 161 CKT1	117
02SP	WERE-WERE	WAKARUSA JCT SS TO FARMER'S CO-OP, 115KV 57277 WAKARUS3 115 to 57236 COOP 3 115 CKT 1	92	99.7	100.2	SW LAWRENCE TO WAKARUSA JCT SS, 115KV 57271 SWLWRNC3 115 to 57277 WAKARUS3 115 CKT1	121

Table 2 – Non - SPP Facility Overloads caused by the OKGE to CLEC 200MW Transfer

Study Year	From Area - To Area	Branch Over 100% RateB	RATEB	BC % I Loading	TC % I Loading	Outaged Branch That Caused Overload
01SP	EES-EES	98107 8RICHARD 500 to 98108 4RICHARD 138 CKT 1	560	93.8	102.1	98107 8RICHARD 500 to 98108 4RICHARD 138 CKT2
01SP	EES-EES	98410 4LIVON 138 to 98147 4L-642TP 138 CKT 1	289	94.3	100.9	98107 8RICHARD 500 to 98430 8WEBRE 500 CKT1
01SP	EES-EES	98520 3HUMPHY 115 to 98521 3GIBSON 115 CKT 1	227	91.8	100.2	98107 8RICHARD 500 to 98430 8WEBRE 500 CKT1
01SP	EES-EES	99264 3MAG-DW 115 to 99230 3COUCH 115 CKT 1	108	97.8	100.5	99249 3EMERSN 115 to 99288 3KERLIN* 115 CKT1
01SP	LAGN-EES	97311 GRENWD 3 115 to 98520 3HUMPHY 115 CKT 1	228	96.4	104.8	98107 8RICHARD 500 to 98430 8WEBRE 500 CKT1
01WP	AECI-AECI	96099 5MONTCT 161 to 96575 2MONTGY 69.0 CKT 1	56	99.4	100.6	96061 5BOONE 161 to 96493 2BOONE 69.0 CKT1
02SP	EES-CELE	98521 3GIBSON 115 to 50168 RAMOS 4 138 CKT 1	253	99.2	106.2	98107 8RICHARD 500 to 98430 8WEBRE 500 CKT1
02SP	LAGN-EES	97320 KSPRGS 4 138 to 98141 4CHAMPNE 138 CKT 1	289	100.0	106.9	98107 8RICHARD 500 to 98430 8WEBRE 500 CKT1
02SP	MIPU-AECI	59217 WINDSR 5 161 to 96071 5CLINTN 161 CKT 1	123	99.1	100.2	58062 SALSBRY5 161 to 58064 NORTON-5 161 CKT1
02SP	SWPA-AECI	52690 CARTHG 269.0 to 96751 2REEDS 69.0 CKT 1	36	99.3	101.0	56793 NEOSHO 7 345 to 96045 7MORGAN 345 CKT1

Table 3 – Previously Assigned and Identified SPP Facilities Impacted by the OKGE to CLEC 200MW Transfer.

Study Year	From Area - To Area	Branch Over 100% RateB	RATEB	BC % I Loading	TC % I Loading	Outaged Branch That Caused Overload	ATC (MW)	Assignment
01SP	AEPW-AEPW	EAST CENTERTON TO GENTRY REC, 161KV 53133 ECNTRTN5 161 to 53187 GENTRYR5 161 CKT 1	335	104.6	105.3	FLINT CREEK TO ELM SPRINGS REC, 161KV 53139 FLINTCR5 161 to 53194 ELMSPRR5 161 CKT1	0	Upgrade Assigned to SPP-2000-086 150680 Est. In-Service Date 4/1/2002
01SP	AEPW-AEPW	CHEROKEE REC TO KNOX LEE, 138KV 53522 CHEROKE4 138 53557 KNOXLEE4 138 CKT 1	209	99.4	104.6	Multiple Outage Contingency SOUTHWEST SHREVEPORT to LONGWOOD, 345KV 53454 SW SHV 7 345 to 53424 LONGWD 7 345 CKT 1 SOUTHWEST SHREVEPORT to DIANA, 345KV 53454 SW SHV 7 345 to 53528 DIANA 7 345 CKT 1	23	Upgrade Assigned to SPP-2000-086 150680 Est. In-Service Date 4/1/2002
01SP	AEPW-AEPW	LONGWOOD TO NORAM, 138KV 53423 LONGWD 4 138 53473 NORAM 4 138 1	234	94.8	100.4	Multiple Outage Contingency SOUTHWEST SHREVEPORT to LONGWOOD, 345KV 53454 SW SHV 7 345 to 53424 LONGWD 7 345 CKT 1 SOUTHWEST SHREVEPORT to DIANA, 345KV 53454 SW SHV 7 345 to 53528 DIANA 7 345 CKT 1	186	Upgrade Assigned to SPP-2000-011 171555
01WP	AEPW-AEPW	EAST ROGERS TO DYESS, 161KV 53135 EROGERS5 161 to 53131 DYESS 5 161 CKT 1	245	101.9	103.5	FLINT CREEK TO GENTRY, 161KV 53139 FLINTCR5 161 to 53187 GENTRYR5 161 CKT1	0	Upgrade Assigned to SPP-2000-004 163951 Est. In-Service Date 6/1/2002
02SP	AEPW-AEPW	TATUM TO CHEROKEE REC 138KV 53611 TATUM 4 to 53522 CHEROKE4 1	209	100.0	105.2	Multiple Outage Contingency SOUTHWEST SHREVEPORT to LONGWOOD, 345KV 53454 SW SHV 7 345 to 53424 LONGWD 7 345 CKT 1 SOUTHWEST SHREVEPORT to DIANA, 345KV 53454 SW SHV 7 345 to 53528 DIANA 7 345 CKT 1	0	Upgrade Assigned to SPP-2000-086 150680 Est. In-Service Date 2/1/2003
02SP	KACP-KACP	STILLWELL TO LA CYGNE, 345KV 57968 STILWEL7 345 to 57981 LACYGNE7 345 CKT 1	1202	103.4	104.5	WEST GARDNER TO LA CYGNE, 345KV 57965 W.GRDNR7 345 to 57981 LACYGNE7 345 CKT1	0	SPP Flowgate
02SP	SWPA-SWPA	ROBERT S. KERR TO VAN BUREN 52782 RS KERR5 161 to 52722 VAN BUR5 161 CKT 1	167	101.3	103.9	BONANZA TAP TO AES, 161KV 55261 BONANZT5 161 to 55262 AES 5 161 CKT1	0	Previously Identified
02SP	AEPW-AEPW	LONGWOOD TO NORAM, 138KV 53423 LONGWD 4 138 53473 NORAM 4 138 1	234	99.2	105.0	Multiple Outage Contingency SOUTHWEST SHREVEPORT to LONGWOOD, 345KV 53454 SW SHV 7 345 to 53424 LONGWD 7 345 CKT 1 SOUTHWEST SHREVEPORT to DIANA, 345KV 53454 SW SHV 7 345 to 53528 DIANA 7 345 CKT 1	28	Upgrade Assigned to SPP-2000-011 171555
02SP	AEPW-AEPW	RAINES TO NORAM, 138KV 53439 RAINES 4 138 53473 NORAM 4 138 1	234	97.7	103.5	Multiple Outage Contingency SOUTHWEST SHREVEPORT to LONGWOOD, 345KV 53454 SW SHV 7 345 to 53424 LONGWD 7 345 CKT 1 SOUTHWEST SHREVEPORT to DIANA, 345KV 53454 SW SHV 7 345 to 53528 DIANA 7 345 CKT 1	79	Upgrade Assigned to SPP-2000-043 194656, 194657

Table 3 continued – Previously Assigned and Identified SPP Facilities Impacted by the OKGE to CLEC 200MW Transfer.

Study Year	From Area - To Area	Branch Over 100% RateB	RATEB	BC % I Loading	TC % I Loading	Outaged Branch That Caused Overload	ATC (MW)	Assignment
02SP	AEPW-AEPW	LONGWOOD TO OAK REC, 138KV 53423 LONGWD 4 138 53457 OAKPH 4 138 1	190	94.7	104.1	Multiple Outage Contingency SOUTHWEST SHREVEPORT to LONGWOOD, 345KV 53454 SW SHV 7 345 to 53424 LONGWD 7 345 CKT 1 SOUTHWEST SHREVEPORT to DIANA, 345KV 53454 SW SHV 7 345 to 53528 DIANA 7 345 CKT 1	113	Upgrade Assigned to SPP-2000-086 150680
02SP	AEPW-AEPW	CHEROKEE REC to KNOX LEE, 138KV 53522 CHEROKE4 138 to 53557 KNOXLEE4 138 CKT 1	209	105.6	110.9	Multiple Outage Contingency SOUTHWEST SHREVEPORT to LONGWOOD, 345KV 53454 SW SHV 7 345 to 53424 LONGWD 7 345 CKT 1 SOUTHWEST SHREVEPORT to DIANA, 345KV 53454 SW SHV 7 345 to 53528 DIANA 7 345 CKT 1	200	Upgrade Assigned to SPP-2000-086 150680 Est. In-Service Date 4/1/2002

5. Conclusion

The previously assigned and identified facilities limit the ATC to zero due to the inability to upgrade the constraints as required. Those facilities that have an ATC of zero are given below.

- For the 2001 Summer (6/1/01-10/1/01), the ATC is zero due to the loading of the East Centerton to Gentry 161kV line. The estimated in service date of the upgrade is 4/1/2002.
- For the 2001/2002 Winter (12/1/01-4/1/01), the ATC is zero due to the loading of the Dyess to East Rogers 161kV line. The estimated in service date of the upgrade is 6/1/2002.
- For the 2002 Summer (6/1/02-10/1/02), the ATC is zero due the loading of the Cherokee to Tatum 138kV line, the La Cygne to Stillwell 345kV line, and the R.S. Kerr to Van Buren 161kV line. The estimated in service date of the Cherokee to Tatum 138kV line upgrade is 2/1/2003. No upgrades have been assigned for the La Cygne to Stillwell and R.S. Kerr to Van Buren overloads.

Given the estimated in service dates of these Upgrades, the ATC of the existing transmission system cannot be increased as required to provide continuous service over the reservation period. Therefore, the requested reservations will be refused.

Appendix A

PSS/E CHOICES IN RUNNING LOAD FLOW PROGRAM AND ACCC

BASE CASES:

Solutions - Fixed slope decoupled Newton-Raphson solution (FDNS)

1. Tap adjustment – Stepping
2. Area interchange control – Tie lines only
3. Var limits – Apply automatically
4. Solution options - Phase shift adjustment
 - Flat start
 - Lock DC taps
 - Lock switched shunts

ACCC CASES:

Solutions – AC contingency checking (ACCC)

1. MW mismatch tolerance – 1.0
2. Contingency case rating – Rate B
3. Percent of rating – 100
4. Output code – Summary
5. Min flow change in overload report – 1mw
6. Excl'd cases w/ no overloads form report – YES
7. Exclude interfaces from report – NO
8. Perform voltage limit check – YES
9. Elements in available capacity table – 60000
10. Cutoff threshold for available capacity table – 99999.0
11. Min. contng. case Vltg chng for report – 0.02
12. Sorted output – None

Newton Solution:

1. Tap adjustment – Stepping
2. Area interchange control – Tie lines only
3. Var limits - Apply automatically
4. Solution options - Phase shift adjustment
 - Flat start
 - Lock DC taps
 - Lock switched shunts